

INSTALLATION INSTRUCTIONS

IMPORTANT: Read carefully before installing fixture.
Retain for future reference.

BC, BW, BWVE, BCVE,
BCHE, BWHE, SERIES LUMINAIRES
INCANDESCENT AND COMPACT
FLUORESCENT

6/93

IMI-313

General: Upon receipt of fixture thoroughly inspect for any freight damage, which should be brought to the attention of the delivering carrier. Compare the catalog description listed on the packing slip with the fixture label on the housing to assure you have received the correct merchandise.

Safety: This fixture must be wired in accordance with the National Electrical Code and applicable local codes and ordinances. Proper grounding is required to insure personal safety. Carefully observe grounding procedure under installation section. All work should be done by a qualified electrician.

WARNING: Make certain power is OFF before starting installation or attempting any maintenance.


CLEANING: The reflector and lens may be cleaned with any non-abrasive cloth and mild detergent (i.e. 409 Cleaner). Cleaning should be done on the lens at room temperature, and out of direct sunlight. To remove paint, lipstick, marker, etc., the following solvents may be used:

RECOMMENDED: a solution of three (3) parts alcohol, one (1) part TOLUOL.

OR: four (4) parts alcohol, one part Methylethylketone (MEK).

Also safe, but less effective: Naphtha, Butyl Cellosolve, Kerosene.

NEVER USE: Gasoline, Benzene, Acetone, Carbon Tetrachloride or highly alkaline cleaners. Never clean Luminaire while energized, or while lens is hot.



WARNING: If the lens has a Factory-applied trim color, these solvents will also remove this paint. Replacement of the entire lens is recommended in this case.

1. Remove lens, using a torx screwdriver (for screws with center-pin).
2. Remove the four 5/10" knock-outs.
3. Determine correct fasteners to use for the mounting surface. Fasteners should be 1/4" normal.
4. The mounting gasket may be used as a template to lay out the fastener locations.
5. Make wiring connections.
6. Place two of the mounting screws through the mounting plate, and position the mounting gasket into position on the back (wall-side) of the plate.
7. Position mounting plate on wall in one of the "UP" orientations, according to the embossed arrows on the mounting plate. Check position of internal reflector, if equipped (see Note).
8. Start mounting fasteners but do not tighten.
9. Check the gasket position. At least 1/4 of gasket should extend beyond the mounting plate, all the way around.
10. Tighten all four mounting fasteners.
11. Install lamp. Screw base lamps should be tightened, then loosened one to two turns, then re-tightened. This will properly seat the lamp for best mechanical and electrical connection.
12. Replace lens, tighten screws.

NOTE: For optional Internal Reflectors

If the fixture has a reflector attached to the mounting plate, it should be positioned above the lamp. If the lens has a portion "Painted Out" to form an "Eyelid", this portion should be positioned toward the ceiling, and over the internal reflector.

Photoelectric Control

A Photoelectric Control may be added by first obtaining the following accessories from your Cooper Lighting Distributor:

- Surface Conduit Box CAT#SCB
- “Photocell Kit” CAT#PB-120V OR #PB-277V

Follow the instructions provided with the kit, installing the photocell in an unused conduit entry location which positioned the Photocell in a horizontal orientation.