


PHOTOMETRICS

Candlepower Distribution



H2600E42
Lamp=1/26W Triple CF
Spacing Criteria=1.7

Test No. 11871.0
Lumens=1800
Efficiency=94.6%

Candlepower

Deg.	CD	55	171	120	109
0	172	60	164	125	86
5	167	65	173	130	64
10	161	70	174	135	38
15	171	75	174	140	17
20	190	80	171	145	4
25	207	85	169	150	02
30	203	90	166	155	1
35	193	95	164	160	1
40	195	100	160	165	1
45	191	105	155	170	1
50	179	110	145	175	1
		115	131	180	1

Average Luminance

Deg.	CD/SQ M
45	1950
55	1815
65	1987
75	2237
85	2567

Zonal Lumen Summary


Zone	Lumens	%Lamp	%Luminaire
0-30	159	8.8	9.3
0-40	281	15.7	16.6
0-60	582	32.3	34.2
0-90	1119	62.2	65.7
90-120	470	26.1	27.6
90-130	547	30.4	32.1
90-150	582	32.3	34.1
90-180	583	32.4	34.2
0-180	1702	94.6	100.0

Coefficient of Utilization

rc	80%				70%				50%				30%				10%				0%	
	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR 0	105	105	105	105	99	99	99	99	87	87	87	76	76	76	67	67	67	62				
1	91	85	79	74	85	79	74	70	69	65	61	60	57	54	51	49	47	42				
2	81	71	63	57	75	67	60	53	58	52	47	50	45	41	42	39	36	32				
3	73	61	52	45	68	57	49	43	50	43	38	43	38	33	36	32	29	25				
4	66	53	44	37	61	50	42	35	43	37	31	37	32	27	32	27	24	20				
5	60	47	38	31	56	44	36	29	38	31	26	33	27	23	28	24	20	17				
6	55	42	33	27	51	39	31	25	34	27	22	30	24	20	25	21	17	14				
7	51	38	29	23	47	35	27	22	31	24	19	27	21	17	23	18	15	12				
8	47	34	26	20	44	32	24	19	28	22	17	24	19	15	21	16	13	11				
9	44	31	23	18	41	29	22	17	26	19	15	22	17	13	19	15	12	9				
10	41	28	21	16	38	27	20	15	24	18	13	21	15	12	18	13	10	8				

rc=Ceiling reflectance, rw=Wall reflectance, rcr=Room cavity ratio: CU Data Based on 20% Effective Floor Cavity Reflectance.

Candlepower Distribution



H2600E42
Lamp=1/32W Triple CF
Spacing Criteria=1.7

Test No. 11873.0
Lumens=2400
Efficiency=93.5%

Candlepower

Deg.	CD	60	218	125	128
0	186	65	219	130	99
5	184	70	226	135	69
10	183	75	233	140	38
15	194	80	232	145	14
20	215	85	230	150	4
25	231	90	227	155	1
30	232	95	227	160	0
35	224	100	221	165	1
40	231	105	212	170	1
45	232	110	199	175	2
50	230	115	180	180	2
		120	155		

Average Luminance

Deg.	CD/SQ M
45	2368
55	2393
65	2517
75	3006
85	3509

Zonal Lumen Summary


Zone	Lumens	%Lamp	%Luminaire
0-30	178.99	7.5	8
0-40	322.06	13.4	14.4
0-60	702.47	29.3	31.3
0-90	1416.44	59	63.1
90-120	646.73	26.9	28.8
90-130	761.51	31.7	33.9
90-150	826.59	34.4	36.8
90-180	827.68	34.5	36.9
0-180	2244.13	93.5	100

Coefficient of Utilization

rc	80%				70%				50%				30%				10%				0%	
	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR 0	103	103	103	103	97	97	97	97	85	85	85	74	74	74	64	64	64	59				
1	89	83	77	72	83	77	72	68	67	63	59	57	54	51	48	46	44	39				
2	79	70	62	55	73	65	58	52	56	50	45	47	43	39	40	36	33	29				
3	71	60	51	44	66	56	48	41	48	41	36	41	35	31	34	30	26	23				
4	65	52	43	36	60	48	40	34	42	35	30	35	30	25	29	25	22	18				
5	59	46	37	30	54	43	34	28	37	30	25	31	26	21	26	22	18	15				
6	54	41	32	25	50	38	30	24	33	26	21	28	22	18	23	19	15	12				
7	50	37	28	22	46	34	26	21	29	23	18	25	20	16	21	17	13	11				
8	46	33	25	19	43	31	23	18	27	20	16	23	18	14	19	15	12	9				
9	43	30	22	17	40	28	21	16	24	18	14	21	16	12	18	13	10	8				
10	40	27	20	15	37	26	19	14	22	16	12	19	14	11	16	12	9	7				

rc=Ceiling reflectance, rw=Wall reflectance, rcr=Room cavity ratio: CUJ Data Based on 20% Effective Floor Cavity Reflectance.

Candlepower Distribution



H2600E42
Lamp=1/42W Triple CF
Spacing Criteria=1.7

Test No. 11875.0
Lumens=3200
Efficiency=79.4%

Candlepower

Deg.	CD	55	253	120	190
0	167	60	251	125	160
5	167	65	250	130	127
10	168	70	253	135	95
15	185	75	259	140	61
20	209	80	263	145	25
25	232	85	263	150	8
30	236	90	259	155	2
35	233	95	258	160	2
40	245	100	253	165	2
45	252	105	245	170	2
50	254	110	233	175	3
		115	214	180	3

Average Luminance

Deg.	CD/SQ M

<tbl_r cells="2" ix="5" maxcspan="1" max