

Ceiling Cutout: 5 1/16" (129 mm) Dia.

Ceiling Thickness: 1 1/8" Max

Reflector Trim			Frame-In Kit	Lamp
Finish	White Flange	Polished Flange		
Comfort Clear Diffuse	C4MRD CCDW	C4MRD CCDP	C420MREU – Electronic 120/277V Non-IC	(1) 20W MR16 CMH GX10 Base
Comfort Clear	C4MRD CCLW	C4MRD CCLP		
Champagne Bronze	C4MRD CCZW	C4MRD CCZP		

Features

- 1. Trim Kit Aperture Cone:** 50° visual cut-off to lamp and lamp image. Low brightness, 0.040" aluminum, anodized; keyed to lamp support assembly for true aiming of lamp to prevent incorrect installation of cone. Hinged and snaps on for easy tool-less installation.
- 2. Lamp Support:** Die-form aluminum with knurled surface for easy gripping during relamping. Spring tension clips hold lamp and lens and allow fast snap-in, snap-out relamping. Matte black finish.
NOTE: HID lampholder ship with the frame. Discard the incandescent lampholder that ships standard with the trims.
- 3. Horizontal Adjustment Mechanism:** Die-form steel ring, matte black finish. Provides 360° horizontal stop, lockable.
- 4. Frame Vertical Adjustment Mechanism:** Accommodates mounting to virtually any ceiling system using pre-installed mounting bars, or 1/2" EMT tubing (by others). Single locking feature secures all adjustments. Alignment holes and markings allow fixture to be pre-set prior to installation. Final adjustment can be made from below inside fixture.
- 5. Mounting Bars:** Galvanized steel, 0.048"; pre-installed telescoping bars extend to 30" long and lock securely into position. Built-in locking tabs provide positive attachment to common T-bars systems. Self-centering feature simplified installation in 24" O.C. grid systems. Attaches to steel or wood joists without accessories
- 6. Socket Harness:** Twist and lock base. 5kV (600V) pulse rated PPS, black T240 body socket with nickel-plated contacts. 18 AWG silicone leads with fiberglass outer sleeve

Options and Accessories

Accepts one accessory

Labels

U.L (Suitable for Damp Locations)

Teflon® is a registered trademark of E.I. DuPont.


US Patent No. 5,957,573. Other US and Foreign Patents Pending.

Job Information	Type:
Job Name:	
Cat. No.:	
Lamp(s):	
Notes:	

Lightolier a Genlyte company www.lightolier.com
 631 Airport Road, Fall River, MA 02720 • (508) 679-8131 • Fax (508) 674-4710
 We reserve the right to change details of design, materials and finish.
 © 2006 Genlyte Group LLC • A1007



C4MRDCCLW, 20W G.E. HID SPOT, 12° GX10 BASE



CANDLEPOWER SUMMARY		
Angle	Mean CP	Lumens
0	6795	
5	5107	457
10	2136	
15	803	293
20	386	
25	207	108
30	134	
35	52	42
40	30	
45	16	12
50	0	
55	0	0
60	0	
65	0	0
70	0	
75	0	0
80	0	
85	0	0
90	0	

LUMEN RATING = 1000 LMS.
SC = .3
TEST REPORT NO. 3405FR

ZONAL LUMENS AND PERCENTAGES			
ZONE	LUMENS	%LAMP	%LUMINAIRE
0-30	857	85.75	94.06
0-40	899	89.97	98.69
0-60	911	91.16	100.00
0-90	911	91.16	100.00
40-90	11	1.19	1.31
60-90	0	.00	.00
90-180	0	.00	.00
0-180	911	91.16	100.00

** EFFICIENCY = 91.2% **


LUMINANCE SUMMARY	
ANGLE	MEAN CD/SQ M
45	2475
55	0
65	0
75	0
85	0

COEFFICIENTS OF UTILIZATION ZONAL CAVITY METHOD																				
EFFECTIVE FLOOR CAVITY REFLECTANCE = .20																				
CC	80				70				50				30				10			
	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10			
0	1.09	1.09	1.09	1.09	1.06	1.06	1.06	1.06	1.01	1.01	1.01	.97	.97	.97	.93	.93	.93	.91		
1	1.06	1.04	1.03	1.02	1.04	1.03	1.01	1.00	.99	.98	.97	.95	.95	.94	.92	.92	.91	.90		
2	1.03	1.01	.98	.96	1.01	.99	.97	.95	.96	.95	.93	.94	.93	.92	.91	.91	.90	.88		
3	1.01	.97	.95	.93	.99	.96	.94	.92	.94	.92	.91	.92	.91	.90	.91	.89	.88	.87		
4	.99	.95	.92	.90	.98	.94	.92	.90	.92	.90	.89	.91	.89	.88	.89	.88	.87	.86		
5	.97	.93	.90	.88	.95	.92	.89	.87	.90	.88	.87	.89	.87	.86	.88	.87	.85	.84		
6	.95	.91	.88	.86	.94	.90	.87	.85	.89	.87	.85	.88	.86	.84	.87	.85	.84	.83		
7	.93	.89	.86	.84	.92	.88	.86	.83	.87	.85	.83	.86	.84	.83	.86	.84	.82	.82		
8	.92	.87	.84	.82	.91	.86	.84	.82	.86	.83	.82	.85	.83	.81	.84	.83	.81	.80		
9	.90	.85	.83	.81	.89	.85	.83	.81	.84	.82	.80	.84	.82	.80	.83	.81	.80	.79		
10	.88	.84	.81	.79	.88	.84	.81	.79	.83	.81	.79	.82	.80	.79	.82	.80	.79	.78		

CU VALUE GREATER THAN 1.00
determined in accordance with current IES published procedures
LUMINAIRE INPUT WATTS = 26.0

Tested according to IES procedures.
Test distance exceeds five times the greatest luminous opening of luminaire.

C4MRDCCLW, 20W G.E. HID FLOOD, 25° GX10 BASE



CANDLEPOWER SUMMARY		
Angle	Mean CP	Lumens
0	3280	
5	2896	267
10	2105	
15	1316	386
20	715	
25	342	184
30	187	
35	92	67
40	53	
45	30	22
50	0	
55	0	0
60	0	
65	0	0
70	0	
75	0	0
80	0	
85	0	0
90	0	

LUMEN RATING = 1000 LMS.
SC = .4
TEST REPORT NO. 3392FR

ZONAL LUMENS AND PERCENTAGES			
ZONE	LUMENS	%LAMP	%LUMINAIRE
0-30	836	83.67	90.41
0-40	903	90.33	97.61
0-60	925	92.54	100.00
0-90	925	92.54	100.00
40-90	22	2.21	2.39
60-90	0	.00	.00
90-180	0	.00	.00
0-180	925	92.54	100.00

** EFFICIENCY = 92.5% **


LUMINANCE SUMMARY	
ANGLE	MEAN CD/SQ M
45	4709
55	0
65	0
75	0
85	0

COEFFICIENTS OF UTILIZATION ZONAL CAVITY METHOD																				
EFFECTIVE FLOOR CAVITY REFLECTANCE = .20																				
CC	80				70				50				30				10			
	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10			
0	1.10	1.10	1.10	1.10	1.08	1.08	1.08	1.08	1.03	1.03	1.03	.98	.98	.98	.94	.94	.94	.93		
1	1.07	1.05	1.04	1.02	1.05	1.04	1.02	1.01	1.00	.99	.98	.96	.95	.95	.93	.93	.92	.91		
2	1.04	1.01	.99	.96	1.02	.99	.97	.95	.96	.95	.93	.94	.93	.91	.92	.91	.90	.88		
3	1.01	.97	.94	.92	1.00	.96	.94	.92	.94	.92	.90	.92	.90	.89	.90	.89	.87	.86		
4	.98	.94	.91	.89	.97	.93	.91	.88	.92	.89	.87	.90	.88	.86	.88	.87	.85	.84		
5	.96	.91	.88	.85	.95	.90	.87	.85	.89	.86	.84	.87	.85	.83	.86	.85	.83	.82		
6	.94	.89	.85	.83	.93	.88	.85	.83	.87	.84	.82	.86	.83	.82	.85	.83	.81	.80		
7	.91	.86	.83	.80	.90	.85	.82	.80	.84	.82	.80	.83	.81	.79	.83	.80	.79	.78		
8	.89	.83	.80	.78	.88	.83	.80	.77	.82	.79	.77	.81	.79	.77	.81	.78	.77	.76		
9	.87	.81	.78	.76	.86	.81	.78	.76	.80	.77	.75	.80	.77	.75	.79	.76	.75	.74		
10	.85	.79	.76	.73	.84	.79	.76	.73	.78	.75	.73	.78	.75	.73	.77	.75	.73	.72		

CU VALUE GREATER THAN 1.00
determined in accordance with current IES published procedures
LUMINAIRE INPUT WATTS = 26.0

Tested according to IES procedures.
Test distance exceeds five times the greatest luminous opening of luminaire.

C4MRDCCLW, 20W G.E. HID FLOOD, 40° GX10 BASE



CANDLEPOWER SUMMARY		
Angle	Mean CP	Lumens
0	2247	
5	1983	187
10	1629	
15	1300	366
20	934	
25	504	255
30	261	
35	120	88
40	62	
45	37	27
50	5	
55	1	2
60	1	
65	1	1
70	0	
75	0	0
80	0	
85	0	0
90	0	

LUMEN RATING = 1000 LMS.
SC = .6
TEST REPORT NO. 3391FR

ZONAL LUMENS AND PERCENTAGES			
ZONE	LUMENS	%LAMP	%LUMINAIRE
0-30	807	80.79	87.15
0-40	896	89.63	96.69
0-60	925	92.56	99.85
0-90	926	92.70	100.00
40-90	30	3.07	3.31
60-90	1	.14	.15
90-180	0	.00	.00
0-180	926	92.70	100.00

** EFFICIENCY = 92.7% **

LUMINANCE SUMMARY	
ANGLE	MEAN CD/SQ M
45	5737
55	260
65	211
75	157
85	200

COEFFICIENTS OF UTILIZATION ZONAL CAVITY METHOD																				
EFFECTIVE FLOOR CAVITY REFLECTANCE = .20																				
CC	80				70				50				30				10			
	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10			
0	1.10	1.10	1.10	1.10	1.08	1.08	1.08	1.08	1.03	1.03	1.03	.99	.99	.99	.95	.95	.95	.93		
1	1.07	1.05	1.03	1.02	1.05	1.03	1.02	1.00	.99	.98	.97	.96	.95	.94	.93	.92	.92	.90		
2	1.03	1.00	.98	.95	1.02	.99	.96	.94	.96	.94	.92	.93	.92	.91	.91	.90	.89	.87		
3	1.00	.96	.93	.91	.99	.95	.92	.90	.93	.91	.89	.91	.89	.87	.89	.88	.86	.85		
4	.97	.93	.89	.87	.96	.92	.89	.86	.90	.87	.85	.88	.86	.84	.87	.85	.83	.82		
5	.94	.89	.85	.83	.93	.88	.85	.82	.87	.84	.82	.86	.83	.81	.84	.82	.80	.79		
6	.92	.86	.83	.80	.91	.86	.82	.80	.85	.82	.79	.83	.81	.79	.82	.80	.78	.77		
7	.89	.83	.79	.77	.88	.83	.79	.76	.82	.78	.76	.81	.78	.76	.80	.77	.75	.75		
8	.87	.80	.77	.74	.86	.80	.76	.74	.79	.76	.74	.78	.75	.73	.77	.75	.73	.72		
9	.84	.78	.74	.71	.83	.77	.74	.71	.76	.73	.71	.76	.73	.71	.75	.72	.70	.70		
10	.81	.75	.72	.69	.81	.75	.72	.69	.74	.71	.69	.74	.71	.68	.73	.70	.68	.67		

CU VALUE GREATER THAN 1.00
determined in accordance with current IES published procedures
LUMINAIRE INPUT WATTS = 26.0

Tested according to IES procedures.
Test distance exceeds five times the greatest luminous opening of luminaire.

Job Information Type:

Lightolier a Genlyte company www.lightolier.com
631 Airport Road, Fall River, MA 02720 • (508) 679-8131 • Fax (508) 674-4710
We reserve the right to change details of design, materials and finish.
© 2006 Genlyte Group LLC • A1007