

Ceiling Cutout: 8" (203 mm) Dia.

Reflector Trim	Frame-In Kit	Lamp
8067 CL Clear Iridescence Free, Flangeless	7213LPM120 Magnetic 2-pin 120V	(2) 13W Twin Tube
8067 CLW Clear Iridescence Free, White Flange	7213LPM277 Magnetic 2-pin 277V	(2) 13W Twin Tube
8067 CLP Clear Iridescence Free, Polished Flange		
8067 WH Matte White, Flangeless		
8067 WHW Matte White, White Flange and Cone		
8067 <input type="checkbox"/> Add suffix. See options for other finishes.		

Features

- 1. Reflector:** 16 ga. Alzak® aluminum, 50° visual cutoff to lamp and lamp image.
- 2. Parabolic Louver:** 18ga. prefinished reflector aluminum, 50° visual cutoff to lamp and lamp image. Snap-in, snap-out system allows easy louver removal for lamping. Louver / reflector / socket support can be rotated up to 40° for horizontal alignment.
- 3. Mounting Frame:** Die-cast aluminum for dry or plaster ceilings.
- 4. Socket Support:** Die-formed steel with venting to dissipate heat. Assures lamps maintain proper optical alignment to reflector. Can be rotated with reflector / louver for horizontal alignment. Pre-wired with No. 18 ga. AWM leads.
- 5. Mounting Brackets:** 16 ga. steel. Adjust from inside of fixture. Use 3/4" or 1 1/2" lathing channel, 1/2" EMT, or optional mounting bars.
- 6. Ballast/J-Box:** Outboard mounted to reduce heat transfer and maintain lamp efficacy and life. Service from below without tools.

Electrical

Note: For ballast electrical data and latest lamp/ballast compatibility refer to "Ballast" specification sheet for complete electrical data.

UL listed for through branch circuit wiring with max of (8) No. 12 AWG, 90° C supply conductors.

Options and Accessories

Comfort Clear™ Finishes¹

Clear **CCL**
Diffuse **CCD**

¹Specify Desired Flange

P-polished, **W**-white

Blank - Molded Trim Ring

Options and Accessories (continued)

Emergency Add suffix **EM***
Chicago Plenum Add suffix **LC**
Emergency Ltg. Kit **FAEMIT**
Fuse (Slow Blow) Add Suffix **F**
*See Spec. Sheets: FAEM

Mounting Bars & Accessories; see Specification Sheet MBA.
Sloped Ceiling Adapters; see Specification Sheet SCA.

Labels

UL listed for damp locations, I.B.E.W.

Alzak® is a registered trademark of ALCOA.

US Patent Pending


Job Information	Type:
Job Name:	
Cat. No.:	
Lamp(s):	
Notes:	

631 Airport Road, Fall River, MA 02720 • (508) 679-8131 • Fax (508) 674-4710

We reserve the right to change details of design, materials and finish.

www.lightolier.com © 2008 Philips Group • B0708


Quick Calculator



Use quick calculator chart to determine spacing of luminaires for desired level of illumination

Spacing Ratio = 1.3

CERTIFIED TEST REPORT NO. 1162FR
COMPUTED BY LSI PROGRAM **TEST-LITE**
CALCULITE LOW PROFILE RECESSED 7" HORIZONTAL FLUORESCENT DOWNLIGHT
SPECULAR CLEAR FINISH REFLECTOR AND CROSS BLADE
2-13W TWIN TUBE SYLVANIA COMPACT FLUORESCENT LAMPS. LUMEN RATING = 800 LMS.
MAGNETEK BALLAST, CAT.# 4114 PBES, 120V AC



CANDLEPOWER DATA
IN 2.5 DEGREE STEPS

ANGLE ALONG	22.5	45	67.5	ACROSS	OUTPUT LUMENS
0	496	496	496	496	
5	506	506	515	522	49
10	519	530	556	564	
15	510	535	576	582	157
20	506	528	570	578	
25	488	504	548	572	245
30	426	435	480	524	
35	305	323	346	387	214
40	159	183	198	191	
45	67	83	91	76	71
50	14	19	26	18	
55	3	2	4	2	6
60	1	1	1	1	
65	0	0	0	0	0
70	0	0	0	0	
75	0	0	0	0	0
80	0	0	0	0	
85	0	0	0	0	0
90	0	0	0	0	

ZONAL LUMENS AND PERCENTAGES

ZONE	LUMENS	% LAMP	% LUMINAIRE
0-30	451	28.23	60.81
0-40	665	41.59	89.61
0-60	742	46.38	99.93
0-90	742	46.42	100.00
40-90	77	4.82	10.39
60-90	0	.03	.07
90-180	0	.00	.00
0-180	742	46.42	100.00

** EFFICIENCY = 46.4% **

COEFFICIENTS OF UTILIZATION ZONAL CAVITY METHOD
%EFFECTIVE FLOOR CAVITY REFLECTANCE = .20

ROOM CAVITY RATIO	80			70			50			30			10			0
	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	
1	.52	.51	.50	.51	.50	.49	.49	.48	.48	.47	.47	.46	.46	.45	.45	.44
2	.49	.47	.46	.48	.46	.45	.46	.45	.44	.45	.44	.43	.44	.43	.42	.42
3	.46	.44	.42	.45	.43	.42	.44	.42	.41	.43	.42	.40	.42	.41	.40	.39
4	.43	.41	.39	.43	.40	.39	.42	.40	.38	.41	.39	.38	.40	.38	.37	.37
5	.40	.38	.36	.40	.37	.36	.39	.37	.35	.38	.37	.35	.38	.36	.35	.34
6	.38	.35	.34	.38	.35	.33	.37	.35	.33	.36	.34	.33	.36	.34	.33	.32
7	.35	.33	.31	.35	.33	.31	.35	.32	.31	.34	.32	.31	.34	.32	.30	.30
8	.33	.31	.29	.33	.30	.29	.32	.30	.29	.32	.30	.28	.32	.30	.28	.28
9	.31	.28	.26	.31	.28	.26	.30	.28	.26	.30	.28	.26	.29	.28	.26	.25
10	.29	.26	.24	.29	.26	.24	.28	.26	.24	.28	.26	.24	.28	.26	.24	.24

DETERMINED IN ACCORDANCE WITH CURRENT IES PUBLISHED PROCEDURES

Job Information **Type:**

631 Airport Road, Fall River, MA 02720 • (508) 679-8131 • Fax (508) 674-4710
We reserve the right to change details of design, materials and finish.
www.lightolier.com © 2008 Philips Group • B0708