
Page 1 of 2

6 3/4" Aperture Step Baffle Wall Washer Low Profile Reflector Trim



1135T/1102T1 Series

#### Complete Fixture consists of Reflector Trim & Frame-In Kit. Select each separately.

Reflector Trim	Fran	Frame-In Kit — See Individual Frame-In Kit Specification Sheets						
	Fluorescent							
	Frame-In Kit	Installation Type	Lamping	Height				
1135T Matte Black Step Baffle	1102T1	Non-IC	2 Lamp 13W Twin Tube	3 7/8"				
1135TWH Matte White Step Baffle	1102TH1	Non-IC	Compact Fluorescent	3 7/8"				
	1102TH2	Non-IC	(Gx23) 2 Pin Base	3 7/8"				
	1102TM1	Non-IC Emergency		3 7/8"				
	1102TM2	Non-IC Emergency		3 7/8"				
	1102TH1R	Non-IC		3 7/8"				
	1102T13U	Non-IC	2 Lamp 13W Quad Tube	3 7/8"				
			Compact Fluorescent					
			(G24q-1) 4 Pin Base					
	1102T18U	Non-IC	2 Lamp 18W Quad Tube	3 7/8"				
			Compact Fluorescent					
			(G24q-2) 4 Pin Base					
	1102T26U	Non-IC	2 Lamp 26W Quad Tube	3 7/8"				
			Compact Fluorescent					
			(G24q-3) 4 Pin Base					

#### **Features**

- Reflector: Hydroformed aluminum, .040" thick (18 ga.). White gloss finish on inside and flange.
- Step Baffle: Die cast aluminum, stepped conical surface for low brightness, matte black finish.
- Aperture Plate: Semi-circular; die-formed steel; matte white; attached to step baffle; snaps out for relamping.
- 4. Scoop Reflector: Hydroformed aluminum, .040" thick (18 ga.), Anobrite® (anodic-processed) semi-specular finish for permanent high reflectivity; provides an even wash of light over wall surface without scallops or shadows
- Frame-In Kit: (1102T1 standard frame shown; other frames listed above.)
  See Frame-In Kit specification sheet for more details.

#### **Options & Accessories**

**Retaining Clips:** 1955 - For installing in existing ceiling

Extra Wide Flange Trim Ring: 1954 - 8-7/8" O.D.

**Plaster Ceiling Ring:** 1961- 7/8" depth for wet plaster ceilings.

#### Labels

UL (Suitable for Damp Locations), I.B.E.W.


US Patent Nos. 4,313,154; 4,327,403

Job Information	Туре:
Job Name:	
Cat. No.:	
Lamp(s):	
Notes:	

**Lightolier** a Genlyte company www.lightolier.com 631 Airport Road, Fall River, MA 02720 • (508) 679-8131 • Fax (508) 674-4710 We reserve the right to change details of design, materials and finish. © 2006 Genlyte Group LLC • E1006

# Page 2 of 2

6 3/4" Aperture Step Baffle Wall Washer Low Profile Reflector Trim



# **LIGHTING DATA**


EXAMPLE: Multiple units with 2 Lt. 26W Quad Tube lamps, located 2' from wall and 2' on center, illumination on the wall 3' down from the ceiling is 31 f.c. beneath and 32 f.c. between fixtures.

# **FOOTCANDLES ON WALL FROM MULTIPLE UNITS**

2 LT. 26W Quad Tube										
	UNITS 2 FEET FROM WALL									
			2'	一占	Ь	— 3' ·				
5,	1	5!	5 53	55	41	31	41			
≦	2	43	3 45	43	30	29	30			
106	3	3.	1 32	31	31	22	21			
	4	2	1 22	21	15	15	15			
E	5	1:	5 15	15	10	11	10			
9	6	11	1 11	11	8	8	8			
DISTANCE FROM CEILING, FT.	7	1	8	8	6	6	6			
	8		6 6	6	5	5	5			
	9	!	5 5	5	4	4	4			

	2 LT. 26W Quad Tube									
	UNITS 3 FEET FROM WALL									
l <del></del>		<u> </u>	— 3' -	-Н	Ь	— 4'	一占			
5	1	28	25	28	23	19	23			
≘	2	23	23	23	18	17	18			
100	3	19	20	19	15	15	15			
≧	4	16	17	16	12	13	12			
监	5	12	13	12	10	10	10			
9	6	10	10	10	8	8	8			
DISTANCE FROM CEILING, FT.	7	8	8	8	6	6	6			
$\equiv$	8	6	7	6	5	5	5			
	9	5	6	5	4	4	4	·		

For 2 Lt. 18W Quad Tubes, multiply footcandle above by 0.7.



# **LIGHTING DATA**

EXAMPLE: Multiple units with 2 Lt. 13W Quad Tube lamps, located 2' from wall and 2' on center, illumination on the wall 3' down from the ceiling is 17 f.c. beneath and 17 f.c. between fixtures.

# FOOTCANDLES ON WALL FROM MULTIPLE UNITS

	2 LT. 13W Twin Tube									
	UNITS 2 FEET FROM WALL									
l <sub>H</sub>			_ 2′	一占	占	— 3,	一占			
DISTANCE FROM CEILING, FT.	1	27	27	27	19	16	19			
≦	2	22	2 22	22	16	14	16			
9	3	17	17	17	11	11	11			
∫ ≥	4	12	12	12	8	9	8			
	5	٤	9	9	6	6	6			
2	6	6	6	6	5	5	5			
I ₹	7	4	4	4	3	3	3			
ă	8	3	3	3	3	3	3			
	9	2	2 2	2	2	2	2			

For 2 Lt. 13W Quad Tubes, multiply footcandle above by 0.7.

Footcandle values are averaged and rounded off and are based on a minimum of five units.

For fixture-to-wall distances, other than those shown, use maximum of 1 of 1 spacing (distance between fixtures not more than distance to wall) for best result.

#### Job Information Type:

