



Ordering Information

Catalog No.	Finish	Mounting	Compatible Plug-In Breakers
6133WH 6133BK	Matte White Matte Black	Mounts directly to surface or to a 4" octagonal outlet box. Connects to Advent Plain track units. Suitable for mounting to grid ceiling runners. Can be used with stem mounted Advent track.	Compatible with PLD powerbreakers. Refer to PLD120 spec sheet. Ordered Separately

Features

- Wire Cover:** Plastic Polycarbonate.
- Mounting Plate:** .075 thick galvanized steel.
- Round Knock Out:** (2) 7/8 dia. knockouts for electrical feed. (1) or (2) circuits can be fed into connector. Offset to accommodate grid ceiling runners.
- Ground Terminals:** (2) ground terminals.
- Rectangular Knock Out:** Allows feeding from j-box with proper UL area for splice inspection without removing connector from j-box.
- Mounting Holes:** (4) holes on 3.5 in. centers secure connector to j-box or mounting surface.
- Track Connector Screw Terminals:** Each terminal accepts (2) 12 or 14 ga. copper feed wires.
- Advent Track Connector:** (2) assemblies keyed to maintain proper polarity with track. Installs into track providing electrical and mechanical connection.
- Circuit Breaker:** (Sold Separately). One or two can be installed. Limits the amount of electrical load that can be placed on the circuit. Can be used as standard On/Off switch.
- Cover Mounting Screws:** Pin Torx head steel screws secure cover to plate. Color matches fixture color.
- Electrical Wires:** (3) 12 ga. jumper wires are installed by factory. The wires can be removed for alternate wiring scheme.
- Tamperproof Locking Screw:** (2) Mechanically secures connector into track. Color matches fixture color.

Electrical

Capacity is 120 volts, 60Hz. All Lytespan Track luminaires are polarized and continuously grounded throughout. Electrical conductors are concealed in an insulating liner. Intended for wiring to branch circuit building wire with ground. All wiring must be in accordance with National and Local Codes.

Labels

U.L. listed.

Note: to assure full compliance with local energy codes and regulations check with your local code official.

Job Information	Type:
Job Name:	
Cat. No.:	
Lamp(s):	
Notes:	