


Assembly Instructions



- 1, CAREFULLY TAKE THE FIXTURE OUT OF THE CARTON, AND CHECK THAT ALL THE PARTS ARE INCLUDED REFERRING TO THE ABOVE DRAWING.BE SURE NOT TO MISPLACE ANY PARTS THAT ARE NEEDED TO INSTALL THIS LAMP.
- 2, REFER TO MOUNTING AND WIRING INSTRUCTION SHEET.
- 3, THREAD THE HEX NUT(5) ONTO THE NIPPLE(4), THEN SCREW THE NIPPLE(4) INTO THE COUPLING(6).
- 4, SLIDE THE COLUMN(3), WASHER(2) ONTO NIPPLE(4), THEN SCREW THE LOOP(1) ONTO THE NIPPLE(4).
- 5, THREAD THE HEX NUT(11) ONTO THE NIPPLE(12), THEN SCREW THE NIPPLE(12) INTO THE COUPLING(10).
- 6, SLIDE THE CAP(13) ONTO THE NIPPLE(12), FIX IT BY FINAL(14).
- 7, PUT GLASS SHADE(7) ONTO SOCKET(8), SECURED THEM WITH SOCKET RING(6).
- 8, INSTALL THE LAMPS ON.
- 9, THE FIXTURE IS ASSEMBLED.



Assembly Instruction for the fixture with safety cable

NOTE: Fixtures weighing over 50 lbs, must be supported independently of the outlet box

1)Turn off power

2)Supply wires shall enter the outlet box through any knockout except the top center knockout,

3)Fixture is to be mounted by a steel pipe approximately 3/4?of 3/8-18NPSN threads at bottom. (Not Supplied) Position pipe so that approximately 1/2"of thread protrudes into outlet box. Attach pipe to a structural bridging member of sufficient strength to support at least 4 times the fixture weigh.

4) Thread pipe coupling onto protruding inside outlet box.

5)Thread hex nut onto threaded pipe. Screw threaded pipe into pipe coupling. Secure in place by tightening hex nut against pipe coupling and tightening allen head screw.

6)Thread hex nut. Ship on ground wire and thread a second hex nut onto threaded pipe.

7)Connect scraw collar loop (without threaded ring) to threaded pipe.

8)Pass canopy over screw collar loop. Approximately one-half of the screw collar loop exterior thread should be exposed. Adjust loop as required. Remove canopy and tighten hex nut against screw collar loop. Tighten second hex nut against first to hold ground wire in place.

9) Attach chain to fixture (not shown)

10)Slip threaded ring then canopy onto chain

11) Attach chain (with fixture connected) to bottom of screw collar loop.

12)Weave silver support cable up chain and exit through top hole inside of pipe coupling. Slip cable through top existing opening or drill 3/16" dia. Hole near center of outlet box. Wrap cable around structural member described in step #3. Cable must be pulled tight to evenly distribute fixture weight between cable and chain. Secure cable with (2) claps provided.

13) Weave both fixture wires and copper ground wire up chain and exit through top hole inside of pipe coupling.

14)Connect fixture ground wire and ground wire attached to threaded pipe to outlet box ground wire with wire connector (not provided). Never connect ground wire to black or power supply wires.

Make wire connections (connectors not provided) Reference chart below for correct connections and wire accordingly.

Connect Black or	Connect Black or
Red Supply Wire to:	White Supply Wire to:
Black	White
*Parallel cord (round & smooth)	*Parallel cord (square & ridged)
Clear,Brown,Gold or	Clear, Brown, Gold or
Black without tracer	Black without tracer
Insulated wire (other than	Insulated wire (other than
green) with copper conductor	green) with silver conductor

Notes: When parallel (SPTI & SPTIII) are used. The Neutral wire is square shaped or ridged and the other wire Will be round in shape or smooth (see us)

Warning: Consult a qualified Electrician for installation

