EM Gateway

User's Manual

For Watlow part number EM00-GATE-0000





1241 Bundy Boulevard, P.O. Box 5580, Winona, Minnesota USA 55987-5580 Phone: +1 (507) 454-5300, Fax: +1 (507) 452-4507, Internet: http://www.watlow.com

EM Gateway

Table of Contents

Chapter 1:	Product Overview Ethernet Gateway	4 4
	Ethernet Gateway Ethernet Gateway Architecture	4
	Program Upgrades	5
Chapter 2:	Installation and Wiring	6
	Dimensions	7
Chapter 3:	Configuration	8
	Getting Started	8
	Network Services	8
	Email Alarm Notification	8
	Data Logging	9
	Control Monitoring and Configuration	9
Chapter 4:	HTML Pages	10
	EM Gateway	10
	EM Gateway Setup	11
	EM Gateway Network Setup	12
	EM Gateway Email Setup	13 14
	EM Gateway Clock Setup EM Gateway Serial Statistics	15
	EM Gateway Network Statistics	16
Chapter 5:	Controller Parameters and Registers	17
	Series 96 – non-ramping	17
	Series 97	17
	Series 981 / 982	17
	Series 988 / 989	18
	Series 998 / 999	18
	Series F4S / F4D Series F4P	18 19
	MicroDin	19
	Power Series	19
	CLS200 Series	20
	Series SD – non-ramping	20

EM Gateway

Table of Contents – cont.

Chapter 6:	Reference Documents	25
	Reference Documents	25
	Serial Numbers	25
Chapter 7:	Specifications	26
	Power Supply	26
	Environmental	26
	Indication	26
	Agency	26
	Communications	26
	Control Output Signals	26
	Enclosure Size	26
	User Interface	26
	Ordering Information	26
Declaration of	of Conformity	27
How to Read	•	28

Chapter One

Product Overview

The EM00-GATE-0000 is a gateway / bridge that allows up to 32 Watlow controllers to be directly connected to an Ethernet network. Using an HTTP Browser such as Microsoft Internet Explorer or Netscape Navigator you may access 16 controllers and view several controllers' parameters via an onboard Web (HTTP) server.

Ethernet Gateway

The Ethernet gateway provides a means for monitoring and configuring runtime parameters of multiple controllers via a web browser. The gateway is also a bridge for Modbus messages between the Ethernet bus and EIA-485 or EIA-232 links. The Gateway supports full product configuration; monitoring and configuration of runtime parameters via MODBUS TCP over TCP/IP using a software package such as Watview sold by Watlow.

Ethernet Gateway Architecture


This product has three physical connectivity points to the physical world. They are the serial (EIA-485 or EIA-232), Ethernet port (10BaseT), and the power supply pins.

The EIA-485 / EIA-232 connection supports Modbus RTU protocol and operates as a Master port. It will initiate data read/write requests to supported standard Watlow controllers. There exists a virtual image of the controller's data points in the gateway. The polling engine that initiates the Modbus RTU requests is responsible for synchronization of the virtual image and the actual controller. Changes to control data occur both at the controller and at the virtual image.

The 10BaseT connection supports the TCP/IP stack. At the application layer it has an HTTP (web) and Modbus server. The HTTP server will provide current controller status from the virtual image via HTML. The HTTP server provides a means of changing some runtime parameters via HTML. The TCP/IP stack supports DHCP client, AutoIP, static IP, DNS client, and Netbios name resolution. The 10BaseT connector is an RJ45 per the IEEE 802.3 specification.

The EM00-GATE-0000 can be used as a bridge for Modbus RTU messages. This is concurrent with all other communicating functions. In this scenario, the gateway simply passes the request that comes in on the Ethernet connection through to the EIA-485 or EIA-232 connection. When the response is returned from the controller, it is sent back on the Ethernet connection. No processing of the packet contents is necessary to bridge the two physical layers.

Block Diagram of Gateway



Program Upgrades


The gateway has a TFTP server for the purposes of reprogramming the program memory. A program update will be initiated when a TFTP client, residing on a PC, begins to write a new program file to the gateway TFTP server. When reprogramming the program memory, all other gateway services are unavailable.

The gateway provides no means of updating the program memory of controller devices, such as flashing new information into the Series F4.

Chapter Two


Installation & Wiring


EIA-485 Wiring




UL Approved, Class 2 power supply required

EIA-232 Wiring







Chapter Three

Configuration

Getting Started

Perform these steps;

- Connect the EM00-GATE-0000 gateway to your computer's Ethernet port using a cross-wired RJ45 cable or connect the EM00-GATE-0000 to a hub or network using a straight wired RJ45 Category 5 cable. The EM00-GATE-0000 is limited to a 10BaseT connection and will not work on an Ethernet port set for 100BaseT only. Use of a 10/100 hub will overcome this issue if your PC has only a 100BaseT port.
- Wire the temperature controllers to the gateway's EIA-485 port. You may connect the gateway's EIA-232 port to a controller if you will be using only one controller, provided that the controller has an EIA-232 port.
- 3. Wire a 24-volt AC or DC power supply to the gateway terminals. This is not polarity sensitive.
- 4. Configure each controller to the same baud rate (9600 or 19200) from the front panel of the controller. Set each controller's Modbus address to a unique number. As an example, set the first controller to address 1, the second to address 2 and so on.
- 5. Power up the gateway, controllers and PC.
- 6. Start your Internet browser. Enter the TCP/IP address of the gateway into the browsers' address field. Two different addresses may be used to access the gateway. Either EMxxxxxx, where xxxxxx is the first six digits of the serial number, or WATxxxxxx, where xxxxxx is the last six digits of the gateways' MAC address. The MAC address is printed on a decal in the form xx:xx:xx:xx:xx:xx.
- 7. Select the Gateway Setup Page. Enter User name 'new' and Password 'user' by default. The Password can be changed on the Security Configuration screen.
- 8. Configure the Baud Rate and range of controllers' addresses to match those you configured in step four.
- 9. Click on Rescan Modbus Network
- 10. Click on the back button of the browser to return to the previous page.
- 11. Click on the refresh button of the browser and your controllers' information should now be visible.

Note: You must click on the refresh button within the browser to capture the latest controller information. This information is automatically refreshed after 10 seconds by default. You may change this refresh time using the appropriate page.

Network Services

The EM00-GATE-0000 supports DHCP client, autoIP, and static IP for address assignment. Normally you will not need to make any changes. The user is able to configure preferences as to which services are used if available. Intelligence is employed within the gateway to revert to backup IP assignment methods if the primary method is unavailable.

The gateway does support DNS client and Netbios name resolution. Configuration information may be entered at the EM Gateway Network Display Setup page.

Email Alarm Notification

The email function allows the user to send emails to four addresses alerting them of alarm conditions that have occurred on the controllers connected to the Gateway. A button on the Graphical User Interface (GUI) allows the user to enable or disable this feature. Emails can be generated whenever an alarm condition occurs for each controller. An email acknowledge feature requires that the user acknowledge the email message by operating the email acknowledge button before additional email alarm messages can be generated for that controller. For multiloop controllers only one email acknowledge feature is supported; if more than one loop produces an alarm, only the first alarm detected will generate an email until acknowledged.

You will need to configure your Gateway with your SMTP server name or address. A DNS server address must also be configured if using a SMTP name. Contact your system administrator if you don't know the SMTP name or address.

Data Logging

The gateway provides no explicit means of data logging. Data can be polled via Modbus TCP by an external PC program. Consider WatView from Watlow for your setup, data logging and graphing needs.

Control Monitoring and Configuration

The gateway provides a means of monitoring the current process value for analog inputs of each controller using a built-in HTTP server. It also provides a means of monitoring the present alarm status of each controller. Additionally, you may monitor and change control set points for control loops of each controller.

The gateway is capable of supporting Watlow Series 96 non-ramping, 97, 981, 982, 988, 989, 999, F4S, F4D, F4P, MicroDin, Power Series, CLS200and SD non-ramping controllers with up to 16 controllers in any combination.

The gateway is capable of automatically determining when a controller is connected to the serial bus. It will identify the model and address of each controller. Controllers with duplicate Modbus addresses will be ignored by the gateway.

You can configure the baud rate of the EIA-485 or EIA-232 bus. You may also specify which controller addresses are scanned under the EM Gateway Setup page. The gateway supports from 1 to 16 controllers in any combination of supported model numbers. Select Rescan Modbus Network to update the detection of controllers on the bus. The Modbus network is automatically scanned every two minutes for new devices.


Chapter Four

HTML Pages

The section describes the pages available from the EM Gateway's Web server.

When the web page is first accessed, you are prompted for a User name and Password. The default User name is 'new'. The default Password is 'user'. These are case sensitive. The user name and password may be changed on the security configuration page.





This is the main page for monitoring the controllers on the Gateway. You can click on values that are located within a box. Entering in a new value may change these values. In addition, use Alarm Ack to clear alarms when a process value has returned within a safe operating range. Use the Email Ack to reactivate future emails for this controller. See the controller's user's manuals for details of Modes, Errors, and Alarm operation.



Serial Statistics

This page was loaded Thu Feb 14 13:37:08 2002

Display Setup	
▼ Enable "Home" pa	ge auto-refresh interval.
30 Time period of	"Home" page auto refresh (5-9999 seconds).
Submit Reset	
Modbus	
Note: Submitting any char	nges to the Modbus settings below will cause the EM Gateway to rediscover any serial devices.
Rescan Modbus Netw	<u>'ork</u>
Baud Rate:	1) 9600 🔽
Start Address:	1-247
End Address:	1 1-247
Maximum Nodes:	1-16
Submit Reset	
Ethernet	
Network Setup	
Email Setup	
Clock Setup	
Network Statistics	

Use this page to disable or enable automatic page refreshing or to change the time in between refreshes.

In addition, you can force a rescan of the Modbus Network. This will cause the Gateway to detect any new devices added to the serial network. Set the baud rate of the network to 9600 or 19200-baud. The value selected must match the value in all of the controllers on the serial network. Up to 16 controllers may be scanned by the Gateway using the built-in HTTP server. Set a start address to the lowest address number of the controller on the serial network. Set an end address to the highest address number of the controller on the serial network.

As an example, you have your first controller set to address 23 and the last one set to 35. Set Start Address to 23 and End Address to 35. You can limit the number of controllers accessed by the Gateway by setting the Maximum Nodes value to less than 16.

Lastly, this page provides links to Network Setup, Email Setup, Clock Setup, Network Statistics, and the Serial Statistics pages.



This page was loaded Thu Feb 14 13:37:30 2002

Device Identification

Name EM000100

Current Settings

 IP Address
 7.3.37.91

 Subnet Mask
 255.255.224.0

 Default Gateway
 7.3.63.250

 DNS Server
 7.3.55.4

IP Address Resolution Method

Choose the method for this hosts IP address assignment.

 Try DHCP server, then use Auto IP, then use fixed IP address

C Try DHCP server, then use fixed IP address

C Try Auto IP, then use fixed IP address

C Use Fixed IP address

Fixed IP Address

 Fixed IP Address
 0.0.0.0

 Fixed Subnet Mask
 0.0.0.0

 Fixed Gateway
 0.0.0.0

 Fixed DNS Server
 0.0.0.0

Submit Reset

Use this page to change the Gateway identification name or to change the IP Address Resolution Method. Contact your IS administrator for questions regarding these settings.



EM Gateway Email Setup

This page was loaded Thu Feb 14 13:37:49 2002

Electronic Notification

The SMTP Server Address has priority over the SMTP Server Name. To use the SMTP Server Name, leave the SMTP Server Address blank. The SMTP Server Name requires a DNS look-up.

Alarms that occur before the Server Name is resolved are not sent.

Enable Email Notification	
SMTP Server Name	Example: smtp.company.com
SMTP Server Address	Example: 102.43.23.2
Email Subject	Example: EM Gateway Alert
Source Email Address	Example: joe_service@company.com
Email Recipient 1	Example: 3125554444@pager.com
Email Recipient 2	Example: anyone@yahoo.com
Email Recipient 3	Leave blank if unused
Email Recipient 4	Leave blank if unused
Location Info Appended to Email	
Submit Reset	

Use this page to enable notification and configure the addresses for email recipients. These recipients will receive an email when an alarm occurs on any controller. Contact your IS administrator for questions regarding these settings.



EM Gateway Clock Setup

This page was loaded Thu Feb 14 13:38:06 2002

Current EM Gateway Time: 14-Feb-2002 13:35:42



Use this page to update the time and date stored in the Gateway. This information is used to identify the time and date of alarms when emails are sent.

WATLOW

EM Gateway Serial Stats

Device Address	Feb 14 13:38:53 2002 Timeout Errors	Retry Errors	CRC Errors	Bad Polls	Good Polls	Illness
1	0	0	0	0	1174	0
2	0	0	0	0	1174	0
3	0	0	0	0	1174	0
4	0	0	0	0	1174	0
5	0	0	0	0	1174	0
6	0	0	0	0	1174	0
7	0	0	0	0	1174	0
8	0	0	0	0	1174	0
9	0	0	0	0	1174	0
10	0	0	0	0	1174	0
11	5	2	0	3	1167	0
12	0	0	0	0	1174	0
13	0	0	0	0	1174	0
14	0	0	0	0	1174	0
15	0	0	0	0	1174	0
16	0	0	0	0	1174	0

The Serial Statistic page is used to monitor the health of the controller network. These numbers will help identify when there are issues with wiring, duplicate Modbus ID addresses or noise on communication wires on the controller side of the network. In this example, controller number 11 is experiencing failure in communication quality.

Timeout Errors increments anytime that a controller does not respond in an appropriate amount of time.

Retry Errors increments anytime that a controller does not respond after 3 attempts to read information.

CRC Errors increments anytime that the controller responds with a bad packet.

Bad Polls increments when there are timeouts and the retries did not successfully retrieve information. Good Polls increments on each valid packet received.

Illness increments anytime that there are 5 CRC or Timeout errors in a row. After a count of 5 in the Illness column, the controller is flagged as having no communication. On the next valid packet received, the Illness value is cleared to zero and communications is restored.

You must refresh the browser to see these numbers update.



Big Queue Min

Little Queue Length

Little Queue Max

Little Queue Min

EM Gateway Network Stats

This page was loaded Wed Feb 1318: 00:28 2002

IP Address 7.3.37.91 Subnet 255.255.224.0 Gateway 7.3.63.250

00:03:AA:00:00:C1

Mac Address Receives 128349 Unicasts 1207 Multicasts 0 Broadcasts 127061 Rx Errors 0 Rx Missed 2089 Rx CRC Errors 28 0 Rx Drops **Transmits** 1251 **Buffer Defers** 0 Tx Errors 0 Tx Collisions 0 Tx Coll. Overflow 0 0 Tx FILO Errors Traffic Backoffs 0 **Network Rejects** 84154 Address Rejects 25 Protocol Rejects 10492 **ARP Rejects** 19361 SMTP Server IP 0.0.0.0 Send Queue Length 0 Send Queue Max 1 Send Queue Min 0 Recv Queue Length 0 7 Recv Queue Max Recv Queue Min 0 Big Queue Length 28 Big Queue Max 30

26

28

30

The Network Statistics page monitors the health of the Ethernet network. These numbers will help identify settings for the EM Gateway as well as when there are issues with wiring, incorrect addresses or noise on communication wires on the Ethernet side of the Gateway.

Chapter Five

Controller Parameters and Registers

The EM Gateway supports the following parameters for each type of controller when using an HTTP browser:

Series 96 - non-ramping

Operation Mode - register 200 with choice of Auto or Manual as read only

Input Error – register 101 with choice of Sensor Error or Ok as read only

Process Value Input 1 – register 100 as read only

Process Value Input 2 - register 105 as read only

Auto Set Point 1 – register 300 as read/write

Alarm Status Output 2 – register 106 with choice of Ok, Alarm High, Alarm Low, Alarm High Latched, Alarm Low Latched, Alarm High Silenced, Alarm Low Silenced, Alarm High Latched Silenced, Alarm Low Latched Silenced, Waiting for in Range Alarm, Alarm Disabled, or Alarm Error as read only

Alarm Status Output 3 – register 106 with choice of Ok, Alarm High, Alarm Low, Alarm High Latched, Alarm Low Latched, Alarm High Silenced, Alarm Low Silenced, Alarm High Latched Silenced, Alarm Low Latched Silenced, Waiting for in Range Alarm, Alarm Disabled, or Alarm Error as read only Alarm Acknowledge – register 331 with choice to clear alarm as write only

Note: Selecting Manual control using the Operation Mode, an input error or inputting a Set Point value less than –30000 will disable the Auto Set Point. Alarms not configured are not displayed. Alarms can not be acknowledged while the alarm condition exists.

Series 97

Process Value Input 1 – register 100 as read only

Limit Status – register 319 with choice of Ok, High Limit, Low Limit, or Limit Error as read only Alarm Status Output 2 – register 106 with choice of Ok, Alarm High, Alarm Low or Alarm Error as read only

Alarm Status Output 3 – register 110 with choice of Ok, Alarm High, Alarm Low, or Alarm Error as read only

Alarm Acknowledge – register 331 with choice to clear alarm as write only

Note: Alarms configured are displayed. Alarms can not be acknowledged while the alarm condition exists.

Series 981 / 982

Operation Mode – register 200 with choice of Hold, Run, or Pre-run as read only

Input Error – register 209 with choice of Sensor Error or Ok as read only

Process Value Input 1 – register 100 as read only

Auto Set Point - register 300 as read/write

Alarm Status Output 2 – register 106 with choice of Ok, Alarm High, Alarm Low or Alarm Error as read only

Alarm Status Output 3 – register 110 with choice of Ok, Alarm High, Alarm Low, or Alarm Error as read only

Alarm Acknowledge – register 106 with choice to clear alarm as write only

Note: An input error or inputting Set Point values less than –30000 will disable the Auto Set Point. Alarms not configured are not displayed. Alarms can not be acknowledged while the alarm condition exists.

Series 988 / 989

Operation Mode – register 10 with choice of Auto or Manual as read only

Input Error – register 4 with choice of Sensor Error or Ok as read only

Process Value Input 1 – register 1 as read only

Process Value Input 2 - register 2 as read only

Auto Set Point – register 7 as read/write

Alarm Status Output 2/3 – register 3 with choice of Ok, Alarm High, Alarm Low or Alarm Error as read only

Alarm Acknowledge – register 3 with choice to clear alarm as write only

Note: Selecting Manual control using the Operation Mode, an input error or inputting Set Point values less than –30000 will disable the Auto Set Point. Alarms not configured are not displayed. Alarms can not be acknowledged while the alarm condition exists.

Series 998 / 999

Operation Mode – register 301 with choice of Auto or Manual as read only

Input Error – register 209 with choice of Sensor Error or Ok as read only

Process Value Input 1 – register 100 as read only

Process Value Input 2 – register 104 as read only

Auto Set Point 1 - register 300 as read/write

Auto Set Point 2 - register 319 as read/write

Alarm Status Output 3 – register 110 with choice of Ok, Alarm High, Alarm Low, or Alarm Error as read only

Alarm Acknowledge – register 110 with choice to clear alarm as write only

Note: Selecting Manual control using the Operation Mode, an input error or inputting Set Point values less than –30000 will disable Auto Set Points 1 or 2. Alarms not configured are not displayed. Alarms can not be acknowledged while the alarm condition exists.

Series F4S / F4D

Operation Mode – register 200 with choice of Auto or Manual as read only

Input 1 Error – register 101 with choice of Sensor Error or Ok as read only

Input 2 Error – register 105 with choice of Sensor Error or Ok as read only

Input 3 Error – register 109 with choice of Sensor Error or Ok as read only

Process Value Input 1 – register 100 as read only

Process Value Input 2 – register 104 as read only

Process Value Input 3 – register 108 as read only

Auto Set Point 1 – register 300 as read/write

Auto Set Point 2 - register 319 as read/write

Alarm Status Output 2 – register 102 with choice of Ok, Alarm High, Alarm Low, Alarm High Latched, Alarm Low Latched, Alarm High Silenced, Alarm Low Silenced, Alarm High Latched Silenced, Alarm Low Latched Silenced, Waiting for in Range Alarm, Alarm Disabled, or Alarm Error as read only

Alarm Status Output 3 – register 106 with choice of Ok, Alarm High, Alarm Low, Alarm High Latched, Alarm Low Latched, Alarm High Silenced, Alarm Low Silenced, Alarm High Latched Silenced, Alarm Low Latched Silenced, Waiting for in Range Alarm, Alarm Disabled, or Alarm Error as read only

Alarm 1 Acknowledge – register 312 with choice to clear alarm as write only

Alarm 2 Acknowledge – register 331 with choice to clear alarm as write only

Note: Alarms configured are displayed. Alarms can not be acknowledged when the alarm condition still exists.

Series F4P

Operation Mode - register 200 with choice of Auto or Manual as read only

Input 1 Error – register 101 with choice of Sensor Error or Ok as read only

Input 2 Error – register 105 with choice of Sensor Error or Ok as read only

Input 3 Error – register 109 with choice of Sensor Error or Ok as read only

Process Value Input 1 – register 100 as read only

Process Value Input 2 - register 104 as read only

Process Value Input 3 – register 108 as read only

Auto Set Point - register 300 as read/write

Alarm Status Output 2 – register 102 with choice of Ok, Alarm High, Alarm Low, Alarm High Latched, Alarm Low Latched, Alarm High Silenced, Alarm Low Silenced, Alarm High Latched Silenced, Alarm Low Latched Silenced, Waiting for in Range Alarm, Alarm Disabled, or Alarm Error as read only

Alarm Status Output 3 – register 106 with choice of Ok, Alarm High, Alarm Low, Alarm High Latched, Alarm Low Latched, Alarm High Silenced, Alarm Low Silenced, Alarm High Latched Silenced, Alarm Low Latched Silenced, Waiting for in Range Alarm, Alarm Disabled, or Alarm Error as read only

Alarm 1 Acknowledge - register 312 with choice to clear alarm as write only

Alarm 2 Acknowledge – register 331 with choice to clear alarm as write only

Note: Alarms configured are displayed. Alarms can not be acknowledged when the alarm condition still exists.

MicroDIN

Operation Mode – register 200 with choice of Auto or Manual as read only

Input Error – register 101 with choice of Sensor Error or Ok as read only

Process Value Input 1 – register 100 as read only

Auto Set Point - register 300 as read/write

Alarm Status Output 2 – register 106 with choice of Ok, Alarm High, Alarm Low, Alarm High Latched, Alarm Low Latched, Alarm High Silenced, Alarm Low Silenced, Alarm High Latched Silenced, Alarm Low Latched Silenced, Waiting for in Range Alarm, Alarm Disabled, or Alarm Error as read only Alarm Acknowledge – register 331 with choice to clear alarm as write only

Note: Alarms configured are displayed. Alarms can not be acknowledged when the alarm condition still exists.

Power Series

Heat Sink Temperature in Degrees C - register 1590 as read only

Load Current in Amps RMS on Line 1 - register 154 as read only (Based on configuration)

Load Current in Amps RMS on Line 2 - register 164 as read only (Based on configuration)

Load Current in Amps RMS on Line 3 - register 174 as read only (Based on configuration)

Note: Display of current on lines 1, 2, and 3 depends on the number of zones, the installed options and the load type.

CLS200 Series (Loop 1 to 16 if available)

Operation Mode – register 264 to 279 with choice of Auto or Manual as read only

Input Error – registers 660 to 675 with choice of Ok, TC Reversed, TC Short, TC Open, RTD Open, or RTD Short as read only

Process Value - registers 363 to 378 as read only

Auto Set Point – registers 330 to 345 as read/write

Alarm Status – registers 660 to 675 with choice of Ok, Low Deviation, High Deviation, Low Process, or High Process as read only

Alarm Acknowledge - registers 8311 to 8326 with choice to clear alarm as write only

Note: Alarms configured are displayed. Alarms can not be acknowledged when the alarm condition still exists.

Note: The Communication Specifications manual list absolute registers, which are the relative register with 40001 added to them. As an example, relative register 264 is absolute register 40265.

Series SD – non-ramping

Operation Mode – register 25 with choice of Auto or Manual as read only

Input Error – registers 24 with choice of Ok or Error as read only

Process Value – registers 20, 21 as read only

Auto Set Point – registers 27, 28 as read/write

Alarm 1 Status – registers 29 and 30 of Alarm 1 Ok, Alarm 1 Low Alarm, or Alarm 1 High Alarm as read only

Alarm 2 Status – always OK as this is the same output as communications.

Alarm 3 Status – registers 33 and 34 of Alarm 3 Ok, Alarm 3 Low Alarm, or Alarm 3 High Alarm as read only

Note: Alarms configured are displayed. Alarms can not be acknowledged when the alarm condition still exists.

In addition, the Series SD has many other parameters to read or change by clicking on the link SeriesSD. Be sure to submit any changes made on these screens using the Submit button at the bottom of the screen.

The following are screen captures from the Series SD:

 WATLOW					EM Ga	teway			
ateway Setup								Software Rev	ision: 2.00 04
is page was load Device	ded Tue Feb 24 i Modbus Address	0:29:36 20 A/M Mode	04 Imput No.	Imput Error	Process Value	Auto Setpoint	Alarm Status	Alarm Ack	Email Ack
Series SD	1	Auto	1)	Ok	0	0	Alarm 1 Ok Alarm 2 Ok Alarm 3 Ok		

WATLOW

SERIES SD

Configuration Inputs

Analog Input 1

Control Loops

Control Loop 1

Ramping

Ramp to Set Point

Outputs

Output 1

Output 2

Output 3

Alarms

Alarm 1

Alarm 2

Alarm 3

Monitor

Monitor Series SD

This page was loaded Tue Feb 24 09:30:53 2004

Configure things using the panel to the left to do whatever you want to the control.

WATLOW

SERIES SD

Configuration Inputs Analog Input 1	Analog Input 1 Configuration This page was loaded Tue Feb 24 09:34:30 2004				
Control Loops Control Loop 1	Analog Input Sensor Type:	Thermocouple 🔻			
Ramping Ramp to Set Point	Thermocouple Parameters Thermocouple Type:	J			
Outputs Output 1 Output 2 Output 3	RTD Parameters RTD Curve:	DIN 0.385 ▼			
Alarms Alarm 1 Alarm 2 Alarm 3	Process Parameters High process scale: Low process scale:	9999.0 -1999 to 9999 Process Units -772.0 -1999 to 9999 Process Units			
Monitor Monitor	High voltage scale: Low voltage scale: High current scale: Low current scale:	5.0 0-10.0 Volts 0 0-10.0 Volts 20.0 0-20.0 mA 4.0 0-20.0 mA			
	Temperature Process Value Config Temperature Process Value Units:				
	Input Filtering Filter Value: Filter Effectivity:	0 Seconds Off ▼			
	InfoSense Data InfoSense Enabled:	No 🔻			
	InfoSense Point 1: InfoSense Point 2:	500.0 500.0			
	InfoSense Point 3: InfoSense Point 4:	500.0			
	Offsets Single offset value:	0 °F			
	Submit Reset				



SERIES SD

Configuration Control Loop 1 Configuration Inputs This page was loaded Tue Feb 24 09:44:08 2004 Analog Input 1 Control Loop Control Loops Control Loop 1 Heat (Indirect) Cool (Direct) Loop Algorithm: On/Off ▼ PID 🔻 Ramping Ramp to Set Point Input Failure Parameters Off 🔻 Failure Latching: Outputs Output transition from Auto Mode Output 1 Fixed Power -(closed loop) to: Output 2 Output 3 Failure Fixed Power: % Power Alarms Limits Limit Low Limit High Alarm 1 Alarm 2 Set Point (Thermocouple): 32.0 1500.0 ۰F <u> Alarm 3</u> 1472.0 Set Point (RTD): -328.0 ۰F Monitor Set Point (Process): -999.0 999.0 On/Off Parameters Heat (Indirect) Cool (Direct) Hysteresis (Temperature): 18.0 1.0 ۰F Hysteresis (Process): 1.0 1.0 PID Parameters Start Autotune Heat (Indirect) Cool (Direct) 25.0 25.0 Prop Band (Temperature): Prop Band (Process): 25.0 25.0 0 0 Integral: 0 0 Derivative: 0 Dead Band: Submit Reset

WATLOW

SERIES SD

Configuration Inputs

Analog Input 1

Control Loops

Control Loop 1

Ramping

Ramp to Set Point

Outputs

Output 1

Output 2 Output 3

Alarms

Alarm 1

Alarm 2 Alarm 3

Monitor

Alarm 1 Configuration

This page was loaded Tue Feb 24 10:26:12 2004

Process Alarm Parameters

Alarm Process Low: 32.0 °F

Alarm Process High: 1500.0 ° F

Deviation Alarm Parameters

Alarm Deviation Low: -999.0 °F

Alarm Deviation High: 999.0 °F

General Alarm Settings

Alarm Hysteresis: 1.0 °F

Latching: No Blocking: No

Message: Yes

Submit Reset

Chapter Six

Reference Documents

The MODBUS RTU specification is located at: http://www.modicon.com/techpubs/toc7.html or http://www.modbus.org

Serial Numbers

Gateways are labeled with a unique serial number in numeric and bar code formats. The serial number is embedded in the gateway firmware.

EM Gateway Features and Benefits

- Ethernet/Internet connectivity
 Operate & monitor your process remotely.
- Browser Graphical User Interface (GUI)
 Operate & monitor your process remotely with standard Web browsers.
- Dedicated Web page design
 Easy to understand and operate
- Email alarm notification
 Reduced process monitoring costs

Chapter Seven

Specifications

Power supply

- Voltage input 24 V (ac/dc) +10%, -15% 50/60 Hz +/- 5
- Connection through 2-position removable screw style terminal block
 - 22 to 12 AWG
- Power consumption 10 VA MAX
 - UL Approved, Class 2 power supply required
- Real-time Clock backed by 3v-lithium battery RAYOVAC BR1225

Environmental

Operating temperature range: 0 to 60°C
 Storage temperature range: -40 to 70°C

Operating and storage humidity: 0 to 90% non-condensing

Indication

- Green LED for Ethernet connection
- Green LED for Ethernet activity
- Green LED for EIA-485 or EIA-232 activity

Agency

CE Approved, see Declaration of Conformity 61326 Industrial Immunity, Class B Emissions

Communications

- MODBUS RTU communications
 - Both EIA-485 and EIA-232 supported at 9600 and 19200 baud
 - Connection through 5-position removable screw style terminal block
 - 22 to 12 AWG
- Ethernet communications
 - Ethernet RJ45 Connector
 - 10BaseT per IEEE 802.3 Ethernet Standard
 - HTTP v1.1
 - Modbus TCP
 - DHCP, Auto IP, Or Fixed IP Address
 - Email Alarm Notification
- Supports Windows browsers
 - Microsoft Internet Explorer 4.0 or newer
 - Netscape 4.0 or newer

Control Output Signals

Activity L.E.D. for Ethernet communications per IEEE 802.3 Activity L.E.D. for Serial communications.

Enclosure Size

Dimensional Size - L: 3.75 in X W: 1 in X H: 2.5 in, with cutouts for L.E.D.s, RJ45 port and power jack.

User Interface

3 L.E.D.s to indicate operation status; Ethernet link, Ethernet traffic and Modbus traffic.

Ordering Information

Order part number EM00-GATE-0000

Declaration of Conformity

Gateway Products



Watlow Winona, Inc. 1241 Bundy Blvd. Winona, MN 55987 USA

Declares that the following product:

Model Numbers: EM00-GATE-0000, NGW0-0000-2400 and NGW0-0000-0000* Classification: Communications interface card, Installation Category I, Pollution

degree II

Rated Voltage: 24V (ac or dc) or 5V (dc)

Rated Frequency: 50/60 Hz or dc Rated Power: 10VA maximum

*NGW0-0000-0000 Requires use of a Ferrico NF130 Clamp on ferrite on all lines to pass Class B emissions. Depending on end use setup, this bead may or may not be necessary.

Meets the essential requirements of the following European Union Directives by using the relevant standards show below to indicate compliance.

89/336/EEC Electromagnetic Compatibility Directive

EN 61326:1997 With A1:1998 – Electrical equipment for measurement, control and laboratory use – EMC requirements (Industrial Immunity, Class B Emissions).

EN 61000-4-2:1996 With A1, 1998 - Electrostatic Discharge Immunity

EN 61000-4-3:1997 - Radiated Field Immunity

EN 61000-4-4:1995 - Electrical Fast-Transient / Burst Immunity

EN 61000-4-5:1995 With A1, 1996 - Surge Immunity

EN 61000-4-6:1996 - Conducted Immunity

EN 61000-4-11:1994 Voltage Dips, Short Interruptions and Voltage Variations Immunity

EN 61000-3-2:1995 With A1-3:1999 – Harmonic Current Emissions

EN 61000-3-3:1995 With A1:1998 - Voltage Fluctuations and Flicker

Use of an appropriately approved class 2 power source is required for compliance.

Jim Boigenzahn

Winona, Minnesota, USA

Name of Authorized Representative Place of Issue

General Manager

Title of Authorized Representative

February 28, 2002 Date of Issue

Signature of Authorized Representative

How to Reach Us

Technical Assistance

If you encounter a problem with your EM Gateway, review all of your wiring and configuration information to verify that your selections are consistent with your application. If the problem persists after checking the above, you can get technical assistance from your local Watlow representative, or by dialing (507) 454-5300. An applications engineer will discuss your application with you.

Warranty

This product is warranted free from defects in material and workmanship for 36 months after delivery to the first purchaser for use, providing that the units have not been misapplied. Since Watlow has no control over their use, and sometimes misuse, we cannot guarantee against failure. Watlow's obligations hereunder, at Watlow's option, are limited to replacement, repair or refund of purchase price, and parts that upon examination prove to be defective within the warranty period specified. This warranty does not apply to damage resulting from transportation, alteration, misuse or abuse.

Returns

- Call or fax Customer Service for a Return Material Authorization (RMA) number before returning any product.
- Put the RMA number on the shipping label, and provide a written description of the problem.
- A restocking charge of 20% of the net price is charged for all standard units returned to stock.

Your Feedback

Your comments or suggestions on this manual are welcome, please send them to: Technical Writer, Watlow Winona, 1241 Bundy Blvd., P.O. Box 5580, Winona, MN 55987-5580, Phone: (507) 454-5300, Fax: (507) 452-4507. Watlow Winona, Inc., ©, copyrights the EM User's Manual February 2002, with all rights reserved. (2206)