



User's Manual

PR5000LCDRTXL5U/ PR6000LCDRTXL5U

IMPORTANT SAFETY INSTRUCTIONS

This manual contains important instructions. Please read and follow all instructions carefully during installation and operation of the unit. Read this manual thoroughly before attempting to unpack, install, or operate the UPS.

CAUTION! The UPS must be connected to a grounded AC power outlet with fuse or circuit breaker protection. DO NOT plug the UPS into an outlet that is not grounded. If you need to power-drain this equipment, turn off and unplug the unit.

CAUTION! The battery can power hazardous components inside the unit, even when the AC input power is disconnected.

CAUTION! The UPS should be near the connected equipment and easily accessible.

CAUTION! To prevent the risk of fire or electric shock, install in a temperature and humidity controlled indoor area, free of conductive contaminants. (Please see specifications for acceptable temperature and humidity range).

CAUTION! To avoid electrical shock, turn off the unit and unplug it from the AC power source before servicing the battery or installing a computer component.

CAUTION! Never install a UPS, or associated wiring or equipment, during a lightning storm.

CAUTION! When installing the equipment, ensure that the sum of the leakage current of the UPS and the connected equipment does not

exceed 3.5mA.

CAUTION! Do not unplug the unit from AC Power during operation, as this will invalidate the protective ground insulation.

CAUTION! DO NOT USE FOR MEDICAL OR LIFE SUPPORT EQUIPMENT! Under no circumstances this unit should be used for medical applications involving life support equipment and/or patient care.


CAUTION! DO NOT USE WITH OR NEAR AQUARIUMS! To reduce the risk of fire, do not use with or near aquariums. Condensation from the aquarium can come in contact with metal electrical contacts and cause the machine to short out.

DO NOT INSTALL THE UPS WHERE IT WOULD BE EXPOSED TO DIRECT SUNLIGHT OR NEAR A STRONG HEAT SOURCE!


DO NOT BLOCK VENTILATION OPENINGS AROUND THE HOUSING!

DO NOT CONNECT DOMESTIC APPLIANCES SUCH AS HAIR HAIR DRYERS, SPACE HEATERS, VACUUM CLEANER ETC TO THE TO UPS OUTPUT SOCKETS.


UNPACKING



UPS unit




Front panel




Rack mount ears (Stands) (2)




User's manual



Rack mount rails (1 set – left and right sides)



Rack mount ear & rails screws (34)



Screw hole dust covers (8)





Warranty registration card

AUTOMATIC VOLTAGE REGULATOR(AVR)

The PR5000LCDRTXL5U/ PR6000LCDRTXL5U stabilizes damaging inconsistent utility power. The Automatic Voltage Regulator automatically regulates low or high voltages to keep equipment working at safe AC power levels (208/240V) without switching to battery. Your equipment operates normally when power problems, such as, short brownouts and blackouts. The unit's powerful sealed lead-acid batteries will provide power during the incoming voltage drops below 131V or increases above 268V.

SYSTEM BLOCK DIAGRAM



HARDWARE INSTALLATION GUIDE

1. Battery charge loss may occur during shipping and storage. Before using the UPS, it's strongly recommended to charge batteries for four hours typically to ensure that the batteries' maximum charge capacity is met. To recharge the batteries, simply plug the UPS into an AC outlet.

2. When using the included software, connect either the serial or the USB cable between the computer and the corresponding port on the UPS. Note: If the USB port is used, the serial port will be disabled. They cannot be used simultaneously. The computer with the PowerPanel® Business Edition Agent software connects to the USB port or the Serial port on the UPS. It can control the operating schedule, battery test, outlet, etc. and obtain information on the UPS status. However, other computers with PowerPanel® Business Edition Client software can only obtain UPS status information via a LAN connection.

3. With the UPS off and unplugged, connect your computer, monitor, and any externally powered data storage device (Hard drive, Tape drive, etc.) into the outlets. DO NOT plug a laser printer, copier, space heater, vacuum, paper shredder or other large electrical device into the UPS. The power demands of these devices will overload and possibly damage the unit.

4. To protect a fax, telephone, modem line or network cable, connect the telephone or network cable from the wall jack outlet to the jack marked "IN" of the UPS. Then, connect a telephone cable or network cable from the jack marked "OUT" on the UPS to the modem, computer, telephone, fax machine, or network device.

5. Press the power switch to turn the UPS on. The Power-On indicator light will illuminate. If an overload is detected, an audible alarm will sound and the UPS will emit one long beep. In order to reset it, turn the unit off and unplug some equipment from outlets. Make sure your equipment carry a load current within the unit's safe range, (refer to the technical specifications), and then turn the unit on.

6. Your UPS is equipped with an auto-charge feature. When the UPS is plugged into an AC outlet, the battery will automatically charge, even when the unit is switched off.

7. To maintain an optimal battery charge, leave the UPS plugged into an AC outlet at all times.

8. Before storing the UPS for an extended period of time, turn the unit OFF. Then cover it and store it with the batteries fully charged. Recharge the batteries every three months to ensure good battery capacity and long battery life. Maintaining a good battery charge will help prevent possible damage to the unit from battery leakage.

9. The unit has one Primary Serial Port (I), one Secondary Serial Port (II), and one USB port, (paired with the Primary Serial Port), to allow connection and communication between the unit and any attached computers. The Primary Serial Port (I) as well as its paired USB port allow for bi-directional communication among the UPS and the primary connected computer running the PowerPanel® Business Edition Agent software. The UPS can control the computer's shutdown in case of an emergency, and at the same time, the computer can monitor the UPS and alter its various programmable parameters. On the other hand, secondary Serial Port II, only allows the UPS to initiate the connected computer's graceful shutdown in case of an emergency.

10. EPO (Emergency Power Off) Port: Use the provided gray cable to connect to a special EPO contact switch. Follow the appropriate circuit diagram below to wire the cable to your EPO configuration. The EPO remote switch is a switch installed in an outside area, connected to the unit via an ordinary RJ-11 phone line. In case of an emergency, it can be used to immediately cut off power from the UPS unit.

11. To avoid electrical shock, before hardwiring the UPS (in/out power cord), turn the unit OFF and disconnect the unit from utility power. The in/out power cord MUST be grounded.

BASIC OPERATION

FRONT/REAR PANEL DESCRIPTION

1. Power Switch

Master On/Off switch for the UPS.

2. Power on Indicator

Indicates the UPS is on and supplying power free of surges and spikes.

3. LCD Readout Toggle Button

Use to rotate through multiple screens of UPS status information.

4. Multifunction LCD Readout

An illuminated digital screen that displays the UPS power status information.

5. Battery Backup & Surge Protected Outlets

This unit provides a total of five outlets with battery backup and surge protection. They ensure that connected equipment will provide power to equipment over a period of time, during a power failure.

Critical /Non-Critical

It is possible to program the unit so that the outlet block marked as "Non-Critical", (3 ports), will stop the supplying to connected equipment after a certain period of time. This allows for additional runtime for the equipment connected on the outlets marked as "Critical", (2 port). This allows the creation of load priorities ensuring the critical equipment is given priority under specific circumstances.

6. Output Circuit Breaker

The circuit breaker serves to provide output overload and fault protection.

7. Input Circuit Breaker

The circuit breaker serves to provide input overload and fault protection.

8. Input Power Cord

Heavy-duty, extra long power cord.

9. SNMP/HTTP Network slot



Slot to install the optional SNMP card for remote network control and monitoring.

10. Serial Port I (Primary)

Serial port I provides bi-directional communication between the UPS and the computer. The UPS can control the computer's shutdown in case of an emergency, and at the same time, the computer can monitor the UPS and alter its various programmable parameters.

11. Serial Port II (Secondary)

Serial Port II allows the UPS to initiate a connected computer's graceful auto-shutdown in case of an emergency.



12. USB port to PC

This is a connectivity port allowing communication and control between the UPS and the connected computer. You should install the PowerPanel® Business Edition Agent software on the PC/Server connected with the USB cord.

13. EPO (Emergency Power Off) Port:

Allows for an emergency UPS Power-Off from a remote location.

14. Surge Protected Communication Ports - RJ11/RJ45

These ports are used to protect standard RJ-45/RJ-11 based, (ADSL, LAN, Phone/Modem-Lines), and cabling systems from surges.

15. Extended Runtime (XL) Battery Pack Connector

Provides a connection for additional CyberPower XL Battery Packs

16. Ground Stud

Use the Ground Stud to ground the UPS.

HARDWARE INSTALLATION

HARDWARE INSTALLATION

These versatile UPS systems can be mounted in a rack mount or vertical /tower orientation. This versatility is especially important to growing organizations with changing needs that value having the option to position a UPS on a floor, or in a rack mount system. Please follow the instructions below for the respective mounting method.


SAFETY PRECAUTIONS

CAUTION! To prevent the risk of fire or electric shock, use only the supplied hardware to attach the mounting brackets.

RACKMOUNT INSTALLATION

Step 1: Rack mount ears installation

Attach the two rack mount ears to the UPS using the provided screws.




Step 2: Rack mount rail Installation

Ensure rack stability prior to installing devices in the rack.


The first step should have a directions and a picture of assembling the rails.

The second step should be the rack mount installation directions and pictures.




Attach the rack mount rails to your rack using fasteners that are designed for your rack system.

Step 3: Adjust rack mount rails to fit your rack



Take the rack mount rail inscribed with an "L" (Left) and attach it to the rear bracket of the Rack-mount Rail using three (3) of the six (6) Rack-mount Rail Screws. Do not fully tighten the rack mount rail screws, as the rack mount rails will need to be adjusted to fit your rack. Once complete, perform the same steps for assembling the Rack-mount Rail inscribed with an "R" (Right).

Step 4: Carefully align the front panel connector and latches with the PR5000LCDRTL5U/ PR6000LCDRTL5U




CAUTION! The UPS must be installed at the bottom of the rack system.

CAUTION! Do not lift the front panel when removing the UPS unit.


HARDWARE INSTALLATION

VERTICAL/TOWER INSTALLATION




Step 1: Attach the base stands
Simply slide the base stands onto the bottom of the UPS, roughly 8-10" apart.



Step 2: Attach dust covers
Insert dust covers into the rack mount ear screw holes that are not being used.



Step 3: Rotate the Multifunction LCD Readout
Separate the front panel and the UPS. Gently lift the LCD out. Rotate it to the preferred orientation. Reinstall the display for a tower configuration.



ELECTRICAL INSTALLATION

After completing the hardware installation of the UPS, you are now ready to plug in the UPS and attach your equipment.

SAFETY PRECAUTIONS

- **CAUTION!** - Installation environment should be in a temperature and humidity controlled indoor area free of conductive contaminants. Do not install this UPS where excessive moisture or heat is present (Please see specifications for acceptable temperature and humidity range)
- **CAUTION!** - Never install a UPS, or associated wiring or equipment, during a lightning storm.
- **CAUTION!** - Do not work alone under hazardous conditions.
- **CAUTION!** - To reduce the risk of electric shock, do not remove the top cover.
- **CAUTION!** - The battery can energize hazardous live parts inside even when the AC input power is disconnected.

DEFINITION FRO ILLUMINATED LCD INDICATORS


MULTIFUNCTION LCD READOUT



The multifunction LCD readout provides ready access to power/battery condition vitals, such as: Runtime, Load, Temperature, and much more.

The screen is also rotatable so the UPS can be used in either rack mount or vertical/tower orientation.

BASIC OPERATION



Select Button

Screen toggle – To toggle through the status screens press the Select button which is located directly next to the LCD.

Screen illumination– After 30 seconds of inactivity, the LCD backlight will automatically turn off to conserve energy. Keeping the LCD screen lit at all times is not an option on this UPS.

Select Button

- If the LCD screen is not lit pressing the Select button once will turn the LCD on. If the LCD screen is lit, then pressing the Select button once will toggle through the status screens.
- Pressing and holding the Select button for four (4) seconds while UPS is in Normal operation will initiate the Self Test.
- Pressing and holding the Select button for four (4) seconds while UPS is in Battery/Offline mode will activate Silent Mode on the UPS.

MAIN FEATURES


Load Level: The total load of the connected equipment shown in 20% increments.

Battery Capacity: The battery's current charge level shown in 20% increments.

Normal Icon: This icon appears when the UPS is working under normal conditions.

Battery Icon: This icon appears when the UPS is operating using battery power. The UPS will also sound alarms (two short beeps followed by a pause) when this icon is lit. When the Battery Icon is lit and the Battery Capacity falls to 20% the frequency of the alarms will increase indicating that the UPS batteries are nearly out of power. If this occurs, it is recommended that you either restore AC power, or manually power down your equipment that may be negatively affected by sudden power loss.

Silent icon: This icon appears when the UPS is in silent mode. During Silent mode, the unit's alarm does not sound until the Battery Capacity falls to < 20%.




Overload icon: This icon appears when the Battery/Surge outlets on the UPS are overloaded. The UPS will also sound an alarm at this point. To clear the overload, the total load of the connected equipment must be less than the unit's maximum capability. The easiest way to correct this problem is to remove noncritical equipment from the Battery/Surge outlets.

Fault icon: This icon appears if there is an internal problem with the UPS. Please contact Technical Support if this icon is lit.

Automatic Voltage Regulation (AVR) icon: This icon appears when the UPS is automatically correcting AC input line voltage without using battery power. This is a normal, automatic operation of your UPS, and no action is required. The AVR in this UPS continuously conditions the power to a nominal 208V output to connected equipment. In the event of a complete power loss, severe brownout, or over voltage, the UPS relies on its internal battery back up to supply a consistent 208V output.

DEFINITION FRO ILLUMINATED LCD INDICATORS


TOGGLE SCREENS



Input Voltage
 The Input Voltage screen displays the AC voltage that the UPS system is receiving from the utility wall receptacle. This can be used as a diagnostic tool to identify poor quality input power. Units are listed in V (Volts).




Output Voltage
 The Output Voltage screen measures, the AC voltage that the UPS is providing to your connected equipment via the UPS outlets. Units are listed in V (Volts).



Output Frequency
 The Output Frequency screen displays the current frequency at which the UPS is operating. Units are listed in Hz (Hertz).



Estimated Runtime
 The Estimated Runtime Screen displays how many minutes of runtime can be expected of the UPS if it were to experience a power outage. Note: The number displayed may be less than actual runtimes for low loads.



Load Capacity
 Similar to the Load/Current Level screen, this displays the total load/current of the connected equipment expressed as a percentage (%).



Battery Capacity
 The Battery Capacity screen displays the battery's current charge level and is expressed as a percentage (%) of the battery's total capacity of 100%.



Temperature
 The Temperature screen displays the internal temperature of the UPS in degrees Centigrade. Normal ranges are 0°C-40°C. If the temperature exceeds 40°C, additional methods should be implemented to cool the UPS (i.e. air conditioning, additional ventilation, isolation from other heat producing equipment, etc.).



Temperature
 The Temperature screen displays the internal temperature of the UPS in degrees Fahrenheit. Normal ranges are 32°F-104°F. If the temperature exceeds 104°F, additional methods should be implemented to cool the UPS (i.e. air conditioning, additional ventilation, isolation from other heat producing equipment, etc.).

MAINTENANCE

Storage

To store your UPS for an extended period, cover it and store with the battery fully charged. Recharge the battery every three months to ensure battery life.

Battery Replacement

Please read and follow the Safety Instructions before servicing the battery. Battery replacement should be performed by trained personnel who are familiar with the procedures and safety precautions.

Safety Precautions

- **CAUTION!** – Only use replacement batteries which are certified by CyberPower Systems. Use of incorrect battery type is an electrical hazard that could lead to explosion, fire, electrical shock, or short circuit.
- **CAUTION!** – Batteries contain an electrical charge that could cause severe burns. Before servicing batteries, please remove any conductive materials such as jewelry, chains, wrist watches, and rings.

- **CAUTION!** - Do not open or mutilate the batteries. Electrolyte fluid is harmful to the skin/eyes and may be toxic.
- **CAUTION!** - To avoid electrical shock, turn off and unplug the UPS from the wall receptacle before servicing the battery.
- **CAUTION!** – Only use tools with insulated handles. Do not lay tools or metal parts on top of UPS or battery terminals.


Replacement Batteries

Please refer to the Technical Specifications of the user manual for the model number of the correct replacement batteries. To purchase these batteries, log onto www.CPSww.com, or contact your local dealer.


Battery Disposal

Batteries are considered hazardous waste and must be disposed of properly. Contact your local government for more information about proper disposal and recycling of batteries. Do not dispose of batteries in a fire.


Battery Installation




① Remove the front panel.




② Remove the retaining screws of the cable protection cover, and then remove the cover itself.



③ Pull the plastic sticker out slowly to remove the battery module.



④ Put the new battery modules back into the compartment.



⑤ Tighten the screws and replace the cable protection cover and the front panel.

TECHNICAL SPECIFICATIONS

Model	PR5000LCDRTL5U	PR6000LCDRTL5U
Configuration		
Capacity (VA)	5000VA	6000VA
Capacity (Watts)	4000W	4500W
Energy-saving Technology	GreenPower UPS™ Bypass	
Input		
Nominal Input Voltage	208V	
Input Voltage Range	148-254V	
Input Adjustable Voltage Range	131-268V	
Frequency Range	50/60Hz +/- 3Hz	
Input Plug Type	NEMA L6-30P	
Cold Start	Yes	
Output		
UPS Outlets	(3) NEMA L6-30R, (2) NEMA L6-20R	
On Battery Output Voltage	Pure Sinewave, 208V +/- 5%	
On Battery Output Frequency	50/60Hz +/- 1%	
Transfer Time (Typically)	4ms	
Overload Protection	On Utility: Circuit Breaker; On Battery: Internal Current Limiting	
Data line Protection		
Surge Protection	2430J	2430J
Phone / Network Protection	RJ11/RJ45 (One In/One Out)	
Battery		
Specifications	(16) 12V/9.0AH	
Sealed, Maintenance Free	Yes	
User Replaceable	Yes	
Recharge Time (Typically)	4 hours	
Status Indicators		
Indicator LEDs	Power On, LCD Display (Using Battery, AVR, Load Level, Battery Level)	
Audible Alarms	On Battery, Low Battery, Overload	
Environment		
Operating Temperature	32°F to 104°F (0°C to 40°C)	
Operating Relative Humidity	0 to 95% Non-Condensing	
Management		
On-Device Features	Self Test, Auto-Charge, Auto-Restart	
Connectivity Ports	(1) USB, (2) Serial	
SNMP/HTTP Capable	Yes	
Software		
Power Management Software	PowerPanel® Business Edition	
Physical		
Dimensions (LxWxH) (in)	25.25" x 17" x 8.75"	
Weight (lbs)	222	226
Safety		
Conformance Approvals	FCC Class A certified, UL 1778, CSA C22.2 No. 107.3-05	
Warranty		
Product Warranty	3 years Limited	
Connected Equipment Guarantee	300,000	

PRODUCT REGISTRATION & WARRANTY

Product Registration

CyberPower requests that you complete and return the Warranty Registration Card enclosed with the Product or register the Product at its website (www.CPSwww.com) to establish that you are the Initial Customer of the Product, and therefore entitled coverage under the Limited Warranty and the Connected Equipment Guarantee. (Registration is not required for coverage, but note: if you do not register your purchase, you will be required to provide proof of purchase.)

Limited Warranty and Connected Equipment Guarantee

Read the following terms and conditions carefully before using the CyberPower UPS (the "Product"). By using the Product you consent to be bound by and become a party to the terms and conditions of this Limited Warranty and Connected Equipment Guarantee (together referred to as this "Warranty"). If you do not agree to the terms and conditions of this Warranty, you should return the Product for a full refund prior to using it.

Who Is Providing This Warranty?

CyberPower Systems (USA), Inc. ("CyberPower") provides this Limited Warranty.

What Does This Warranty Cover?

This warranty covers defects in materials and workmanship in the Product under normal use and conditions. It also covers equipment that was connected to the Product and damaged because of the failure of the Product.

What Is The Period of Coverage?

This warranty covers the Product for three years and connected equipment for as long as you own the Product.

Who Is Covered?

This warranty only covers the original purchaser. Coverage ends if you sell or otherwise transfer the Product.

How Do You Get Service?

1. Call us at (877) 297-6937 or write to us at Cyber Power Systems (USA), Inc., 4241 12th Ave. E., STE 400, Shakopee, MN 55379 or send us an e-mail message at claims@cpswww.com for instructions.
2. When you contact CyberPower, identify the Product, the Purchase Date, and the item(s) of Connected Equipment. Have information on all applicable insurance or other resources of recovery/payment that are available to the Initial Customer and Request a Claim Number.
3. You must provide a purchase receipt (or other proof of the original purchase) and provide a description of the defect.
4. Pack and ship the product to CyberPower and, if requested, the item(s) of Connected Equipment, a repair cost estimate for the damage to the Connected Equipment, and all claim forms that CyberPower provides to you. Show the Claim Number on the shipping label or include it with the product. **You must prepay all shipping costs, you are responsible for packaging and shipment, and you must pay the cost of the repair estimate.**

How Long Do I Have To Make A Claim?

All claims must be made within ten days of the occurrence.

What Will We Do To Correct Problems?

CyberPower will inspect and examine the Product.

If the Product is defective in material or workmanship, CyberPower will repair or replace it at CyberPower's expense, or, if CyberPower is unable to or decides not to repair or replace the Product (if defective) within a reasonable time, CyberPower will refund to you the full purchase price you paid for the Product (purchase receipt showing price paid is required).

If it appears that our Product failed to protect any equipment plugged into it, we will also send you forms for making your claim for the connected equipment. We will repair or replace the equipment that was damaged because of the failure of our Product or pay you the fair market value (NOT REPLACEMENT COST) of the equipment at of the time of the damage. We will use Orion Blue Book, or another a third-party valuation guide, or eBay, craigslist, or other source to establish that amount. Our liability is limited to the Connected Equipment Guarantee amount as stated in the Technical Specifications section.

Who Pays For Shipping?

We pay when we send items to you; you pay when you send items to us.

What Are Some Things This Warranty Does Not Cover?

1. This Warranty does not cover any software that was damaged or needs to be replaced due to the failure of the Product or any data that is lost as a result of the failure or the restoration of data or records, or the reinstallation of software.
2. This Warranty does not cover or apply to: misuse, modification, operation or storage outside environmental limits of the Product or the equipment connected to it, nor for damage while in transit or in storage, nor if there has been improper operation or maintenance, or use with items not designed or intended for use with the Product, such as laser printers, appliances, aquariums, medical or life support devices, etc.

What Are The Limitations?

1. This Warranty does not apply unless the Product and the equipment that was connected to it were connected to properly wired and grounded outlets (including compliance with electrical and safety codes of the most current electrical code), without the use of any adapters or other connectors.
2. The Product must have been plugged directly into the power source and the equipment connected to the Product must be directly connected to the Product and not "daisy-chained" together in serial fashion with any extension cords, another Product or device similar to the Product, surge suppressor, or power tap. Any such installation voids the Limited Warranty.
3. The Product and equipment connected to it must have been used properly in a suitable and proper environment and in conformance with any license, instruction manual, or warnings provided with the Product and the equipment connected to it.
4. The Product must have been used at all times within the limitations on the Product's VA capacity.

Where Can I Get More Information?

For further information please feel free to contact CyberPower at Cyber Power Systems (USA), Inc. 4241 12th Ave E., STE 400, Shakopee, MN 55379; call us at (877) 297-6937; or send us an e-mail message at claims@cpswww.com.

SERVICE INFORMATION

FREQUENTLY ASKED QUESTIONS (FAQs)

What types of equipment are NOT allowed to be plugged into the UPS?

Any device which exceeds the unit's VA/Watt rating should not be plugged into the UPS. High drain devices, medical equipment, and aquatic equipment also void the unit's warranty. Below is a list of other devices that also void the warranty.

- Laser printers
- Space heaters
- Copiers
- Paper shredders
- Vacuums
- Curling Irons

Can I increase the runtime by hooking up multiple UPS units in a row?

This configuration is called "daisy-chaining" and will void the UPS's warranty.

Can I hookup a surge strip to the UPS unit?

No. Surge strips cannot be installed before or after the UPS unit. Doing so will void the UPS's warranty. If you require additional outlets, upgrade your UPS to a model that has more outlets, or simply add an additional UPS to your existing configuration. If you need a longer input cord, you can purchase a UL certified extension cord that is rated for the respective current of the unit. This cord MUST be a single-outlet extension cord.

Should the cooling fan on my CyberPower UPS be running at all times?

No. The internal cooling fan will only run when it's required. CyberPower UPS systems utilize an internal thermal sensor which activates the fan when the temperature exceeds a certain threshold. When the UPS is running Online (off AC power), it is completely normal for the fan to not be running.

Do I have to have the UPS turned on in order for it to charge?

No. The UPS will charge the battery whether the unit is turned on or turned off.

My LCD screen shuts off after 15-30 seconds of inactivity. Is there a way to keep the LCD screen illuminated at all times?

No. The LCD display will only light up when the Select button is pressed. This extends the life of the LCD screen and is part of the energy saving design of our UPS systems.

NEED ADDITIONAL HELP?

Contact the Tech Support department with installation, troubleshooting, or general product questions.

CyberPower Technical Support

Phone: 1-877-297-6937

Email: tech@cpsww.com

Web: www.CPSww.com

Mail: 4241 12th Avenue E, Suite 400 Shakopee, MN 55379

Hours of Operation:

Monday – Friday, 8:00am – 5:00pm (CST)