

ioLogik R1200 Series Quick Installation Guide

Second Edition, April 2014

Overview

The ioLogik R1200 comes with 2 RS-485 serial ports, which can be used in one of two ways:

- 1. For backup or asset monitoring, or
- 2. As an RS-485 repeater.

The ioLogik R1200 has the industry's first all-in-one design and provides Automatic Field Configuration via USB. No technical background is needed, and maintenance is easy since users can upload a device's configuration settings and firmware via USB, without needing to take a PC to the field site.

Model Selection:

ioLogik	DI	DIO	Relay	ΑI	AO
R1210	16	ı	-	ı	ı
R1212	8	8	-	-	-
R1214	6	-	6	ı	-
R1240	_	_	_	8	_
R1241	_	_	_	_	4

Package Checklist

- 1 ioLogik R1200 series remote I/O product
- · Documentation and software CD
- Quick installation guide (printed)

Specifications

System	
Serial IO	2 x RS-485-2W: Data+, Data-, GND
	(5-contact terminal block)
Protection	8 KV ESD, 1 KV surge, 3 KV EFT
Protocols	Modbus/RTU
Power Input	24 VDC nominal, 12 to 48 VDC
Wiring	I/O cable max. 14 AWG
Dimensions	27.8 x 124 x 84 mm (1.09 x 4.88 x 3.31 in)
Weight	under 200 g
Operating Temperature	Standard Models: -10 to 75°C (14 to 167°F)
	Wide Temperature Models: -40 to 85°C (-40 to 185°F)
Storage Temperature	-40 to 85°C (-40 to 185°F)

A 1: 1 B 1 ::	In		
Ambient Relative	5 to 95% (non-condensing)		
Humidity			
Altitude	Up to 2000 m		
Note: Please contact Mo	oxa if you require products guaranteed to		
function properly at hig			
Standards and	UL 508, CE, FCC Class A		
Certifications	F (
Warranty Period	5 years (excluding ioLogik R1214*)		
etails See www.moxa.com/warranty			
	lifetime of power relay, products that us		
	ered by a 2-year warranty.		
	meters (Initial mode)		
Parity	None, Even, Odd (default = None)		
Data Bits	8		
Stop Bits	1, 2 (default = 1)		
Flow Control	None, XON/XOFF (default = None)		
Baudrate	1200 to 921.6 kbps (default = 9600)		
Digital Input			
Sensor Type	NPN, PNP, and Dry contact		
I/O Mode	DI or Event Counter		
Dry Contact	On: short to GND		
	Off: open		
Wet Contact	• On: 10 to 30 VDC		
(DI to COM)	• Off: 0 to 3 VDC		
Isolation	3K VDC or 2K Vrms		
Counter/Frequency	2.5 kHz, power off storage		
Digital Output			
I/O Mode	DO or Pulse Output		
Pulse Wave	0.1 ms / 5 kHz		
Width/Frequency			
Over-voltage	45 VDC		
Protection			
Over-current Protection	2.6 A (4 channels @650 mA)		
Over-temperature	175°C (typical), 150°C (min.)		
Shutdown			
Current Rating	200 mA per channel		
Isolation	3K VDC or 2K Vrms		
Relay Output			
Туре	Form A (N.O.) relay outputs, 5A		
Contact Rating	5 A @ 30 VDC, 5 A @ 250 VAC, 5 A @ 11 VAC		
Inductance Load	2 A		
Resistance Load			
Breakdown Voltage	500 VAC		
Relay On/Off Time	1500 ms (Max.)		
Initial Insulation	1G min. @ 500 VDC		
Resistance	15 mm. @ 500 VDC		


Expected Life	100,000 times (Typical)		
Initial Contact	30 milli-ohms (Max.)		
Resistance			
Pulse Output	0.3 Hz at rated load		
Analog Input			
Туре	Differential input		
Resolution	16 bits		
I/O Mode	Voltage / Current		
Input Range	0 to 10 VDC, 4 to 20 mA		
Accuracy	±0.1% FSR @ 25°C		
	±0.3% FSR @ -10 and 60°C		
	±0.5% FSR @ -40 and 75°C		
Sampling Rate (all	12 samples/sec		
channels)			
Input Impedance	10M ohms (minimum)		
Built-in Resistor for	120 ohms		
Current Input			
Analog Output			
Resolution	12 bits		
Output Range	0 to 10 VDC, 4 to 20 mA		
Voltage Output	10 mA (Max.)		
Accuracy	±0.1% FSR @ 25°C		
	±0.3% FSR @ -40 and 75°C		
Load Resistor	Internal power: 400 ohms		
	• External 24V power: 1000 ohms		

Installation

Power and Networking

Connect the +12 to +48 VDC power line to the ioLogik R1200's terminal block V+ terminal; connect the ground from the power

supply to the V- terminal. Connect the ground pin () if earth ground is available.




NOTE For safety reasons, the wires attached to the power should be at least 2 mm (12 gauge) in diameter.

P/N: 1802012002011

Switch Settings


The R1200 series provides Dual/Rep and Run/Initial switch settings to set up the communication mode.

Duel (Default)	Dual RS-485 mode
Rep	Repeater mode
Run	User define communication parameters
Initial (Default)	Initial RS-485 communication parameters



Jumper Settings

The models with DIO or AI channels require configuring the jumpers inside the enclosure. Remove the screw located on the back panel and open the cover to configure the jumpers.



DIO mode configuration is shown to the right (default: DO Mode).



Voltage Mode Current Mode

Analog mode configuration is shown to the right (default: Voltage Mode).

Mounting


The ioLogik R1200 is designed with a vertical form factor, and can be used with both DIN-Rail and wall mounting applications. When mounting on a rail, release the bottom mounting kit, install the ioLogik on the rail, and then restore the bottom mounting kit to fix the ioLogik to the rail. When using wall mounting, release both the upper and bottom DIN-Rail kits.

LED Indicators

Type	LED Color	LED Action		
PWR	Green	On:	Power On	
		Off:	Power Off	
RDY Green/		Green:	System Ready	
	Red	Green Blinking:	Located	
		Red:	System Boot-up Error	
		Red Blinking:	Firmware upgrade / USB upgrade	
		Green/Red Blinking:	Safe Mode	
		Off:	System NOT Ready	
P1	Green/	Green:	Tx	
	Amber	Amber:	Rx	
		Blinking:	Data Transmitting	
		Off:	Disconnected	
P2	Green/	Green:	Tx	
	Amber	Amber:	Rx	
		Blinking:	Data Transmitting	
		Off:	Disconnected	


I/O Wiring

Digital Input/Output (Sink Type)



Analog Input

Relay Output (Form A)



9 S Load **Power**

System Configuration

ioSearch Utility

ioSearch is a search utility that helps users locate an ioLogik R1200 on the local network. The utility can be found in the Document and Software CD → Software → ioSearch; the latest version can be downloaded from Moxa's website.

Load Factory Default Settings

There are three ways to restore the ioLogik R1200 to the factory default settings.

- 1. Hold the RESET button for 5 seconds.
- 2. Right click the specified ioLogik in the ioSearch utility and select "Reset to Default."
- 3. Select "Load Factory Default" from the web console.

Modbus Address Table

Please refer to the user's manual for details of the ioLogik's Modbus address.

MOX/

www.moxa.com/support

The Americas: +1-714-528-6777 (toll-free: 1-888-669-2872)

Europe: +49-89-3 70 03 99-0 Asia-Pacific: +886-2-8919-1230

China: +86-21-5258-9955 (toll-free: 800-820-5036)

© 2014 Moxa Inc., All Rights Reserved