

Testing of Conducted Energy Weapons

CPRC CEW Test 004

Reference

OPCC file 2587

Victoria Police Department, Victoria British Columbia Attention: Sergeant Kerry Panton

Performed April 18, 2008

Testing performed by: Sergeant Mark Barclay and Constable Michael Azar of the Ottawa Police Services

> Written by: Steve Palmer P. Eng , Executive Director, Canadian Police Research Centre

> > 22 July 2008

Submitted by

Stephen Palmer, P.Eng Executive Director Canadian Police Research Centre. Ottawa, Ontario Wednesday, July 23, 2008

Date

Taser X26 Electrical Performance Evaluation

Table of Contents

Testing Overv	iew	1
Discussion of	the results	2
Peak open	circuit arcing voltage	2
Voltage and	Current measured under Load	3
Peak Vol	age under Load	3
Peak Cur	rent under Load	4
Summary		4
Appendix A,	Test results, test setup	
Appendix B,	Taser X26 Performance Specifications	
Appendix C	Taser International Test Procedures	
Appendix D	Taser International Correspondence, Peak arcing voltage measurement	

Testing Overview

In 2005 the Canadian Police Research Centre (CPRC) in collaboration with several organizations released technical report TR-01-2006 Review of Conducted Energy Devices. One of the findings in the report was a lack of independent test facilities in Canada capable of electrical testing to determine if the specifications for Taser¹© outputs were met (TR-01-2006 pg 29). During 2006 and 2007 the CPRC worked to develop testing protocols and assemble the equipment necessary to provide this service. CPRC began testing in early 2008 and has completed the evaluation of 7 Taser International's series X26 Conducted Energy Weapons. The X26 is a prohibited firearm in Canada and testing is performed by sworn police officers. The testing results for the two weapons submitted are attached in Appendix A

The primary objective of the testing is to determine whether or not the units meet the manufacturer's standards for electrical performance. The Taser X26 uses proprietary technology which is the property of Taser International, Scottsdale Arizona. The performance specifications of the Taser X26 are attached in Appendix B.

To undertake the tests the CPRC obtained a copy of the test procedures from Taser International for peak open circuit arcing voltage and peak loaded voltage and current measurements. The test protocols are included in Appendix C. Neither the performance specifications nor the testing procedures provide information on the electrical output tolerances for the X26. Taser International was contacted and these were received on 6 June 2008, dated 21 May 2008, Appendix D

In the letter the Vice president of Research and development for Taser International advised that "an overall accuracy of $\pm 15\%$ is reasonable for X26 measurements" This is the standard variation used to evaluate the devices.

These tests were also selected as they were objective in that the electrical characteristics are read directly from the instruments and no calculations are required. Photographs were taken of the measurements and the weapon together to link the exhibit directly with the measured results, Appendix A. The CPRC test equipment and typical testing setup is included in Appendix A.

¹ TASER® is a registered trademark of TASER International, Inc.

Discussion of the results

CPRC has evaluated 7 Taser X26 weapons and performed in service testing on an additional 40 weapons. The two weapons provided for examination will be compared to the other 5 CEWs that have been evaluated.


Weapons tested:

Taser X26 X00-010000 Taser X26 X00-009704

The testing was performed at the Canadian Police Research Centre's facility at 1200 Montreal Road, Ottawa, Ontario on April 18, 2008. Two members of the Ottawa Police Service conducted the tests, Sergeant Mark Barclay and Constable Michael Azar. Sergeant Barkley is a member of the Ottawa Police Emergency Response Team and has received significant training in Taser usage and Constable Michael Azar is an electronic equipment specialist.

Peak open circuit arcing voltage

The peak open circuit arcing voltage is the 50,000 volt output commonly referred to when discussing the Taser Conducted Energy Weapons.




The two units tested both measured below the 50, 000 volt specified by Taser International; however both units are within the plus or minus 15% tolerance specified by the manufacturer. This range is between 57,500 Volts and 42,500 Volts.

Voltage and Current measured under Load

These tests simulate the Taser when it is in electrical contact with the human body either in push stun mode or in probe mode. A 250 ohm resistor is used to simulate the resistance across the human body. Tests are conducted to measure the voltage across the resistor and the current flowing through the resistor.

Peak Voltage under Load




The Taser International specification for voltage under load is 1,200 volts plus or minus 15% (1020 to 1380 volts). Unit X00-010000 is within the manufacturer's specification. The unit X26 X00-009704 had a slightly higher output voltage than specified.


In the letter from Taser International date 21 May 2008 Max Nerheim Vice President, Research and development provides background information on the tolerances which explain this. "Voltagre (sic) and current measurements into 250 ohm load will vary depending on several variables in each weapon. The major variables are output capacitor and spark gap tolerances. The capacitors have a tolerance of +/-10%, the spark gap has a tolerance of +/-15%. These tolerances add up, although not linearly, and affect the measured output current of each device."


This also needs to be taken into consideration with the next measurement, the current under load. This CEW had the lowest current of all weapons evaluated by CPRC. The energy input into the load is a function of the current and voltage together.

Peak Current under Load

Taser International does not provide a specification for this measurement. The average of the measurements by CPRC is 3.091 Amperes. Both units tested were within the standard specification tolerance of plus or minus 15 percent (2.63 to 3.55 Amps).







Summary

Taser X26 X00-010000 was found to be within the manufacturing tolerances provided by the manufacturer or calculated using the test procedures provided by Taser International.

Taser X26 X00-009704 was generally within the manufacturing tolerances provided by the manufacturer or calculated using the test procedures provided by Taser International. The exception was a slightly higher voltage under load. The 1469 volts measured is higher than the 1380 volts at the upper end of the variance provided by the manufacturer. While it is slightly higher than anticipated the current measured for this CEW is lower than all others. The power of the input into the load, representing the human body, is directly proportional to the product of the voltage and the current. The Vice president of Research and Development of Taser International has also provided comment on how the specification range was derived which may well explain this variance.

No other tests were performed on these weapons. The energy pulse calculations are not part of our current test procedures.

No other variances other than mentioned above were noted during the test and evaluation process.

Appendix A

Test results and Typical Test bench Setup

Taser Voltage and Current Testing

Taser International is the premier supplier of ECD's (Electronic Control Devices) to law enforcement agencies across North America. Taser uses electrical impulses that cause stimulation of both motor and sensory nerves. The effect is a disruption of the information carried from the body to the brain, and commands from the brain to the muscles that control movement. Neuromuscular Incapacitation (NMI) occurs due to this involuntary stimulation, and it is not dependent on pain.

There has been considerable controversy of late as to the level of safety involved with deployment of the Taser device. The media has broadcasted countless reports relating to the high voltage discharge of the device, and the possibility of deployed units producing greater than specified output voltage and current amounts. One study, which was withdrawn after errors in calculations were revealed, indicated output discrepancies that were several times higher than specified by Taser International. Nonetheless, we believe it prudent to conduct output verification test on a random selection of Taser devices. These devices were supplied by various police agencies, and were drawn from front line, training, and inventory units. This broad spectrum of selection provides units with non-sequential serial numbers, different manufacture dates, light to no previous usage, along with moderate to heavily used devices.


Testing procedures are mirrored from Taser Internationals verification procedure, including, but not limited to identical Oscilloscopes, high voltage probes, current probes, and Ohmite resistor. In order to address the most common concerns, the following three tests were performed:

1 - Open load maximum voltage. This test captures the highest voltage produced by the Taser device when it is arcing (through open air) across the upper and lower contact.

2 - Maximum voltage under load. This test captures the highest voltage produced by the Taser device when it's electrical output is loaded across a 250 Ohm ceramic resistor.

3 - Maximum output current under load. This test captures the highest current output produced by the Taser device, when it's loaded across a 250 Ohm ceramic resistor.

Note: The use of the 250 Ohm resistor is to simulate resistance of the human body. Dry skin does not conduct electricity well, and therefore has very high resistance, from 10-100 Kilo Ohms. Wet skin on the other hand is a very good electrical conductor, and consequently has a much lower resistance, approximately 1 Kilo Ohms. These are accepted resistances when calculating the effects of electrical current on the human body. Therefore, the use of a 250 Ohm resistor produces appropriate results for the above noted tests.



Tests for X26 Taser – Serial Number X00-010000

Test Type:	Open Load Voltage Test
Model:	X26
Serial Number:	X00-010000
Maximum Voltage:	44.36kv (44,360 volts)
Equipment Used:	Tektronix 3034B scope, two high voltage probes



Test Type:	Maximum voltage and current under load test
Model:	X26
Serial Number:	X00-010000
Maximum Voltage:	1.08kv (1080 volts)
Maximum Current:	3.253 amperes
Equipment Used:	Tektronix 3034B scope, one high voltage probe, one current probe,
	one 250 Ohm ceramic resistor




Tests for X26 Taser – Serial Number X00-009704

Test Type: Model: Serial Number: Maximum Voltage: Equipment Used:

Open Load Voltage Test X26 X00-009704 45.38kv (45,380 volts) Tektronix 3034B scope, two high voltage probes




Test Type:	Maximum voltage and current under load test
Model:	X26
Serial Number:	X00-009704
Maximum Voltage:	1.469kv (1469 volts)
Maximum Current:	2.424 amperes
Equipment Used:	Tektronix 3034B scope, one high voltage probe, one current probe,
	one 250 Ohm ceramic resistor



Typical Test Bench Setup





Appendix B

Taser X26 Performance Specifications



TASER® X26E SERIES ELECTRONIC CONTROL DEVICE SPECIFICATION (Law Enforcement X26)



La	w Enforcement I	Models⁵						
	Mod		Model No.	Color	Magazine Typ	e	Grip color/style	Holster
TA	SER® X26E (Lav	v Enforcement)	26000	Black	DPM		Black on Stainless	eXoskeleton
TA	SER® X26E (Lav	v Enforcement)	26005	Yellow	DPM		Stainless on Black	eXoskeleton
TA	SER® X26E (Lav	v Enforcement)	26004	Clear	DPM		Black on Stainless	eXoskeleton
TA	SER® X26E (Lav	v Enforcement)	26013	Black	XDPM		Black on Stainless	eXoskeleton
TA	SER® X26E (Lav	v Enforcement)	26025	Yellow	XDPM		Stainless on Black	eXoskeleton
	SER® X26E (Lav	v Enforcement)	26019	Clear	XDPM		Black on Stainless	eXoskeleton
Sp	ecifications				Features			
 Output characteristics^{3,8}: Wave form: Complex shaped pulse Pulse rate: 19 pulses per second (PPS) Pulse duration: 100 microseconds The trigger activates a 5-second cycle. The cycle can be stopped by placing the safety lever in the safe position. Peak open circuit arcing voltage: 50,000 V Peak loaded voltage: 1,200 V, avg. voltage over duration of main phase 400 V, avg. over full phase 350 V, avg. over one second 0.76 V. Current: 2.1 mA average Energy per pulse: Nominal at main capacitors: 0.36 joules Delivered into load: 0.07 joules Power rating: Nominal at main capacitors: 6.84 watts Delivered into load: 1.33 watts Power source: Digital Power Magazine (DPM)^{4,8} a battery of two 3-volt cells, or Extended Digital Power Magazine (XDPM) 4,8 Temperature range: -4 °F [-20°C] to 122 °F [50 °C] Relative humidity: 15% to 80% Housing: High impact polymer Patent: U.S. D508,277, D504,489, and other patents pending 			 Integrated 6 Capable of installed. Electrical ch cumulative 6 Central Info remaining D expiration, 0 current time Ambidextroi denotation. Warranty: available.² Unit stores 6 and remainin approximate using a USE which can b Compatible TASER C2 	50 nrr drive- arge of clot rmatic PM e and us sal -year ime, f ng DF -year ime, f a data e ord with a Cartri	fety levers with Safe "S' r standard, with extended date, burst duration, un PM energy percentage 500 firings. Data can be a interface module or TA ered separately. all TASER Cartridges ^{6,7}	acquisition). SER Cartridge [5 cm] robe. t LED displays st time, warranty status, and " and Fire "F" ed warranties it temperature, for e downloaded ASER CAM TM , , but not the		
	ysical Dimensio		Without Cartri	dae)			Dimensions (With	n Cartridge) ^{1,6}
	Length (L)	Height (H)	Width	0 /	Weight		Length	
	• · · /	/	1		J		· · · · · · · · · · · · · · · · · · ·	

	Dimensions (V	Dimensions (With Cartridge) ^{1,6}		
Length (L)	Height (H)	Width (W)	Weight	Length (L2)
6.00" [15.24 cm]	3.20" [8.13 cm]	3.20" [8.13 cm] 1.300" [3.30 cm]		7.250" [18.52 cm]

- 1. Dimensions are in English [metric].
- 2. Additional terms and conditions may apply (for additional information contact a TASER International sales representative or visit online at: <u>www.TASER.com</u>).
- 3. Product specifications may change without notice; actual product may vary from picture.
- 4. Material Safety Data Sheet (MSDS) concerning lithium cells available upon request.
- 5. TASER X26E not available for sale to the general public. Additional models available. Please contact a TASER International sales representative for more information.
- 6. For standard TASER Cartridges, see TASER specification RD-SPEC-CRTG-001.
- 7. TASER Cartridges available up to a maximum range of 35' [10.66 m]. Use of cartridges not authorized by TASER International will void the product warranty.
- 8. Output specifications may vary depending upon temperature, battery charge, and load characteristics.
- 9. TASER® is a registered trademark of TASER International, Inc. All rights reserved.

RD-SPEC-X26E-001 Rev: J	May 15, 2007	Page: 1 of 1			
TASER International reserves the right to change this specification without notice.					


Appendix C

Taser International Test Procedures

TASER Open Circuit Voltage Measurement Procedure




EQUIPMENT NEEDED



Test Setup

Plug the two probes into channels 1 and 2 of the oscilloscope.


Connect the ground clips to each other.



Connect the <u>CH 1 probe to the **upper** electrode</u> on the weapon and the <u>CH 2 probe to the **bottom** electrode.</u>



OSCILLOSCOPE SETTINGS




Press the "QUICK MENU" button.




OSCILLOSCOPE SETTINGS

"QUICK MENU"



- 1) Adjust the Trigger Mode from "Auto" to "Normal"
- 2) Change the Acquire mode to "Sample"


CHANNEL 1 SETTINGS




1) Press the yellow CH1 button.

2) Press the "MENU" button.

3) Press the "Probe Setup" button and adjust to 1 kX.




CHANNEL 2 SETTINGS




1) Press the Blue CH2 button.

2) Press the "MENU" button.

3) Press the "Probe Setup" button and adjust to 1 kX.




MATH SETTINGS




1) Press the Red "MATH" button.


2) Set equation to (Ch 1) - (Ch 2)



X-26 Waveform




M-26 Waveform




TASER Load Voltage and Current Measurement Procedure



EQUIPMENT NEEDED








1) Connect the large resistor across the output of the weapon.

2) Plug the current probe into channel 4 of the oscilloscope.

3) Clamp current probe around the output wire and halfways in between the resistor and electrode. Make sure the arrow is in the same direction as the current.

4) Clip the High Voltage Probe across the resistor.

CHANNEL 4 SETTINGS




1) Press the Green CH4 button.


2) Press the "MENU" button.

3) Press the "Probe Setup" button and adjust to 10 X with the Knob.

4) Change Probe to "Current"



X-26 Waveforms



Appendix D

Taser International Correspondence, Peak arcing voltage measurement



17800 North 85th Street • Scottsdale, Arizona 85255 • www.TASER.com Phone: 480.905.2000 • 800.978.2737 • Fax: 480.991.0791

Date: May 21, 2008 Peak arcing voltage measurement of TASER X26 and M26 devices

The peak arcing voltage at the output of the X26 and M26 devices depend on environmental and device mechanical dimensions. The measured number depends on additional instrumentation effects.

Measuring the high voltage arcing waveform generated by the X26 or M26 devices is not intuitive or easy. Most industry expertise in the high voltage area is in much lower frequency waveforms. The outputs from the TASER devices is both high frequency and high voltage – making the measurements prone to many factors that affect measurement accuracy and reliability. Many measurement subtleties could make the results inaccurate or unreliable.

Environmental factors that affect the accuracy are temperature, humidy, and elevation. A variation in each of these factors will increase or decrease the arcing breakover voltage.

The device mechanical dimensions that affect the peak arcing voltage is the precise distance between the tho probe points in front of the weapon. Slightly closer probe points will result in slightly lower peak voltages before the arc is generated. If two weapons have identical spacing between the probes and are tested on the same day with the same equipment, the results should be identical. However, the instrumentation factors will influence what is displayed on the scope...

The instrumentation effects depend on the accuracy of the scope probe, the oscilloscope used for making the measuremenst, and the effect of the scope probe on the device under test. TASER typically use two Tektronix P6015A high voltage probes for conducting peak voltage measurements. Both of them are hooked up to a Tektronix TDS3034B 300 MHz bandwidth oscilloscope. The tip of each probe is connected to the output terminal of the device under test – one probe tip to each weapon output terminal. The probe ground leads are connected together. The resulting peak output voltage is calculated by using the TDS3034B's built in math function: "Output voltage equals channel A minus channel B". We typically measure peak arcing voltages of 46 to 60KV

The high voltage probes must be calibrated following the Tektronix user manual guidelines. If this has been accomplished, the P6015 user manual table 1-1 shows that the attenuation can be variable by +/-5%. I take this to mean that at a certain voltage and frequency, the attenuation might be 1000 minus 5%, i.e 950:1, while at another combination of voltage and frequency the attenuation might be 1050:1. In the first case, a 10000 volt waveform would display on the scope as 9500 volts, in the second case as 10500 volts. In addition to the scope probes having +/-5% accuracy, the TDS3034B oscilloscope has a +/-2% vertical accuracy (typical for most scopes).

In order to capture the actual peak of the X26 output pulse the scope must have sufficient bandwidth and capture rate to capture the actual peak. The X26 output ramps up at around 100 volts/nanosecond, or 100 billion volts per second. This signal edge rate is on the order of 100 times faster than a USB 2.0 signal. This means test setup and scope configuration is very critical.



17800 North 85th Street • Scottsdale, Arizona 85255 • www.TASER.com Phone: 480.905.2000 • 800.978.2737 • Fax: 480.991.0791

The scope probes must be compensated to the actual scope used for the test. By not utilizing optimum settings, we have seen a 48 kV measurement range from 30 to 65 kV displayed on the scope! I also question if the probes are actually capable of a reliable voltage measurement at these edge rates. At testing done at TASER, we have added some extra capacitance to the load, in the order of several picofarads. This has smoothed out the waveform on the scope. The smoothing out might be caused by the previous rise time exceeding the rise time capability of the scope probe. If the rise time capability of the scope probe is exceeded, the measurement is not reliable.

The manual for the P6015A probe has additional information on probe impedance versus frequency. The frequency component for the X26 high voltage output is on the order of hundred(s) of kilohertz – it goes from zero to the breakover voltage of approximately 50 kV in approximately 1.5 microseconds. From the P6015A manual figure 1-8, this results in a typical probe impedance between 1 and 10 kohm. This is a very significant load on the output of the device under test! For example, a best case impedance of 10 kohm with a frequency of 10 kHz has a peak dissipation factor of 250kwatt (assuming 50 kV and 100 kHz). Since the arcing X26 pulse is very short, the actual power delivered by the X26 into the scope probe is most likely a quarter of a watt per pulse or less – but still significant. I.e. the scope probe will have a significant effect on the output voltage measurement. Chart 1-7 in the same manual also characterize the effect of temperature and humidity on probe performance – higher humidity and temperatures decrease probe performance from a 40 kV probe to a 20 kV prbe worst case (I assume sea level pressures were used for the graph – increasing elevation would further derate the performance).

Voltagre and current measurements into 250 ohm load will vary depending on several variables in each weapon. The major variables are output capacitor and spark gap tolerances. The capacitors have a tolerance of +/-10%, the spark gap has a tolerance of +/-15%. These tolerances add up, although not linearly, and affect the measured output current of each device. In addition, the breakover voltage of the spark gap will vary from pulse-to pulse. In order to obtain a stable, average value, it is best to set the scope to average around 10 samples. Due to the output capacitor and the spark gap tolerance, a current and voltage measurement difference of around +/-15% can be expected from device-to device.

In summary:

A combination of weapon probe spread and component tolerances, oscilloscope accuracy and setup, combined with scope probes that are difficult to verify for high voltage pulses, results in many unknowns. Therefore, we think an overall accuracy of around +/-15% is reasonable for the X26 measurements. We hold as evidence that the probe spread on the X26 is held within much closer tolerances than the variations we see in peak output voltages before the arc is created.

Measurements of arcing voltages between 50 to 55KV, stimphase of 1 to 1.2KV, and 3 to 3.4A are within tolerance limits.

Respectfully: Max Nerheim Vice President, Research and Developmen



17800 North 85th Street • Scottsdale, Arizona 85255 • www.TASER.com Phone: 480.905.2000 • 800.978.2737 • Fax: 480.991.0791