CONCEPTS OF TRANSIENT RECORDER DEVELOPMENT FOR ACOUSTIC EMISSION ANALYSIS

KONZEPTE DER TRANSIENTENREKORDER ENTWICKLUNG FÜR DIE SCHALLEMISSIONSANALYSE

DES CONCEPTES DU DEVELOPMENT D'UN LECTEUR POUR ANA-LYSER DES EMISSIONS ACOUSTIQUES

J.H. Kurz, V. Wolter, G. Bahr und M. Motz

SUMMARY

The large number of acoustic emissions occurring during an experiment require a fast and high resolution transient recorder system. A standard personal computer with a RAID system and two data acquisition cards, each has got 4 input channels, 5 MHz sampling rate and 12 bit amplitude resolution, build the hardware platform. Using this hardware two transient recorder software concepts were realized. The first one is an event controlled system where each event is triggered and stored immediately with a rate of up to 50 events per second. The second one is a continuously recording system where the data flow is recorded and stored continuously and the events are extracted afterwards. The advantage here is that really all events are recorded but really large datasets need to be handled.

ZUSAMMENFASSUNG

Die große Anzahl während eines Versuches auftretenden Schallemissionen bedarf eines schnellen und hochauflösenden Transientenrekorders. Ein Standard PC mit einem RAID System und zwei Messkarten, jede mit 4 Kanälen, 5 MHz Sampling Rate und 12-Bit Amplitudenauflösung, bildet die Hardware Plattform. Auf Basis dieses Equipments wurden zwei Transientenrekorder Systeme umgesetzt. Das eine System zeichnet kontinuierlich den Datenfluss auf, aus dem hinterher die einzelnen Schallemissionsereignisse extrahiert werden. Der Vorteil dieses Prinzips ist, dass wirklich alle Schallemissionen erfasst werden. Aller-

dings müssen hier teilweise sehr große Datensätze bearbeitet werden. Das andere System arbeitet Ereignis basiert, d.h. wird ein Ereignis durch die Triggerbedingung als solches erkannt, so wird es sofort abgespeichert. Mit diesem System wird dabei eine Speicherrate von 50 Schallemissionen pro Sekunde erzielt.

RESUME

Le grand numero des emissions acoustiques qui se manifestent pendant une experience a besoin d'un lecteur pour des emissions acoustiques qui est vite et qui est en haute definition. Un ordinateur normal avec un system RAID et deux cartes de mesure, chaque avec 4 canals, 5 MHz quote-part de balayer et 12 bit resolution des amplitudes forment la base de hardware. Deux systemes differentes pour enregistrer des emissions acoustiques etait realiser a la base de ce hardware. La premiere systeme enregistre chaque emission acoustique juste apres le determination. Avec ce system un quote-part de accumulation de 50 emissions acoustiques par seconde aura gagne. La deuxieme systeme enregistre les carateristiques continu et chaque emission acoustique aura extrai apres l'experience. L'avantage de ce system est que vraiment tous emissions acoustiques auraient enregistent. A l'otre cote on gagne des ensembles de donnees tres grand.

KEYWORDS: Transient recorder, acoustic emissions, data acquision

INTRODUCTION

Acoustic emissions are defined as the spontaneous release of localised strain energy in stressed material. Due to micro cracking in the material, this energy release can be recorded by transducers on the material's surface [Große, 2002]. Acoustic emission analysis is capable of revealing damage processes in material during the entire load history. It is obvious that the recording of damage processes from the microscopic to the macroscopic scale produces a large number of events during relative short time spans. The number of events can be about several thousands during one test. Due to the large number of occurring acoustic emissions within short periods, it is obvious that a fast recording system is needed. Furthermore, the events' frequencies are in the ultrasonic frequency range. Therefore, the transient recorder needs a high sampling rate, too. The kernel of such a system is the data acquisition part. Here, a fast and high resolution A/D converter in form of a measurement card is generally used. In the case of that more than one card is used, they need to be synchronised. The data then

is stored by a computer system which must be fast during the process of data storage and which must have sufficient disk space. All these processes are controlled by the corresponding software.

The rate of acoustic emissions during experiments especially in concrete can be about 30 or more events per second. Commercial data acquisition systems including the software detect between 2 and more than 100 events per second depending on the time delay of the system during the process of storage. The sampling rate for concrete specimens should be greater than 1 MHz with a high amplitude resolution. The required disk space should be about several gigabyte. The more sensors are used the better the data analysis works. Therefore, in general more than one data acquisition card is needed. The cards then need to be synchronised. These are the benchmarks a good system for acoustic emission analysis on concrete should achieve.

REALISATION OF THE REQUIRED HARDWARE STANDARDS

The most limiting factor concerning the chosen hardware and not mentioned yet, is the constricted budget. With an infinite budget it would be possible to go far beyond the required hardware standards. But with the chosen concept a relatively cheap solution was found which fulfils all mentioned benchmarks.

The chosen hardware is a standard personal computer with an AMD Athlon 1800⁺ processor and a raid controller onboard. The system has got 1 GB RAM and 3 hard disks, each with about 60 GB memory. The first hard disk contains the operating system while the two other hard disks are the memory for the transient recorder. They are configured as a RAID 0. RAID means Redundand Arrays of Inexpensive Disks. That means a compound of hard disks which complement each other. RAID 0 especially also called striping arranges the data equally on both disks. The data transfer rate is so twice as high as with one disk. With respect to fast data processing on a second system the two RAID disks were set into two carrier bodies.

Data acquisition is realised with two measurement cards of type PCI-6110 from National Instruments implemented in the personal computer. The connection between sensors and data acquisition system is realised via a self designed panel. Each measurement card contains 4 analog inputs, 2 analog outputs and 8 digital in-/outputs as well as two 24 bit counter/timer. Concerning the transient recorder only the analog inputs are needed. Each analog input has got an own ADC with a resolution of 12 bit, differential input mode, input coupling

switchable between DC/AC and 8 bipolar ranges from +/- 0.2 V to +/- 42 V. The sampling rate can be chosen between 1 kS/s and 5 MS/s.

The onboard trigger is a bit limited. It is only possible to trigger on one channel and logical connections between different channels are not possible. A slewrate trigger is not realised, too. Using the analog trigger mode one input channel or an external signal is the trigger source. The trigger level has got a resolution of 8 bit. Within the digital trigger mode an external TTL signal is used. Furthermore, triggering by a software signal is also possible and pre- and posttrigger are supplied, too.

A flexible interface which can be used for generating a timing signal is also implemented on the measuring card. This interface can be used for routing the timing signal to other data acquisition systems or to an external output. The routing possibility is essential for a transient recorder system with two or more cards because there is a need of sending the clock pulse as well as the trigger pulse from the trigger channel to the other measurement cards. This is realised via the RTSI (Real Time System Integration) bus which is a simple connection between the data acquisition cards [PCI-6110/6111, 2000].

The up to now short description of the chosen hardware will be completed by a brief description of the two software systems in the following which control the whole recording implemented on the data acquisition unit. The first one is an event controlled program while the second one is a continuous recording system.

DEVELOPMENT OF AN EVENT CONTROLLED TRANSIENT RE-CORDER SOFTWARE

The event controlled transient recorder software was developed with Lab-VIEW 6.1 using the Programming language G which is widespread in the field of data acquisition and measurement systems (LabVIEW, 2002). Using Lab-VIEW the coding is realised in a graphical way which is different to e.g. Fortran or C# but easy to learn. Furthermore, the program flow in LabVIEW is not sequential but related to the data flow. This simplificates process parallelization. Other programming features like loops and sequences are also available as well as subroutines called SubVI (VI: virtual instrument).

Each LabVIEW program is called a VI and consists of a front panel and a diagram. In the following a simle example shell demonstrate the programming procedures within LabVIEW (Fig. 1).




Fig. 1: Example for the structure of a LabVIEW program, left front panel, right diagram.

Two numbers shell be entered on a user interface, then multiplied with each other and finally the result displayed on a moving coil instrument (Fig. 1, left). Pressing the stop button the program is terminated. The buttons, instruments and controls can be placed on the front panel which is the user interface by drag and drop operations. The example shows two controls (factor 1 and 2), a boolean control button (STOP) and a numerical display in form of a moving coil instrument. Each control element or display creates automatically a terminal on the diagram surface (Fig. 1, right). Within the diagram functions, operators and structures are used which can also be placed by drag and drop operations. The diagram's elements are then connected by virtual wires. Fig. 1 (right) shows a while loop (grey border line) and within the loop the two input elements factor 1 and factor 2 and the multiplication operator (cross sign). The multiplication operator is connected to the two input elements and the output display (product) and the stop terminal is connected to the conditional terminal of the while loop. After starting the program two number can be multiplied with each other until the STOP button is pressed which cancels the while loop.

This relative simple example shows the general procedure of programming in G. The transient recorder software is a much more complex problem but it is in principal the same basic system. The software's front panel (Fig. 2) has got a menu bar including the menus File, Settings, Measure, Display and Help.

The menu Settings contains dialogs for the data acquisition settings and for the definition of the auto-sequence. The menu Measure is for starting and stopping the measurement as well as the auto-sequence. The menu Display contains the possible display settings and the Help menu calls the help functions.




Fig. 2: Front panel of the new transient recorder software

Below the menu bar is the symbol bar situated containing the most important functions from the menu bar. The screen's largest part is acquired for displaying the signals of each channel. The display settings of each channel can be chosen by using the change button on the left side of each channel or via the Display menu in the menu bar. At the bottom of the front panel a table for chosen parameters is situated.

The control panel of the data acquisition card is shown in Fig. 3. All essential interfaces and displays can be found in the four index cards Timebase, Input Amplifier, Trigger and Physical Unit. The auto-sequence panel is shown in Fig. 4. The available functions can be chosen from the corresponding interface and are copied into the auto-sequence list. The commands listed in there define the current auto-sequence which is started by pressing the Auto Record button in the symbol bar.

The front panel's diagram structure is the code behind the above shown graphical user interface (Fig. 2). Its architecture will be shown in the following: The VI "Main Panel" is the top level VI (Fig. 5). It consists of 2 while loops

which are executed parallel. The upper loop shows the event control. The user activates an event e.g. by pressing a button on the front panel or choosing a menu entry from the menu bar. The programmer defines which control elements are activated by a certain event using the so called event structure (inner frame in the upper loop of Fig. 5). Each event has got an own case in the event structure whose subdiagram will executed if the corresponding event occurs. As long as no event appears the event structure is in a sleeping mode which saves processor capacity.




Fig. 3: Control panel of the data acquisition card




Fig. 4: Auto sequence panel




Fig. 5: Diagram of the front panel showing 2 parallel while loops

Fig. 5 shows the event case which will be executed if the record button on the front panel (Fig. 2) is pressed. Then an array consisting of symbolic constants with the elements "Config and Route", "Start and Read Data", "Unroute" and "Display Data" will be created. This array leaves the events structure using a so called tube with destination to the "First Notifier" (lower loop in Fig. 5). A "Notifier" enables the communication between 2 independent parts of a block diagram. Its principal is comparable to a mailbox which also sends and receives data. The "Notifier's" data output is connected to the input tube of a for loop whose auto-indexing is activated. The tube's output is connected to the selector of a case structure which is situated in the for loop. The auto-indexing affects that the elements of an array which is connected to the input tube of the for loop are passed one after the other to the loop. The loop counter (n-terminal) which normally controls the number of loop executions, does not need to be connected to the loop. The loop is executed with respect to the dimension of the array. The mode of operation works as follows: If the user initiates an event, an array consisting of symbolic constants is situated at the input tube of the for loop. During each execution of the for loop one symbolic constant of the array is read, i.e. During the firts loop execution the "Config and Route" constant which is passed to the selector of the case structure that executes the corresponding "Config and Route" subdiagram (Fig. 5, lower loop). Having read all constants the "Notifier" lapses into a sleeping mode until a new event is initiated. Other events create arrays consisting of different symbolic constants which call certain case structures. Such a programming architecture is called state machine.

The data transfer of subdiagrams of the state machine is realised by so called shift registers. A shift register is a pair of connections which are situated on the vertical sides of the loop frame (triangle signs in the lower loop of Fig. 5). The connection on the right hand side (triangle upwards) stores the data at the end of one loop execution, that it can be used in the next run as input by the other connection (triangle downwards). A shift register can be used with different data types. The advantage of such an architecture is the simple way of extending the program. If further functions are needed the corresponding case structures are implemented in the state machine and if needed also in the event control.

Until now the used programming environment (LabVIEW) was introduced and the main features of the graphical user interface of the transient recorder software were shown. In the following a few important details of the coding are presented.

Using 8 sensors two data acquisition cards are needed. Herefore, the synchronisation of the cards is important. Each card can be used separately for signal recording with up to 4 sensors. But for an acoustic emission analysis it is important that the cards have got the same timebase, i.e. they need to be synchronised. Therefore, the SubVI "Config & Route" was developed (Fig. 6). Further SubVIs are implemented in this routine and connected by the "Daisy Chain Procedure" [ObjectVIEW, 2002]. That means the output parameters of one VI represent the input parameters for another one. This leads to a sequential data flow which is useful here.

The left side of Fig. 6 contains the controls "Master device" and "Slave device" which represent the two data acquisition cards. The decision which trigger channel is chosen in the control panel determines which card will be master and which slave. The parameters "Master device", "Master channel scan list" (list of channels used for measurement), "coupling & input config" (input configuration and input coupling) and "Blocklength" are set in the control panel and passed to the SubVI "AI Config" which is executed first. The sampling rate is set in the

SubVI "Clock config". Trigger channel, trigger slope, trigger level and hysteresis are set in the SubVI "Trigger config".




Fig. 6: SubVI "Config & Route" for configuration and routing

The trigger procedure is very important for the whole process of data acquisition. Therefore, a more detailed description will be given. If the trigger condition is fulfilled the analog trigger on the data acquisition card generates an internal trigger signal. This internal digital trigger signal is send by the SubVI "Route signal" to the RTSI bus (connection RTSI 0) where it can be received by the second data acquisition card. Within the post-trigger mode or if the pre-trigger samples are set to zero, this internal signal is the starting point for the data acquisition. During the pre-trigger mode the internal signal stops the acquisition because the data acquisition has already started and the pre-trigger samples must be seized, before the trigger condition is fulfilled.

Each data acquisition card has got a 20 MHz time base from where the needed timing signals are send e.g. to the A/D converter. The board clock can also be routed by the RTSI bus, though other data acquisition cards can use the same time base. This is performed by the second call of the SubVI "Route signal" where the signal "Board clock" is send to the "RTSI bus" (Fig. 6). The next two SubVIs configure the slave device in the same manner as described for the master device. Configuring the trigger of the slave device is different from the master device trigger configuration. Herefore, a digital trigger is used and the trigger channel is not an analog external signal but the RTSI 0 connection which uses the master device trigger signal. Though the both cards are triggered si-

multaneously. Finally the board clock of the slave device is set to the RTSI clock, that the sampling is synchronised in phase and frequency.

A further important point is the error trapping. Most of the SubVIs of the diagram shown in Fig. 6 contain an error input and an error output which is connected to the error input of the following VI. Error in- and output are in form of a cluster which is comparable to a dataset or a structure in text based programming languages. This cluster contains a boolean, a numerical and a string control or indicator. If an error occurs the boolean element is set true, the numerical element contains the error number and the string the error message. The next SubVI which receives the error cluster has then the possibility to decide how to handle the further proceeding. Fig. 7 shows an example for such an error handling in the SubVI "Clock config". If this SubVI receives an error cluster the case "Fehler" is selected from which the task ID and the error cluster are passed to the following VI (Fig. 7, right). If no error occurs the subdiagram of this case called "Kein Fehler" is executed. If an error occurs during the execution of this case the error cluster is set to error and the error number and the error message "AI Clock Config" is passed to the error output (Fig. 7, left).

The described part of the program containing configuration and routing must only be executed once if the configuration is not changed. The next parts of the software which control the start of the data acquisition or the recording of the data can be repeated without re-configuring and re-routing.




Fig. 7: Error handling within the SubVI "Clock config"

After configuration and start of the recording system, the data acquisition cards wait for a trigger condition for data storage. All available VIs concerning

the idle running time before an event occurs blocked the program, i.e. no precast VI could be used. Using a timeout function to stop the data acquisition if no event occurs, did not produce satisfying results, too. Therefore, the SubVI "Read Data" was developed (Fig. 8, left).




Fig. 8: SubVI "Read Data" (left) and Subdiagram "Waiting" (right)which corresponds to the Subdiagram "Data Available" on the left side for idle running time handling

The SubVi "Read Data" (Fig. 8, left) imports zero datapoints from the master device in a while loop by using the SubVI "AI Read", i.e. the loop cannot be blocked. The parameter "Scan Backlog" which is returned by this VI says how many datapoints are staying in the buffer after the SubVI's execution. As long as no trigger condition is fulfilled the "Scan Backlog" value is zero and the subdiagramm "Waiting" (Fig. 8, right) of the following case structure is passing only the master and slave IDs and the error cluster to the following loop execution where again "Scan Backlog" is read out. The break switch within the subdiagramm which can be used via the VI-server function by other VIs enables to stop the data acquisition if the corresponding control button is used on the main panel. If the trigger condition is fulfilled and all data is in the buffer the "Scan Backlog" value is the value of the blocklength. Then the subdiagram "Data Available" is executed where the data readout of the master and the slave device from the buffer is realised. Activating the termination condition of the whileloop within this subdiagramm the SubVI "Read Data" is ceased. The data is now available in the terminals master device data and slave device data for storage or display.

DEVELOPMENT OF A CONTINUOUSLY RECORDING TRANSIENT RECORDER SOFTWARE

The continuously recording transient recorder system is based on the same hardware platform as the event controlled one. The software DevTRec is written in Visual C++. The data acquisition cards are approached by the C-libraries of National Instruments (NI-DAQ) [LabVIEW, 2002].

The data acquisition is organised via a ringbuffer which enables measurements with up to 8 channels and 2 megasamples continuously (Fig. 9).




Fig. 9: Ring buffer organisation

Though, the experiment is recorded completely. The data analysis is performed afterwards. Due to the buffer arrangement the data is organised block by block in a binary file and needs to be sorted afterwards. Therefore, the optimal performance is guaranteed for data acquisition.

The data acquisition cards write the data block by block into the ringbuffer. That means at first card number 1 writes a block of data into the ringbuffer, then card number 2, then number 1 again and so on. Within each block the data of each channel is lined up in succession. Due to the knowledge of the blocklength it is then possible to put the data in the correct order. This ordered data is written to the so called "Basefile". The data is still in a binary 12-bit format. The format conversion uses the following formula:

measured value*10/(2048*gain) = real value

Finally each event is extracted from the continuous data file. Herefore, a simple trigger level can be chosen which defines the occurring of an event (Fig. 10).

The measured values are compared in succession to the trigger level value. It is possible to decide if a definite number of samples is extracted after the trigger level is reached or if the extraction of the event is finished if the values sink again below the trigger level. The events are written separately to a file whereas an information file is also created for every event which contains the relative trigger time. Due to the fact that the "Basefile" is not erased, the extraction can be repeated with different trigger values.




Fig. 10: Screenshot of DevTRec

The data visualisation is performed using the above shown conversion formula. Using the menu bar it is possible to decide how many values are shown and how many values per redrawing will be shown. That means it is possible to view even huge signal in a kind of film.

PERFORMANCE OF THE DEVELOPED SOFTWARE AND CONCEPTS FOR THE DATA ANALYSIS

The two described transient recorder systems on one hardware platform were developed to be able to store as much events per second as possible. The

continuous recording system records all occurring acoustic emissions. But they need to be extracted from the continuous data stream. That means the user has to deal with large data sets. The point of concern using this system is not the storing rate but the effective handling of the data.

Each data acquisition card is able to use a sampling rate of 5 MHz. If the two cards are used coupled and synchronised the sampling rate for the event controlled system is reduced to 2,5 MHz. The reason herefore seems to be that the onboard FIFO (First In First Out) memory which has got a capacity of 8 kB, is not able to pass the data fast enough via the PCI bus. However, the continuously recording system is only able to sample with 2 MHz using all 8 channels. The reason is not completely clear. If it is a software error the problem may be searched within the National Instruments software (NI-DAQ), i.e. within the C-libraries. The problem might also be based within the buffer organisation and monitoring routine. It is also possible that the data flow is around the limit of what the system bus of a standard personal computer is able to pass to the hard disk, i.e. the problem is a hardware problem.

The disc space of 120 GB makes recording times of more than 30 minutes possible but the user has to take into consideration that for the acoustic emission extraction further disc space is needed. The extraction is performed by a thresholding algorithm. The event extraction works automatically but however it is relatively slow. Therefore, removable hard discs are used in the transient recorder, so the data analysis can be realised on another computer. A further possibility would be to divide the raw data file, containing the continuous data, into several pieces and apply the extraction procedure on them. Until now there is not much experience in handling the huge data sets gained with the continuous recording system.

The event controlled recording system is not able to record all acoustic emissions occurring during one experiment. But is has got a much better performance than the until now used event controlled system which was only able to record 1 event per second with 5 MHz sampling rate (amplitude resolution 12 bit). A performance test revealed that the new transient recorder system is able to trigger and store about 50 events per second with a sampling rate of 2.5 MHz and 12 bit amplitude resolution. This transient recorder system produces large data sets, too, but much less disc space is needed than with the continuously recording system. The larger data sets enable a better analysis e.g. an automatic onset detection algorithm with a rate of success of about 40 % leads generally to

more significant results with 3000 recorded events than having only recorded 300. Concerning the system's hardware performance better data acquisition cards are available (16 bit amplitude resolution, 12 channels, 10 MHz sampling rate, 6 GB onboard memory) but the price of one of the best systems available now is factor 10 higher than of the one we developed.

ACKNOWLEDGEMENTS

These investigations are part of our work in the collaborative research center SFB 381 at the University of Stuttgart which is financially supported by the Deutsche Forschungsgemeinschaft (DFG). We gratefully acknowledge this support.

REFERENCES

- [1] GROSSE, C. U.: BASICS OF ACOUSTIC EMISSION MEASUREMENT TECHNIQUES, KLUWER ACADEMIC PUBLISHERS, HINGHAM MA, USA, CH. 9, P. 45, 2002.
- [2] LABVIEW BENUTZERHANDBUCH, NATIONAL INSTRUMENTS, EDITION JANUAR 2002, 2002.
- [3] OBJECTVIEW BENUTZERHANDBUCH, VOGEL AUTOMATISIERUNGSTECHNIK GMBH, 1. AUFLAGE, 2002.
- [4] PCI-6110/6111 USER MANUAL, NATIONAL INSTRUMENTS, EDITION NOVEMBER 2000, 2000