
DIVISION 28 23 23

**VR1100 SERIES – FIBER OPTIC RECEIVER
ENGINEERING SPECIFICATIONS**

PART 1 - GENERAL**1.01 SUMMARY**

- A. Fiber Optic AM Video Receiver

1.02 SECTION INCLUDES

- A. VR1100 Series AM Video Receiver – Standalone
B. VR1100-R3 Series AM Video Receiver - Rack Mount

1.03 REFERENCES

- A. Underwriters Laboratory (UL)
B. Underwriters Laboratory Canada (ULC)
C.

1.04 SYSTEM DESCRIPTION

- A. Performance Requirements: Provide an AM Video Receiver with AGC (automatic gain control).
1. The system shall utilize an 850nm optic capable of receiving a video signal on one multimode optical fiber. (VR1100)

1.05 SUBMITTALS

- A. Product Data: Manufacturer's printed product data sheet for each type of Transmitter/Receiver specified.
B. Detail Drawings: Electrical and optical connect drawings. Product mounting template.
C. Manufacturer's Installation and Operating Manual: Printed installation and operating information for each type of Transmitter/Receiver specified.
D. Test Reports: Manufacturer's Printed Test Report via a Tektronics VM700A Video Test Generator verifying product performance meets or exceeds the specified product performance referenced in Part 2.
E. Warranty: Manufacturer's Printed Warranty

1.06 DELIVERY, STORAGE AND HANDLING

- A. Deliver materials in unopened factory packaging with Manufacturer's bar coding to the job site.
B. Inspect product upon delivery to assure that specified products have been received.
C. Store in original packaging in a climate controlled environment. Storage Temperature not to exceed: -40° C to +85° C

1.07 PROJECT/SITE CONDITIONS

- A. Temperature Requirements: Products shall operate in an environment with an ambient temperature range of -40° C to +74° C without the assistance of fan-forced cooling.
B. Humidity Requirements: Products shall operate in an environment with relative humidity of 0% to 95% (non-condensing). If product is installed in condensation conditions, unit shall have conformal coating applied to the printed circuit board.

1.08 WARRANTY

- A. Standard International Fiber Systems Comprehensive Lifetime Warranty: IFS warrants the product to be free of factory defects under manufacture's Lifetime Warranty as submitted under article 1.05 (E)

PART 2 - PRODUCTS**2.01 MANUFACTURER**

- A. Acceptable Manufacturer: International Fiber Systems, Inc.; 16 Commerce Road, Newtown, CT 06470 USA; Telephone: 203-426-1180; Fax 203-426-3326; Email: sales@ifs.com; Internet: www.ifs.com
B. Substitutions: Not Permitted
C. All fiber optic modules shall be supplied from a single manufacturer.

2.02 MANUFACTURED UNITS

- A. Model Number Descriptions: Reference Table A: Product Number Descriptions
B. Model Compatibility Chart: Reference Table B: Product Compatibility Chart

2.03 GENERAL SPECIFICATIONS

- A. The AM Video Receiver shall be an IFS VR1100 series module. The module shall be capable of receiving full color video in real time in NTSC, PAL or SECAM formats. The module shall require no in-line attenuators to ease installation. The module shall provide power and AGC status indicating LED's for monitoring proper system operation. The module shall provide (AGC) automatic gain control so there will be no optical or electrical in-field adjustments to ease installations. The modules shall provide automatic re-settable solid-state current limiters and independent voltage regulators on each module to reduce the chance of a single point failure of the system. The module shall be hot swappable in a rack mount system to reduce complete system shut down during maintenance or repair. The module shall have an MTBF of >100,000 hours and operate in an environment of -40° C to +74° C and relative humidity between 0% to 95% (non-condensing). The module shall be UL and ULC listed and . The circuit board shall be UL 94 flame rated and meet all PCI standards. All PC boards shall be designated with part number, PC board number and show appropriate revision number. Housing shall be of all metal construction. All LED indicators and both electrical and mechanical connections shall be identified with silk-screened labels. The module shall have a lifetime warranty to reduce system life cycle cost in an event of a module failure.

2.04 VIDEO SPECIFICATIONS

- A. Output Video: 1 volt pk-pk (75 ohms)
B. Bandwidth: 5 Hz – 10 MHz
C. Differential Gain: < 5 %
D. Differential Phase: < 5 °
E. Tilt: <1%
F. Signal/Noise Ratio: 60dB

2.05 OPTICAL SPECIFICATIONS

- A. IFS Model Number VR1100
 - 1. Optical Fiber: 62.5/125 micron multimode
 - 2. Number of Fibers Required: 1
 - 3. Optical Wavelength: 850nm
 - 4. Optical Receiver Type: 850nm Pin Diode
 - 5. Optical Attenuation: No manual adjustments required

2.06 STATUS INDICATORS

- A. Power: On/Red – Off/Off
- B. AGC (automatic gain control): AGC/Yellow – No AGC/Off

2.07 CONNECTORS

- A. Optical: ST
- B. Power: Terminal Block with Screw Clamps
- C. Video: BNC (Gold Plated Center-PIN)

2.08 ELECTRICAL SPECIFICATIONS

- A. Power: 12VDC
- B. Current Protection: Automatic re-settable solid-state current limiters
- C. Voltage Regulation: Solid-state, Independent on each board
- D. Circuit Board: UL 94 flame rated and meets all PCI standards.
- E. Rack mount Card: Shall be hot-swappable with IFS Model Number R3 (EIA 19" card cage)

2.09 MECHANICAL SPECIFICATIONS

- A. Surface Mount Dimensions: 7.1" x 4.9" x 1.0" (18.00 cm x 12.45 cm x 2.54 cm)
- B. Rack Mount Dimensions: 7.7" x 5.0" x 1.0" (19.56 cm x 12.70 cm x 2.54 cm)
- C. Number of Rack Slots: 1
- D. Finish: Module shall be constructed of a metal enclosure with a powder coat finish model Number F63B12 with all connections and indicators silk-screened directly on unit. Rack mount units shall be constructed of anodized aluminum.
- E. Weight: <2.0 lbs./1.0kg

2.10 ENVIRONMENTAL SPECIFICATIONS

- A. MTBF: >100,000 Hours
- B. Operating Temp: -40° C to +74° C
- C. Storage Temp: -40° C to +85° C
- D. Relative Humidity: 0% to 95% (non-condensing). If product is installed under condensation conditions, unit shall have conformal coating applied to the printed circuit board. (Add -C to model number for conformal coated printed circuit board)

2.11 REGULATORY AGENCIES/APPROVALS AND LISTINGS

- A. Underwriters Laboratory (UL) Listing Number: I.T.E. 6D16
- B. Underwriters Laboratory Canada (ULC) Listing Number: I.T.E. 6D16
- C. UL 94-flame rated PCB board: 94VO
- D.

2.12 ACCESSORIES

- A. Card Cage: IFS Model Number R3 (EIA 19" card cage) shall be available to house and power rack mount modules.
- B. Blank Panels: IFS Model Number R3-BP shall be available to cover unused rack slots.

PART 3 - EXECUTION

3.01 EXAMINATION

- A. Inspect modules before installation.
- B. Modules shall be free of any cosmetic defects or damage.
- C. All optical connectors shall be covered with dust caps and remain on the module until installing cable connectors to module.
- D. Shipping box shall include the module, power supply and operations manual.

3.02 PREPARATION

- A. Standalone Module (Surface Mount)
 - 1. Shall be mounted on a properly prepared surface adequate for the size and weight of module. The placement of the unit shall allow provision for cable installation and maintenance as indicated on the approved detail drawings and in compliance with the IFS mounting template and installation manual.
- B. Rack Mount Module (19" Rack)
 - 1. Shall be installed in the IFS Model Number R3 card cage. Ensure the card cage is installed in a standard EIA 19" (482.6 mm) rack or wall standoff bracket adequate for the size and weight of the card cage. The placement of the unit shall allow provision for cable installation and maintenance as indicated on the approved detail drawings and in compliance with the IFS installation manual.
- C. Optical Fibers
 - 1. Caution: NEVER look into the end of an active optical fiber when using laser light output. Eye damage can occur. Wear eye protection when cleaving, terminating, and splicing fiber.
 - 2. The number and type (multimode or single-mode) of optical fiber shall meet the requirements of the IFS model number in article 2.05 used in the installation.
 - 3. All optical fiber cables shall be properly installed and terminated with the mating optical connectors as submitted in article 2.07 (A).
 - 4. The optical link shall be tested with either a power meter, at a minimum, or OTDR to ensure the link budget (overall path loss) plus an added 3dB of optical safety margin does not exceed the optical power budget as submitted in article 2.05.
 - 5. All optical connectors on cable shall be cleaned in compliance to optical connector manufactures specifications and covered

with dust caps until connection to the fiber optic module.

3.03 INSTALLATION

- A. General: Locate fiber optic modules as indicated on the approved detail drawings and install module in compliance with the IFS installation and operations manual.

3.04 TESTING

- A. Testing the Fiber Optic Video Link.
 - 1. Verify that the coax and optic fibers are properly connected.

- 2. Make sure that power is applied to all fiber optic modules, camera, and video monitor or other equipment used in the system.
- 3. The level detect indicator LED should be lit confirming a presence of a video signal.
- 4. Successful video link operation should be visible at this point as witnessed by a good quality video picture on the monitor.

3.05 CLEANING

- A. Follow all instructions for proper use of solvents and adhesives used for termination and splicing.
- B. At completion of the installation, dispose of all fiber scraps properly.

MANUFACTURED UNITS REFERENCE TABLES

Table A: Product Number Descriptions

VR1100 SERIES	DESCRIPTION
VR1100	MM – 850 > Video, 1 Fiber
VR1100-R3	MM – 850 > Video, 1 Fiber, Rack Mount

Table B: Product Compatibility Chart

RECEIVER	COMPATIBLE TRANSMITTERS
VR1100	VT1101M, VT1001, VT1001-R3, VT1000AC
VR1100-R3	VT1101M, VT1001, VT1001-R3, VT1000AC

END OF SECTION
