GuardLogix

SAFETY FUNCTION DOCUMENTS

NHP

Emergency Stop





Safety Function: Emergency Stop Products: GuardLogix® Series Connection of E-stops

Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008





Table of Contents:

| Introduction | 6-121 |
|----------------------------------|-------|
| Important User Information | 6-121 |
| Safety Function Realization | 6-122 |
| General Safety Information | 6-122 |
| Setup and Wiring | 6-123 |
| Configuration | 6-124 |
| Programming | 6-128 |
| Falling Edge Reset | 6-129 |
| Verification and Validation Plan | 6-131 |
| Additional Resources | 6-134 |





Safety Function: Emergency Stop Products: GuardLogix[®] Series Connection of E-stops

Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008

Introduction

This Safety Function application note explains how to wire, configure, and program a Compact GuardLogix[®] controller and POINT Guard I/O[™] module to monitor a series of dual-channel safety E-stop devices. If any of the E-stops is actuated or a fault is detected in the monitoring circuit, the GuardLogix controller de-energizes the final control device, in this case, a redundant pair of 100S contactors.

This example uses a Compact GuardLogix controller, but is applicable to any GuardLogix controller.

Important User Information

Solid state equipment has operational characteristics differing from those of electromechanical equipment. Safety Guidelines for the Application, Installation and Maintenance of Solid State Controls (publication SGI-1.1 available from your local Rockwell Automation[®] sales office or online at http://www. rockwellautomation.com/literature) describes some important differences between solid state equipment and hard-wired electromechanical devices. Because of this difference, and also because of the wide variety of uses for solid state equipment, all persons responsible for applying this equipment must satisfy themselves that each intended application of this equipment is acceptable.

In no event will Rockwell Automation, Inc. be responsible or liable for indirect or consequential damages resulting from the use or application of this equipment.

The examples and diagrams in this manual are included solely for illustrative purposes. Because of the many variables and requirements associated with any particular installation, Rockwell Automation, Inc. cannot assume responsibility or liability for actual use based on the examples and diagrams.

No patent liability is assumed by Rockwell Automation, Inc. with respect to use of information, circuits, equipment, or software described in this manual.

Reproduction of the contents of this manual, in whole or in part, without written permission of Rockwell Automation, Inc., is prohibited.




Safety Function: Emergency Stop Products: GuardLogix® Series Connection of E-stops

Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008

Safety Function Realization: Risk Assessment

The required performance level is the result of a risk assessment and refers to the amount of the risk reduction to be carried out by the safety-related parts of the control system. Part of the risk reduction process is to determine the safety functions of the machine. For the purposes of this document the assumed required performance level is Category 3, PLd.



Emergency Stop Safety Function

Emergency stop by actuation of an emergency stop push button.

Safety Function Requirements

Pressing of any one of the series wired E-Stops will stop and prevent hazardous motion by removal of power to the motor. Upon resetting the E-Stop pushbutton, hazardous motion and power to the motor will not resume until a secondary action (start button depressed) occurs. Faults at the E-Stop button, wiring terminals or safety controller will be detected before the next safety demand. This Emergency Stop function is complementary to any other safeguards on the machine and shall not reduce the performance of other safety related functions. The safety function in this example is capable of connecting and interrupting power to motors rated up to 9A, 600VAC.

The safety function will meet the requirements for Category 3, Performance Level "d" (Cat 3, PLd), per ISO 13849-1, and SIL3 per IEC 62061, and control reliable operation per ANSI B11.19.

Throughout this manual, when necessary, we use notes to make you aware of safety considerations.

| \bigwedge | WARNING: Identifies information about practices or circumstances that can cause an explosion in a hazardous environment, which may lead to personal injury or death, property damage, or economic loss. |
|-------------|--|
| IMPORTANT | Identifies information that is critical for successful application and understanding of the product. |
| \bigwedge | ATTENTION: Identifies information about practices or circumstances that can lead to personal injury or death, property damage, or economic loss. Attentions help you identify a hazard, avoid a hazard, and recognize the consequence. |
| \bigwedge | SHOCK HAZARD: Labels may be on or inside the equipment, for example, a drive or motor, to alert people that dangerous voltage may be present. |
| | BURN HAZARD: Labels may be on or inside the equipment, for example, a drive or motor, to alert people that surfaces may reach dangerous temperatures. |

General Safety Information

Contact Rockwell Automation to find out more about our safety risk assessment services.

| IMPORTANT | This application example is for advanced users and assumes that you are trained and experienced in safety system requirements. |
|-------------------|--|
| $\mathbf{\nabla}$ | ATTENTION: A risk assessment should be performed to make sure all task and hazard combinations have been identified and addressed. The risk assessment may require additional circuitry to reduce the risk to a tolerable level. Safety circuits must take into consideration safety distance calculations which are not part of the scope of this document. |



Safety Function: Emergency Stop Products: GuardLogix[®] Series Connection of E-stops

Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008

Functional Safety Description

Hazardous motion is interrupted or prevented by actuation of any emergency stop pushbutton (ES1, ES2 or ES3). Each E-Stop is considered a separate safety function. The E-stop pushbuttons are connected in series to a pair of safety inputs of a Safety Input module (SI1). The safety contactors (K1 & K2) are connected to a pair of safety outputs of a Safety Output module (SO1). The I/O modules are connected via CIP Safety over an EtherNet/ IP network to the Safety Controller (SC1). The safety code in SC1 monitors the status of the E-Stop pushbuttons using a pre-certified safety instruction named Dual Channel Input Stop (DCS). When all conditions are satisfied, no faults are detected on the input modules, and the reset push button is pressed, a second certified function block called Configurable Redundant Output (CROUT) checks the status of the final control devices, a pair of 100S redundant contactors. The controller then issues an output signal to the safety output module (SO1) to switch ON a pair of outputs to energize the safety contactors.

Bill of Material

This application example uses these components.

| Cat No. | Description | Qty |
|--------------------|--|-----|
| 800FM- MT34MX02 | 800F Non-illuminated Mushroom Operators, Twist To Release, 30 mm, Round Metal, Red, Metal Latch Mount, 2 N.C. Contact(S) | 3 |
| 800FM-G611MX10 | 800F Reset Push Button - Metal, Guarded, Blue, R, Metal Latch Mount, 1 N.O. Contact(S), Standard | 1 |
| 100S-C09ZJ23C | Bulletin 100S-C - Safety Contactors | 2 |
| 1768-ENBT | CompactLogix™ EtherNet/IP Bridge Module | 1 |
| 1768-L43S | Compact GuardLogix Processor, 2.0 MB standard memory, 0.5 MB safety memory | 1 |
| 1768-PA3 | Power Supply, 120/240 VAC Input, 3.5 A @ 24V DC | 1 |
| 1769-ECR | Right End Cap/Terminator | 1 |
| 1734-AENT | 24V DC Ethernet Adapter | 1 |
| 1734-TB | Module Base with Removable IEC Screw Terminals | 4 |
| 1734-IB8S | POINT Guard Safety Input Module | 1 |
| 1734-0B8S | POINT Guard Safety Output Module | 1 |
| 1783-US05T | Stratix 2000™ Unmanaged Ethernet Switch | 1 |

Setup and Wiring

For detailed information on installing and wiring, refer to the product manuals listed in the Additional Resources.

System Overview

The 1734-IB8S input module monitors the inputs from the E-stops, which are connected in series. This method conserves the number of inputs that are used, but reduces the granularity of system diagnostics. Typically E-stops are not operated as often as a safety gate, for example; therefore the need to connect each E-stop contact into its own dedicated input is reduced.

An E-stop is considered to be a complementary safety device.

EN 12100-2 5.5.1 provides details on complementary protective measures. These are measures which are neither inherently safe design nor safeguarding, but are required due to intended use or reasonably foreseeable misuse of the machine. The circuit is tested by using test pulses (T0 and T1) on the inputs, 10 and 11. These test pulses source the 24V DC for the circuit. By periodically dropping the 24V DC to OV DC, it is possible to detect cross-channel faults and shorts to an external 24V DC. Shorts to 0V DC will be seen as an open circuit by the input and will be detected by either the hardware, if configured to detect discrepancy errors, or by the appropriate safety function block in the application code.


The final control device in this case is a pair of 100S safety contactors, K1 and K2. The contactors are controlled by a 1734-OBS safety output module. These are wired in a redundant configuration and are tested on start up for faults. The start-up test is accomplished by using a CROUT instruction to monitor the feedback circuit into input 7 (I7) before the contactors are energized. The system is reset by means of the momentary push button, PB1.



Safety Function: Emergency Stop Products: GuardLogix[®] Series Connection of E-stops

Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008

Electrical Schematic



Configuration

The Compact GuardLogix controller is configured by using RSLogix[™] 5000 software, version 17 or later. You must create a new project and add the I/O modules. Then, configure the I/O modules for the correct input and output types. A detailed description of each step is beyond the scope of this document. Knowledge of the RSLogix programming environment is assumed.


Configure the Controller and Add I/O Modules

Follow these steps.

1. In RSLogix 5000 software, create a new project.

| pr. | 1768L435 CompactLogi/53435 Safety Controller | OK. |
|---------------|--|--------|
| evisiori | 18 | Cancel |
| | F Ridden France | Help |
| ine: | GEX | _ |
| exception | 3 | |
| | 21 | |
| (iiii) Type : | (Israel) | |
| a), | Safety Patrice SCA: Setemptin | |

2. In the Controller Organizer, add the 1768-ENBT module to the 1768 Bus.





Safety Function: Emergency Stop Products: GuardLogix[®] Series Connection of E-stops

Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008

Configure the Controller and Add I/O Modules (cont)


3. Select the 1768-ENBT module and click OK.

| No | Description | Vendor |
|--|---|------------------------------|
| Communications 1768-CH8/A 1768-CH8/A | 1768 Controlliet Bridge 1768 Controlliet Bridge, Redundent Vieda | Alen-Bradiey Alen-Bradier |
| EXAMPLETA EAST-ENERTA Notion | LXM 10,100 Hope Ethernet Bridge, Treated Par Ho LXM 10,000 Hope Ethernet Bridge Treatment Free | |
| | | |

4. Name the module, type its IP address, and click OK. We used 192.168.1.8 for this application example. Yours may be different.

| Type: Vervilor | 1769 ENBTJA 1768 10/100 M Twated Pas Media Allen Brades | |
|-------------------|---|--------------------------------------|
| Parent: Later | Local [Det | Addess / Host Name |
| Desception | - | F IP Addess 188 1 8 |
| | | - C Hot Nave |
| Sec. | 1 4 | |
| Revision | F 1 3 | Electronic Keyleg Compatible Keyling |

5. Add the 1734-AENT adapter by right-clicking the 1768-ENBT module in the Controller Organizer and choosing New Module.



6. Select the 1734-AENT adapter and click OK.

| Module GD Co | ine contañacia | Description | Vendor |
|-----------------|--|--|---|
| | 2734-4251 1734-425118 1738-42517 1738-42517 1736-45128 1736-451278 1736-451278 1736-451278 1736-451274 1736-45427/8 1736-45427/8 | 1334 Ethernet Adapter, Twisted Par Meda 1734 Ethernet Adapter, 2 4Port, Twisted Par Meda 1738 Ethernet Adapter, Twisted Par Meda 1738 Ethernet Adapter, 2 4Port, Twisted Par Meda 1736 5 10/100 Mops Ethernet Bridge, Piber Meda 1756 30/100 Mops Ethernet Bridge, 2 4Port, Twisted Par 1756 30/100 Mops Ethernet Bridge, 2 4Port, Twisted Par 1756 50/100 Mops Ethernet Bridge, 2 4Port, Twisted Par 1756 50/100 Mops Ethernet Bridge, 2 4Port, Twisted Par 1756 Billionet Communication Interface 1756 Ethernet Communication Interface 1756 Ethernet Communication Interface | Mon-Bradey Alen-Bradey Alen-Bradey Alen-Bradey Alen-Bradey Alen-Bradey Alen-Bradey Alen-Bradey Alen-Bradey Alen-Bradey Alen-Bradey Alen-Bradey |
| | | Fed | Add Fevorke |

 Name the module, type its IP address, and click OK. We used 192.168.1.11 for this application example. Yours may be different.

| - | ENDT | | Elforent Addee | | 3 |
|--|------|---|--------------------------------|----|---|
| esplose octube Deter evenue: lectores: Ka science: Scie resson Dice | Ag. | 21 Compatible Ho Racis Cutimitie 1 | C Pladens C Hat Name Ske | (i | |
| | | | | | |

8. Click Change.



Safety Function: Emergency Stop Products: GuardLogix[®] Series Connection of E-stops


Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008

Configure the Controller and Add I/O Modules (cont)

9. Set the Chassis Size as 3 for the 1734-AENT adapter and click OK. Chassis size is the number of modules that will be inserted in the chassis. The 1734-AENT adapter is considered to be in slot 0, so for one input and one output module, the chassis size is 3.

| Hodule Definition* | | × |
|--------------------------------|-------------------|---|
| Revision: Electronic Keying | 3 1 1 | × |
| Connection: Chassis Size: | Rack Optimization | ÷ |
| | | ; |
| OK. | Cancel Help | |

10. In the Controller Organizer, right-click the 1734-AENT adapter and choose New Module.



11. Expand Safety, select the 1734-IB8S module, and click OK.

| | Nendar. | Description | otule 1) Antokia 3) Digital |
|-------------|----------------------------|-------------|-----------------------------------|
| | Aler-Brader Aler-Brader | | - Safety - 173+885 |
| Fed. 1975 | Fed. Statistics | | |

12. In the New Module dialog box, name the device 'CellGuard_1' and click Change.

| | US WILL THIN 24YOC SHI PAM | | |
|----------------|--------------------------------|---------------|-------------------------------|
| | in Bader | | |
| | Ref | | |
| - 3 | dine. | Malain Taraha | 1 - |
| ister T | - | Select Tensor | 1349,293,000 |
| | -1 | Surfar | S-RE-SERVICE TO BRIDE TELEVIS |
| | | | The second second second |
| Andre Delt-Mor | A Date | 1 | |
| WIND: | Contraction of the second | | |
| bellene Bayry | Crystee Hote | 52.1 | |
| taidgamenty. | The Contrase | - | |
| and Delter | Selling . | | |
| MOUTOWN: | 760 | | |
| whell Status | Contineer Status Prover Hubing | - | |

13. When the Module Definition dialog box opens, change the Input Status to Combined Status-Power, and click OK.



- 14. Close the Module Properties dialog box by clicking OK.
- 15. Repeat steps 10-14 to add the 1734-OB8S safety output module.



Safety Function: Emergency Stop Products: GuardLogix[®] Series Connection of E-stops

Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008


Configure the I/O Modules

Follow these steps to configure the POINT Guard I/O modules.


- 1. In the Controller Organizer, right-click the 1734-IB8S module and choose Properties.
- 2. Click Input Configuration and configure the module as shown.



3. Click Test Output and configure the module as shown.



- 4. Click OK.
- 5. In the Controller Organizer, right-click the 1734-OB8S module and choose Properties.
- 6. Click Output Configuration and configure the module as shown.



7. Click OK.



Safety Function: Emergency Stop Products: GuardLogix[®] Series Connection of E-stops


Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008

Programming

The Dual Channel Input Stop (DCS) instruction monitors dualinput safety devices whose main function is to stop a machine safely, for example, an E-stop, light curtain, or safety gate. This instruction can only energize Output 1 when both safety inputs, Channel A and Channel B, are in the active state as determined by the Input Type parameter, and the correct reset actions are carried out. The DCS instruction monitors dual-input channels for consistency (Equivalent – Active High) and detects and traps faults when the inconsistency is detected for longer than the configured Discrepancy Time (ms). The Configurable Redundant Output (CROUT) instruction controls and monitors redundant outputs. The reaction time for output feedback is configurable. The instruction supports positive and negative feedback signals.

The safety application code in the safety output routine prevents outputs from restarting if the input channel resets automatically, providing anti-tiedown functionality for the Circuit Reset.

The Input OK status is used as a permissive in the safety output routines.





Safety Function: Emergency Stop Products: GuardLogix[®] Series Connection of E-stops

Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008

Falling Edge Reset

ISO 13849-1 stipulates that instruction reset functions must occur on falling edge signals. To comply with this requirement, add a One Shot Falling instruction to the rung immediately preceding the Cmd_Zone1_OutputEnable rung, Then use the OSF instruction Output Bit tag as the reset bit for the following rung. The Cmd_Zone1_OutputEnable is then used to Enable the CROUT instruction.

Modify the reset code as shown below.

| Whi, Zonet JFallingEage Zonet_ISAM.01 Zonet_KHK2FP | Oni_Zoni1_OutputEni |
|--|--|
| Crist_Zonet_CoutoutEnable | |
| | CROUT |
| | CROUT Zonet_K1K2 -(01 |
| | Feedback Type NEOATIVE Feedback Reaction Time (Maec) 500 -(0) |


Calculation of the Performance Level

When configured correctly, the safety system can achieve a safety rating of PLd, Cat. 3 according to EN ISO 13849.1 2008.

The Functional Safety Specifications of the project call for a Performance Level on PLd (minimum) and a structure of Cat 3 (minimum). A PFHd of less than 1.0 E-06 for the overall safety function is required for PLd.

| Modu | e Properties: AENT:1 (1734- | 1885 1.1) | |
|-------|----------------------------------|------------------------------|-------------|
| Genet | al Connection Salety Modul | e Info Input Configuration | Test Output |
| Poin | Point Mode | | |
| 0 | Not Used | | |

When modeled in SISTEMA, each safety E-stop string is treated as an individual safety function and can be modeled as follows. This diagram shows a single E-stop safety function.





Safety Function: Emergency Stop Products: GuardLogix[®] Series Connection of E-stops

Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008

Calculations are based on 1 operation of the E-stop per month, with 12 operations per year; therefore 36 operations of contactors per year.

The Diagnostic Coverage (Dcavg) is reduced to 60% for the E-stops because they are connected in series.

The measures against Common Cause Failure (CCF) are quantified using the scoring process outlined in Annex F of ISO 13849-1. For the purposes of the PL calculation, the required score of 65 needed to fulfill the CCF requirement is considered to be met. The complete CCF scoring process must be done when implementing this example.

| SB Estop 1 | | |
|------------|----------------|--|
| PL | d | |
| PFH [1/h] | 1.01E-7 | |
| Cat. | 3 | |
| MTTFd [a] | 100 (High) | |
| DCavg [%] | 60 (Low) | |
| CCF | 65 (fulfilled) | |

| 5B Safety I/O: 1734-IB8S | | |
|--------------------------|--------------|--|
| PL | e | |
| PFH [1/h] | 2.25E-10 | |
| Cat. | 4 | |
| MTTFd [a] | not relevant | |
| DCavg [%] | not relevant | |
| CCF | not relevant | |
| | | |

| Safety PLC: Compact GuardLogix 1768 | | | |
|-------------------------------------|--------------|--|--|
| PL | e | | |
| PFH [1/h] | 2.1E-10 | | |
| Cat. | 4 | | |
| MTTFd [a] | not relevant | | |
| DCavg [%] | not relevant | | |
| CCF | not relevant | | |

| Safety I/O: 1734-0885 | | |
|-----------------------|--------------|--|
| PL | e | |
| PFH [1/h] | 2.29E-10 | |
| Cat. | 4 | |
| MTTFd [a] | not relevant | |
| DCavg [%] | not relevant | |
| CCF | not relevant | |

| 58 Contactors | | |
|---------------|----------------|--|
| PL | e | |
| PFH [1/h] | 2.47E-8 | |
| Cat. | 4 | |
| MTTFd [a] | 100 (High) | |
| DCavg [%] | 99 (High) | |
| CCF | 65 (fulfilled) | |



Safety Function: Emergency Stop Products: GuardLogix[®] Series Connection of E-stops

Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008

Verification and Validation Plan

Verification and Validation play an important role in the avoidance of faults throughout the safety system design and development process. ISO/EN 13849-2 sets the requirements for verification and validation. It calls for a documented plan to confirm all the Safety Functional Requirements have been met.

Verification is an analysis of the resulting safety control system. The Performance Level (PL) of the safety control system is calculated to confirm it meets the Required Performance Level (PLr) specified. The SISTEMA software tool is typically utilized to perform the calculations and assist with satisfying the requirements of ISO 13849-1.

Validation is a functional test of the safety control system to demonstrate that it meets the specified requirements of the safety function. The safety control system is tested to confirm all of the safety related outputs respond appropriately to their corresponding safety related inputs. The functional test should include normal operating conditions in addition to potential fault inject of failure modes. A checklist is typically used to document the validation of the safety control system.

Validation of software development is a process in which similar methodologies and techniques that are used in hardware development are deployed. Faults created through poor software development process and procedure are systemic in nature rather than faults associated with hardware which are considered as random.

Prior to validating the GuardLogix Safety System, it is necessary to confirm the safety system and safety application program have been designed in accordance with the GuardLogix System Safety Reference Manual (1756-RM093) and the GuardLogix Application Instruction Safety Reference Manual (1756-RM095).



Safety Function: Emergency Stop Products: GuardLogix[®] Series Connection of E-stops

Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008

Verification and Validation Checklist

| | | GENERAL MACHINERY INFORMATION | | |
|----------------|--|--|----------------|-------------------------|
| Machine Name | / Model Number | | | |
| Machine Serial | Number | | | |
| Customer Nam | e | | | |
| Test Date | | | | |
| Tester Name(s) | | | | |
| Schematic Dra | wing Number | | | |
| Controller Nam | 1e | | | |
| Safety Signatu | re ID | | | |
| Safety Networ | k Number(s) | | | |
| RSLogix5000 S | oftware Version | | | |
| Safety Contr | ol System Modules | GuardLogix Modules | | Firmware Version |
| GuardLogix Sa | fety Controller | 1768-L43S | | |
| CompactLogix | Ethernet Bridge | 1768-ENBT | | |
| POINT I/O Ethe | rnet Adapter | 1734-AENT | | |
| POINT I/O Inpu | t Modules | 1734-IB8S | | |
| POINT I/O Outp | out Modules | 1734-0885 | | |
| | | GuardLogix Safety System Configuration and Wiring Verification | | |
| Test Step | | Verification | Pass/Fail | Changes/Modifications |
| 1 | Verify the safety system | has been designed in accordance with the GuardLogix System Safety Reference Manual 1756-RM093. | | |
| 2 | | Verify the safety application program has been designed in accordance with the GuardLogix Application Instruction Safety Reference Manual 1756-RM095. | | |
| 3 | Visually inspect the safe | ty system network and I/O is wired as documented in the schematics. | | |
| 4 | Visually inspect the RSLogix 5000 program to verify that the safety system network and I/O module configuration is configured as documented. | | | |
| 5 | Visually inspect the RSLogix 5000 application program to verify suitable safety certified instructions are utilized. The logic is readable, understandable and testable with the aid of clear comments. | | | |
| 6 | All input devices are qualified by cycling their respective actuators. Monitor the status in the RSLogix 5000 Controller Tags window. | | | |
| 7 | All output devices are qualified by cycling their respective actuators. Monitor the status in the RSLogix 5000 Controller Tags window. | | | |
| | Normal Operation Ve | rification - The GuardLogix safety system properly responds to all normal Start, Stop, Estop | p, Lock and Re | set Commands |
| Test Step | | Verification | Pass/Fail | Changes/Modifications |
| 1 | Initiate a Start Command. Both contactors should energize for a normal machine run condition. Verify proper machine status indication and RSLogix 5000 safety application program indication. | | | |
| 2 | Initiate a Stop Command. Both contactors should de-energize for a normal machine Stop condition. Verify proper machine status indication and RSLogix 5000 safety application program indication. | | | |
| 3 | While Running, press the E-Stop pushbutton. Both contactors should remain de-energized and open for a normal safe condition. Verify proper machine status indication and RSLogix 5000 safety application program indication. Repeat for all E-Stop pushbuttons. | | | |
| 4 | While Stopped, press the E-Stop pushbutton and initiate a Start Command. Both contactors should remain de-energized and open for a normal safe condition. Verify proper machine status indication and RSLogix 5000 safety application program indication. Repeat for all E-Stop pushbuttons. | | | |
| 5 | Initiate Reset Command. Both contactors should remain de-energized. Verify proper machine status indication and RSLogix 5000 safety application program indication. | | | |



Safety Function: Emergency Stop Products: GuardLogix[®] Series Connection of E-stops

Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008

Verification and Validation Checklist

| | Abnormal Operation Verification - The GuardLogix safety system properly responds to all foreseeable faults with corresponding diagnostics. E-Stop Input Tests | | | |
|-----------|--|-----------|-----------------------|--|
| Test Step | Validation | Pass/Fail | Changes/Modification | |
| 1 | While Running, remove the Channel 1 wire from the Safety I/O. Both contactors should de-energize. Verify proper machine status indication and RSLogix 5000 safety application program indication. Restore Channel 1 and repeat for Channel 2. | | | |
| 2 | While Running, short the Channel 1 of the Safety I/O to +24VDC. Both contactors should de-energize. Verify proper machine status indication and RSLogix 5000 safety application program indication. Verify unable to reset and restart with fault. Restore Channel 1 and repeat for Channel 2. | | | |
| 3 | While Running, short the Channel 1 of the Safety I/O to (-) 0VDC. Both contactors should de-energize. Verify proper machine status indication and RSLogix 5000 safety application program indication Restore Channel 1 and repeat for Channel 2. | | | |
| 4 | While Running, short the Channels 1 & 2 of the Safety I/O. Both contactors should de-energize. Verify proper machine status indication and RSLogix 5000 safety application program indication. Restore Channel 1 & 2 wiring. | | | |
| | GuardLogix Controller and Network Tests | | | |
| Test Step | Validation | Pass/Fail | Changes/Modifications | |
| 1 | While Running, remove the Ethernet network connection between the Safety I/O and the controller. All contactors should de-energize. Verify proper machine status indication and I/O Connection Status in the RSLogix 5000 safety application program. | | | |
| 2 | Restore the Safety I/O module network connection and allow time to reestablish communication. Verify the Connection Status Bit in the RSLogix 5000 safety application program. Repeat for all Safety I/O connections. | | | |
| 3 | While Running, switch the controller out of Run Mode. All contactors should de-energize. Return key switch back to Run Mode, all contactors should remain de-energized. Verify proper machine status indication and RSLogix 5000 safety application program indication. | | | |
| | Safety Contactor Output Tests | | | |
| Test Step | Validation | Pass/Fail | Changes/Modifications | |
| 1 | Initiate a Start Command. Both contactors should energize for a normal machine run condition. Verify proper machine status indication and RSLogix 5000 safety application program indication. | | | |
| 2 | While Running, remove the contactor feedback from the Safety I/O. All contactors should remain energized. Initiate a Stop command and attempt a Reset command. The system should not Restart or Reset. Verify proper machine status indication and RSLogix 5000 safety application program indication. | | | |
| 3 | While Running, short the contactor feedback to the Safety I/O. All contactors should remain energized. Initiate a Stop command and attempt a Reset command. The system should not Restart or Reset. Verify proper machine status indication and RSLogix 5000 safety application program indication. | | | |



Safety Function: Emergency Stop Products: GuardLogix[®] Series Connection of E-stops

Safety Rating: PLd, Cat. 3 to EN ISO 13849.1 2008

Additional Resources

For more information about the products used in this example refer to these resources.

| Resource | Description |
|---|---|
| Compact GuardLogix Controllers User Manual, Publication <u>1768-UM002</u> | Provides information on configuring, operating, and maintaining Compact GuardLogix controllers. |
| POINT Guard I/O Safety Modules Installation and User Manual, Publication <u>1734-UM013</u> | Provides information on installing, configuring, and operating POINT Guard I/O Modules. |
| GuardLogix Controller Systems Safety Reference Manual, Publication <u>1756-RM093</u> | Contains detailed requirements for achieving and maintaining safety ratings with the GuardLogix controller system. |
| GuardLogix Safety Application Instruction Set Reference Manual, Publication <u>1756-RM095</u> | Provides detailed information on the GuardLogix Safety Application Instruction Set. |
| Safety Accelerator Toolkit for GuardLogix Systems Quick Start Guide, Publication IASIMP-QS005 | Provides a step-by-step guide to using the design, programming, and diagnostic tools in the Safety Accelerator Toolkit. |
| Safety Products Catalog | |

You can view or download publications at <u>http://www.rockwellautomation.com/literature</u>. To order paper copies of technical documentation, contact your local Allen-Bradley[®] distributor or Rockwell Automation sales representative.



Safety Function Document

Disclaimer

The information contained in this and any related publications is intended as a guide only. Every care has been taken to ensure that the information given is accurate at time of publication.

Neither NHP nor any of the manufacturers portrayed in this and any related publications accept responsibility for any errors or omissions contained therein nor any misapplications resulting from such errors or omissions.

Risk assessments should be conducted by authorized persons. The purchaser and installer are responsible for ensuring the safety system(s) incorporating these products complies with all current regulations and applicable standards.

Products are subject to change without notice and may differ from any illustration(s) provided. All products offered for sale are subject to NHP standard Conditions of Sale, a copy of which is available on application.