

ABAX WIRELESS SYSTEM CONTROLLER

ACU-250

WARNINGS

The device should be installed by qualified personnel.

Prior to installation, please read carefully this manual in order to avoid mistakes that can lead to malfunction or even damage to the equipment.

Disconnect power before making any electrical connections.

Changes, modifications or repairs not authorized by the manufacturer shall void your rights under the warranty.

The SATEL's goal is to continually upgrade the quality of its products, which may result in alterations of their technical specifications and firmware. The current information on the introduced modifications is available on our website.

Please visit us:
<http://www.satel.eu>

Hereby, SATEL sp. z o.o., declares that this device is in compliance with the essential requirements and other relevant provisions of Directive 1999/5/EC. The declaration of conformity may be consulted at www.satel.eu/ce

The following symbols may be used in this manual:



- note;



- caution.

CONTENTS

1. General	2
2. Features	2
3. Electronics board	2
4. Installation of the controller	2
5. Programming the controller	4
5.1 Parameters, options and functions	4
6. Wireless devices supported by the controller	6
7. Installation of wireless devices	6
7.1 Work with the INTEGRA / INTEGRA Plus control panels	7
7.1.1 Adding new wireless devices	9
7.1.2 Removing wireless devices	10
7.2 Work with the VERSA control panels	11
8. Programming the wireless devices	11
8.1 Parameters and options	11
8.2 Programming in the INTEGRA / INTEGRA Plus system	12
8.2.1 DLOADX program	12
8.2.2 LCD keypad	14
8.3 Programming in the VERSA system	14
8.3.1 DLOADX program	14
8.3.2 LCD keypad	14
9. Specific character of the operation of wireless devices	14
9.1 Wireless detectors	15
9.2 Wireless sirens	15
9.3 Wireless expanders of hardwired zones and outputs	16
9.4 230 V AC wireless controllers	17
10. APT-100 keyfobs	17
10.1 Keyfobs in the INTEGRA / INTEGRA Plus system	17
10.1.1 Adding the APT-100 keyfob by means of the DLOADX program	19
10.1.2 Removing the APT-100 keyfob by means of the DLOADX program	19
10.2 Keyfobs in the VERSA system	19
11. Specifications	20
12. Manual update history	21

1. General


The ACU-250 controller works with the INTEGRA, INTEGRA Plus and VERSA control panels. It enables expansion of the security alarm system by adding the ABAX wireless devices. The ABAX system is based on two-way communication. All transmissions are acknowledged, which ensures that the information has been received and makes it possible to check the presence of devices in the system in real time. Configuration of parameters and testing of the ABAX system wireless devices is performed by radio, so dismantling of their enclosures is unnecessary. Additionally, the controller allows you to operate the security alarm system, using the ABAX system two-way keyfobs.

2. Features

- Support for up to 48 ABAX system wireless devices (the number of supported devices depends on the control panel).
- Support for up to 248 APT-100 keyfobs (the number of supported keyfobs depends on the control panel).
- Two-way encrypted radio communication in the 868 MHz frequency band.
- Controller firmware update capability.
- Tamper protection in 2 ways – cover removal and tearing enclosure from the wall.

3. Electronics board

- ① terminals:
+12V - power input;
COM - common ground;
CLK - clock;
DAT - data.
- ② RS-232 port (TTL standard) to enable updating the controller firmware. The controller can be connected to the computer using the cables included in the DB9FC/RJ-KPL set, offered by SATEL.
- ③ tamper contact.
- ④ LED indicator of communication with the control panel:
– blinking – data exchange with the control panel;
– steady light – no communication with the control panel.
- ⑤ DIP-switch package for setting individual controller address.



4. Installation of the controller




Disconnect power before making any electrical connections.

The controller should be installed indoors, in spaces with normal air humidity. Prior to installation you should plan the arrangement of all ABAX system wireless devices which are to be operated by the controller. When selecting the controller installation place, make sure that all these devices will be located within its operating range. Remember that thick walls, metal partitions, etc. will reduce the range of the radio signal. It is recommended that the controller be mounted high above the floor. This will allow you to get a better range of radio communication and avoid the risk of the controller being accidentally covered by people moving around the premises. Mounting the controller near electrical installations is not advisable, as this may cause malfunction of the device.

Several ABAX wireless system controllers can work within each other's range. Automatic synchronization with the wireless systems already in use is always performed when the controller is switched on, and after each operation of addition/removal of supported devices. The number of wireless devices working within each other's range depends on the RESPONSE PERIOD (see section PARAMETERS, OPTIONS AND FUNCTIONS p. 4) and can vary from 150 to 450. The higher the response frequency, the lower the number of devices that can work within each other's range.

1. Open the enclosure of the controller (Fig. 2).
2. Make the opening in the enclosure base for the communication bus and power cables.
3. Pass the wires through the opening. It is recommended to use a straight-through unshielded cable. When using the twisted-pair type of cable, the CLK (clock) and DAT (data) signals must not be sent through one twisted pair.
4. Using wall plugs (screw anchors) and screws, fasten the enclosure base to the mounting surface.
5. Connect the CLK, DAT and COM terminals with wires to the communication bus of the control panel.
6. Connect the power leads to the +12 V and COM terminals. If the distance to the control panel is less than 300 meters, the controller can be supplied directly from the control panel. If the distance to the control panel is higher, the controller must be supplied from another power source, which is located at a closer distance (a power supply unit or an expander with power supply).
7. Using the DIP-switches, set the controller address. It must be different from that of the other modules connected to the communication bus. The address is a sum of numerical values set on the switches 1-5 (see Table 1). When the controller works with the VERSA control panel, address 8 must be set (switch 4 must be in ON position, the other switches in OFF position).



i When connecting the controller to the INTEGRA or INTEGRA Plus control panel to which the ABAX system controller is already connected, it is recommended that a higher address be set in the new controller than that in the controller already connected to the control panel.

DIP-switch number	1	2	3	4	5
Numerical value	1	2	4	8	16

Table 1. Numerical values corresponding to the switches set to ON position (in the OFF position, the value 0 is assigned to each switch).

8. Close the controller enclosure.
9. Turn on the power of the alarm system.
10. Start the identification function in the control panel.



The ACU-250 controller will be identified as ACU-100 and this name will be assigned to it by default by the control panel.

5. Programming the controller

Programming of the controller is carried out by means of the control panel, using:

- the LCD keypad in service mode:
 - INTEGRA / INTEGRA Plus – the controller programming functions are available in the SETTINGS submenu (▶STRUCTURE ▶HARDWARE ▶EXPANDERS ▶SETTINGS). Upon entering the submenu, a list of devices will be displayed. Using the ▼ and ▲ keys, find the controller name and press the # key to get access to the list of functions. To program the controller name, use the NAMES submenu (▶STRUCTURE ▶HARDWARE ▶EXPANDERS ▶NAMES).
 - VERSA – most of the controller parameters can be programmed in the 2. SETTINGS submenu (▶2. HARDWARE ▶1. KPDS & EXPS. ▶2. SETTINGS). Upon entering the submenu, a list of devices will be displayed. Using the ▼ and ▲ keys, find the controller name and press the # key to start the "step by step" programming. The functions to start synchronization and to enter / exit the test mode are available in the 3. WIRELESS MOD. submenu (▶2. HARDWARE ▶1. KPDS & EXPS. ▶3. WIRELESS MOD.).
- the DLOADX program:
 - INTEGRA / INTEGRA Plus – in the "Structure" window, "Hardware" tab, after clicking on the controller name in the list of devices (Fig. 3);
 - VERSA – in the "Versa – Structure" window, "Hardware" tab, after clicking on the controller name.

5.1 Parameters, options and functions

Name – individual name of device (up to 16 characters).


Tamper signaled in partition – the partition in which tamper alarm will be triggered in the event of module tamper.

No auto-reset after three module tamper alarms – it is possible to disable the feature limiting the number of tamper alarms from the expander to three (this feature prevents the same events from being repeatedly recorded and applies to consecutive, non-cleared alarms).

Response period – communication with wireless devices takes place in specified intervals. The controller is then gathering information on the status of wireless devices and, if necessary, sending commands to the devices, e.g. switching the detectors to their active/passive state, switching on/off the test mode and/or changing configuration of the devices. The response period can be 12, 24 or 36 seconds. The less often communication between the controller and the wireless devices takes place, the more wireless devices can work within each other's operating range (12 seconds – up to 150, 24 seconds – up to 300, 36 seconds – up to 450). Beyond the response period, information about tampers of devices and violations of detectors operating in active mode are sent to the controller. The response period has an effect on the level of energy consumption by the wireless devices. The less often communication between the controller and the wireless devices takes place, the lower energy consumption and the longer battery life are.



In the case of the AMD-103 detector, no communication takes place during polling.



Higher sensitivity for jamming detection – if this option is enabled, the sensitivity of detection of radio communication jamming is boosted.

Synchronize – this function starts the procedure of synchronization, i.e. checking for presence of other ABAX wireless system controllers working within the controller operating range. The controller will synchronize the response period so that the radio transmissions of some controllers should not be mutually jammed. Synchronization is performed automatically upon starting the controller and after each operation of adding/removing devices supported by it.

Test mode – in the ABAX system the test mode can be started, in which:

- LED indicators are enabled in the wireless devices (the LEDs are disabled during normal operation) – information provided by means of the LEDs depends on the device;
- signaling is blocked in the sirens.

The test mode is started/ended during polling, which results in a delay, its duration depending on the programmed response period. The test mode will be turned off automatically after 30 minutes of:

- starting the test mode from the DLOADX program (the 30-minute period is running from the moment of exiting the controller settings),
- exiting the service mode in the control panel.



According to requirements of the EN50131 standard, the level of radio signals sent by wireless devices is reduced during the test mode operation.

For the AMD-103 detector, entering the test mode remotely is not possible.

6. Wireless devices supported by the controller

Detectors

- AFD-100 – wireless water flood detector.
- AGD-100 – wireless glass-break detector.
- AMD-100 – wireless magnetic contact.
- AMD-101 – dual channel wireless magnetic contact.
- AMD-102 – wireless magnetic contact with input for roller shutter detector.
- AMD-103 – wireless magnetic contact.
- APD-100 – wireless passive infrared detector.
- APMD-150 – wireless dual motion detector.
- ARD-100 – wireless reorientation detector.
- ASD-110 – wireless smoke and heat detector.
- ATD-100 – wireless temperature detector [supported, if the controller works with the INTEGRA or INTEGRA Plus control panel].
- AVD-100 – wireless vibration detector and magnetic contact.

Sirens

- ASP-105 – wirelessly triggered outdoor siren.
- ASP-205 – wireless indoor siren.

Other

- ACX-200 – hardwired zone / output expander.
- ACX-201 – hardwired zone / output expander with power supply.
- ARF-100 – radio signal level tester.
- ARU-100 – radio signal repeater [supported, if the controller works with the INTEGRA or INTEGRA Plus control panel].
- ASW-100 E / ASW-100 F – 230 V AC wireless controller.

7. Installation of wireless devices

After the control panel has identified the controller, you can begin installation of the ABAX system wireless devices. Before installing a wireless device, check the level of radio signal received by the device from controller and by the controller from device at the planned installation place. The ARF-100 tester is a useful tool to check the signal level. The level of signal received by device/controller may not be lower than 40%. If the radio signal level at the planned installation place is too low, select another installation location. Sometimes it is sufficient to move the device ten or twenty centimeters to obtain a significant improvement of signal quality. You can install the device permanently only after reaching the optimum level of radio signal.

The wireless devices must be registered to the alarm system. This can be done using the LCD keypad or DLOADX program. The controller can support up to 48 wireless devices, but some devices take up more than one position on the list. For example, after adding to the system the ACX-200 expander module, which takes up 4 positions on the list of devices, the controller will still be able to handle 44 more wireless devices. The number of positions on the list is at the same time the number of zones and, in case of some devices, also outputs which will be taken by the device in the system.



The data relating to wireless devices are stored in the controller. If the controller with registered wireless devices is connected to the control panel, the wireless devices will be automatically assigned to the system zones/outputs during identification procedure.

7.1 Work with the INTEGRA / INTEGRA Plus control panels

The number of supported wireless devices depends on the control panel.

When adding and removing the wireless devices, remember that the identification function registers zones and outputs by groups of 8. Already after adding one wireless device which takes up 1 zone, the control panel will reserve 8 zones in the system for wireless devices. The LCD keypad makes it possible to select the zone to which that device will be assigned. Observe continuity, i.e. avoid leaving any gaps in the list, which will later reduce the number of available zones in the system. Remember to preserve continuity also when removing wireless devices. For example, if the devices registered in the controller occupy 9 positions on the list, then 16 zones (2x8) are reserved in the system. After removal of the device which occupied position 7 on the list, there will still be 16 zones (2x8) reserved in the system for wireless devices, although 8 positions are actually taken up on the list of wireless devices (see: Table 2). In such a case, it is recommended that the last devices be removed from the list and then added to the system again, so as to fill up the gap in the list and reduce the number of zones reserved for wireless devices.

ACU-100 / ACU-250		INTEGRA / INTEGRA Plus				
It..	list of devices	zones		outputs		
		No	device	No	device	
1	APD-100 detector	8	17	APD-100 detector	17	unused/unavailable
2	APD-100 detector		18	APD-100 detector	18	unused/unavailable
3	AMD-100 detector		19	AMD-100 detector	19	unused/unavailable
4	AMD-100 detector		20	AMD-100 detector	20	unused/unavailable
5	AMD-101 detector		21	AMD-101 detector	21	unused/unavailable
6	^		22	AMD-101 detector	22	unused/unavailable
7			23	unused/unavailable	23	unused/unavailable
8	ASP-105 siren		24	ASP-105 siren	24	ASP-105 siren
9	^	8	25	ASP-105 siren	25	ASP-105 siren
10			26	unused/unavailable	26	unused/unavailable
11			27	unused/unavailable	27	unused/unavailable
12			28	unused/unavailable	28	unused/unavailable
13			29	unused/unavailable	29	unused/unavailable
14			30	unused/unavailable	30	unused/unavailable
15			31	unused/unavailable	31	unused/unavailable
16			32	unused/unavailable	32	unused/unavailable


Table 2. An example of how the wireless devices should not be registered. For devices taking up 8 positions, the system must reserve 16 zones and 16 outputs, as well as 2 addresses.

ACU-100 / ACU-250		INTEGRA / INTEGRA Plus			
It.	list of devices	No	zones device	No	outputs device
1	ASP-105 siren	17	ASP-105 siren	17	ASP-105 siren
2	^	18	ASP-105 siren	18	ASP-105 siren
3	APD-100 detector	19	APD-100 detector	19	unused/unavailable
4	APD-100 detector	20	APD-100 detector	20	unused/unavailable
5	AMD-100 detector	21	AMD-100 detector	21	unused/unavailable
6	AMD-100 detector	22	AMD-100 detector	22	unused/unavailable
7	AMD-101 detector	23	AMD-101 detector	23	unused/unavailable
8	^	24	AMD-101 detector	24	unused/unavailable

Table 3. An example of how to correctly register the wireless devices (compare also Fig. 4). For 8 devices, the system has reserved 8 zones and 8 outputs, as well as 1 address.

In case of devices which, in addition to zones, also take up outputs, it is recommended that you add them to the system first. This will allow you to maintain the continuity of use of not the zones alone, but the outputs as well. Table 2 shows a situation in which the siren first output occupies position 8, and the second output – position 9. As a result, 16 outputs have been reserved for wireless devices in the system, though actually 2 outputs are used (the eighth output in the first group of 8 outputs and the first output in the second group of 8 outputs).

In some cases, the gaps in the list of zones/outputs cannot be avoided. It applies to situation when the number of zones/outputs, which is used by the devices, is not a multiple of 8.



For each group of 8 zones /outputs, one address on the expander bus is reserved. The controller can occupy from 1 to 6 addresses. This must be taken into account at the system design stage and sufficient number of free addresses must be left for the controller. If, when new wireless devices have been added to the controller, it turns out that next addresses are needed, and these are taken up by other devices, successful completion of the expander

identification procedure will be impossible. It will be necessary to change addresses of the devices connected to the bus.

7.1.1 Adding new wireless devices



For some wireless devices, you can select whether the device will take up one or two positions (channels) on the list of devices. Depending on the device, if one position is selected:

- AMD-102 – only additional inputs (roller shutter and NC) will be supported;
- ATD-100 – you will be able to program only one temperature threshold;
- AVD-100 – only the vibration detector will be supported.

DLOADX program

You can add wireless devices in the "Structure" window, "Hardware" tab, after clicking on the controller name in the list of devices. Before making any changes, click on the "Read" button, and after making the changes – on the "Write" button (the data relating to wireless devices

are not read and saved after clicking on the  button in the DLOADX program main menu).

1. Click on the "New device" button. The "New device" window will open.
2. Enter in the appropriate field the 7-digit serial number of the device you want to add. The serial number can be found on the electronics board or on the enclosure. Each ARF-100 radio signal level tester has serial number 0000500.
3. Depending on which device is to be added to the system:
 - power on the ACX-200 or ACX-201 expander module,
 - turn on the ARF-100 tester,
 - insert the ASW-100 E / ASW-100 F wireless controller into 230 V AC socket,
 - violate (open) the tamper contact in case of the other devices.

If an invalid serial number is entered, it will be indicated by a suitable message. In such a case, enter the correct serial number and repeat the above mentioned step.
4. The message will confirm that a new device has been added. It will be assigned to the first free zone from the pool reserved for the controller. A suggested name for that zone will appear (the name is editable). The name will be also assigned to the output, if the device is to be assigned to the output. For some devices, you can also select whether the device will take up one or two positions on the list of devices.
5. Click on the "OK" button to complete the procedure of adding a new device. You can cancel adding the new device by pressing the "Cancel" button. You can also press the "Next" button to immediately begin adding another wireless device.



Having added new wireless devices, start the expansion module identification function.

LCD Keypad

You can add wireless devices in service mode, using the NEW DEVICE function (►STRUCTURE ►HARDWARE ►EXPANDERS ►SETTINGS ►*controller name* ►NEW DEVICE).

1. Start the NEW DEVICE function.
2. Enter the device 7-digit serial number and press the # key. The serial number can be found on the electronics board or on the enclosure. Each ARF-100 radio signal level tester has serial number 0000500. If a device with the entered serial number is already registered, the keypad will not proceed to the next step of the procedure.

3. When the "Open device tamper" command is displayed:
 - power on the ACX-200 or ACX-201 expander module,
 - turn on the ARF-100 tester,
 - insert the ASW-100 E / ASW-100 F wireless controller into 230 V AC socket,
 - violate (open) the tamper contact in case of the other devices.

If the serial number of device to be added is not consistent with that previously entered, you will be informed about it by a suitable message. If this is the case, press the * key and then start the device adding procedure from the beginning.
4. The name and serial number of the new device will be displayed. Press the key 1 to proceed to the next step of the procedure (press another key to terminate the new device adding procedure).
5. A suitable message will inform you about the option, if any, whether the device will take up one or two positions (channels) on the list of devices. Press the key 1 to select one channel or press the key 2 to select two channels.
6. A list of system zones to which the device can be assigned will be displayed. Using the ▼ and ▲ keys, select one of them and press the # key (press the * key to terminate the new device adding procedure). If the device takes more than one position on the list of devices, additional zones, following the selected one, will be automatically assigned to the device.
7. A message will be displayed to inform you that the expander identification function has been started.
8. After identification of the devices, the keypad will display a suggested name for the zone to which the device is assigned. The name can be changed. The name will also be assigned to the output, if the device is to be assigned to the output. Press the # key to save the new name. Press the * key to terminate the name giving procedure (the zone will then be given a name consisting of the name and serial number of the device). If the device occupies more than one zone, this procedure is repeated for each zone.

7.1.2 Removing wireless devices

DLOADX program

You can remove wireless devices in the "Structure" window, "Hardware" tab, after clicking on the controller name in the list of devices.

1. Click on the list on the wireless device to be removed (if the device takes up some positions on the list, you can click on any of them).
2. Click on the "Remove device" button. The "Confirm" window will open.
3. Click on the "Yes" button. The device will be removed.



Having removed a wireless device, start the expansion module identification function.

LCD keypad

You can remove a wireless device in the service mode, using the REMOVE DEVICE function (►STRUCTURE ►HARDWARE ►EXPANDERS ►SETTINGS ►*controller name* ►REMOVE DEVICE).

1. Start the REMOVE DEVICE function.
2. Using the ▼ and ▲ keys, select from the list the device to be removed and then press the # key.
3. Press the key 1 to confirm that you want to remove the device (pressing another key will take you back to the wireless device selection list).

4. The device will be removed. A message on the display will inform you that the expander identification function has been started.
5. After identification of the devices, return to the list of wireless devices will follow.

7.2 Work with the VERSA control panels

The VERSA control panels can support up to 30 wireless devices. For information about operation of the ABAX system controller with the VERSA control panels, as well as adding and removing wireless devices, please refer to the installer manual of VERSA control panels.

8. Programming the wireless devices

8.1 Parameters and options

Filter – the number of consecutive response periods, during which communication with the device failed to be established, for the loss of communication with the device to be reported. Values from the 0 to 50 range can be entered. Entering the digit 0 will disable control of the device presence in the system.



In the case of the AMD-103 magnetic contact, the presence check is performed in a different way than for the other ABAX system devices. If the value programmed for the FILTER parameter differs from 0, the lack of presence will be reported if no transmission from the AMD-103 magnetic contact is received within one hour.

ARU – parameter available for a wireless device, if the ARU-100 repeater is registered in the controller (the controller is connected to the INTEGRA or INTEGRA Plus control panel). It allows you to define whether the device is to communicate to the controller directly, or via the selected ARU-100 repeater (several ARU-100 repeaters can be registered in the controller). The programming procedure is described in section PROGRAMMING IN THE INTEGRA / INTEGRA PLUS SYSTEM (p. 12).

Always active – the option is available for the most of wireless detectors. If enabled, the detector is permanently switched over to the active mode (see section WIRELESS DETECTORS p. 15).



The ALWAYS ACTIVE option need not be enabled for the wireless detectors assigned to the 24-hour zones and for the AMD-103 detector.

Configuration – some of the wireless devices provide additional parameters and options, which can be configured by radio (shown in square brackets is information on the zone for which additional parameters can be programmed, if the device takes up more than 1 zone):

AGD-100 – wireless glass-break detector. Sensitivity is to be programmed.

AMD-100 / AMD-101 – wireless magnetic contact. The active reed switch is to be selected.

AMD-102 – wireless magnetic contact with input for roller shutter detector. The following is to be programmed:

- active reed switch [first zone];
- number of pulses after which alarm will be triggered by the roller shutter input [second zone];
- time during which the specified number of pulses must occur for the roller shutter input to trigger alarm [second zone].

APMD-150 – wireless dual motion detector. The following is to be programmed:

- sensitivity of PIR sensor;
- sensitivity of microwave sensor;
- the way of operation in test mode.

APD-100 – wireless passive infrared detector. The following is to be programmed:

- sensitivity,
- option of immunity to pets up to 15 kg.

ARD-100 – wireless reorientation detector. Sensitivity is to be programmed.

ATD-100 – wireless temperature detector. For both positions occupied by detector, the temperature threshold parameters can be programmed (thus two different temperature threshold can be programmed):

- threshold type: high (when the temperature rises above the defined temperature value, alarm will be triggered) or low (when the temperature drops below the defined temperature value, alarm will be triggered);
- temperature;
- tolerance.

AVD-100 – wireless vibration detector and magnetic contact. The following is to be programmed:

- active reed switch [first zone];
- sensitivity of vibration detector (registering a single vibration meeting the sensitivity criterion will cause alarm) [second zone];
- the number of pulses which, if registered by vibration detector will cause alarm (the pulses need not meet the sensitivity criterion) [second zone].



Working parameters of the vibration detector are independently analyzed. The detector can trigger alarm after registering a single, strong vibration caused by a powerful impact, and also on registering several slight vibrations caused by a series of weak strikes.

ASP-105 – wirelessly triggered outdoor siren. The following is to be programmed:

- type of acoustic signaling;
- maximum duration of acoustic signaling.

ASP-205 – wireless indoor siren. Signaling parameters can be programmed for both positions occupied by the siren (thus allows to program two different signaling types):

- maximum duration of signaling;
- type of acoustic signaling;
- optical signaling option.

ASW-100 E / ASW-100 F – 230 V AC wireless controller. Operating mode can be programmed.

8.2 Programming in the INTEGRA / INTEGRA Plus system

8.2.1 DLOADX program

You can program the wireless devices in the "Structure" window, "Hardware" tab, after clicking on the controller name in the list of devices (Fig. 3). Before making any changes, click on the "Read" button, and after making the changes – on the "Write" button (the data

relating to wireless devices are not read and saved after clicking on the  button in the DLOADX program main menu).

ARU

In the "ARU" column:

- leave the field blank, if the device is to communicate directly to the controller;
- enter the ARU-100 repeater number in the list of wireless devices, if the device is to communicate to the controller via the repeater (the ARU-100 repeater takes up two positions on the list of devices – enter the number of the first of them).

Configuration

Described below is how the additional parameters and options should be programmed in the "Configuration" column.

AGD-100 – enter a digit from the 1 to 3 range to set the sensitivity (1 – low , 2 – medium, 3 - high).

AMD-100 / AMD-101 – enter the digit 0 (bottom reed switch) or 1 (side reed switch) to determine which of the two reed switches is to be active.

AMD-102 – for the magnetic contact, enter the digit 0 (bottom reed switch) or 1 (side reed switch) to determine which of the two reed switches is to be active. For the roller shutter input, enter 2 digits:

1st digit – number of pulses: from 1 to 8.

2nd digit – pulse validity: 0 (30 seconds), 1 (120 seconds), 2 (240 seconds) or 3 (unlimited duration).

APMD-150 – enter 3 digits:

1st digit – sensitivity of infrared path: from 1 to 4 (1 – minimum; 4 – maximum).

2nd digit – sensitivity of microwave path: from 1 to 8 (1 – minimum; 8 – maximum).

3rd digit – the way of operation in the test mode: 0 (alarm triggered after motion is sensed by both detectors), 1 (alarm triggered after motion is sensed by infrared detector) or 2 (alarm triggered after motion is sensed by microwave detector).

APD-100 – enter 2 digits:

1st digit – sensitivity: 1 (low), 2 (medium) or 3 (high),

2nd digit – pet immunity option: 0 (disabled) or 1 (enabled).

ARD-100 – enter a number from the 1 to 16 range to determine sensitivity (1 – minimum; 16 – maximum).

ATD-100 – for each position taken by the detector, enter in turn:

– letter H (high temperature threshold) or L (low temperature threshold);

– numerical value corresponding to a temperature from the -30° C to +70° C range (with up to 0.5° accuracy),

– numerical value corresponding to a tolerance from the 0.5° C to 10° C range (with up to 0.5° accuracy).

AVD-100 – for the magnetic contact, enter the digit 0 (bottom reed switch) or 1 (side reed switch) to determine which of the two reed switches is to be active. For the vibration detector, enter 2 digits:

1st digit – sensitivity: from 1 to 8 (1 – minimum ; 8 – maximum).

2nd digit – number of pulses: from 0 to 7. For the value 0, pulses are not counted.

ASP-105 – enter 2 digits:

1st digit – type of acoustic signaling: from 1 to 4.

2nd digit – maximum duration of acoustic signaling: 1 (1 minute), 2 (3 minutes), 3 (6 minutes) or 4 (9 minutes).

ASP-205 – for both positions taken on the list by the siren, enter 3 digits:

1st digit – maximum duration of signaling: 1 (1 minute), 2 (3 minutes), 3 (6 minutes) or 4 (9 minutes).

2nd digit – type of acoustic signaling: 0 (disabled), 1 (sound type 1), 2 (sound type 2) or 3 (sound type 3).

3rd digit – optical signaling: 0 (disabled) or 1 (enabled).

ASW-100 E / ASW-100 F – enter 0 (only remote control of the electric circuit); 1 (remote or manual control of the electric circuit) or 2 (remote or manual control of the electric circuit, but with option to manually block the remote control).

8.2.2 LCD keypad

You can configure the wireless devices in service mode, using the USE ARU-100, ACTIVE MODE, CONFIGURATION and FILTER functions, which are available for the controller (►STRUCTURE ►HARDWARE ►EXPANDERS ►SETTINGS ►*controller name*). Having started the function, use the ▼ and ▲ keys to select the zone to which the do wireless device is assigned and press the # key.

Use ARU-100

Using the ▼ and ▲ keys you can select whether the wireless device is to communicate to the controller directly, or via a selected repeater (the name of the zone to which the repeater is assigned is displayed on the list).

Configuration

Use the arrow keys for programming additional parameters and options. The values which can be programmed for individual parameters of wireless devices are presented in the section describing configuration of the devices by means of the DLOADX program.

8.3 Programming in the VERSA system

8.3.1 DLOADX program

You can configure wireless devices in the "Versa – Structure" window, "Hardware" tab, after clicking on the controller name in the list of devices. The programming is performed in the same way as in the INTEGRA / INTEGRA Plus system. Before making any changes, click on the "Read" button, and after making the changes – on the "Write" button (the data relating to

the wireless devices are not read after clicking on the  button or saved after clicking on

the  button in the DLOADX program main menu).

8.3.2 LCD keypad

For information on configuring wireless devices from the LCD keypad, please refer to the VERSA control panel programming manual.

9. Specific character of the operation of wireless devices

This chapter describes the peculiar character of the operation of individual groups of wireless devices, which affects the method of programming the zones and outputs to which the wireless devices are assigned.

9.1 Wireless detectors

The wireless detectors send information on violations, tampers and low-battery status. The information on violations and tampers is sent to the zones to which the detectors are assigned. The system zones to which the wireless detectors are assigned can be programmed as:

- NC, NO or EOL – the zone will inform about detector violation;
- 2EOL/NC or 2EOL/NO – the zone will inform about detector violation and tamper.

The mode of operation of wireless detectors depends on the status of partition to which the zone with wireless detector belongs:

partition disarmed – the detector operates in **passive mode**. It is a battery saving mode, in which communication with the controller takes place mainly during time intervals determined by the `RESPONSE PERIOD` parameter. At that time, information on violations and battery status is sent. Only detector tampers are sent immediately.

partition armed – the detector operates in **active mode**. The detector sends immediately all information to the controller.

Because switching the detectors over from the passive into active mode and conversely takes place during the response time, it is performed with some delay in relation to arming/disarming. The maximum delay – depending on the selected response frequency – can be 12, 24 or 36 seconds.

The AMD-103 detector and wireless detectors assigned to the 24-hour zones, which are permanently armed, are in the active mode at all times. Also other wireless detectors can always work in the active mode, if the `ALWAYS ACTIVE` option is enabled for them (see section `PARAMETERS AND OPTIONS` p. 11).



According to the EN50131-3 standard all ABAX system Hold-Up devices must be always in active mode.

Batteries ensure approx. 3 years operation of the detectors, assuming that the detectors are in passive state for part of that period and the `RESPONSE PERIOD` is 12 seconds. A longer response period (24 or 36 seconds) means extension of the battery life time. The battery life time in the detectors switched permanently into the active mode is shorter than in those which are periodically switched to the passive mode. However, if the specific character of a detector or its installation place is such that the number of violations is low, switching the detector permanently into the active mode will not adversely affect the battery life time.

9.2 Wireless sirens

The wireless sirens take up 2 outputs and 2 zones in the system. How the signaling is controlled by the outputs depends on the siren:

ASP-105 – the first of the outputs to which the siren is assigned controls the acoustic signaling. Parameters of the acoustic signaling are programmed for the siren (type and maximum duration of the sound signal). The second output controls the optical signaling. The optical signaling is enabled when the output is active. The command to start and stop signaling is sent to the siren immediately.

ASP-205 – both outputs to which the siren is assigned control both the acoustic and optical signaling. Parameters of the signaling triggered by each of the outputs are programmed separately for the siren. Thus two different, independently triggered ways of signaling can be configured. As a result, the outputs can separately control the optical and acoustic signaling or signal different alarm types (e.g. burglary and fire). The command to start the signaling is sent to the siren only during the response time. Therefore, the cut-off time for

the control panel outputs which control the siren must be longer than the response period. It is recommended that cut-off time correspond to maximum duration of signaling programmed for the siren.

The zones in the system to which the wireless sirens are assigned can be programmed as:

- NC, NO or EOL – the zone will inform about power failures;
- 2EOL/NC or 2EOL/NO – the zone will inform about power failures and tamper.

The type of zones to which the wireless siren is assigned should be matched to the information sent:

ASP-105 – first zone: low battery and tamper; second zone: external 12 V DC power loss and tamper.

ASP-205 – both zones: low battery and tamper.

The tamper information is sent immediately, while the trouble information – during the response time.

Tamper alarm on opening the tamper switch in the siren:

ASP-105 – lasts for the maximum time of acoustic signaling programmed for the siren (sound type selected during programming and optical signaling);

ASP-205 – lasts 3 minutes (sound type 1 and optical signaling).



After starting the SERVICE MODE or TEST MODE and for 40 seconds after power-up, the signaling in the siren is blocked. It enables installation work to be carried out. Opening the tamper switch will not trigger loud signaling, but information on tamper will be sent (when in service mode, the control panel will not signal the tamper alarms). The command to block/unblock the signaling connected with starting / ending the test mode or the service mode is sent during the response time.

9.3 Wireless expanders of hardwired zones and outputs

The wireless expander of hardwired zones and outputs (ACX-200 or ACX-201) takes up 4 zones and 4 outputs in the system. The alarm system zone / output to which the zone / output in ACX-200 or ACX-201 expander is assigned is programmed in the same way as the other hardwired zones / outputs of the control panel. You should remember however that sensitivity of the expander zones may be different from that programmed in the control panel:

- from 20 ms to 140 ms – the same as the value programmed in the control panel;
- above 140 ms – only some values are available: 300 ms, 500 ms, 700 ms, etc. every 200 ms (the programmed value is rounded up to that supported by the expander).



The EN50131-3 standard requires that zones must react to signals lasting more than 400 ms. It means in case of the wireless expanders of hardwired zones and outputs that no values exceeding 300 ms should be entered when programming the sensitivity (the higher the value, the lower the sensitivity).

The expansion module informs you about the zone status as it changes. Also the expander outputs are controlled in real time. Only the programming of zones takes place during the response time (in one period, data relating to configuration of one zone are sent to the expander module, i.e. sending the information on settings of four zones require four response periods).



If communication with the controller is lost, all previously activated outputs will be deactivated after 20 response periods.

Additionally, the ACX-201 expander module sends information about:

- status of AUX1 and AUX2 power supply outputs – information on overload is sent when the AUX1 or AUX2 output load exceeds 0.5 A.
- battery status – information on low battery is sent when the battery voltage drops below 11 V for more than 12 minutes (3 battery tests). The expander will keep sending this information to the controller until the battery voltage rises and remains above 11 V for longer than 12 minutes (3 battery tests).
- AC power status – information on the loss of power supply is sent when the AC power loss lasts for more than 30 seconds. The AC power restore is reported with the same delay.

9.4 230 V AC wireless controllers

Activation of the output to which the controller is assigned will result in energizing the 230 V AC electrical circuit (if reverse polarity of the output has been programmed, the circuit will be deenergized).

Depending on the operating mode, information on the button status (mode 0) or on the electric circuit status (mode 1 and mode 2) is sent to the zone to which the controller is assigned. Information on the button status is sent in real time. Information on the electric circuit status is sent during the response time. Pressing the button / closing the electric circuit means violation of the zone to which the controller is assigned.

10. APT-100 keyfobs

The maximum number of supported keyfobs depends on the maximum number of the control panel users.



The data related to keyfobs are stored in the controller. After the controller containing keyfob data is connected to the control panel, keyfobs will be automatically assigned to the existing users.

10.1 Keyfobs in the INTEGRA / INTEGRA Plus system

The user can have one APT-100 keyfob. If more than one ABAX wireless system controllers are connected to the INTEGRA / INTEGRA Plus control panels, the keyfob will be supported by all of them. The keyfob data are automatically saved to all controllers.

When connecting the controller to the INTEGRA 128-WRL control panel or to the control panel to which the ABAX system controller is already connected, you should make uniform the data relating to APT-100 keyfobs. In the keypad service mode, the COPY ABAX KFOBS function is available (►STRUCTURE ►HARDWARE ►EXPANDERS ►COPY ABAX KFOBS), which enables copying of the keyfob data. In the DLOADX program, to write the APT-100 keyfobs data to a new controller, open the "Keyfobs ABAX" window and do the following:

- INTEGRA 128-WRL – click on the "Write to all" button (the button is available, when the ABAX system controller is connected to the control panel).
- other INTEGRA / INTEGRA Plus control panels – click on the "Read" button and immediately after reading the data, click on the "Write" button (after the data are read, you must not make any changes).

The functions are executed by means of controlling the status of system zones. Using the keyfob, you can control up to 6 zones in the alarm system. These zones should not exist physically and the wiring type programmed in them must be different from NO DETECTOR and FOLLOW OUTPUT. You can program any function for these zones. Pressing the keyfob button

(or two buttons simultaneously) will violate the zone and cause suitable reaction from the control panel.


On pressing any keyfob button (not necessarily the one used to control a system zone), information on the status of three selected system outputs will be presented on the keyfob LEDs. Thus you can get confirmation that the function has been executed or information on the current system status. The outputs whose status is presented by means of the keyfob LEDs do not have to exist physically. The installer can indicate up to 8 outputs in the system which will be used to inform the keyfob users (ABAX CONFIRMAT. function in the keypad [SERVICE MODE ►STRUCTURE ►HARDWARE ►EXPANDERS ►ABAX CONFIRMAT.] or "Keyfobs ABAX" window in the DLOADX program).

Pressing a button / combination of buttons in the keyfob can generate a keyfob use event.

For information on adding / removing keyfobs by means of the keypad please refer to the control panel user manual.

In the DLOADX program, you can add and remove keyfobs in the "Keyfobs ABAX" window (Fig. 5). The window opening command is available in the "Users" menu. Before making any changes, click on the "Read" button, and after making the changes – on the "Write" button

(the data related to keyfobs are not read and saved after clicking on the  button in the DLOADX program main menu).



Removal of a keyfob will not erase its settings (dependences between the buttons and zones, confirmation rules, etc.). When added to the user, the new keyfob will have the same settings as the deleted one.

The installer can remove all keyfobs, including their settings, by means of the REM.ABAX KEYFOB function available in the service mode in the keypad (►STRUCTURE ►HARDWARE ►EXPANDERS ►REM.ABAX KEYFOB).

10.1.1 Adding the APT-100 keyfob by means of the DLOADX program

Entering the serial number manually

1. Click on the field in the "S/N" column next to the name of the user to whom you want to assign a keyfob.
2. Enter the keyfob serial number and confirm by pressing ENTER.

Reading the serial number during transmission

1. Click on the field in the "S/N" column next to the name of the user to whom you want to assign a keyfob.
2. Click on the "New" button. The "New" window will open.
3. According to the command which will appear in the window, press the keyfob button.
4. When the keyfob serial number is displayed in the window, click on the "OK" button. The "New" window will close. The serial number of the new keyfob will be shown in the "S/N" column.

Assigning new function to the keyfob button (combination of buttons)

1. Click on the field corresponding to the button (combination of buttons) to which you want to assign a zone.
2. Enter the zone number and press ENTER to confirm.
3. Using the SPACE key enable/disable the event generating function. If the ✕ symbol is displayed next to the zone number, the event will not be saved after pressing the button / combination of buttons (if no symbol is displayed, the event will be saved).

Assigning outputs to the LEDs

1. Click on the field in the "LED" column.
2. Using the keyboard, enter up to 3 digits. Each of the digits must correspond to the number of field with output selected for confirmation (on the window right side) i.e. it can be from the 1 to 8 range. The names of outputs in fields designated with these digits will be shown in bold-type face.

10.1.2 Removing the APT-100 keyfob by means of the DLOADX program

1. Click on the field in "S/N" column next to the name of user whose keyfob is to be removed.
2. Click on the "Delete" button.
3. In the window which will be displayed, click on the "Yes" button to confirm that you want to remove the keyfob. The keyfob serial number shown in the "S/N" column will be erased.

10.2 Keyfobs in the VERSA system

The functions which can be started using the keyfobs and the information that can be presented on the LEDs are described in manuals for the VERSA control panels. After a keyfob has been added, its settings will be configured automatically, based on the user schedule. These settings can be modified (different functions can be assigned to the buttons / combination of buttons and different information to the LEDs).

The user manual for VERSA control panels describes the procedures for adding and editing the user by means of the keypad, during which you can add or remove the keyfob and program its settings.

In the DLOADX program, you can add and delete keyfobs in the "Versa – Structure" window, "Hardware" tab, after clicking on the controller name in the list of devices, and then on the "Keyfobs" tab (Fig. 6). Before making any changes, click on the "Read" button, and after making the changes – on the "Write" button (the data relating to keyfobs are not read after

clicking on the  button or saved after clicking on the  button in the DLOADX program main menu).

i Removal of a keyfob by means of the keypad will not erase its settings (the functions assigned to the buttons). When added to the user, the new keyfob will have the same settings as the deleted one.


The installer can remove all keyfobs, including their settings, by means of the REM.ABAX KFBS function available in the service mode in the keypad (▶2. HARDWARE ▶1. KPDS. & EXPS. ▶8. REM.ABAX KFBS).

Adding and removing a keyfob with the DLOADX program is carried out in the same way as for the INTEGRA and INTEGRA Plus control panels. Functions can be assigned to the buttons (combination of buttons) in the following way:

1. Click on the field corresponding to the selected button (combination of buttons).
2. Right click on your mouse. A drop-down menu will appear in which you are to select the new function.

In order to determine the information which will be presented on the LEDs:

1. Click on the field corresponding to the selected LED.
2. Right click on your mouse. A drop-down menu will appear in which you are to select the new information.



11. Specifications

- Supply voltage 12 V DC ±15%
- Standby current consumption33 mA
- Maximum current consumption33 mA
- Operating frequency band..... 868.0 MHz ÷ 868.6 MHz
- Radio communication rangeup to 500 m (in open area)

Security grade according to EN50131-3 Grade 2
 Complied with standards..EN 50130-4, EN 50130-5, EN 50131-1, EN 50131-3, EN 50131-5-3
 Environmental class according to EN50130-5 II
 Operating temperature range.....-10 °C...+55 °C
 Maximum humidity 93±3%
 Enclosure dimensions.....24 x 110 x 27 mm
 Weight..... 35 g

12. Manual update history

DATE	FIRMWARE	CHANGES MADE
2013-04	4.02	<ul style="list-style-type: none"> Information on AMD-103 wireless magnetic contact has been added (p. 5, 5, 11 and 15).
2014-02	4.03	<ul style="list-style-type: none"> Information on ARU-100 radio signal repeater has been added (p. 6, 11, 13 and 14).