



Model 40/40M

Multi IR Hydrocarbon and Hydrogen Flame Detector

User Guide



FM, CSA Approved

Class I Div. 1 Groups B, C, D
Class II/III Div. 1 Groups E, F, G

ATEX, IECEx Approved

Ex II 2 G D, Ex d e IIC T5 Gb
Ex tb IIIC T96°C Db

Document ref: TM 40/40M, (9) August 2015



218 Little Falls Rd., Cedar Grove, NJ 07009, USA
Phone: +1 (973) 239 8398 Fax: +1 (973) 239 761
Web-Site: www.spectrex.net; Email: spectrex@spectrex.net

Legal Notice

The SharpEye Optical Flame Detector described in this document is the property of Spectrex, Inc.

No part of the hardware, software or documentation may be reproduced, transmitted, transcribed, stored in a retrieval system or translated into any language or computer language, in any form or by any means, without prior written permission of Spectrex, Inc.

While great efforts have been made to assure the accuracy and clarity of this document, Spectrex, Inc. assumes no liability resulting from any omissions in this document, or from misuse of the information obtained herein. The information in this document has been carefully checked and is believed to be entirely reliable with all of the necessary information included. Spectrex Inc. reserves the right to make changes to any products described herein to improve reliability, function, or design, and reserves the right to revise this document and make changes from time to time in content hereof with no obligation to notify any persons of revisions or changes. Spectrex, Inc. does not assume any liability arising out of the application or any use of any product or circuit described herein; neither does it convey license under its patent rights or the rights of others



Warning: This manual should be read carefully by all individuals who have or will have responsibility for using, maintaining or servicing the product.

The Detector is not field-repairable due to the meticulous alignment and calibration of the sensors and the respective circuits. Do not attempt to modify or repair the internal circuits or change their settings, as this will impair the system's performance and void the Spectrex, Inc. Product warranty.

Warranty

SPECTREX INC. Agrees to extend to Purchaser/Distributor a warranty on the SPECTREX supplied components of the SharpEye products. SPECTREX warrants to Purchaser/Distributor that the products are free from defects in materials and workmanship for a period of five (5) years, commencing with the date of delivery to Purchaser/Distributor. SPECTREX expressly excludes damage incurred in transit from the factory or other damage due to abuse, misuse, **improper installation, or lack of maintenance or "Act of God" which are above and beyond its control.** SPECTREX will, upon receipt of any defective product, transportation prepaid, repair or replace it at its sole discretion if found to have been defective when shipped. Said repair or **replacement is SPECTREX'S sole liability under this warranty and SPECTREX'S liability shall be** limited to repair or replacement of the component found defective and shall not include any liability for consequential or other damages. The customer is responsible for all freight charges and taxes due on shipments both ways. This warranty is exclusive of all other warranties express or implied.

Release History

Rev	Date	Revision History	Prepared by	Approved by
0	July 2008	First Release	Ian Buchanan	Eric Zinn
1	September 2008	Second Release	Ian Buchanan	Eric Zinn
2	July 2010	Third Release	Ian Buchanan	Eric Zinn
3	August 2010	Fourth Release	Ian Buchanan	Eric Zinn
4	November 2010	Fifth Release	Ian Buchanan	Eric Zinn
5	February 2013	Sixth Release	Ian Buchanan	Eric Zinn
6	July 2013	Seventh Release	Ian Buchanan	Eric Zinn
7	February 2015	Eighth Release	Ian Buchanan	Eric Zinn
8	June 2015	Ninth Release	Ian Buchanan	Eric Zinn
9	August 2015	Tenth Release	Ian Buchanan	Eric Zinn

About this Guide

This guide describes the SharpEye Model 40/40M Multi IR Flame Detector and its features and provides instructions on how to install, operate and maintain the detector.

This guide includes the following chapters and appendixes:

- ♦ **Chapter 1, Introduction**, provides a general overview of the product, principles of operation, and performance considerations.
- ♦ **Chapter 2, Installing the Detector**, describes how to install the detector including preparations before installation, wiring and mode settings.
- ♦ **Chapter 3, Operating the Detector**, describes how to power-up and test the detector. The chapter also lists safety precautions you should take when operating the detector.
- ♦ **Chapter 4, Maintenance and troubleshooting**, describes basic maintenance procedures, and troubleshooting and support procedures.
- ♦ **Appendix A, Technical Specifications**: Lists the detectors technical and other specifications.
- ♦ **Appendix B, Wiring Instructions**, lists the wiring instructions for connecting the detector and also provides examples of typical wiring configurations.
- ♦ **Appendix C, RS-485 Communication Network**, provides an overview of the RS-485 communications network.
- ♦ **Appendix D, Accessories**, describes the accessories available for the detector.
- ♦ **Appendix E, SIL-2 Features**, describes the special conditions to comply with the requirements of EN 61508 for SIL 2 according to TUV.

Abbreviations and Acronyms

Abbreviation	Meaning
ATEX	Atmosphere Explosives
AWG	American Wire Gauge
BIT	Built In Test
EMC	Electromagnetic Compatibility
EOL	End of Line
FOV	Field of View
HART	Highway Addressable Remote Transducer-communication protocol
IAD	Immune at Any Distance
IECEX	International Electrotechnical Commission Explosion
IPA	Isopropyl Alcohol
IR	Infrared
JP5	Jet Fuel
Latching	Refers to relays remaining in the ON state even after the ON condition has been removed
LED	Light Emitting Diode
LPG	Liquefied Petroleum Gas
mA	Milliamps (0.001 amps)
MODBUS	Master-slave messaging structure
N.C.	Normally Closed
N.O.	Normally Open
N/A	Not Applicable
NFPA	National Fire Protection Association
NPT	National Pipe Thread
SIL	Safety Integrity Level
UNC	Unified Coarse Thread
VAC	Volts Alternating Current

Table of Contents

Model 40/40M Multi IR Hydrocarbon and Hydrogen Flame Detector User Guide.....	i
Legal Notice.....	iii
Warranty.....	iii
Release History	iv
About this Guide.....	v
Abbreviations and Acronyms.....	vi
1 Introduction	1
1.1 Overview	1
1.2 Model and Types.....	2
1.3 Features and Benefits.....	4
1.4 Principles of Operation.....	4
1.4.1 Fire Detection Principle.....	5
1.4.2 Heated Optics.....	5
1.4.3 HART Protocol	5
1.4.4 RS-485 Modbus	6
1.4.5 Product Certification.....	6
1.5 Performance Considerations	7
1.5.1 Detection Sensitivity	8
1.5.2 Cone of Vision	10
1.5.3 False Alarms Prevention.....	12
1.5.4 Visual Indicators	13
1.5.5 Output Signals.....	14
1.5.6 Detector Status	15
1.5.7 Auxiliary Relay as End-of-Line	16
1.6 Internal Detector Tests	16
1.6.1 Continuous Feature Test	16
1.6.2 Built-In-Test (BIT)	17
2 Installing the Detector	21
2.1 General Guidelines	21
2.2 Unpacking the Product.....	22
2.2.1 Checking the Product Type.....	22
2.3 Required Tools.....	23
2.4 Certification Instructions.....	24

2.5	Installation Cables	25
2.5.1	Conduit Installation.....	25
2.6	Installing the Tilt Mount (part no. 40/40-001)	26
2.6.1	Tilt Mount Assembly	27
2.7	Connecting the Detector	28
2.7.1	Verifying the Detector Wiring	30
2.8	Configuring your Detector	31
2.8.1	Sensitivity.....	32
2.8.2	Alarm Delay	32
2.8.3	Address Set-up.....	32
2.8.4	Function Set-up.....	33
2.8.5	Heated Optics.....	33
3	Operating the Detector	35
3.1	Powering Up.....	35
3.2	Safety Precautions	36
3.2.1	Default Functions Settings	36
3.3	Testing Procedures.....	37
3.3.1	Automatic BIT Test	37
3.3.2	Manual BIT Test.....	37
3.3.3	Testing with Flame Simulator Model 20/20-313	37
4	Maintenance and Troubleshooting	39
4.1	Maintenance.....	39
4.1.1	General Procedures	39
4.1.2	Periodic Procedures	40
4.1.3	Keeping Maintenance Records	40
4.2	Troubleshooting.....	41
	Appendices.....	43
A	Specifications	45
A.1	Technical Specifications	45
A.2	Electrical Specifications.....	46
A.3	Outputs	46
A.4	Approvals.....	49
A.5	Mechanical Specifications.....	49
A.6	Environmental Specifications	50

B	Wiring Instructions.....	53
B.1	General Instructions for Electrical Wiring.....	53
B.2	Typical Wiring Configurations	55
C	RS-485 Communication Network	59
C.1	RS-485 Overview	59
D	Accessories.....	61
D.1	Long Range Multi IR Flame Simulator	61
D.1.1	Unpacking.....	62
D.1.2	Operating Instructions.....	62
D.1.3	Range	63
D.1.4	Charging the Battery	63
D.1.5	Technical Specifications	64
D.2	Tilt Mount - P/N 40/40-001	64
D.3	Duct Mount P/N 777670.....	65
D.4	Weather Cover - P/N 777163.....	66
D.5	Laser Detection Coverage Pointer - P/N 777166.....	67
D.6	Air Shield - P/N 777650	68
E	SIL-2 Features.....	69
E.1	40/40M Flame Detector	69
E.1.1	Safety Relevant Parameters	69
E.1.2	Guidelines for Configuring, Installing, Operating and Service.....	69
	Technical Support	72

List of Figures

Figure 1: Vertical Field of View for Gasoline	10
Figure 2: Horizontal Field of View for Gasoline	11
Figure 3: Fields of View for Hydrogen (Horizontal and Vertical)	11
Figure 4: Indication LED.....	13
Figure 5: Detector with Tilt Mount	26
Figure 6: Tilt Mount Assembly.....	27
Figure 7: Tilt Mount Assembly (dimensions in mm and inches).....	27
Figure 8: Detector with Cover Removed	29
Figure 9: Wiring Terminals	55
Figure 10: Typical Wiring for 4 Wire Controllers (Using Option 1 or 2 Wiring)	56
Figure 11: 0-20mA Wiring Option 1 (Sink 4-Wire) - Default.....	57
Figure 12: 0-20mA Wiring Option 1 (Converted to Source 3-Wire)	57
Figure 13: 0-20mA Wiring Option 1 (Non-isolated Sink 3-Wire).....	58
Figure 14: 0-20mA Wiring Option 2 and 3 (Source 3-Wire available with the HART Protocol).....	58
Figure 15: RS-485 Networking.....	59
Figure 16: SharpEye Multi IR Long Range Flame Simulator 20/20-313	61
Figure 17: 40/40M Multi IR Detector Target Point.....	62
Figure 18: Tilt Mount	64
Figure 19: Duct Mount	65
Figure 20: Weather Cover	66
Figure 21: Laser Detection Coverage Pointer	67
Figure 22: Air Shield.....	68

List of Tables

Table 1: Wiring Options	3
Table 2: Sensitivity Range Levels	8
Table 3: Fuel Sensitivity Ranges.....	9
Table 4: Immunity to False Alarm Sources	12
Table 5: Welding Immunity Distance	13
Table 6: LED Indications	13
Table 7: Available Output Types.....	14
Table 8: Detector Status	15
Table 9: Output Signals versus Detector State	15
Table 10: Results of a Successful BIT.....	18
Table 11: Results of an Unsuccessful BIT	18
Table 12: Results of a Successful Manual BIT.....	19
Table 13: Results of an Unsuccessful Manual BIT	19
Table 14: Tools.....	23
Table 15: Model 40/40M Wiring Options.....	30
Table 16: Sensitivity Settings	32
Table 17: Functions.....	33
Table 18: Default Function Values	36
Table 19: Results of Successful Flame Simulator Test	38
Table 20: Troubleshooting Table	41
Table 21: Electrical Specifications.....	46
Table 22: Contact Ratings	47
Table 23: 20 mA Current Output	47
Table 24: Electromagnetic Compatibility (EMC)	51
Table 25: Maximum DC resistance at 68°F (20°C) for copper wire.....	53
Table 26: Wiring length in feet (meter)	54
Table 27: Wiring Connections	56
Table 28: Sensitivity Ranges.....	63

1 Introduction

➤ In this chapter...

<i>Overview</i>	<i>page 1</i>
<i>Model and Types</i>	<i>page 2</i>
<i>Features and Benefits</i>	<i>page 4</i>
<i>Principles of Operation</i>	<i>page 4</i>
<i>Performance Considerations</i>	<i>page 7</i>
<i>Internal Detector Tests</i>	<i>page 16</i>

1.1 Overview

The 40/40M Multi IR Flame Detector is specifically designed for detection of hydrocarbon and hydrogen flames. It detects hydrocarbon-based fuel and gas fires at long distances with the highest immunity to false alarms. The 40/40M can detect a gasoline pan fire at 215 ft. (65m) or a hydrogen flame at 100 ft. (30m) in less than 5 seconds.

All 40/40 series detectors include a heated optical window for improved performance in icing, snow and condensation conditions.

Detection performance can be easily adapted to all environments, **applications and requirements, by changing the detector's configuration** parameters. Adjusting these parameters, as well as performing other maintenance and monitoring tasks, is possible by means of RS485-based Modbus communication or HART communication (in models with 0-20mA output).

The detector enclosure is ATEX certified Exd flameproof with an integral, segregated, rear, Exe terminal compartment (avoiding exposure of the sensors and electronics to surrounding environment). Hence the combined approval:

Ex II 2 G D
Ex d e IIC T5 Gb
Ex tb IIIC T96°C Db
(-55°C ≤ Ta ≤ +75°C)

or

Ex II 2 G D
Ex d e IIC T4 Gb
Ex tb IIIC T106°C Db
(-55°C ≤ Ta ≤ +85°C)

The SharpEye 40/40 detectors are designed to operate as a stand-alone unit directly connected to an alarm system or an automatic fire extinguishing system. The detector can also be a part of a more complex system, where many detectors and other devices are integrated through a common control unit.

1.2 Model and Types


The 40/40M is provided in various configurations depending on:

- ◆ Wiring options
- ◆ Temperature ranges
- ◆ Type of cable entries
- ◆ Housing material type
- ◆ Required approval

The configuration detail is included in the product part number on the product label and takes the form: 40/40M-XXXXX, where XXXXX defines the model according to the above requirements.

To modify the default or pre-ordered configuration and perform maintenance tasks, please refer to the *HART Protocol TM777030*, the *RS-485 Manual TM 777050* or *TM777070*.

The Part Numbers are defined as:



*Aluminum housing is not available in FM version.

Table 1 describes the wiring options in detail.

Table 1: Wiring Options

Wiring Option	Connections Provided						
	Power	Manual BIT	Fault Relay N.C.	Alarm Relay N.O.	0-20mA Sink	RS-485	HART
1	Power	Manual BIT	Fault Relay N.C.	Alarm Relay N.O.	0-20mA Sink	RS-485	HART
2	Power	Manual BIT	Fault Relay N.C.	Alarm Relay N.O., N.C.	0-20mA Source	RS-485	HART
3	Power	Manual BIT	Fault Relay N.O.	Alarm Relay N.O., N.C.	0-20mA Source	RS-485	HART
4	Power	Manual BIT	Fault Relay N.C.	Alarm Relay N.O.	Auxiliary N.O.	RS-485	-
5	Power	Manual BIT	Fault Relay N.O.	Alarm Relay N.O.	Auxiliary N.O.	RS-485	-

Note: Wiring option 1 is default. The mA 'Sink' output can be altered to 'Source' type, with a link between terminals 1 and 8. No other wiring options can be changed on site.

For example, product number 40/40M-321SC has the following options:

- ♦ **Wiring Option:** 3 (Power, Manual BIT, RS-485, 0-20mA (Source) with the HART protocol, Fault Relay (N.O.), Alarm Relay (N.O., N.C.))
- ♦ **Temperature Range:** 2 (85°C)
- ♦ **Cable Entry:** 1 (M25)
- ♦ **Housing :** S (Stainless Steel)
- ♦ **Approval:** C (ATEX, IECEx)

Note: Check your specific part numbers against the information in *Checking the Product Type* on page 22.

1.3 Features and Benefits

- ◆ Detects Hydrocarbons and Hydrogen Flames.
- ◆ Detection Range: Up to 215 ft. (65m) for a 1 ft² (0.1m²) n-heptane fire.
- ◆ Ultra High Immunity to False Alarms: See Table 4 on page 12.
- ◆ Advanced Digital Processing of the Dynamic Characteristics of Fire: Flickering, threshold correlation and ratio.
- ◆ Multi IR Channels: Between 2-5 microns.
- ◆ Field Programmable Sensitivity: Four ranges to avoid zone crossover.
- ◆ Built In Test (BIT): Manual and Automatic (see ***Built-In-Test (BIT)*** on page 17).
- ◆ Heated Window: Prevents effects of icing, snow, condensation.
- ◆ Electrical Interface:
 - ◆ Dry contact relays
 - ◆ Communication network RS-485
 - ◆ 0-20mA output
- ◆ HART Protocol: Communication protocol (see ***HART Protocol*** on page 5).
- ◆ Exde: Integral junction box for easy wiring.
- ◆ SIL-2: TÜV approved.
- ◆ Hazardous Area Certification: ATEX, IECEx, FM, CSA.
- ◆ Functionality Approval:
 - ◆ EN54-10 approved by VdS
 - ◆ FM approved per FM3260
- ◆ Accessories are approved as part of ATEX & IECEx approval.

1.4 Principles of Operation

This section describes the 40/40M principles of operation and includes:

- ◆ Fire Detection Principle, page 5
- ◆ Heated Optics, page 5
- ◆ HART Protocol, page 5
- ◆ RS-485 Modbus, page 6
- ◆ Product Certification, page 6

1.4.1 Fire Detection Principle

The SharpEye 40/40M detector is designed to detect hydrocarbon flames that produce CO₂ in their combustion process and non-hydrocarbon flames that produce mainly water vapor (H₂O) from inorganic fuels, for example, hydrogen, ammonia, hydrofluoric acid, hydrochloric acid and so on.

The detector's principle of operation is based on the patented spectral analysis technology that identifies the IR spectral signature of fire products, namely the hot CO₂ spectral emission band at 4.2-4.7 microns and the hot water (H₂O) spectral emission band at 2.7-3.0 microns. Additional spectral bands (above and below these bands) are analyzed for background interferences.

The spectral analysis incorporates several detection algorithms, according to several types of fire events, taking into account simultaneous detection of both CO₂ and H₂O peaks, or only one of them, as well as flickering analysis at frequencies typical to these flames. Only when all the parameters of the spectral analysis and the flickering analysis meet the predetermined values, is a fire condition identified and the fire alarm is issued.

When exposed to non-fire radiation sources, these parameters do not identify a fire condition and the detector does not react.

1.4.2 Heated Optics

The SharpEye 40/40 Flame Detectors use heated optics. The heater increases the temperature of the optical surface by 5-8°F (~3-5°C) above the ambient temperature to improve performance in icing, condensation and snow conditions.

The heated optics can be set to one of the following:

- ◆ Not operated
- ◆ On continuously
- ◆ Automatic, per temperature change (default): you can define the start temperature below which the window is heated. (The default is 41°F (5°C).) This temperature can be defined between 32°F (0°C) to 122°F (50°C). The heating stops when the temperature is 27°F (15°C) above the start temperature.

For more information, see *Configuring your Detector* on page 31.

1.4.3 HART Protocol

The SharpEye40/40 Flame Detectors use the HART protocol.

HART Communication is a bi-directional industrial field communication protocol used to communicate between intelligent field instruments and host systems. HART is the global standard for smart process instrumentation and the majority of smart field devices installed in plants worldwide are HART-enabled. HART is available in wiring options 1, 2 and 3, see Table 1, page 3.

HART technology is easy to use and very reliable.

Through the HART connection, you are able to perform:

- ◆ Detector set-up
- ◆ Detector troubleshooting
- ◆ Detector health and status

For more details, refer to the *HART Manual TM 777030*.

1.4.4 RS-485 Modbus

For more advanced communications, the 40/40M detector has an RS 485 Modbus-compatible output that provides data communication from a network (up to 247 detectors) to a host computer or universal controller for central monitoring. This feature allows for reduced installation costs, easy maintenance and local or remote diagnostic tools.

1.4.5 Product Certification

The 40/40M Flame Detectors have the following certifications:

- ◆ ATEX, IECEx, page 6
- ◆ FM, CSA, page 7
- ◆ SIL-2 (TÜV), page 7
- ◆ EN54-10, page 7

1.4.5.1 ATEX, IECEx

The 40/40M Flame Detector is certified to:

- ◆ ATEX per SIRA 07ATEX1250 and IECEx per IECEx SIR 07.0085.

Ex II 2 G D
Ex d e IIC T5 Gb
Ex tb IIIC T96°C Db
(-55°C ≤ Ta ≤ +75°C)

or

Ex II 2 G D
Ex d e IIC T4 Gb
Ex tb IIIC T106°C Db
(-55°C ≤ Ta ≤ +85°C)

The accessories, Tilt Mount P/N 40/40-001, Weather Cover P/N 777163 and P/N 777268, Duct Mount P/N 777670 and Air Shield P/N 777650 are included in the approval

This product is suitable to use in hazardous zones 1 and 2 with IIC gas group vapors present, and zones 21 and 22 with IIIC dust type present.

1.4.5.2 FM, CSA

The 40/40M Flame Detector is certified to FM and CSA Explosion Proof and Functionality per FM3260:

- ♦ Class I, Division 1, Groups B, C and D, T5 Ta = 85°C.
- ♦ Dust Ignition Proof – Class II/III Division 1, Groups E, F and G.
- ♦ Ingress Protection – IP67, IP66, NEMA 250 Type 6P.
- ♦ For more details see FM Report Project ID3029553 and CSA Report No. 2451134.

1.4.5.3 SIL-2 (TÜV)

The 40/40M Flame Detector is certified to SIL-2 requirement per IEC 61508.4, Chapter 3.5.12.

The alert condition according to SIL-2 can be implemented by:

- ♦ Alert signal via 0-20mA current loop.
or
- ♦ Alert signal via alarm relay and fault relay.
- ♦ For more details and guidelines for configuring, installing, operating and service – see **SIL-2 Features** on page 69 and TÜV Report No. 968/EZ 348.02/14.

1.4.5.4 EN54-10

The 40/40M Flame Detector is certified to EN54-10 and CPD.

- ♦ The detector has been tested and approved per EN54-10 by VdS.
- ♦ This test includes functional test, environmental test, EMI/EMC test and software check.
- ♦ For more details see **VdS Reports No's. BMA 12117 and BMA 12118.**

1.5 Performance Considerations

This section describes performance aspects of the 40/40M and includes:

- ♦ Detection Sensitivity, page 8
- ♦ Cone of Vision, page 9
- ♦ False Alarms Prevention, page 12
- ♦ Visual Indicators, page 13
- ♦ Output Signals, page 14
- ♦ Detector Status, page 15
- ♦ Auxiliary Relay as End-of-Line , page 16

1.5.1 Detection Sensitivity

Detection sensitivity is the maximum distance at which the detector reliably detects a specific size of fire and typical type of fuel (standard fire).

1.5.1.1 Standard Fire

Defined as a 1ft² / 0.1m² n-heptane pan fire, with maximum wind speed of 6.5 ft./sec (2 m/sec).

1.5.1.2 Sensitivity Ranges

The detector has four user-selectable sensitivity ranges. For each range there are two response levels.

- ◆ WARNING (Pre-alarm)
- ◆ ALARM

The detection distance, for the WARNING level, is approximately 10% higher than the ALARM distance.

Alarm response times for a standard fire at a specified range are shown Table 2.

Table 2: Sensitivity Range Levels

Level	Response Time (sec)	Sensitivity Range- ft. (m) (for 1ft ² / 0.1m ² n-heptane pan fire)
1	3	50 (15)
2 Default	5	100 (30)
3	8	150 (45)
4	10	215 (65)

For some typical ambient conditions the Zeta parameter as defined in NFPA 72 for the detector is 0.005 (1/meter).

Note: Zeta parameters may vary significantly with changes in temperature, air pressure, humidity, visibility conditions, and so on.

1.5.1.3 Other Fuels

The detector reacts to other types of fire as follows:

- ◆ The baseline fire refers to n-heptane 1ft² (0.1m²) and is defined as 100% sensitivity.
- ◆ For fuel fire – standard pan fire size: 1 ft² (0.1 m²).
- ◆ For gas flame - 30 inch (0.75m) high, 10 inch (0.25m) width plume fire.
- ◆ Maximum Response Time: 10 sec.

Table 3: Fuel Sensitivity Ranges

Type Of Fuel	Percent of Max. Distance at each Sensitivity Range	Max. Distance (ft./m)
Gasoline	100%	215 / 65
N-Heptane	100%	215 / 65
JP5	70%	150 / 45
Kerosene	70%	150 / 45
Diesel Fuel	70%	150 / 45
Ethanol 95%	60%	135 / 40
IPA	60%	135 / 40
Methanol	55%	115 / 35
Methane*	70%	150 / 45
LPG*	70%	150 / 45
Paper	38%	82 / 25
Polypropylene	55%	115 / 35
Hydrogen*	50%	125 / 38
Silane**	3%	7 / 2
Ammonia**	27%	60 / 18

*30" (0.75m) high, 10" (0.25m) width plume fire

**20" (0.5m) high, 8" (0.2m) width plume fire

1.5.2 Cone of Vision

1.5.2.1 Gasoline

- ♦ **Horizontal:** 67°
- ♦ **Vertical:** 70°




Figure 1: Vertical Field of View for Gasoline




Figure 2: Horizontal Field of View for Gasoline

1.5.2.2 Hydrogen

- ♦ **Horizontal:** 80°
- ♦ **Vertical:** 80°




Figure 3: Fields of View for Hydrogen (Horizontal and Vertical)

1.5.3 False Alarms Prevention

To prevent false alarms, the detector will not alarm or react to the radiation sources specified in Table 4.

Table 4: Immunity to False Alarm Sources

Radiation Source	Immunity Distance ft. (m)
Indirect or reflected sunlight	IAD
Vehicle headlights (low beam) conforming to MS53023-1	IAD
Incandescent frosted glass light, 300 W	IAD
Fluorescent light with white enamel reflector, standard office or shop, 70 W (or two 35 W)	IAD
Electric arc [12mm ($^{15}/_{32}$ ") gap at 4000 V alternating current, 60 Hz]	IAD
Arc welding [6 mm ($^{5}/_{16}$ ") rod; 210 A]	See Table 5
Ambient light extremes (darkness to bright light with snow, water, rain, desert glare and fog)	IAD
Bright colored clothing, including red and safety orange	IAD
Electronic flash (180 watt-seconds minimum output)	IAD
Movie light, 625 W quartz DWY lamp (Sylvania S.G.-55 or equivalent)	>6.5 (2)
Blue-green dome light conforming to M251073-1	IAD
Flashlight (MX 991/U)	IAD
Radiation heater, 3000 W	>3 (1)
Radiation heater, 1000 W with fan	IAD
Quartz lamp (1000 W)	>3 (1)
Mercury vapor lamp	IAD
Grinding metal	IAD
Lit cigar	>1 (0.3)
Lit cigarette	>1 (0.3)
Match, wood, stick including flare up	>13 (4)

Notes:

- ♦ IAD = Immune at Any Distance.
- ♦ All sources are chopped from 0 to 20 Hz.

Table 5: Welding Immunity Distance


Sensitivity Setting	Detection Range	Immunity Distance
1	50 ft. (15m)	>6 ft. (2m)
2	100 ft. (30m)	>12 ft. (4m)
3	150 ft. (45m)	>17 ft. (6m)
4	215 ft. (65m)	>25 ft. (7.5m)

1.5.4 Visual Indicators

One 3-color LED indicator is located inside the detector window, as shown in Figure 4. The detector statuses are listed in Table 6.

Table 6: LED Indications

Detector Status	LED color	LED mode
Fault, BIT Fault	Yellow	4 Hz - flashing
Normal	Green	1 Hz - flashing
Warning	Red	2 Hz - flashing
Alarm	Red	Steady

**Figure 4: Indication LED**

1.5.5 Output Signals

Outputs are available according to the default configuration or the wiring options selected for the 40/40M detector. Determine the outputs for your model according to Table 7.

The detector incorporates several types of output suitable to different control systems:

- ♦ 0-20mA (stepped) with HART
- ♦ Relays (Alarm, Fault, Auxiliary)
- ♦ RS-485 Modbus

Table 7: Available Output Types

Output Type	Version	Detector Status
Alarm relay	40/40M – Options 1XXXX, 4XXXX, 5XXXX	The relay is N.O.
	40/40M – Options 2XXXX, 3XXXX	The relay is N.O. and N.C.
Auxiliary relay	40/40M – Options 4XXXX and 5XXXX	The relay is N.O.
Fault relay	40/40M – Options 1XXXX, 2XXXX, 4XXXX	The relay is N.C. energized
	40/40M – Options 3XXXX, 5XXXX	The relay is N.O. energized
0-20mA current output	40/40M – Option 1XXXX	SINK with the HART protocol, (can be changed to Source – see Figure 11, Figure 12 and Figure 13)
	40/40M – Options 2XXXX and 3XXXX	SOURCE with the HART protocol
RS-485	All versions	Modbus protocol

1.5.6 Detector Status

The possible detector function statuses are listed in Table 8. A more detailed fault analysis can be seen via HART or RS485.

Table 8: Detector Status

Status	Description
Normal	Normal operation.
BIT	Built-In-Test being performed.
Warning	Fire detected - changed to Warning (pre-alarm state).
Alarm	Fire detected - changed to Fire Alarm state.
Latched Alarm (Optional)	The alarm outputs remain latched on following detection of a fire that has already been extinguished.
BIT Fault	A fault is detected during BIT sequence or other electric failure. The detector will continue to detect for fire.
Fault	A fault is detected when the power supply is too low or due to a software fault or electrical failure. The detector will NOT detect fire in this condition.

In each state, the detector activates different outputs, as specified in Table 9.

Table 9: Output Signals versus Detector State

Detector State	LED Indicator	LED Mode	Alarm Relay	Auxiliary Relay	Fault Relay	mA output
Normal	Green	1 Hz	Off	Off	On	4 mA
Warning	Red	2 Hz	Off	On ⁽⁴⁾	On	16 mA
Alarm ⁽¹⁾	Red	Constant	On	On	On	20 mA
Latch ⁽²⁾	Red	Constant	On	Off	On	20 mA
				On ⁽⁴⁾	On	20 mA
BIT Fault ⁽³⁾	Yellow	4 Hz	Off	Off	Off	2 mA
Warning at BIT Fault	Red	Constant	Off	On ⁽⁴⁾	Off	16 mA
Alarm at BIT Fault	Red	Constant	On	On	Off	20 mA
Fault	Yellow	4 Hz	Off	Off	Off	0 mA

Notes:

- 1 The alarm outputs are activated while alarm conditions exist and will stop approximately 5 seconds after the fire is no longer detected.
- 2 The Alarm state can be optionally latched via programmed function. (Default is non-latching).

- 3 The detector will remain in BIT Fault state until it has passed a successful BIT.
- 4 The Auxiliary Relay can be activated at the Warning level or Alarm level, depending on programmed function.
- 5 The outputs depend on the wiring options.

1.5.6.1 Optional Latching

Alarms are set as non-latching by default. However, the detector includes a latched alarm output capability, which operates according to the programmed function.

If selected, upon detection of a fire, the detection signal is latched until a manual reset is performed (disconnecting the power supply or performing a manual BIT (see *Manual BIT* on page 19).

Latching affects the Alarm Relay, 0-20mA output, the Alarm LED (the Auxiliary Relay will be latched only when the programmable function **Auxiliary Relay** is set to **YES**).

Notes:

- ♦ The Auxiliary Relay is available only in Models with suffix – 4XXXX and 5XXXX
- ♦ The 0-20mA is available only in Models with suffix – 1XXXX, 2XXXX, 3XXXX

1.5.7 Auxiliary Relay as End-of-Line

The Auxiliary Relay can be used as End-of-Line in Models with suffix-4XXXX, and 5XXXX only. In this case, the Auxiliary Relay is active as long as the detector is powered.

1.6 Internal Detector Tests

The detector performs two types of self-tests:

- ♦ Continuous Feature Test, page 16
- ♦ Built-In-Test (BIT), page 17

1.6.1 Continuous Feature Test

During normal operation, the detector tests itself continuously and indicates a fault if a failure is found. This type of test complies with SIL-2 requirements.

The detector continuously tests:

- ♦ Input voltage level
- ♦ All internal regulator voltage level
- ♦ Voltage level status of sensor and sensor circuitry for noise or disconnection in the electronic circuitry
- ♦ 0-20mA level output

- ◆ Relays and heater operation
- ◆ Processor Watch dog
- ◆ Software
- ◆ Memory
- ◆ Oscillator frequency

Response to Fault Indication

If a failure is found, the detector indicates by:

- ◆ Fault relay:
 - ◆ Opens in wiring option 1, 2, and 4
 - ◆ Closes in wiring option 3 and 5
- ◆ 0-20mA: indicates Fault (0mA or 2mA) in wiring option 1, 2, 3
- ◆ LED – Yellow flashes (4 Hz)
- ◆ Correcting the Fault

The fault indications remain until the detector's power is removed. The fault indications return if the fault is still found when power is restored.

1.6.2 Built-In-Test (BIT)

The detector's Built-In-Test (BIT) also checks the following:

- ◆ Electronics circuitry
- ◆ Sensors
- ◆ Window cleanliness

The detector can be set to perform the BIT in the following modes:

- ◆ Automatically and manually
- ◆ Manually only

Note: In Manual BIT, the outputs may also be tested and Control System 'inhibit' should be applied if this could initiate other systems.

1.6.2.1 How the BIT Operates

- ◆ The detector's status remains unchanged if the result of a BIT is the same as the current status (NORMAL or BIT Fault)
- ◆ the detectors' status is changed (from Normal to BIT Fault or vice versa) if the BIT differs from the current status

Note: In 'BIT Fault' status the detector can continue to detect a fire.

1.6.2.2 Automatic BIT

The detector automatically performs a BIT every 15 minutes. A successful BIT sequence does not activate any indicator.

All outputs of BIT results will function as described in Table 10 and Table 11, and the BIT will be automatically executed every 1 minute.

This continues until a successful BIT occurs, when the detector resumes normal operation.

Table 10: Results of a Successful BIT

Output	Result
Fault relay	<ul style="list-style-type: none">♦ Wiring options 1, 2, 4: remains CLOSED♦ Wiring options 3 and 5: remains OPEN
0-20mA output	Wiring option 1, 2, 3: Normal (4 mA)
Power LED	Green, Flashing, 1 Hz On (Normal)

Table 11: Results of an Unsuccessful BIT

Output	Result
Fault relay	<ul style="list-style-type: none">♦ Wiring option 1, 2, 4: changes to Open♦ Wiring option 3 and 5: changes to Closed
0-20mA output	Wiring option 1, 2, 3: BIT Fault (2mA)
Power LED	Yellow, Flashing, 4 Hz
BIT procedure	Performed every 1 minute

1.6.2.3 Manual BIT

The BIT is manually initiated by momentarily connecting Terminal 3 with Terminal 2 (or a switch across these terminals in the safe area).

The results of a successful and unsuccessful Manual BIT are listed in Table 12 and Table 13.

Table 12: Results of a Successful Manual BIT

Output	Result
FAULT relay	<ul style="list-style-type: none"> Wiring options 1, 2, and 4: remains CLOSED (Normal) Wiring options 3 and 5: remains OPEN (Normal)
ALARM relay	Activated for 3 sec (only when the function Alarm BIT is set to YES)
AUXILIARY relay	For wiring options 4 and 5: is activated for 3 sec (only when the function Auxiliary BIT is set to YES)
0-20mA output	Wiring option 1, 2, 3: <ul style="list-style-type: none"> Initiates 20 mA only when the function Alarm BIT is set to YES Initiates 16 mA when the function Auxiliary BIT is set to YES and the function Alarm BIT is set to NO
POWER LED	Green, Flashing, 1 Hz

Table 13: Results of an Unsuccessful Manual BIT

Output	Result
FAULT relay	<ul style="list-style-type: none"> Wiring option 1, 2, 4: changes to OPEN Wiring option 3 and 5: changes to CLOSED
0-20mA output	Wiring option 1, 2, 3: Indicates BIT FAULT (2mA)
POWER LED	Yellow, Flashing, 4 Hz

1.6.2.4 Manual BIT only selected

The BIT is initiated manually by momentarily connecting Terminal Number 3 with Terminal Number 2 or a switch across these terminals in the safe area.

2 Installing the Detector

➤ In this chapter...

<i>General Guidelines</i>	<i>page 21</i>
<i>Unpacking the Product</i>	<i>page 22</i>
<i>Required Tools</i>	<i>page 23</i>
<i>Certification Instructions</i>	<i>page 24</i>
<i>Installation Cables</i>	<i>page 25</i>
<i>Installing the Tilt Mount (part no. 40/40-001)</i>	<i>page 26</i>
<i>Connecting the Detector</i>	<i>page 28</i>
<i>Configuring your Detector</i>	<i>page 31</i>

This chapter provides basic guidelines for installing the detector. It does not attempt to cover all of the standard practices and codes of installation. Rather, it emphasizes specific points of consideration and provides some general rules for qualified personnel. Wherever applicable, special safety precautions are stressed.

2.1 General Guidelines

To ensure optimal performance and an efficient installation, consider the following guidelines:

- ♦ **Sensitivity:** To determine the level of sensitivity, consider the following:
 - ♦ Size of fire at the required distance to be detected
 - ♦ Type of flammable materials
- ♦ **Wiring:**
 - ♦ The wire gauge must be designed according to the distance from the detector to the controller and the number of detectors on the same power line. See *Wiring Instructions* on page 53.
 - ♦ To fully comply with EMC directive and protect against interference caused by RFI and EMI, the cable to the detector must be shielded and the detector must be grounded. The shield should be grounded at the detector end.
- ♦ **Spacing and Location:** The number of detectors and their locations in the protected area are determined by:
 - ♦ Size of the protected area
 - ♦ Sensitivity of the detectors
 - ♦ Obstructed lines of sight
 - ♦ Cone of view of the detectors



♦ **Environment:**

- ♦ Dust, snow or rain can reduce the detectors sensitivity and require more maintenance activities.
- ♦ The presence of high intensity flickering IR sources may affect sensitivity.

♦ **Aiming the Detector:**

- ♦ The detector should be aimed toward the center of the detection zone and have a completely unobstructed view of the protected area.
- ♦ Whenever possible, the detector face should be tilted down at a 45° angle to maximize coverage and prevent accumulation of dust and dirt.
- ♦ Do not start an installation unless all conceivable considerations regarding detection location have been taken into account.

Installation should comply with **NFPA 72E or any other local and International regulations and standards**, as applicable to flame detectors and installation of Ex approved products.

2.2 Unpacking the Product

Upon receipt of your detector, verify that you have received the following contents:

- ♦ Delivery form
- ♦ Flame detector
- ♦ Plastic Weather Cover
- ♦ User manual
- ♦ Quality document
- ♦ Tool keys (per shipment)

Check and record the following:

- 1 Verify the appropriate Purchase Order.

Record the Part Number (P/N) and Serial Number of the detectors, and the installation date in an appropriate Log-book.

- 2 Verify that all components required for the detector installation are readily available before beginning the installation. If the installation is not completed in a single session, secure and seal the detectors and conduits / cable entries.

2.2.1 Checking the Product Type

Check that your product has the configuration / options that you ordered. Check the detailed part number on the label and compare this information with the descriptions contained in **Model and Types** on page 2.

2.3 Required Tools

The detector can be installed using general-purpose common tools and equipment. Table 14 lists the specific tools required to install the detector.

Table 14: Tools

Tool	Function
Hex Key $\frac{1}{4}$ inch	Mount the detector on the tilt mount
Hex Key $\frac{3}{16}$ inch	Open and close detector cover (for wiring)
Flat Screw Driver 6 mm	Connect ground terminal
Flat Screw Driver 2.5 mm	Connect wires to the terminal blocks

For wiring, use color-coded conductors or suitable wire markings or labels. 12 to 20 AWG (0.5 mm² to 3.5 mm²) wires may be used for site wiring. The selection of wire gauge should be based on the number of detectors used on the same line and the distance from the control unit, in compliance with specifications (see *General Instructions for Electrical Wiring* on page 53).

2.4 Certification Instructions



Warning: Do not open the detector, even when isolated, when flammable atmosphere present.

Use the following certification instructions:

- ◆ The cable entry point may exceed 167°F (75°C). Suitable precautions should be taken when selecting the cable.
- ◆ The equipment may be used with flammable gases and vapors with apparatus groups IIA, IIB and IIC:
 - ◆ T5 in the ambient temperature range: -67°F (-55°C) to +167°F (+75°C).
 - ◆ T4 in the ambient temperature range: -67°F (-55°C) to +185°F (+85°C).
- ◆ Installation shall be carried out by suitably trained personnel in accordance with the applicable code of practice such as. EN 60079-14: 1997.
- ◆ Inspection and maintenance of this equipment shall be carried out by suitably trained personnel in accordance with the applicable code of practice such as EN 60079-17.
- ◆ Repair of this equipment shall be carried out by suitably trained personnel in accordance with the applicable code of practice such as EN 60079-19.
- ◆ The certification of this equipment relies upon the following materials used in its construction:
 - ◆ **Enclosure:** 316L Stainless Steel or Aluminum
 - ◆ **Window:** Sapphire Glass
- ◆ If the equipment is likely to come into contact with aggressive substances, then it is the responsibility of the user to take suitable precautions that prevent it from being adversely affected, thus ensuring that the type of protection provided by the equipment is not compromised:
 - ◆ Aggressive substances: acidic liquids or gases that may attack metals, or solvents that may affect polymeric materials.
 - ◆ Suitable precautions: regular checks as part of routine inspections or **establishing from the material's data sheets that it is resistant to** specific chemicals.

2.5 Installation Cables

Follow the following guideline for the cable installation:

- ♦ All cables to the detector must be well shielded in order to comply with EMC requirement (see *Technical Specifications* on page 64).
- ♦ Ground the detector to the nearest ground point (not more than 3m from the detector location).
- ♦ Install the detector with the cable entries placed downwards.

2.5.1 Conduit Installation

The conduit used for the cabling must comply with the following:

- ♦ To avoid water condensation water in the detector, install the detector with the conduits placed downward, that include drain holes.
- ♦ When using the optional tilt mount, use flexible conduits for the last portion connecting to the detector.
- ♦ For installations in atmospheres as defined in group B of the NFPA 72E, seal the conduits inlets.
- ♦ When pulling the cables through the conduits, ensure that they are not tangled or stressed. Extend the cables about 30 cm. (12 in.) beyond the detector location to accommodate wiring after installation.
- ♦ After the conductor cables have been pulled through the conduits, perform a continuity test.

2.6 Installing the Tilt Mount (part no. 40/40-001)

The Tilt Mount enables the detector to be rotated up to 60° in all directions.

Figure 5 shows the Detector mounted on the Tilt Mount.




Figure 5: Detector with Tilt Mount

➤ **To install the Tilt Mount and Detector:**

- 1** Place the tilt mount in its designated location and secure it with four (4) fasteners through four (4) holes 7 mm in diameter. Use the four (4) screws and spring washers according to the kit.

Note: Removing the detector for maintenance purpose does not require the Tilt Mount to be removed.
- 2** Unpack the detector.
- 3** Place the detector with its conduit/cable entries pointing downwards on the holding plate of the tilt mount. Secure the detector with $\frac{5}{16}$ " 18 UNC x 1" screw to the tilt mount.
- 4** Release the Horizontal and Vertical Locking Screws using $\frac{3}{16}$ " Hex Key such that the detector can be rotated. Point the detector towards the protected area and make certain that the view of the area is unobstructed. Secure the detector in that position by tightening the locking screws on the tilt mount. (Make sure the detector is in the correct position.)

The detector is now correctly located, aligned and ready to be connected to the system.

2.7 Connecting the Detector

This section describes how to connect the electric cabling to the detector (Figure 8).

➤ **To connect the detector to the electrical cables**

- 1** Disconnect the power.
- 2** Remove the back cover of the detector by removing three (3) socket head-screws in the cover bolts. The terminal chamber is now revealed.
- 3** Remove the protective plug mounted on the Detector Conduit/Cable entry; pull the wires through the Detector Inlet.

- 4 Use a ¾" – 14 NPT explosion-proof conduit connection or M25x1.5 flameproof gland to assemble the cable / conduit to the detector.




Figure 8: Detector with Cover Removed

- 5 Connect the wires to the required terminals on the Terminal Board according to the wiring diagram (Figure 8) and Table 15.
- 6 Connect the grounding (earth) wire to the ground (earth) screw outside the detector (Earth Terminal). The detector must be well grounded to earth ground.
- 7 Verify the wiring. Improper wiring may damage the detector.
- 8 Check the wires for secure mechanical connection and press them neatly against the terminal to prevent them from interfering while closing the back cover (Figure 8).
- 9 Place and secure the detector's back cover by screwing the three (3) socket-head-screws in the Cover Bolts (Figure 5).

2.7.1 Verifying the Detector Wiring

The detector has five output wiring options within the Exde integral terminal section of the enclosure. There are 12 terminals labeled 1-12.

Table 15 describes the function of each terminal for all the wiring options.

Table 15: Model 40/40M Wiring Options

Wire Terminal No.	Option 1 Default	Option 2	Option 3	Option 4	Option 5
1	+24 VDC	+24 VDC	+24 VDC	+24 VDC	+24 VDC
2	0 VDC	0 VDC	0 VDC	0 VDC	0 VDC
3	Manual BIT	Manual BIT	Manual BIT	Manual BIT	Manual BIT
4	Fault Relay N.C.	Fault Relay N.C.	Fault Relay N.O.	Fault Relay N.C.	Fault Relay N.O.
5					
6	Alarm Relay N.O.	Alarm Relay N.O.	Alarm Relay N.O.	Alarm Relay N.O.	Alarm Relay N.O.
7	Alarm Relay C	Alarm Relay C	Alarm Relay C	Alarm Relay C	Alarm Relay C
8	0-20mA In	Alarm Relay N.C.	Alarm Relay N.C.	Auxiliary N.O.	Auxiliary N.O.
9	0-20mA Out*	0-20mA Out*	0-20mA Out*	Auxiliary C	Auxiliary C
10	RS-485+ (1)	RS-485+ (1)	RS-485+ (1)	RS-485+ (1)	RS-485+ (1)
11	RS-485- (1)	RS-485- (1)	RS-485- (1)	RS-485- (1)	RS-485- (1)
12	RS-485 GND	RS-485 GND	RS-485 GND	RS-485 GND	RS-485 GND

*Available with the HART protocol.

Notes:

- ◆ RS-485 is used for communication network as specified in **Appendix C** (Terminals 10, 11, 12) and to connect (in safe area) to PC/Laptop for configuration/diagnostics.
- ◆ Alarm relay:
 - ◆ N.O. energized contact in wiring options 1, 4, 5.
 - ◆ N.O. and N.C. energized in options 2 and 3.
- ◆ 0-20mA is 'Sink' in option 1 and 'Source' in option 2 and 3.
- ◆ 0-20mA options 1, 2 and 3 available with the HART protocol.
- ◆ In Wiring Option 1, link Terminals 1 and 8 to change the mA output to 'Source'.

- ♦ The Fault output is N.C. energized SPST relay. The contacts are closed when the Detector is in its normal operational condition in options 1, 2 and 4, and available as N.O. energized in options 3 and 5.
- ♦ The Auxiliary output is N.O. energized (SPST) relay. The Auxiliary Relay may act in parallel with the ALARM relay to activate another external device or it may provide a warning signal, depending on the function configuration.

2.8 Configuring your Detector

You can reprogram the function setup using the RS-485 connection or using the HART protocol as follows:

- ♦ **Mini Laptop Kit** (P/N 777820): The mini laptop, pre-loaded with the Spectrex host software, enables you to re-configure settings or perform diagnostics on all 40/40 series flame detectors.

Refer to manual TM777070 for programming instructions when using the Mini Laptop Kit.

- ♦ **USB RS485 Harness Kit** (P/N 794079-5): The USB RS485 Harness Kit with RS485/USB converter, used with the Spectrex host software, enables you to connect to any available PC or laptop to re-configure settings or perform diagnostics on all 40/40 series flame detectors.

Refer to manual TM777050 for programming instructions when using the USB RS485 Harness Kit.

- ♦ **HART Protocol**: Refer to Manual TM 777030 for programming instructions.

These functions enable you to set:

- ♦ Sensitivity
- ♦ Alarm Delay
- ♦ Address Setup
- ♦ Mode of Operation
- ♦ Heated Optics Operation

The factory Default settings listed for each function are:

- ♦ Sensitivity – 30
- ♦ Alarm Delay – A
- ♦ Alarm Latch – No
- ♦ Auxiliary Relay – No
- ♦ Automatic BIT – Yes
- ♦ Alarm BIT – No
- ♦ Auxiliary BIT – No
- ♦ EOL – No

- ♦ Heated Optics – Auto
- ♦ Temperature – 41°F (5°C)

2.8.1 Sensitivity

The detector offers four (4) sensitivity settings. The settings refer to an n-heptane or gasoline fire of 1ft² (0.1m²), from low sensitivity of 50 ft. (15m) to 215 ft. (65m). For other types of fuel sensitivity, refer to Table 3.

Table 16: Sensitivity Settings

Sensitivity Setting	Detector Distance feet	Detector Distance meters
15	50	15
30 (default)	100	30
45	150	45
60	215	65

2.8.2 Alarm Delay

The detector is equipped with an Alarm Delay option, which provides programmable time delays with settings at:

- ♦ Antiflare* (default)

*The Antiflare mode is selected to prevent false alarms in locations where fast flares may be present. The Time Delay for fire alarms in this mode ranges from 2.5 to 15 seconds (usually, less than 10 seconds).

Other delays settings are available:

- ♦ 0, 3, 5, 10, 15, 20 or 30 seconds

When an Alarm (Detection) level condition occurs, the detector delays the execution of the Alarm outputs by the specified period of time. The detector then evaluates the condition for 3 seconds. If the Alarm level is still present, the Alarm outputs are activated. If this condition no longer exists, the detector returns to its standby state.

The Alarm delay option affects the output relays and the 0-20mA. The LEDs and outputs indicate warning levels during the delay time only if the fire condition exists.

2.8.3 Address Set-up

The detector provides up to 247 addresses that can be changed with the RS485 communication link or the HART protocol.

2.8.4 Function Set-up

You can select the desired functions as detailed in Table 17.

Table 17: Functions

Function	Setting
Alarm Latch	<ul style="list-style-type: none"> ♦ Yes: Enable Alarm latching. ♦ No: Disable Alarm latching (default).
Auxiliary Relay*	<ul style="list-style-type: none"> ♦ Yes: Activate Auxiliary Relay at Warning level. ♦ No: Activate Auxiliary Relay at Alarm level (default).
Automatic BIT	<ul style="list-style-type: none"> ♦ Yes: Perform Automatic & Manual Bit (default). ♦ No: Perform Manual Bit only.
Alarm BIT	<ul style="list-style-type: none"> ♦ Yes: Successful Manual Bit activates the Alarm Relay for approximately 3 seconds (default). ♦ No: Successful Manual Bit does not activate the Alarm Relay.
Auxiliary BIT*	<ul style="list-style-type: none"> ♦ Yes: Successful Manual Bit activates the Auxiliary Relay for approximately 3 seconds (default). ♦ No: Successful Manual Bit does not activate the Auxiliary Relay.
EOL*	<ul style="list-style-type: none"> ♦ Yes: Auxiliary Relay is used as End of Line. ♦ No: Auxiliary Relay operates in accordance with Function 2 and 5 (default).

Note: * only available in Model 40/40M-4XXXX and 5XXXX

2.8.5 Heated Optics

The heated optics can be defined as one of the following modes:

- ♦ Heated Mode
 - ♦ OFF: Not operated
 - ♦ On: Continuously
 - ♦ AUTO: Per temperature change

In AUTO mode, the default HEAT ON setting is 41°F (5°C). Heating stops when the temperature is 27°F (15°C) above the start temperature.

You can define the start temperature below which the window will be heated. The temperature can be defined between 32°F and 122°F (0°C to 50°C).

3 Operating the Detector

➤ In this chapter...

<i>Powering Up</i>	<i>page 35</i>
<i>Safety Precautions</i>	<i>page 36</i>
<i>Testing Procedures</i>	<i>page 37</i>

This chapter describes how to power up and test the detector. It also includes some very important safety checks that you should make before operating the detector.

3.1 Powering Up

This section describes how to power up the detector. Follow these instructions carefully to obtain optimal performance from the detector over its life cycle:

➤ To power up the detector:

- 1 Turn on the power.
- 2 Wait approximately 60 seconds for the detector to finish the start-up procedure.

Applying power initiates the following sequence of events:

- ♦ The yellow LED flashes at 4 Hz.
- ♦ BIT is executed.

If successful, the green LED flashes at 1 Hz and the FAULT relay contacts close, mA output is 4 mA.

- 3 Enter to Normal mode.

Note: The majority of detectors are used in the default non-latching alarm mode. Only perform a Reset when the Latching alarm option has been programmed.

➤ To reset the detector when it is in a LATCHED ALARM state:

- ♦ Do one of the following:
 - ♦ Disconnect power (Terminal Number 1 or Terminal Number 2).
 - or
 - ♦ Initiate a Manual BIT.

3.2 Safety Precautions

After powering-up, the detector requires almost no attention in order to function properly, but the following should be noted:

- ♦ Follow the instructions in this guide and refer to the drawings and specifications.
- ♦ Do not expose the detector to radiation of any kind unless required for testing purposes.
- ♦ Do not open the detector housing, while power is applied.
- ♦ Do not open the electronic compartment. This part should be kept closed at all times and only opened in the factory. Opening the electronic component side invalidates the warranty.
- ♦ You should only access the wiring compartment to wire or remove the detector or access RS485 terminals for maintenance.
- ♦ Disconnect or disable external devices, such as automatic extinguishing systems before carrying out any maintenance.

3.2.1 Default Functions Settings

Table 18 lists the default function configuration supplied with the detector.

Table 18: Default Function Values

Function	Value	Notes
Sensitivity	30	
Alarm Delay	A	Antiflare
Alarm Latch	No	
Auxiliary Relay	No	In wiring options 1, 2, 3 the Auxiliary Relay is not available. This function is not used.
Automatic BIT	Yes	
Alarm BIT	No	
Auxiliary BIT	No	In wiring options 1, 2, 3 the Auxiliary Relay is not available. This function is not used.
EOL	No	In wiring options 1, 2, 3 the Auxiliary Relay is not available. This function is not used.
Heat Mode	Auto	
Heat On	41 °F (5°C)	The detector starts heating the window for any temperature below this value (in degrees Celsius).

- ♦ In order to change the default function use:
 - ♦ Mini Laptop Kit P/N 777820. Refer to manual TM777070 for programming instructions when using the Mini Laptop Kit.
 - ♦ USB RS485 Harness Kit P/N 794079-5. Refer to manual TM777050 for programming instructions when using the USB RS485 Harness Kit.
 - ♦ HART protocol, refer to Manual TM777030 for instructions.

3.3 Testing Procedures

This section describes the proof testing procedure for proper operation of the detector. The detector can be tested using the Manual Built-in-Test or the Spectrex Flame Simulator 20/20-313.

The detector performs internal test continuously and automatic BIT test every 15 minutes for more details refer to *Built-In-Test (BIT)* on page 17.

This section includes the following topics:

- ✦ Automatic BIT Test, page 37
- ✦ Manual BIT Test, page 37
- ✦ Testing with Flame Simulator Model , page 37

3.3.1 Automatic BIT Test

Check that the indicators show normal conditions. See *Powering Up* on page 35.

3.3.2 Manual BIT Test

Important: If the function setup **Alarm BIT** and/or **Auxiliary BIT** are set to **Yes** (default **No**), the Alarm, Auxiliary Relay and 0-20mA outputs are activated during a Manual BIT. Therefore, automatic extinguishing systems or any external devices that may be activated during BIT **must** be disconnected.

➤ **To perform a Manual BIT:**

- 1 Verify that the detector is Normal Mode.
- 2 Initiate Manual BIT. The results of successful and unsuccessful manual BITs are detailed in Table 12 and Table 13.

3.3.3 Testing with Flame Simulator Model 20/20-313

The Flame Simulator Model 20/20-313 can be used to simulate exposure of the detector to a real fire condition. The detector is exposed to radiation at the required detection level. As a result, the detector will generate a Fire Alarm signal. See *Long Range Multi IR Flame Simulator* on page 61 for more information.

Important: If the detector is exposed to a flame simulator, the Alarm and Accessory Relays and 0-20mA are activated during the simulation. Therefore, automatic extinguishing systems or any external devices, which may be activated during this process, must be disconnected.

➤ **To perform Flame Simulator Test:**

- 1 Power up the system and wait up to 60 seconds for the detector to turn to a normal state. The Power LED turns on.



- 2** Aim the Spectrex Flame Simulator Model 20/20-313 at the target point of the detector, in a way that the radiation emitted by it is facing directly towards the detector. (See *Long Range Multi IR Flame Simulator* on page 61).
- 3** Press the operation button once. After few seconds, a successful test shows the results shown in Table 19.

Table 19: Results of Successful Flame Simulator Test

Component	Action	Notes
0-20mA	Turn to 20mA	For a few seconds and then return to 4mA
Alarm Relay	Activated	for a few seconds and then returns to Normal
Auxiliary Relay	Activated	for a few seconds and then returns to Normal
Fault Relay	Remains active during the test	
LED	Red, steady	

The detector is now ready for operation.

4 Maintenance and Troubleshooting

➤ In this chapter...

Maintenance *page 39*

Troubleshooting *page 41*

This chapter deals with preventive maintenance, describes possible faults in detector operation and indicates corrective measures. Ignoring these instructions may cause problems with the detector and may invalidate the warranty. Whenever a unit requires service, please contact Spectrex or its authorized distributor for assistance.

4.1 Maintenance

This section describes the basic maintenance steps that should be taken to keep the detector in good working condition and includes the following topics:

- ♦ General Procedures, page 39
- ♦ Periodic Procedures, page 40
- ♦ Keeping Maintenance Records, page 40

4.1.1 General Procedures

Maintenance should be performed by suitably qualified personnel, who are familiar with local codes and practice. Maintenance requires ordinary tools.

4.1.1.1 Cleaning

The detector must be kept as clean as possible. Clean the viewing window and the reflector of the Flame Detector periodically.

The frequency of cleaning operations depends upon the local environmental conditions and specific applications. The fire detection system designer will give his recommendations.

➤ To clean the detector viewing window and reflector:

- 1** Disconnect power to the detector before proceeding with any maintenance including window/lens cleaning.
- 2** Use water and detergent, and then rinse the viewing window with clean water.
- 3** Where dust, dirt or moisture accumulates on the window, first clean only with a soft optical cloth and detergent, and then rinse with clean water.

4.1.2 Periodic Procedures

In addition to preventive cleaning and maintenance, the detector should be functionally tested every six months or as dictated by local codes and regulations. These tests should also be carried out if the detector has been opened for any reason.

4.1.2.1 Power-Up Procedure

Perform Power-Up procedure every time power is restored to the system. Follow the instructions described in *Powering Up* on page 35.

4.1.2.2 Functional Test Procedure

Perform a functional test of the detector as described in *Internal Detector Tests* on page 16.

4.1.3 Keeping Maintenance Records

It is recommended that maintenance operations performed on a detector are recorded in a Log-book. The record should include the following:

- ◆ Installation date, and contractor
- ◆ Serial and tag no.
- ◆ Entries for every maintenance operation performed, including the description of the operation, date and personnel ID.

If a unit is sent to Spectrex or a distributor for service, a copy of the maintenance records should accompany it.

4.2 Troubleshooting

This section is intended to be a guide to correct problems which may happen during normal operation.

Table 20: Troubleshooting Table

Problem	Cause	Corrective Action
LEDs Off Fault Relay at N.O 0-20mA at 0mA	No power at the unit	<ul style="list-style-type: none"> Check that the correct power is sent to the detector. Check power polarity. Check wiring in the detector. Send the detector back for repairs.
Yellow LED flashes at 4 Hz Fault Relay at N.O 0-20mA at 0mA	Fault Detector <ul style="list-style-type: none"> Low Voltage Faulty Detector 	<ul style="list-style-type: none"> Check the voltage at the detector; verify at least 24V at the detector terminal. Send the detector back for repairs.
Yellow LED flashes at 4 Hz Fault Relay at N.O 0-20mA at 2mA	BIT Fault <ul style="list-style-type: none"> Faulty Detector 	<ul style="list-style-type: none"> Clean detector window. Re-power the detector. Replace the detector.
Red LED constantly on	If no fire exists, then, detector alarm latched	Perform Reset to the detector.
Alarm Relay at On 0-20mA at 20mA	Alarm condition	<ul style="list-style-type: none"> Check cause for alarm. If no alarm, re-power the detector. Send the detector back for repairs.

Appendices

A Specifications

➤ In this appendix...

<i>Technical Specifications</i>	<i>page 45</i>
<i>Electrical Specifications</i>	<i>page 46</i>
<i>Outputs</i>	<i>page 46</i>
<i>Approvals</i>	<i>page 49</i>
<i>Mechanical Specifications</i>	<i>page 49</i>
<i>Environmental Specifications</i>	<i>page 50</i>

A.1 Technical Specifications

Spectral Response	Multi IR Bands			
Detection Range (at highest Sensitivity Setting for 1ft ² (0.1m ²) pan fire)	Fuel	ft. / m	Fuel	ft. / m
	n-Heptane	215 / 65	Kerosene	150 / 45
	Gasoline	215 / 65	Ethanol 95%	135 / 40
	Diesel Fuel	150 / 45	Methanol	115 / 35
	JP5	150 / 45	IPA (Isopropyl Alcohol)	135 / 40
	Methane*	150 / 45	Polypropylene Pellets	115 / 35
	LPG*	150 / 45	Ammonia**	60 / 18
	Hydrogen*	125 / 38	Silane**	7 / 2
	Office Paper	82 / 25		
	* 30" (0.75m) high, 10" (0.25m) width plume fire			
	**20" (0.5m) high, 8" (0.2m) width plume fire			
Response Time	Typically 5 seconds			
Adjustable Time Delay	Up to 30 seconds			
Sensitivity Ranges	2 ranges for 1 ft ² (0.1m ²) n-heptane pan fire from 50 ft. (15m) to 215 ft. (65m)			
Fields of View	Gasoline: Horizontal 67°, Vertical 70° Hydrogen: Horizontal 80°, Vertical 80°			
Built-In-Test (BIT)	Automatic (and Manual)			

A.2 Electrical Specifications

Operating Voltage: 18-32 VDC

Power Consumption: Table 21

Table 21: Electrical Specifications

Operating Voltage	Status	All Outputs	Without 0-20mA
Power Consumption (Max. 24VDC)	Normal	1.61W	1.56W
	Normal when Heater On	2.28W	2.16W
	Alarm	2.64W	2.28W
	Alarm when Heater On	3.24W	2.88W
Maximum Current (Max. 24VDC)	Normal	70mA	65mA
	Normal when Heater On	95mA	90mA
	Alarm	110mA	95mA
	Alarm when Heater On	135mA	120mA
Power Consumption (Max. 18-32VDC)	Normal	1.95W	1.85W
	Normal when Heater On	2.56W	2.45W
	Alarm	3.04W	2.56W
	Alarm when Heater On	3.68W	3.2W
Maximum Current (18-32VDC)	Normal	90mA	85mA
	Normal when Heater On	105mA	100mA
	Alarm	130mA	115mA
	Alarm when Heater On	160mA	145mA

Electrical Input Protection The input circuit is protected against voltage-reversed polarity, voltage transients, surges and spikes according to MIL-STD-1275B

A.3 Outputs

Electrical Interface

There are five output-wiring options. These options must be defined at the factory per the customer order and cannot be changed at the customer facility.

See **General Instructions for Electrical Wiring** on page 53 for the wiring/terminal diagram for each option.

Unless otherwise specified, the default is Option 1. The wiring arrangement is identified on the detector by the part number (see **Model and Types** on page 2).

- **Option 1:** Power, RS-485, 0-20mA (Sink), Fault I Relay (N.C), Alarm Relay, (N.O) (see Figure 8).

Electrical Outputs

- ♦ **Option 2:** Power, RS-485, 0-20mA (Source) and HART protocol, Fault Relay (N.O), Alarm Relay, (N.O), (N.C).
- ♦ **Option 3:** Power, RS-485, 0-20mA (Source) and HART protocol, Fault Relay (N.O), Alarm Relay (N.O, N.C).
- ♦ **Option 4:** Power, RS-485, Fault Relay (N.C), Auxiliary Relay (N.O), Alarm Relay, (N.O).
- ♦ **Option 5:** Power, RS-485, Fault Relay (N.O), Auxiliary Relay (N.O), Alarm Relay, (N.O).
- ♦ **Dry Contact Relays**

Table 22: Contact Ratings

Relay Name	Type	Normal Position	Maximum Ratings
Alarm	SPDT	N.O., N.C.	2A at 30 VDC
Auxiliary	SPST	N.O.	2A at 30 VDC
Fault (see Notes 1 and 2)	SPST	N.C. or N.O	2A at 30 VDC

Notes:

1. The Fault relay (in wiring options 1, 2, 4) is normally energized closed during normal operation of the detector. The relay is de-energized open if a fault condition or low voltage situation occurs.
 2. In wiring options 3, 5 the relay is normally energized open during normal operation of the detector. The relay is de-energized close contact if a fault condition or low voltage situation.
- ♦ **0-20mA Current Output:** The 0-20mA can be Sink or Source according to the wiring option source (see *General Instructions for Electrical Wiring* on page 53). The maximum permitted load resistance is 600Ω.

Table 23: 20 mA Current Output

State	Output
Fault	0 +1 mA
BIT Fault	2 mA±10%
Normal	4 mA±10%
Warning	16 mA±5%
Alarm	20 mA±5%

♦ HART Protocol

The HART protocol is a digital communication signal at a low level on top of the 0-20mA. This is a bi-directional field communication protocol used to

communicate between intelligent field instruments and the host system. HART is available in wiring options 2 and 3.

Through the HART protocol the detector can:

- ◆ Display set-up
- ◆ Reconfigure the set-up
- ◆ Display detector status and definition
- ◆ Perform detector diagnostics
- ◆ Troubleshoot

For more details refer to *HART Manual TM777030*.

- ◆ **Communication Network:** The detector is equipped with an RS-485 communication link that can be used in installations with computerized controllers.

The communications protocol is Modbus compatible.

- ◆ This protocol is a standard and widely used.
- ◆ It enables continuous communication between a standard Modbus controller (Master device) and a serial Network of up to 247 detectors.

Heated Optics

The front window can be heated to improve performance in icing, condensation and snow conditions. The heater increases the temperature of the optical surface by 5-8°F (3-5°C) above the ambient temperature. The heated optics can be configured in three ways:

- ◆ **Off:** The optics are not heated
- ◆ **On:** The optics are heated continuously
- ◆ **Auto:** Operated only when the change of temperature requires the heating. (default)

In **Auto** mode the start heating temperature can be defined between 32°F - 122°F (0°C - 50°C). The detector stops heating the window when the temperature is 27°F (15°C) above the start temperature.

A.4 Approvals

Hazardous Area Approvals

- FM, CSA
Class I Div. 1 Groups B, C and D;
Class II/III Div. 1 Groups E, F and G.
- ATEX, IECEx
Ex II 2 G D
Ex d e IIC T5 Gb
Ex tb IIIC T96°C Db
(-55°C ≤ Ta ≤ +75°C)
or
Ex II 2 G D
Ex d e IIC T4 Gb
Ex tb IIIC T106°C Db
(-55°C ≤ Ta ≤ +85°C)

Functional Approvals

- EN54-10 approved by VdS
- FM approved per FM3260

A.5 Mechanical Specifications

Enclosure

Stainless Steel 316
or
Aluminum, heavy duty copper free (less than 1%),
red epoxy enamel finish

Water and Dust Tight

- NEMA 250 type 6p.
- IP 66 and IP 67 per EN 60529

Electronic Modules

Conformal coated

Electrical Connection (two entries)

- ¾" - 14NPT conduit
or
- M25 x 1.5

Dimensions

4" x 4.6" x 6.18" (101.6 x 117 x 157 mm)

Weight

- Stainless Steel: 6.1 lb. (2.8 kg)
- Aluminium: 2.8 lb. (1.3 kg)

A.6 Environmental Specifications

The SharpEye 40/40M is designed to withstand harsh environmental conditions.

High Temperature	<ul style="list-style-type: none">• Designed to meet MIL-STD-810C, method 501.1 procedure II• Operating temperature: +167°F (+75 °C)• Storage temperature: +185 °F (+85 °C)
Low Temperature	<ul style="list-style-type: none">• Designed to meet MIL-STD-810C, method 502.1, procedure I• Operating temperature: -57°F (-50°C)• Storage temperature: -65°F (-55°C)
Humidity	<ul style="list-style-type: none">• Designed to meet MIL-STD-810C, method 507.1, procedure IV• Relative humidity of up to 95% for the operational temperature range
Salt Fog	<ul style="list-style-type: none">• Designed to meet MIL-STD-810C, method 509.1, procedure I• Exposure to a 5% Salt Solution Fog for 48 hours
Dust	<ul style="list-style-type: none">• Designed to meet MIL-STD-810C, method 510.1, procedure I• Exposure to a dust concentration of 0.3 frames/cubic ft. at a velocity of 1750 fpm, for 12 hours
Vibration	<ul style="list-style-type: none">• Designed to meet MIL-STD-810C, method 514.2, procedure VIII• Vibration at an acceleration of 1.1g within the frequency range of 5-30 Hz, and an acceleration of 3g within the frequency range of 30-500 Hz
Mechanical Shock	<ul style="list-style-type: none">• Designed to meet MIL-STD-810C, method 516.2, procedure I• Mechanical Shock of 30g half-sine wave, for 11 msec

**Electromagnetic
Compatibility (EMC)****Table 24: Electromagnetic Compatibility (EMC)**

	Test Standard	Level Per
Electrostatic Discharge ESD	IEC 61000-4-2	IEC 61326-3
Radiated EM Field	IEC 61000-4-3	IEC 61326-3
Electrical Fast Transients	IEC 61000-4-4	IEC 61326-3
Surge	IEC 61000-4-5	IEC 61326-3
Conducted Disturbances	IEC 61000-4-6	IEC 61326-3
Power Freq. Magnetic Field	IEC 61000-4-8	IEC 61326-3
Radiated Emission	IEC 61000-6-3	EN 55022
Conducted Emission	IEC 61000-6-3	EN 55022
Immunity to Main Supply Voltage Variations	MIL-STD-1275B	

To fully comply with EMC directive 2004/108/EC and protect against interference caused by RFI and EMI, the cable to the detector must be shielded and the detector must be grounded. The shield should be grounded at the detector end.

B Wiring Instructions

➤ In this appendix...

General Instructions for Electrical Wiring *page 53*

Typical Wiring Configurations *page 55*

B.1 General Instructions for Electrical Wiring

Follow the instructions detailed in this section for determining the correct wire gauge to be used for the installation.

- 1 Use Table 25 to determine the required wire gauge /size for general wiring, such as relay wiring. Calculate the permitted voltage drop with respect to load current, wire gauge and length of wires.

Table 25: Maximum DC resistance at 68°F (20°C) for copper wire

AWG #	mm ²	Ohm per 100 ft.	Ohm per 100 m
26	0.12 - 0.15	4.32	14.15
24	0.16 - 0.24	3.42	11.22
22	0.30 - 0.38	1.71	5.60
20	0.51 - 0.61	1.07	3.50
18	0.81 - 0.96	0.67	2.20
16	1.22 - 1.43	0.43	1.40
14	1.94 - 2.28	0.27	0.88
12	3.09 - 3.40	0.17	0.55
10	4.56 - 6.64	0.11	0.35

- 2 Use Table 26 to select wire gauge for power supply wires. **DO NOT connect any circuit or load to detectors' supply inputs.**
 - ♦ Select **Number of detectors** connected in one circuit.
 - ♦ Select wiring **Length** per your installation requirements.
 - ♦ Refer to **Power Supply Range** for voltage extreme applied.

Table 26: Wiring length in feet (meter)

Number of Detectors	Recommended Wire Diameter (AWG)					Power Supply Range (VDC)
	18	16	14	-	-	
24	18	16	14	-	-	22-32
20	18	16	14	-	-	22-32
16	20	18	16	14	-	22-32
12	20	18	16	14	-	20-32
8	20	18	16	14	-	20-32
4 and less	20	18	16	16	14	20-32
Ft (m)	164 (50)	328 (100)	492 (150)	656 (200)	820 (240)	
	Max. Length from Power Supply to Last Detector					

Calculation Formula

Use the following formula to calculate minimum wire gauge per wire length between the power supply (controller) and the detector, considering the number of detectors on the same power line, where:

L = Actual wire length between the detector and the power supply.

N = Number of detectors per loop.

R = Resistance of wire per 100 m (see Table 26).

V = Voltage drop on the wire.

Calculate the voltage drop on the wire as follows:

$$V = \frac{2L \times R}{100} \times N \times 0.2A$$

20+V = Minimum required voltage of the power supply

0.2A is the maximum power consumption of the detector

For example,

If N=1 (1 detector in loop)

$$L=1000m$$

Wire size = 1.5mm² (see Table 25, the resistance per 100m for 1.5mm² is **1.4Ω**)

You calculate the voltage drop in the wire as follows:

$$\frac{2 \times 1000 \times 1.4\Omega}{100} \times 1 \times 0.2A = 5.6V$$

The minimum voltage of the power supply should be 20V + 5.6V = 25.6V

B.2 Typical Wiring Configurations

This section describes examples of typical wiring configurations.




Figure 9: Wiring Terminals

Table 27: Wiring Connections

Wiring Option	Detector Model	Terminals		
		5	8	9
1	40/40M-1XXXX	Fault Relay (N.C)	0-20mA (Sink)	0-20mA (Sink)
2	40/40M-2XXXX	Fault Relay (N.C)	Alarm Relay (N.C)	0-20mA Source
3	40/40M-3XXXX	Fault Relay (N.O)	Alarm Relay (N.C)	0-20mA Source
4	40/40M-4XXXX	Fault Relay (N.C)	Auxiliary Relay (N.O)	Auxiliary Relay N.O.
5	40/40M-5XXXX	Fault Relay (N.O)	Auxiliary Relay (N.O)	Auxiliary Relay N.O.




Figure 10: Typical Wiring for 4 Wire Controllers (Using Option 1 or 2 Wiring)




Figure 11: 0-20mA Wiring Option 1 (Sink 4-Wire) - Default




Figure 12: 0-20mA Wiring Option 1 (Converted to Source 3-Wire)




Figure 13: 0-20mA Wiring Option 1 (Non-isolated Sink 3-Wire)




Figure 14: 0-20mA Wiring Option 2 and 3 (Source 3-Wire available with the HART Protocol)

Note: There are no 0-20mA outputs in wiring options 4 and 5.

C RS-485 Communication Network

➤ **In this appendix...**

RS-485 Overview

page 59

C.1 RS-485 Overview

By using the RS-485 network capability of the Multi IR detector and additional software, it is possible to connect up to 32 detectors in an addressable system with four (4) wires only (2 for power and 2 for communication). Using repeaters, the number of detectors can be much larger (32 detectors for each repeater) up to 247 on the same four (4) wires. When using the RS-485 network, it is possible to read each detector status (FAULT, WARNING, and ALARM) and to initiate a BIT to each detector individually.

For more details, consult Spectrex.




Figure 15: RS-485 Networking

D Accessories

➤ In this appendix...

<i>Long Range Multi IR Flame Simulator</i>	<i>page 61</i>
<i>Tilt Mount - P/N 40/40-001</i>	<i>page 64</i>
<i>Duct Mount P/N 777670</i>	<i>page 65</i>
<i>Weather Cover - P/N 777163</i>	<i>page 66</i>
<i>Laser Detection Coverage Pointer - P/N 777166</i>	<i>page 67</i>
<i>Air Shield - P/N 777650</i>	<i>page 68</i>

This appendix describes the accessories that can help you maximize fire detection with the SharpEye Multi IR flame detector:

D.1 Long Range Multi IR Flame Simulator

The SharpEye Multi IR Long Range Flame Simulator 20/20-313 is designed specifically for use with SharpEye flame detectors. The Flame Simulator emits IR radiation in a unique sequential pattern corresponding to and recognizable by the detector as fire. This allows the detectors to be tested under simulated fire conditions without the associated risks of an open flame.



Figure 16: SharpEye Multi IR Long Range Flame Simulator 20/20-313

D.1.1 Unpacking

Verify that you have received the following contents:

- ◆ Delivery form
- ◆ Flame Simulator with integral batteries
- ◆ Battery charger
- ◆ Storage case

D.1.2 Operating Instructions

Warning: Do not open the Flame Simulator to charge the batteries or for any other reason in a hazardous area.

Caution: The following test simulates a real fire condition and may activate the extinguishing system or other alarms. If this is not desired, disconnect/inhibit them before the test and reconnect after the simulation.

➤ **To simulate a fire:**

- 3** Aim the Flame Simulator towards the detector's Target Point




Figure 17: 40/40M Multi IR Detector Target Point

- 4** When testing keep a distance of at least 50 cm (20 inches) from the detector.
- 5** Press the operation button once. Fire simulation lasts for 20 seconds. The detector sends an alarm signal (solid red LED).
- 6** Wait 20 seconds before repeating the test.
- 7** Verify that the optical window is clean.

D.1.3 Range

Table 28: Sensitivity Ranges

Sensitivity	Detection Range (ft. / m)	Standard Test Range (ft. / m)
1 (Low)	50 / 15	7 / 2.2
2	100 / 30	14.5 / 4.5
3	150 / 45	22 / 7
4 (High)	215 / 65	29 / 9

Notes:

- ♦ The minimum distance from the detector is 20 inches (50 cm).
At extreme temperatures, there is a 15% maximum reduction in the range.

Important: Keep the Flame Simulator in a safe place when not in use.

D.1.4 Charging the Battery

The Flame Simulator uses NiCd batteries as a rechargeable power source. When the batteries are fully charged, the simulator operates for at least 60 times without recharging. An internal buzzer is sounded when the voltage from the batteries is lower than the required operational level.

➤ **To charge the battery:**

- 1** Place the Flame Simulator on a table in a safe area.
- 2** Turn the sealed plug (next to the operation button) counter-clockwise with a suitable wrench.
- 3** Connect the battery charger.
- 4** Charge for a maximum of 14 hours.
- 5** Disconnect the charger.
- 6** Tighten the sealed plug clockwise.

Warning: Charge the simulator only when the battery is fully discharged. During activation of the flame simulator, buzzer activation indicates that the battery is discharged.

D.1.5 Technical Specifications

Mechanical	<ul style="list-style-type: none">• Explosion Proof Enclosure:• AFM(designed to meet)• Class I, Division 1 & 2 Groups B, C and D• Class II, Division 1 & 2 Groups E, F and G• ATEX EX II2G NEMKO 02ATEX255• EExd IIB T5 50°C per En 50-014 & EN50-018
Electrical	<ul style="list-style-type: none">• Power: 8 VDC Max.• 6 x Rechargeable 1.2 VDC NiCd Batteries• Current: 2.5A Avg.• Charge: 400 mA for 14 Hours
Environment	<ul style="list-style-type: none">• Temperature Range: -4 to +122°F (-20 to +50°C)• Vibration Protection: 1g (10-50hz)• Water and Dust: IP 67 per EN 60529
Physical	<ul style="list-style-type: none">• Dimensions: 11.5 x 10.1 x 3.9 in (292 x 258 x 100 mm)• Weight: 7.5 lb. (3.4 Kg)

D.2 Tilt Mount - P/N 40/40-001

The Tilt mount provides accurate directional selection for optimum area coverage.




Figure 18: Tilt Mount

D.3 Duct Mount P/N 777670

The Duct Mount is suitable for use with the SharpEye 40/40 Series Optical Flame Detector 40/40M, for both the aluminum and st.st. enclosure.

The Duct Mount allows flame detection in areas where high temperatures exist or in cases where the detector cannot be installed inside the area. It comprises a special duct mount arrangement with specific optical window to allow installation in high temperature duct applications.

The Duct Mount will limit the cone of vision of the installed detector to 65 horizontal and 65 vertical.

The temperature allowed for the duct mount to be installed at is -55°C to +200°C (-67°F to +392°F).

For more instructions refer to TM777670




Figure 19: Duct Mount

D.4 Weather Cover - P/N 777163

The Weather Cover protects the detector from different weather conditions, such as snow and rain.




Figure 20: Weather Cover

D.5 Laser Detection Coverage Pointer - P/N 777166

The Laser Detection Coverage Pointer evaluates detector coverage on-site. The device is an add-on accessory that enables designers and installers to optimize detector location and assess the actual coverage of installed detectors.

The device is universal and can be used with all 40/40 SharpEye Optical Flame Detectors.




Figure 21: Laser Detection Coverage Pointer

D.6 Air Shield - P/N 777650

The Air Shield is suitable for use with the SharpEye 40/40 Series Optical Flame Detector 40/40M, for both the aluminum and st.st. enclosures.

Optical flame detectors are often used in highly polluted or dirty areas that force maintenance personnel to access the detector frequently to clean its optical window. The special Air Shield, developed for SharpEye 40/40 series optical flame detectors, allows their installation under tough environmental conditions where they may be exposed to oil vapors, sand, dust and other particulate matter.

The temperature of the air supply to the Air Shield should not exceed 60°C (140°F) at any time.

Air pressure source: clean, dry and oil-free air

Pressure: 2-3 bar (30-45 psi)

Fitting: 7/16" – 20UNF-2A

Operation Temperature: -55°C to +85°C (-67°F to +185°F)

For more instructions, refer to TM777650.




Figure 22: Air Shield

E SIL-2 Features

➤ **In this appendix...**

40/40M Flame Detector

page 69

E.1 40/40M Flame Detector

This appendix details the special conditions to comply with the requirements of EN 61508 for SIL 2.

The 40/40M Flame Detector can only be used in low or high demand mode applications, see IEC 61508.4, Chapter 3.5.12.

E.1.1 Safety Relevant Parameters

Perform the following functional checks of the detector:

- ◆ **Alternative 1:** Functional check of the detector every 180 days:
 - ◆ **HFT:** 0
 - ◆ **PFD:** 3.3×10^{-4} ($\approx 3.3\%$ of SIL-2) if only Alarm Relay is used for alerting.
 - ◆ **PFD:** 3.6×10^{-4} ($\approx 3.6\%$ of SIL-2) if 0-20mA interface is used as alarm.
 - ◆ **PFH:** $1.6 \times 10^{-7} \text{ 1/h}$ ($\approx 16.4\%$ of SIL-2) for 0-20mA application.
 - ◆ **SFF:** 95% fulfills the conditions of EN 61508 for SIL2
- ◆ **Alternative 2:** Functional check of the detector every 365 days:
 - ◆ **HFT:** 0
 - ◆ **PFD:** 5.1×10^{-4} ($\approx 5.1\%$ of SIL-2) if only Alarm Relay is used for alerting.
 - ◆ **PFD:** 5.6×10^{-4} ($\approx 5.6\%$ of SIL-2) if 0-20mA interface is used.
 - ◆ **PFH:** $1.6 \times 10^{-7} \text{ 1/h}$ ($\approx 16.4\%$ of SIL-2) for 0-20mA application.
 - ◆ **SFF:** 95% fulfills the conditions of EN 61508 for SIL2

E.1.2 Guidelines for Configuring, Installing, Operating and Service

The alert conditions according to SIL 2 can be implemented by an:

- ◆ Alert signal via 20mA current loop
- or
- ◆ Alert signal via alarm relay and the fault relay

E.1.2.1 Conditions for Safe Operating

- 1** The flame detector shall consist only of the approved hardware and software modules.
- 2** The 24V power supply must fulfill the requirements for PELV / SELV of EN 60950.
- 3** The automatic BIT (Built-In-Test) must be activated.
- 4** The set-up parameters must be verified (as described in *Using the 0-20mA Interface for Alerting* on page 70, point 1 and in *Using the Alarm Relay Contact for Alerting* on page 70, point 1) and the function of the 40/40 Flame Detector (flame detection, function of the 0-20mA interface, relay functions) must be checked completely.

E.1.2.2 Using the 0-20mA Interface for Alerting

- 1** The following parameters shall be set:
 - ♦ AUTOMATIC BIT test = on
 - ♦ Connected to 0-20mA Terminals
- 2** The following allowed output current must be supervised with an accuracy of $\pm 5\%$:
 - ♦ Normal State = 4mA
 - ♦ Warning State = 16mA
 - ♦ Alarm State = 20mA
- 3** The output current must be supervised regarding the over-and under run of the 0-20mA.
- 4** The 0-20mA can be used as low and high demand mode.

E.1.2.3 Using the Alarm Relay Contact for Alerting

- 1** The following parameters shall be set:
 - ♦ AUTOMATIC BIT Test = on
 - ♦ Connected to N.C contact of Alarm Relay Terminals
 - ♦ Connected to Fault Relay Terminals
- 2** The relay contacts ("alarm" – and "faulty relay") must be protected with a fuse rated at 0.6 of the nominal specified relay contact current.
- 3** The maximum contact rating that is allowed per SIL-2 is 30VDC.
- 4** It is to be considered that the contact of the Alarm Relay opens if there is a fire alarm.
- 5** During the forwarding and evaluation of the alarm it must be noted that the relay contact opens.
- 6** The alarm relay can be used as low demand only.

E.1.2.4 Other

- 1** The complete function of the flame detector (flame detection, function of the 0-20mA interface, the relays) must be examined at least every six or twelve months (see ***Safety Relevant Parameters*** on page 69, when the flame detector must be switched OFF and ON.
- 2** The window of the sensor must be examined at appropriate time intervals for partial contamination.
- 3** The HART and the RS 485 interfaces must not be used for the transmission of the safety-related data.

Technical Support

For all technical assistance or support, contact:



218 Little Falls Road
Cedar Grove, NJ 07009, USA

Tel: +1 (973) 239 8398

Fax: +1 (973) 239 7614

Email: spectrex@spectrex.net

Web-site: www.spectrex.net

Your Local Office:

SPECTREX INC.

Texas (USA)

Mr. Jay Cooley, Regional Sales Manager:
16203 Park Row, Suite 150
Houston, Texas 77084
USA

Phone: +1 (832) 321 5229

Email: jay@spectrex.net

Europe

Mr. Ian Buchanan, Regional Manager:
6 Applecross Road
Glasgow G66 3TJ
United Kingdom

Phone: +44 (0) 141 578 0693

Email: ian@spectrex.net

Far East

Mr. Deryk Walker, Regional Sales Manager
59 Fen Ji Hu, Danshui
Taipei County 25163
Taiwan (ROC)

Phone: +886 2 8626 2893

Mobile: +886 926 664 232

Email: deryk@spectrex.net