

CE EMC TEST REPORT

for

AC/DC Switching Adapter

MODEL:

**CP1220, CP1215, CP1210, CP0920, CP0910,
CP0630, CP0620, CP0610, CP0540, CP0530,
CP0520, CP0510, CP050085**

Test Report Number:

80820002-E

Issued for

Coming Data Co., Ltd.

5F-1 No13, WU CHUNG 1 RD, HSIN CHUNG CITY,
TAIPEI HSIEN, TAIWAN, R.O.C.

Issued By:

Compliance Certification Services Inc.

Wugu Laboratory

No. 11, Wu-Gong 6th Rd., Wugu Industrial Park,
Taipei Hsien 248, Taiwan (R.O.C.)

TEL: 886-2-2299-9720

FAX: 886-2-2299-9721

E-Mail: service@tw.ccsemc.com

Issued Date: August 26, 2009



Note: This report shall not be reproduced except in full, without the written approval of Compliance Certification Services Inc. This document may be altered or revised by Compliance Certification Services Inc. personnel only, and shall be noted in the revision section of the document. The client should not use it to claim product endorsement by TAF, A2LA, NIST or any government agencies. The test results in the report only apply to the tested sample.



Revision History

Rev.	Issue Date	Revisions	Effect Page	Revised By
00	August 26, 2009	Initial Issue	ALL	Angel Cheng



TABLE OF CONTENTS

1 TEST CERTIFICATION 4

2 TEST RESULT SUMMARY 5

3 EUT DESCRIPTION 6

4 TEST METHODOLOGY 8

4.1. DECISION OF FINAL TEST MODE 8

4.2. EUT SYSTEM OPERATION 8

5 SETUP OF EQUIPMENT UNDER TEST 9

5.1. DESCRIPTION OF SUPPORT UNITS 9

5.2. CONFIGURATION OF SYSTEM UNDER TEST 10

6 FACILITIES AND ACCREDITATIONS 11

6.1. FACILITIES 11

6.2. ACCREDITATIONS 11

6.3. MEASUREMENT UNCERTAINTY 12

7 EMISSION TEST 13

7.1. CONDUCTED EMISSION MEASUREMENT 13

7.2. CONDUCTED EMISSION MEASUREMENT AT TELECOMMUNICATION PORTS 18

7.3. RADIATED EMISSION MEASUREMENT 21

7.4. HARMONICS CURRENT MEASUREMENT 26

7.5. VOLTAGE FLUCTUATION AND FLICKS MEASUREMENT 29

8 IMMUNITY TEST 33

8.1. GENERAL DESCRIPTION 33

8.2. GENERAL PERFORMANCE CRITERIA DESCRIPTION 34

8.3. ELECTROSTATIC DISCHARGE (ESD) 35

8.4. RADIATED, RADIO-FREQUENCY, ELECTROMAGNETIC FIELD (RS) 39

8.5. ELECTRICAL FAST TRANSIENT (EFT) 44

8.6. SURGE IMMUNITY TEST 47

8.7. CONDUCTED RADIO FREQUENCY DISTURBANCES (CS) 50

8.8. POWER FREQUENCY MAGNETIC FIELD 55

8.9. VOLTAGE DIP & VOLTAGE INTERRUPTIONS 58



1 TEST CERTIFICATION

Product:	AC/DC Switching Adapter	
Model:	CP1220 (12V/2A), CP1215 (12V/1.5A), CP1210 (12V/1A), CP0920 (9V/2A), CP0910 (9V/1A), CP0630 (6V/3A), CP0620 (6V/2A), CP0610 (6V/1A), CP0540 (5V/4A), CP0530 (5V/3A), CP0520 (5V/2A), CP0510 (5V/1A), CP050085 (5V/0.85A)	
Brand:	Coming Data	
Applicant:	Coming Data Co., Ltd. 5F-1 No13, WU CHUNG 1 RD, HSIN CHUNG CITY, TAIPEI HSIEN, TAIWAN, R.O.C.	
Manufacturer:	Coming Data Co., Ltd. 5F-1 No13, WU CHUNG 1 RD, HSIN CHUNG CITY, TAIPEI HSIEN, TAIWAN, R.O.C.	
Tested:	August 21 ~ 22, 2009	
Test Voltage:	230VAC/50Hz	
Applicable Standards:	EN 55022: 2006 + A1: 2007, Class B EN 61000-3-2: 2006, Class A EN 61000-3-3: 2008	EN 55024: 1998 + A1: 2001 + A2: 2003 IEC 61000-4-2: 1995 + A1: 1998 + A2: 2000 IEC 61000-4-3: 2006 IEC 61000-4-4: 2004 IEC 61000-4-5: 2005 IEC 61000-4-6: 2003 + A1: 2004+ A2: 2006 IEC 61000-4-8: 1993 + A1: 2000 IEC 61000-4-11: 2004

Deviation from Applicable Standard

The radiated emissions test items was tested at Compliance Certification Services Inc. (Linkou Lab.)
The test equipments were listed in page 20 and the test data, please refer page 23 ~ 24.

The above equipment has been tested by Compliance Certification Services Inc., and found compliance with the requirements set forth in the technical standards mentioned above. The results of testing in this report apply only to the product/system, which was tested. Other similar equipment will not necessarily produce the same results due to production tolerance and measurement uncertainties.

Approved by:

Reviewed by:

Rex Lai

Gina Lo for

Rex Lai
Section Manager

Amanda Wu
Section Manager



2 TEST RESULT SUMMARY

EMISSION			
Standard	Item	Result	Remarks
EN 55022: 2006 + A1:2007	Conducted (Main Port)	PASS	Meet Class B limit
	Conducted (Telecom port)	PASS	Meet Class B limit
	Radiated	PASS	Meet Class B limit
EN 61000-3-2: 2006	Harmonic current emissions	PASS	Meet Class A limit
EN 61000-3-3: 2008	Voltage fluctuations & flicker	PASS	Meets the requirements

IMMUNITY [EN 55024 (1998 + A1: 2001 + A2: 2003)]			
Standard	Item	Result	Remarks
IEC 61000-4-2: 1995 + A1: 1998 + A2: 2000	ESD	PASS	Meets the requirements of Performance Criterion B
IEC 61000-4-3: 2006	RS	PASS	Meets the requirements of Performance Criterion A
IEC 61000-4-4: 2004	EFT	PASS	Meets the requirements of Performance Criterion B
IEC 61000-4-5: 2005	Surge	PASS	Meets the requirements of Performance Criterion B
IEC 61000-4-6: 2006	CS	PASS	Meets the requirements of Performance Criterion A
IEC 61000-4-8: 1993 + A1: 2000	PFMF	PASS	Meets the requirements of Performance Criterion A
IEC 61000-4-11: 2004	Voltage dips & voltage variations	PASS	Meets the requirements of Voltage Dips: 1) >95% reduction Performance Criterion B 2) 30% reduction Performance Criterion C Voltage Interruptions: 1) >95% reduction Performance Criterion C

Note: (1). The test result judgment is decided by the limit of test standard

(2). The information of measurement uncertainty is available upon the customer's request.

3 EUT DESCRIPTION

Product	AC/DC Switching Adapter
Brand Name	Coming Data
Model	CP1220 (12V/2A), CP1215 (12V/1.5A), CP1210 (12V/1A), CP0920 (9V/2A), CP0910 (9V/1A), CP0630 (6V/3A), CP0620 (6V/2A), CP0610 (6V/1A), CP0540 (5V/4A), CP0530 (5V/3A), CP0520 (5V/2A), CP0510 (5V/1A), CP050085 (5V/0.85A)
Applicant	Coming Data Co., Ltd.
Housing material	Plastic
Serial Number	80820002
Received Date	August 20, 2009
EUT Power Rating	I/P: 230 ~ 50Hz O/P: List as below
AC Power Cord Type	N/A (Wall-mounted)

Remark:

1. All the above models are identical except for the designation of model numbers and ampere
2. Client consigns only one sample to test (model number: CP1220 (12V/2A)). Therefore, the testing Lab. just guarantees the unit, which has been tested.

Model	Voltage	Ampere
CP1220 (12V/2A)	12V	2A
CP1215 (12V/1.5A)	12V	1.5A
CP1210 (12V/1A)	12V	1A
CP0920 (9V/2A)	9V	2A
CP0910 (9V/1A)	9V	1A
CP0630 (6V/3A)	6V	3A
CP0620 (6V/2A)	6V	2A
CP0610 (6V/1A)	6V	1A
CP0540 (5V/4A)	5V	4A
CP0530 (5V/3A)	5V	3A
CP0520 (5V/2A)	5V	2A
CP0510 (5V/1A)	5V	1A
CP050085 (5V/0.85A)	5V	0.85A



I/O PORT

I/O PORT TYPES	Q'TY	TESTED WITH
N/A		

4 TEST METHODOLOGY

4.1. DECISION OF FINAL TEST MODE

1. The following test mode was scanned during the preliminary test:

Pre-Test Mode
Mode 1: CP1220_Full Load
Mode 2: CP0920_Full Load
Mode 3: CP0540_Full Load

2. After the preliminary scan, the following test mode was found to produce the highest emission level.

Final Test Mode		
Emission	Conducted Emission	Mode 1
	Radiated Emission	Mode 1
Immunity		Mode 1

Then, the above highest emission mode of the configuration of the EUT and cable was chosen for all final test items.

4.2. EUT SYSTEM OPERATION

1	EUT Power on.
2	Connection load, The definite output voltage electric current is whether normal.
3	Start the test.

Note: Test program is self-repeating throughout the test.



5 SETUP OF EQUIPMENT UNDER TEST


5.1. DESCRIPTION OF SUPPORT UNITS

The EUT has been tested as an independent unit together with other necessary accessories or support units. The following support units or accessories were used to form a representative test configuration during the tests.

No.	Equipment	Trade Name	Serial No.	FCC ID	Model No.	Data Cable	Power Cord
1	Load	N/A	N/A	N/A	N/A	Unshielded, 1.8m	N/A
2	Multimeter	DHA	DH-370B	N/A	N/A	Unshielded, 1m*2	N/A

Note: Grounding was established in accordance with the manufacturer's requirements and conditions for the intended use.

5.2. CONFIGURATION OF SYSTEM UNDER TEST





6 FACILITIES AND ACCREDITATIONS

6.1. FACILITIES

All measurement facilities used to collect the measurement data are located at:

- No. 81-1, Lane 210, Pa-De 2nd Rd., Luchu Hsiang, Taoyuan Shien, Taiwan.
- No.11, Wugong 6th Rd., Wugu Industrial Park, Taipei Hsien 248, Taiwan

The sites are constructed in conformance with the requirements of ANSI C63.4 and CISPR Publication 22. All receiving equipment conforms to CISPR 16-1-1, CISPR 16-1-2, CISPR 16-1-3, CISPR 16-1-4, CISPR 16-1-5.

6.2. ACCREDITATIONS

Our laboratories are accredited and approved by the following approval agencies according to ISO/IEC 17025.

USA	FCC, A2LA
Canada	INDUSTRY CANADA
Taiwan	TAF, NCC

Copies of granted accreditation certificates are available for downloading from our web site, <http://www.ccsemc.com>

6.3. MEASUREMENT UNCERTAINTY

Where relevant, the following measurement uncertainty levels have been estimated for tests performed on the EUT as specified in CISPR 16-4-2:

Measurement	Frequency	Uncertainty
Conducted emissions	9kHz~30MHz	+/-2.81dB
Radiated emissions # 1	30~200MHz	+/-3.88 dB
	200~1000MHz	+/-3.87 dB

This uncertainty represents an expanded uncertainty expressed at approximately the 95% confidence level using a coverage factor of k=2.

Consistent with industry standard (e.g. CISPR 22: 2006, clause 11, Measurement Uncertainty) determining compliance with the limits shall be base on the results of the compliance measurement.

Consequently the measure emissions being less than the maximum allowed emission result in this be a compliant test or passing test.

The acceptable measurement uncertainty value without requiring revision of the compliance statement is base on conducted and radiated emissions being less than UCISPR which is 3.6dB and 5.2dB respectively. CCS values (called ULab in CISPR 16-4-2) is less than UCISPR as shown in the table above. Therefore, MU need not be considered for compliance.



7 EMISSION TEST

7.1. CONDUCTED EMISSION MEASUREMENT

7.1.1. LIMITS

Frequency (MHz)	Class A (dBuV)		Class B (dBuV)	
	Quasi-peak	Average	Quasi-peak	Average
0.15 - 0.5	79	66	66 - 56	56 - 46
0.50 - 5.0	73	60	56	46
5.0 - 30.0	73	60	60	50

- Note:** (1). The lower limit shall apply at the transition frequencies.
 (2). The limit decreases in line with the logarithm of the frequency in the range 0.15 to 0.50 MHz.
 (3). All emanations from a class A/B digital device or system, including any network of conductors and apparatus connected thereto, shall not exceed the level of field strengths specified above.

7.1.2. TEST INSTRUMENTS

Conducted Emission Room				
Name of Equipment	Manufacturer	Model	Serial Number	Calibration Due
EMI Test Receiver 9kHz-30MHz	Rohde & Schwarz	ESHS30	828144/003	11/18/2010
Two-Line V-Network 9kHz-30MHz	Schaffner	NNB41	03/10013	06/11/2010
LISN 10kHz-100MHz	EMCO	3825/2	9106-1809	04/09/2010
ISN 9kHz-30MHz	FCC	FCC-TLISN-T4	20167	09/14/2010
Test S/W	LABVIEW (V 6.1)			

Note: The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.



7.1.3. TEST PROCEDURES (please refer to measurement standard or CCS SOP PA-031)


Procedure of Preliminary Test

- The EUT and support equipment, if needed, were set up as per the test configuration to simulate typical usage per the user's manual. When the EUT is a tabletop system, a wooden table with a height of 0.8 meters is used and is placed on the ground plane as per EN 55022 (see Test Facility for the dimensions of the ground plane used). When the EUT is a floor standing equipment, it is placed on the ground plane, which has a 3-12 mm non-conductive covering to insulate the EUT from the ground plane.
- All I/O cables were positioned to simulate typical actual usage as per EN 55022.
- The EUT installed by AC main power, through a Line Impedance Stabilization Network (LISN), which was supplied power source and was grounded to the ground plane.
- All support equipment power by a second LISN.
- The test program of the EUT was started. Emissions were measured on each current carrying line of the EUT using an EMI Test Receiver connected to the LISN powering the EUT.
- The Receiver scanned from 150kHz to 30MHz for emissions in each of the test modes.
- During the above scans, the emissions were maximized by cable manipulation.
- The test mode(s) described in Item 3.1 were scanned during the preliminary test.
- After the preliminary scan, we found the test mode described in Item 3.1 producing the highest emission level.
- The worst configuration of EUT and cable of the above highest emission level were recorded for reference of the final test.

Procedure of Final Test

- EUT and support equipment were set up on the test bench as per the configuration with highest emission level in the preliminary test.
- A scan was taken on both power lines, Line 1 and Line 2, recording at least the six highest emissions. Emission frequency and amplitude were recorded into a computer in which correction factors were used to calculate the emission level and compare reading to the applicable limit.
- The test data of the worst-case condition(s) was recorded.

7.1.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.


7.1.5. DATA SAMPLE

Frequency (MHz)	QuasiPeak reading (dBuV)	Average reading (dBuV)	Correction factor (dB)	QuasiPeak result (dBuV)	Average result (dBuV)	QuasiPeak limit (dBuV)	Average limit (dBuV)	QuasiPeak margin (dB)	Average margin (dB)	Remark
x.xx	43.95	33.00	10.00	53.95	43.00	56.00	46.00	-2.05	-3.00	Pass

Frequency (MHz) = Emission frequency in MHz
 Reading (dBuV) = Uncorrected Analyzer/Receiver reading + Insertion loss of LISN, if it > 0.5 dB
 Correction Factor (dB) = LISN Factor + Cable loss
 Result (dBuV) = Raw reading converted to dBuV and CF added
 Limit (dBuV) = Limit stated in standard
 Margin (dB) = Result (dBuV) – Limit (dBuV)

7.1.6. TEST RESULTS

Job No.:	80820002	Date:	2009/8/21
Company:	Coming Data Co., Ltd.	Time:	PM 07:25:43
Standard:	EN55022 Class B Conduction(QP)	Temp.(°C)/Hum.(%):	22(°C)/45%
Test item:	Conduction test	Test By:	Jerry Lin
Line:	L1	Test Voltage:	AC 230V/50Hz
Model:	CP1220	Test Mode:	Mode 1




No.	Frequency (MHz)	QuasiPeak reading (dBuV)	Average reading (dBuV)	Correction factor (dB)	QuasiPeak result (dBuV)	Average result (dBuV)	QuasiPeak limit (dBuV)	Average limit (dBuV)	QuasiPeak margin (dB)	Average margin (dB)	Remark
1	0.1550	58.80	46.80	0.20	59.00	47.00	65.73	55.73	-6.73	-8.73	Pass
2	0.2400	50.66	42.56	0.14	50.80	42.70	62.10	52.10	-11.30	-9.40	Pass
3	0.3000	28.08	12.38	0.12	28.20	12.50	60.24	50.24	-32.04	-37.74	Pass
4	0.3900	33.82	19.02	0.08	33.90	19.10	58.06	48.06	-24.16	-28.96	Pass
5	0.8000	35.37	31.17	0.03	35.40	31.20	56.00	46.00	-20.60	-14.80	Pass
6	1.7550	37.27	28.07	0.03	37.30	28.10	56.00	46.00	-18.70	-17.90	Pass

REMARKS: L1 = Line One (Live Line)



Job No.:	80820002	Date:	2009/8/21
Company:	Coming Data Co., Ltd.	Time:	下午 07:32:45
Standard:	EN55022 Class B Conduction(QP)	Temp.(°C)/Hum.(%):	22(°C)/45%
Test item:	Conduction test	Test By:	Jerry Lin
Line:	L2	Test Voltage:	AC 230V/50Hz
Model:	CP1220	Test Mode:	Mode 1



No.	Frequency (MHz)	QuasiPeak reading (dBuV)	Average reading (dBuV)	Correction factor (dB)	QuasiPeak result (dBuV)	Average result (dBuV)	QuasiPeak limit (dBuV)	Average limit (dBuV)	QuasiPeak margin (dB)	Average margin (dB)	Remark
1	0.1600	56.61	45.91	0.19	56.80	46.10	65.46	55.46	-8.66	-9.36	Pass
2	0.2400	49.77	41.77	0.13	49.90	41.90	62.10	52.10	-12.20	-10.20	Pass
3	0.6300	37.37	28.07	0.03	37.40	28.10	56.00	46.00	-18.60	-17.90	Pass
4	1.2700	36.97	26.77	0.03	37.00	26.80	56.00	46.00	-19.00	-19.20	Pass
5	3.3350	39.98	27.58	0.12	40.10	27.70	56.00	46.00	-15.90	-18.30	Pass
6	4.4700	32.40	20.20	0.20	32.60	20.40	56.00	46.00	-23.40	-25.60	Pass

REMARKS: L2 = Line Two (Neutral Line)



7.2. CONDUCTED EMISSION MEASUREMENT AT TELECOMMUNICATION PORTS

7.2.1. LIMITS

For Class A Equipment

Frequency (MHz)	Voltage Limit (dBuV)		Current Limit (dBuA)	
	Quasi-peak	Average	Quasi-peak	Average
0.15 ~ 0.5	97 ~ 87	84 ~ 74	53 ~ 43	40 ~ 30
0.5 ~ 30.0	87	74	43	30

NOTE: The limits decrease linearly with the logarithm of the frequency in the range 0.15 MHz to 0.5 MHz.

For Class B Equipment

Frequency (MHz)	Voltage Limit (dBuV)		Current Limit (dBuA)	
	Quasi-peak	Average	Quasi-peak	Average
0.15 - 0.5	84 ~ 74	74 ~ 64	40 ~ 30	30 ~ 20
0.5 - 30.0	74	64	30	20

Note: The limits decrease linearly with the logarithm of the frequency in the range 0,15 MHz to 0,5 MHz.

7.2.2. TEST INSTRUMENTS

Conducted Emission Room				
Name of Equipment	Manufacturer	Model	Serial Number	Calibration Due
EMI Test Receiver 9kHz-30MHz	Rohde & Schwarz	ESHS30	828144/003	11/18/2010
Two-Line V-Network 9kHz-30MHz	Schaffner	NNB41	03/10013	06/11/2010
LISN 10kHz-100MHz	EMCO	3825/2	9106-1809	04/09/2010
ISN 9kHz-30MHz	FCC	FCC-TLISN-T4	20167	09/14/2010
Test S/W	LABVIEW (V 6.1)			


NOTE: The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.



7.2.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-031)

- Selecting ISN for unscreened cable or a current probe for screened cable to take measurement.
- The port of the EUT was connected to the remote side support equipment through the ISN/Current Probe and communication in normal condition.
- Making a overall range scan by using the test receiver controlled by controller and record at least six highest emissions for showing in the test report.
- Emission frequency and amplitude were recorded into a computer in which correction factors were used to calculate the emission level and compare reading to the applicable limit.
- In case of measuring on the screened cable, the current limit shall be applied; otherwise the voltage limit should be applied.
- The following test mode was scanned during the preliminary test:
No applicable, the EUT don't have LAN Port or Modem port.

7.2.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

7.2.5. DATA SAMPLE

Frequency (MHz)	QuasiPeak reading (dBuV)	Average reading (dBuV)	Correctrion factor (dB)	QuasiPeak result (dBuV)	Average result (dBuV)	QuasiPeak limit (dBuV)	Average limit (dBuV)	QuasiPeak margin (dB)	Average margin (dB)	Remark
x.xx	43.95	33.00	10.00	53.95	43.00	74.00	64.00	-20.05	-21.00	Pass

Frequency (MHz) = Emission frequency in MHz
 Reading (dBuV) = Uncorrected Analyzer/Receiver reading + Insertion loss of LISN, if it > 0.5 dB
 Correction Factor (dB) = ISN Factor + Cable loss
 Result (dBuV) = Raw reading converted to dBuV and CF added
 Limit (dBuV) = Limit stated in standard
 Margin (dB) = Result (dBuV) – Limit (dBuV)

7.2.6. TEST RESULTS

No applicable, the EUT don't have LAN Port or Modem port.



7.3. RADIATED EMISSION MEASUREMENT

7.3.1. LIMITS

Frequency (MHz)	dBuV/m (At 10m)	
	Class A	Class B
30 ~ 230	40	30
230 ~ 1000	47	37

Note: (1). The lower limit shall apply at the transition frequencies.
(2). Emission level (dBuV/m) = 20 log Emission level (uV/m).

7.3.2. TEST INSTRUMENTS

Open Area Test Site # 1				
Name of Equipment	Manufacturer	Model	Serial Number	Calibration Due
Spectrum Analyzer	ADVANTEST	R3261C	81720301	N.C.R
EMI Test Receiver	R&S	ESVS20	838804/004	03/03/2010
Pre-Amplifier	HP	8447D	2944A09173	04/02/2010
Bilog Antenna	TESEQ	CBL 6112D	23189	06/20/2010
Turn Table	EMCO	2081-1.21	N/A	N.C.R
Antenna Tower	EMCO	2075-2	9707-2604	N.C.R
Controller	EMCO	2090	N/A	N.C.R
RF Switch	Anritsu	MP59B	M54367	N.C.R
Site NSA	CCS	N/A	N/A	02/27/2010
Test S/W	LabVIEW 6.1 (CCS OATS EMI SW V2.7)			

Note: (1). The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.
(2). N.C.R = No Calibration Request.


7.3.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-031)**Procedure of Preliminary Test**

- The equipment was set up as per the test configuration to simulate typical usage per the user's manual. When the EUT is a tabletop system, a wooden turntable with a height of 0.8 meters is used which is placed on the ground plane. When the EUT is a floor standing equipment, it is placed on the ground plane which has a 3-12 mm non-conductive covering to insulate the EUT from the ground plane.
- Support equipment, if needed, was placed as per EN 55022.
- All I/O cables were positioned to simulate typical usage as per EN 55022.
- The EUT received AC power source from the outlet socket under the turntable. All support equipment power received from another socket under the turntable.
- The antenna was placed at 10 meter away from the EUT as stated in EN 55022. The antenna connected to the Spectrum Analyzer via a cable and at times a pre-amplifier would be used.
- The Analyzer / Receiver quickly scanned from 30MHz to 1000MHz. The EUT test program was started. Emissions were scanned and measured rotating the EUT to 360 degrees and positioning the antenna 1 to 4 meters above the ground plane, in both the vertical and the horizontal polarization, to maximize the emission reading level.
- The test mode(s) described in Item 3.1 were scanned during the preliminary test:
- After the preliminary scan, we found the test mode described in Item 3.1 producing the highest emission level.
- The worst configuration of EUT and cable, antenna position, polarization and turntable position of the above highest emission levels were recorded for the final test.

Procedure of Final Test

- EUT and support equipment were set up on the turntable as per the configuration with highest emission level in the preliminary test.
- The Analyzer / Receiver scanned from 30MHz to 1000MHz. Emissions were scanned and measured rotating the EUT to 360 degrees, varying cable placement and positioning the antenna 1 to 4 meters above the ground plane, in both the vertical and the horizontal polarization, to maximize the emission reading level.
- Recording at least the six highest emissions. Emission frequency, amplitude, antenna position, polarization and turntable position were recorded into a computer in which correction factors were used to calculate the emission level and compare reading to the applicable limit and only Q.P. reading is presented.
- The test data of the worst-case condition(s) was recorded.

7.3.4. TEST SETUP



- For the actual test configuration, please refer to the related item - Photographs of the Test Configuration.

7.3.5. DATA SAMPLE


Frequency (MHz)	Reading (dBuV)	Correction Factor (dB/m)	Result (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Degree (°)	Height (cm)	Remark
xx.xx	16.49	9.86	26.35	30.00	-3.65	116.00	101.00	QP

Frequency (MHz) = Emission frequency in MHz
 Reading (dBuV) = Uncorrected Analyzer / Receiver reading
 Correction Factor (dB/m) = Antenna factor + Cable loss – Amplifier gain
 Result (dBuV/m) = Reading (dBuV) + Corr. Factor (dB/m)
 Limit (dBuV/m) = Limit stated in standard
 Margin (dB) = Result (dBuV/m) – Limit (dBuV/m)
 Q.P. = Quasi-Peak

7.3.6. TEST RESULTS

CCS Radiated Test OATS 1

Job No.:	80820002	Ant. Polar.:	Ver.
Standard:	EN 55022 Class B	Tested Distance:	10m
Test Item:	Radiated Emission	Date:	2009/8/22
Temp.(°C)/Hum.(%RH):	25°C/56%RH	Time:	PM 07:42
Company:	Coming Data Co., Ltd.	Tested By:	Stan Lin
Model:	CP1220		




No.	Frequency (MHz)	Reading (dBuV)	Correction Factor(dB/m)	Result (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Degree (°)	Height (cm)	Remark
1	38.46	11.58	15.02	26.60	30.00	-3.40	339.60	100.00	QP
2	47.79	16.79	10.01	26.80	30.00	-3.20	0.00	100.00	QP
3	58.41	15.52	7.68	23.20	30.00	-6.80	351.00	100.00	QP
4	69.27	16.00	7.60	23.60	30.00	-6.40	84.00	100.00	QP
5	86.83	16.76	10.24	27.00	30.00	-3.00	296.40	100.00	QP
6	120.68	10.00	15.00	25.00	30.00	-5.00	1.10	100.00	QP
7	151.13	7.94	13.46	21.40	30.00	-8.60	1.90	100.00	QP

Note: The other emission levels were very low against the limit.

CCS Radiated Test OATS 1

Job No.:	80820002	Ant. Polar.:	Hor.
Standard:	EN 55022 Class B	Tested Distance:	10m
Test Item:	Radiated Emission	Date:	2009/8/22
Temp.(°C)/Hum.(%RH):	25°C/56%RH	Time:	PM 07:47
Company:	Coming Data Co., Ltd.	Tested By:	Stan Lin
Model:	CP1220		



No.	Frequency (MHz)	Reading (dBuV)	Correction Factor(dB/m)	Result (dBuV/m)	Limit (dBuV/m)	Margin (dB)	Degree (°)	Height (cm)	Remark
1	39.00	8.12	14.68	22.80	30.00	-7.20	339.80	400.00	QP
2	68.60	15.82	7.58	23.40	30.00	-6.60	308.70	400.00	QP
3	80.69	13.36	8.84	22.20	30.00	-7.80	145.40	400.00	QP
4	137.47	7.03	13.97	21.00	30.00	-9.00	225.90	400.00	QP
5	175.89	6.30	12.70	19.00	30.00	-11.00	165.40	400.00	QP
6	208.09	6.15	12.85	19.00	30.00	-11.00	202.90	400.00	QP

Note: The other emission levels were very low against the limit.



7.4. HARMONICS CURRENT MEASUREMENT

7.4.1. LIMITS OF HARMONICS CURRENT MEASUREMENT

Limits for Class A equipment		Limits for Class D equipment		
Harmonics Order n	Max. permissible harmonics current A	Harmonics Order n	Max. permissible harmonics current per watt mA/W	Max. permissible harmonics current A
Odd harmonics		Odd Harmonics only		
3	2.30	3	3.4	2.30
5	1.14	5	1.9	1.14
7	0.77	7	1.0	0.77
9	0.40	9	0.5	0.40
11	0.33	11	0.35	0.33
13	0.21	13	0.30	0.21
15<=n<=39	0.15x15/n	15<=n<=39	3.85/n	0.15x15/n
Even harmonics				
2	1.08			
4	0.43			
6	0.30			
8<=n<=40	0.23x8/n			

Note: (1). Class A and Class D are classified according to item 7.4.3.

(2). According to section 7 of EN 61000-3-2, the above limits for all equipment except for lighting equipment having an active input power > 75 W and no limits apply for equipment with an active input power up to and including 75 W.

7.4.2. TEST INSTRUMENTS


Name of Equipment	Manufacturer	Model	Serial Number	Calibration Due
Harmonic & Flicker Tester	EMC-Partner	HAR1000-1P	107	05/20/2010
Test S/W	HARCS (Ver. 4.16)			

NOTE: The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.

7.4.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-029)

- The EUT was placed on the top of a wooden table 0.8 meters above the ground and operated to produce the maximum harmonic components under normal operating conditions for each successive harmonic component in turn.
- The classification of EUT is according to section 5 of EN 61000-3-2.
- The EUT is classified as follows:
Class A: Balanced three-phase equipment, Household appliances excluding equipment as Class D, Tools excluding portable tools, Dimmers for incandescent lamps, audio equipment, equipment not specified in one of the three other classes.
Class B: Portable tools; Arc welding equipment which is not professional equipment.
Class C: Lighting equipment.
Class D: Equipment having a specified power less than or equal to 600 W of the following types: Personal computers and personal computer monitors and television receivers.
- The correspondent test program of test instrument to measure the current harmonics emanated from EUT is chosen. The measure time shall be not less than the time necessary for the EUT to be exercised.

7.4.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

7.4.5. TEST RESULTS

Power Consumption	29.60W	Test Results	PASS
Environmental Conditions	23deg.C, 45% RH	Limits	Class <input checked="" type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D
Test Mode	Mode 1	Tested by	Eddy Chung

Harmonic Emission - IEC 61000-3-2 , EN 61000-3-2 , (EN60555-2)


Comply: IEC 61000-3-2 Ed.3.0 - IEC 61000-4-7 Ed.2.0

AC/DC Switching Adapter

CP1220

Eddy Chung

Remarks : Temp : 25°C Humidity : 45% RH



Harmonic Emission - IEC 61000-3-2 , EN 61000-3-2 , (EN60555-2)

2008/8/22 AM 08:17:1

U_{rms} = 229.9 V P = 29.60 W THC = 0.228 A
 I_{rms} = 0.261 A pf = 0.494

Range: 2 A
 V_{nom}: 230 V
 TestTime: 5 min (100%)

CP1220

Test completed, Result: PASSED

Temp : 25°C Humidity : 45% RH

B4R-1000 EMC-Param

Full Bar : Actual Values

Empty Bar : Maximum Values

Blue : Current , Green : Voltage , Red : Failed

Note: According to clause 7 of IEC 61000-3-2, equipment with a rated power of 75W or less, no limits apply.



7.5. VOLTAGE FLUCTUATION AND FLICKS MEASUREMENT

7.5.1. LIMITS OF VOLTAGE FLUCTUATION AND FLICKS MEASUREMENT

Test Item	Limit	Remark
P_{st}	1.0	P_{st} means short-term flicker indicator.
P_{lt}	0.65	P_{lt} means long-term flicker indicator.
T_{dt} (ms)	500	T_{dt} means maximum time that dt exceeds 3 %.
d_{max} (%)	4%	d_{max} means maximum relative voltage change.
dc (%)	3.3%	dc means relative steady-state voltage change

7.5.2. TEST INSTRUMENTS


Name of Equipment	Manufacturer	Model	Serial Number	Calibration Due
Harmonic & Flicker Tester	EMC-Partner	HAR1000-1P	107	05/20/2010
Test S/W	HARCS (Ver. 4.16)			

NOTE: The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.

7.5.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-030)

- The EUT was placed on the top of a wooden table 0.8 meters above the ground and operated to produce the most unfavorable sequence of voltage changes under normal operating conditions.
- During the flick measurement, the measure time shall include that part of whole operation cycle in which the EUT produce the most unfavorable sequence of voltage changes. The observation period for short-term flicker indicator is 10 minutes and the observation period for long-term flicker indicator is 2 hours.

7.5.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

7.5.5. TEST RESULTS

Observation Period (Tp)	10mins	Test Mode	Mode 1
Environmental Conditions	25deg.C, 55% RH	Tested by	Eddy Cheng

Test Parameter	Measurement Value	Limit	Remark
P _{st}	0.281	1.0	PASS
P _{It}	0.289	0.65	PASS
T _{dt} (ms)	0	500	PASS
d _{max} (%)	1.600 %	4%	PASS
dc (%)	0.110 %	3.3%	PASS

Note: d_{max} (%) limit classified: (1). 6% for equipment which is switched manually or switched automatically more frequently than twice per day.
 (2). 7% for equipment which is attended whilst use or switched on automatically no more than twice per day.



Measurement

Date : 2009/8/22 AM 09:18:40 V4.16

File :

AC/DC Switching Adapter
CP1220
Eddy Chung

Remarks : Temp : 25'C Humidity : 55% RH

Urms = 229.9V Freq = 49.961 Range: 50 A
Irms = 0.011A Ipk = 0.044A cf = 4.091
P = 1.276W S = 2.470VA pf = 0.517

Test - Time : 1 x 10min = 10min (100 %)

LIN (Line Impedance Network) : L: 0.24ohm +j0.15ohm N: 0.16ohm +j0.10ohm

Limits : Plt : 0.65 Pst : 1.00
dmax : 4.00 % dc : 3.30 %
dtLim: 3.30 % dt>Lim: 500ms

Test completed, Result: PASSED

Plt = 0.289

Table with 10 columns: Pst, P50s, P10s, P3s, P1s, P0.1s, Fli, dmax, dc, dt>Lim. Row 1: 0.281, 0.010, 0.010, 0.010, 0.010, 2.363, 0.000, 1.600, 0.110, 0.000.

8 IMMUNITY TEST

8.1. GENERAL DESCRIPTION

Product Standard	EN 55024: 1998 + A1: 2001 + A2: 2003	
	Test Type	Minimum Requirement
Basic Standard, Specification, and Performance Criterion required	IEC 61000-4-2	Electrostatic Discharge - ESD: 8kV air discharge, 4kV Contact discharge, Performance Criterion B
	IEC 61000-4-3	Radio-Frequency Electromagnetic Field Susceptibility Test - RS: 80 ~1000 MHz, 3V/m, 80% AM(1kHz), Performance Criterion A
	IEC 61000-4-4	Electrical Fast Transient/Burst - EFT, AC Power Port: 1kV DC Power Port: 0.5kV Signal Ports and Telecommunication Ports: 0.5kV Performance Criterion B
	IEC 61000-4-5	Surge Immunity Test: 1.2/50 us Open Circuit Voltage, 8 /20 us Short Circuit Current, AC Power Port ~ line to line: 1kV, line to earth (ground): 2kV DC Power Port ~ line to earth: 0.5kV Signal Ports and Telecommunication Ports ~ line to ground: 1kV Performance Criterion B
	IEC 61000-4-6	Conducted Radio Frequency Disturbances Test - CS: 0.15 ~ 80 MHz, 3Vrms, 80% AM, 1kHz, Performance Criterion A
	IEC 61000-4-8	Power frequency magnetic field immunity test 50 Hz, 1A/m Performance Criterion A
	IEC 61000-4-11	Voltage Dips: i) >95% reduction for 0.5 period, Performance Criterion B ii) 30% reduction for 25 period, Performance Criterion C Voltage Interruptions: >95% reduction for 250 period Performance Criterion C

8.2. GENERAL PERFORMANCE CRITERIA DESCRIPTION

<p>Criteria A:</p>	<p>The equipment shell continues to operate as intended without operator intervention. No degradation of performance or loss of function is allowed below a performance level specified by the manufacturer, when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance. If the manufacturer does not specify the minimum performance level or the permissible performance loss, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.</p>
<p>Criteria B:</p>	<p>After test, the equipment shell continues to operate as intended without operator intervention. No degradation of performance or loss of function is allowed, after the application of the phenomenon below a performance level specified by the manufacturer, when the equipment is used as intended. The performance level may be replaced by a permissible loss of performance.</p> <p>During the test, degradation of performance is however allowed. However, no change of operating state if stored data is allowed to persist after the test.</p> <p>If the minimum performance level (or the permissible performance loss), is not specified by the manufacturer, then either of these may be derived from the product description and documentation, and by what the user may reasonably expect from the equipment if used as intended.</p>
<p>Criteria C:</p>	<p>Loss of function is allowed, provided the functions is self-recoverable or can be restored by the operation of controls by the user in accordance with the manufacturer instructions.</p> <p>Functions, and/or information stored in non-volatile memory, or protected by a battery backup, shall not be lost.</p>



8.3. ELECTROSTATIC DISCHARGE (ESD)

8.3.1. TEST SPECIFICATION

Basic Standard:	IEC 61000-4-2
Discharge Impedance:	330 ohm / 150 pF
Discharge Voltage:	Air Discharge: 2; 4; 8 kV (Direct) Contact Discharge: 2; 4 kV (Direct/Indirect)
Polarity:	Positive & Negative
Number of Discharge:	Air Discharge: min. 10 times at single test point for each negative and positive polarity Contact Discharge: min. 200 times in total
Discharge Mode:	Single Discharge 1 second minimum

8.3.2. TEST INSTRUMENT

IMMUNITY SHIELDED ROOM				
Name of Equipment	Manufacturer	Model	Serial Number	Calibration Due
ESD Simulator	NoiseKen	ESS-2002	ESS0463036	07/25/2010

Note: The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.

8.3.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-022)

The discharges shall be applied in two ways:

a) Contact discharges to the conductive surfaces and coupling planes:

The EUT shall be exposed to at least 200 discharges, 100 each at negative and positive polarity, at a minimum of four test points. One of the test points shall be subjected to at least 50 indirect discharges to the center of the front edge of the **Horizontal Coupling Plane (HCP)**. The remaining three test points shall each receive at least 50 direct contact discharges. If no direct contact test points are available, then at least 200 indirect discharges shall be applied in the indirect mode. Test shall be performed at a maximum repetition rate of one discharge per second.


b) Air discharges at slots and apertures and insulating surfaces:

On those parts of the EUT where it is not possible to perform contact discharge testing, the equipment should be investigated to identify user accessible points where breakdown may occur. Such points are tested using the air discharge method. This investigation should be restricted to those area normally handled by the user. A minimum of 10 single air discharges shall be applied to the selected test point for each such area.

The basic test procedure was in accordance with IEC 61000-4-2:

- a) The EUT was located 0.1 m minimum from all side of the **HCP** (dimensions 1.6m x 0.8m).
- b) The support units were located another table 30 cm away from the EUT, but direct support unit was/were located at same location as EUT on the HCP and keep at a distance of 10 cm with EUT.
- c) The time interval between two successive single discharges was at least 1 second.
- d) Contact discharges were applied to the non-insulating coating, with the pointed tip of the generator penetrating the coating and contacting the conducting substrate.
- e) Air discharges were applied with the round discharge tip of the discharge electrode approaching the EUT as fast as possible (without causing mechanical damage) to touch the EUT. After each discharge, the ESD generator was removed from the EUT and re-triggered for a new single discharge. The test was repeated until all discharges were complete.
- f) At least ten single discharges (in the most sensitive polarity) were applied at the front edge of each **HCP** opposite the center point of each unit of the EUT and 0.1 meters from the front of the EUT. The long axis of the discharge electrode was in the plane of the **HCP** and perpendicular to its front edge during the discharge.
- g) At least ten single discharges (in the most sensitive polarity) were applied to the center of one vertical edge of the **Vertical Coupling Plane (VCP)** in sufficiently different positions that the four faces of the EUT were completely illuminated. The **VCP** (dimensions 0.5m x 0.5m) was placed vertically to and 0.1 meters from the EUT.

8.3.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

NOTE:

TABLE-TOP EQUIPMENT

The configuration consisted of a wooden table 0.8 meters high standing on the **Ground Reference Plane**. The **GRP** consisted of a sheet of aluminum at least 0.25mm thick, and 2.5 meters square connected to the protective grounding system. A **Horizontal Coupling Plane** (1.6m x 0.8m) was placed on the table and attached to the **GRP** by means of a cable with 940k Ω total impedance. The equipment under test, was installed in a representative system as described in section 7 of IEC 61000-4-2, and its cables were placed on the **HCP** and isolated by an insulating support of 0.5mm thickness. A distance of 1-meter minimum was provided between the EUT and the walls of the laboratory and any other metallic structure.

FLOOR-STANDING EQUIPMENT

The equipment under test was installed in a representative system as described in section 7 of IEC 61000-4-2, and its cables were isolated from the Ground Reference Plane by an insulating support of 0.1-meter thickness. The GRP consisted of a sheet of aluminum that is at least 0.25mm thick, and 2.5 meters square connected to the protective grounding system and extended at least 0.5 meters from the EUT on all sides.

8.3.5. TEST RESULTS

Temperature	24°C	Humidity	42% RH
Pressure	1010mbar	Tested by	Eddy Cheng
Required Passing Performance		Criterion B	

Air Discharge												
Test Points	Test Levels						Results					
	± 2 kV	Performance Criterion		± 4 kV	Performance Criterion		± 8 kV	Performance Criterion		Pass	Fail	Observation
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Note 1
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Note 1
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Note 1
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Note 1
Top	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Note 1
Bottom	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Note 1

Contact Discharge												
Test Points	Test Levels						Results					
	± 2 kV	Performance Criterion		± 4 kV	Performance Criterion		± 8 kV	Performance Criterion		Pass	Fail	Observation
Front	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/>	Note 2
Back	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/>	Note 2
Left	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/>	Note 2
Right	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/>	Note 2
Top	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/>	Note 2
Bottom	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/> A	<input type="checkbox"/> B	<input type="checkbox"/>	<input type="checkbox"/>	Note 2

For the tested points to EUT, please refer to attached page. (Blue arrow mark for Contact Discharge and red arrow mark for Air Discharge)

Discharge To Horizontal Coupling Plane								
Side of EUT	Test Levels			Results				
	± 2 kV	± 4 kV	± 8 kV	Pass	Fail	Performance Criterion		Observation
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	Note 1
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	Note 1
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	Note 1
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	Note 1

Discharge To Vertical Coupling Plane								
Side of EUT	Test Levels			Results				
	± 2 kV	± 4 kV	± 8 kV	Pass	Fail	Performance Criterion		Observation
Front	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	Note 1
Back	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	Note 1
Left	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	Note 1
Right	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/> A	<input type="checkbox"/> B	Note 1

Note: (1). There was no change compared with initial operation during the test.
 (2). NDP. Means that no discharge point had been occurred during that particular coupling method.



8.4. RADIATED, RADIO-FREQUENCY, ELECTROMAGNETIC FIELD (RS)

8.4.1. TEST SPECIFICATION

Basic Standard: IEC 61000-4-3

Frequency Range: 80 MHz ~1000 MHz

Field Strength: 3 V/m

Modulation: 1kHz Sine Wave, 80%, AM Modulation

Frequency Step: 1 % of preceding frequency value

Polarity of Antenna: Horizontal and Vertical

Test Distance: 3 m

Antenna Height: 1.5m



8.4.2. TEST INSTRUMENT

RS Chamber				
Name of Equipment	Manufacturer	Model	Serial Number	Calibration Due
Pulse Generator	Agilent	81101A	DE41B01423	06/11/2010
Signal Generator (250kHz-40GHz)	Agilent	E8257C	US42340383	07/18/2010
500 Watt 10kHz Amplifier	Amplifier Research	500A100A	300299	N.C.R.
500 Watts 80-1000MHz Amplifier	Amplifier Research	500W 1000A	320994	N.C.R.
250 Watts 1-2.5GHz Amplifier	Amplifier Research	250T1G3M1	320245	N.C.R.
300 Watts 2.5-7.5GHz Amplifier	Amplifier Research	300T2G8M1	320255	N.C.R.
250 Watts 7.5-18GHz Amplifier	Amplifier Research	250T8G18M1	320246	N.C.R.
RF Test System Controller	Amplifier Research	SC1000M3	306666	N.C.R.
Power Meter	Boonton	4232A-01-02	98601	09/15/2010
Power Sensor	Boonton	51013-4E	34242	09/04/2010
Power Sensor	Boonton	51013-4E	34241	09/04/2010
Bi-log Antenna	SCHWAZBECK	VULB9166	9166-1093	N.C.R.
Log-Periodic Antenna	Amplifier Research	AT1080	306709	N.C.R.
Horn	SCHWAZBECK	BBHA 9120D	530	N.C.R.
Field Probe (3M-18GHz)	Amplifier Research	FP7018	311430	05/21/2010
Dual Directional Coupler (80-1000MHz)	Amplifier Research	DC6180A	320285	N.C.R.
Dual Directional Coupler (0.8-4.2GHz)	Amplifier Research	DC7144A	313674	N.C.R.
Dual Directional Coupler (2-8GHz)	Amplifier Research	DC7280A	320524	N.C.R.
Dual Directional Coupler (7.5-18GHz)	Amplifier Research	DC7450M1	0320073	N.C.R.
Antenna Tower	Amplifier Research	TP2000	N/A	N.C.R.
Probe Stand	Amplifier Research	PS2000	N/A	N.C.R.
LISN	FCC	FCC-LISN-5-50-1-01-CISPR 25	06038	03/25/2010
LISN	FCC	FCC-LISN-5-50-1-01-CISPR 25	06039	03/25/2010
Software	SW1006			


Note: (1). The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.
 (2). N.C.R.= No Calibration required.

8.4.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-023)

The test procedure was in accordance with IEC 61000-4-3

- a) The testing was performed in a fully anechoic chamber. The transmit antenna was located at a distance of 3 meters from the EUT.
- b) The frequency range is swept from 80 MHz to 1000 MHz, with the signal 80% amplitude modulated with a 1kHz sine-wave. The rate of sweep did not exceed 1.5×10^{-3} decade/s, where the frequency range is swept incrementally, the step size was 1% of preceding frequency value.
- c) The dwell time at each frequency shall be not less than the time necessary for the EUT to be able to respond.
- e) The test was performed with the EUT exposed to both vertically and horizontally polarized fields on each of the four sides.

8.4.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

NOTE:

TABLETOP EQUIPMENT

The EUT installed in a representative system as described in section 7 of IEC 61000-4-3 was placed on a non-conductive table 0.8 meters in height. The system under test was connected to the power and signal wire according to relevant installation instructions.

FLOOR STANDING EQUIPMENT

The EUT installed in a representative system as described in section 7 of IEC 61000-4-3 was placed on a non-conductive wood support 0.1 meters in height. The system under test was connected to the power and signal wire according to relevant installation instructions.



8.4.5. TEST RESULTS

Temperature	24°C	Humidity	48% RH
Pressure	1012mbar	Dwell Time	3 sec.
Tested by	Eddy Chung	Required Passing Performance	Criterion A

Frequency (MHz)	Polarity	Azimuth	Field Strength (V/m)	Performance Criterion	Observation	Result
80 ~ 1000	V&H	0	3	<input checked="" type="checkbox"/> A <input type="checkbox"/> B	Note 1	PASS
80 ~ 1000	V&H	90	3	<input checked="" type="checkbox"/> A <input type="checkbox"/> B	Note 1	PASS
80 ~ 1000	V&H	180	3	<input checked="" type="checkbox"/> A <input type="checkbox"/> B	Note 1	PASS
80 ~ 1000	V&H	270	3	<input checked="" type="checkbox"/> A <input type="checkbox"/> B	Note 1	PASS

Note: (1). There was no change compared with the initial operation during the test.



8.5. ELECTRICAL FAST TRANSIENT (EFT)

8.5.1. TEST SPECIFICATION

Basic Standard:	IEC 61000-4-4
Test Voltage:	<input checked="" type="checkbox"/> AC Power Port: 1kV <input type="checkbox"/> DC Power Port: 0.5kV <input type="checkbox"/> Signal Ports and Telecommunication Ports: 0.5kV
Polarity:	Positive & Negative
Impulse Frequency:	5 kHz
Impulse Wave-shape:	5/50 ns
Burst Duration:	15 ms
Burst Period:	3 Hz
Test Duration:	Not less than 1 min.

8.5.2. TEST INSTRUMENT


Immunity Shield Room				
Name of Equipment	Manufacturer	Model	Serial Number	Calibration Due
ECAT Control Center	KeyTek	E-Class Series 100	9502325	04/10/2010
Capacitor Clamp	KeyTek	CCL-4	9503290	N.C.R.
Test S/W	E400 Burstware (V4.19 (c))			

Note: (1). The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.
(2). N.C.R.= No Calibration required.

8.5.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-024)

- a) Both positive and negative polarity discharges were applied.
- b) The length of the “hot wire” from the coaxial output of the EFT generator to the terminals on the EUT should not exceed 1 meter.
- c) The duration time of each test sequential was 1 minute.
- d) The transient/burst waveform was in accordance with IEC 61000-4-4, 5/50ns.

8.5.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

NOTE:

TABLETOP EQUIPMENT

The configuration consisted of a wooden table (0.8m high) standing on the Ground Reference Plane. The GRP consisted of a sheet of aluminum (at least 0.25mm thick and 2.5m square) connected to the protective grounding system. A minimum distance of 0.5m was provided between the EUT and the walls of the laboratory or any other metallic structure.

FLOOR STANDING EQUIPMENT

The EUT installed in a representative system as described in section 7 of IEC 61000-4-4 and its cables, were isolated from the Ground Reference Plane by an insulating support that is 0.1-meter thick. The GRP consisted of a sheet of aluminum (at least 0.25mm thick and 2.5m square) connected to the protective grounding system.



8.5.5. TEST RESULTS

Temperature	25°C	Humidity	47% RH
Pressure	1011mbar	Tested by	Eddy Chung
Required Passing Performance		Criterion B	

Test Point	Polarity	Test Level (kV)	Performance Criterion	Observation	Result
L	+/-	1	<input checked="" type="checkbox"/> A <input type="checkbox"/> B	Note 1	PASS
N	+/-	1	<input checked="" type="checkbox"/> A <input type="checkbox"/> B	Note 1	PASS
L+N	+/-	1	<input checked="" type="checkbox"/> A <input type="checkbox"/> B	Note 1	PASS

Note: (1). There was no change compared with initial operation during the test.



8.6. SURGE IMMUNITY TEST

8.6.1. TEST SPECIFICATION

Basic Standard:	IEC 61000-4-5
Wave-Shape:	Combination Wave 1.2/50 us Open Circuit Voltage 8/20 us Short Circuit Current
Test Voltage:	<input checked="" type="checkbox"/> AC Power Port ~ line to line: 1kV, line to earth (ground): 2kV <input type="checkbox"/> DC Power Port ~ line to earth: 0.5kV <input type="checkbox"/> Signal Ports and Telecommunication Ports ~ line to ground: 1kV
Surge Input/Output:	<input checked="" type="checkbox"/> AC Power Port: L-N / L-PE / N-PE <input type="checkbox"/> DC Power Port: L-PE <input type="checkbox"/> Signal Ports and Telecommunication Ports: T to Ground/ R to Ground
Generator Source Impedance:	2 ohm between networks 12 ohm between network and ground
Polarity:	Positive/Negative
Phase Angle:	0 / 90 / 180 / 270
Pulse Repetition Rate:	1 time / min. (maximum)
Number of Tests:	5 positive and 5 negative at selected points

8.6.2. TEST INSTRUMENT

Immunity Shield Room				
Name of Equipment	Manufacturer	Model	Serial Number	Calibration Due
ECAT Control Center	KeyTek	E-Class Series 100	9502325	04/10/2010
External Coupler / Decoupler For Telecom Lines	KeyTek	CM-TELCD	0104399	N.C.R.
I/O Signal Line Coupler / Decoupler	KeyTek	CM-I / OCD	0103234	N.C.R.
Test S/W	E500 Surgeware (V4.19cc)			

Note: (1). The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.

(2). N.C.R.= No Calibration required.

8.6.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-025)

a) For EUT power supply:

The surge is applied to the EUT power supply terminals via the capacitive coupling network. Decoupling networks are required in order to avoid possible adverse effects on equipment not under test that may be powered by the same lines, and to provide sufficient decoupling impedance to the surge wave. The power cord between the EUT and the coupling/decoupling networks was shorter than 2 meters in length.


b) For test applied to unshielded un-symmetrically operated interconnection lines of EUT:

The surge was applied to the lines via the capacitive coupling. The coupling / decoupling networks didn't influence the specified functional conditions of the EUT. The interconnection line between the EUT and the coupling/decoupling networks was shorter than 2 meters in length.

c) For test applied to unshielded symmetrically operated interconnection / telecommunication lines of EUT:

The surge was applied to the lines via gas arrestors coupling. Test levels below the ignition point of the coupling arrestor were not specified. The interconnection line between the EUT and the coupling/decoupling networks was shorter than 2 meters in length.

8.6.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.



8.6.5. TEST RESULTS

Temperature	24°C	Humidity	46% RH
Pressure	1010mbar	Tested by	Eddy Cheng
Required Passing Performance		Criterion B	

Test Point	Polarity	Test Level (kV)	Performance Criterion	Observation	Result
L - N	+/-	1	<input checked="" type="checkbox"/> A <input type="checkbox"/> B	Note 1	PASS

Note: (1) There was no change compared with initial operation during the test.



8.7. CONDUCTED RADIO FREQUENCY DISTURBANCES (CS)

8.7.1. TEST SPECIFICATION

Basic Standard:	IEC 61000-4-6
Frequency Range:	0.15 MHz ~ 80 MHz
Field Strength:	3 Vrms
Modulation:	1kHz Sine Wave, 80%, AM Modulation
Frequency Step:	1 % of preceding frequency value
Coupled cable:	Power Mains, Unshielded
Coupling device:	<input checked="" type="checkbox"/> CDN-M2 (2 wires) <input type="checkbox"/> CDN-M3 (3 wires) <input type="checkbox"/> CDN-T2 for Line <input type="checkbox"/> CDN-T4/T8 for LAN



8.7.2. TEST INSTRUMENT

Immunity Shield Room				
Name of Equipment	Manufacturer	Model	Serial Number	Calibration Due
Signal Generator	Agilent	8648C	4108A05773	09/19/2010
Power Amplifier	ar	500A100A	300299	N.C.R.
High Power Attenuator	Narda	769-6	02541	N.C.R.
Power Meter	Boonton	4232A-01-02	98501	09/20/2010
Power Sensor	Boonton	51011-EMC	32862	09/20/2010
Power Sensor	Boonton	51011-EMC	32864	09/20/2010
Power Line Coupling Decoupling Network	Fischer Custom Communications, Inc.	FCC-801-M2-16A	03026	09/21/2010
Power Line Coupling Decoupling Network	Fischer Custom Communications, Inc.	FCC-801-M3-16A	03027	09/21/2010
Signal Line Coupling Decoupling Network	Fischer Custom Communications, Inc.	FCC-801-T2	03016	09/21/2010
Signal Line Coupling Decoupling Network	Fischer Custom Communications, Inc.	FCC-801-T4	03017	09/21/2010
EM Injection Clamp	Fischer Custom Communications, Inc.	F-203I-23mm	421	09/21/2010
Passive Impedance Adapters	Fischer Custom Communications, Inc.	FCC-801-150-50-CDN	03053&03054	09/21/2010
Calibration Fixture	Fischer Custom Communications, Inc.	F-203I-CF-23mm	408	09/21/2010
Signal Line Coupling Decoupling Network	Fischer Custom Communications, Inc.	FCC-801-T8-RJ45	04024	09/21/2010
Attenuator	Amplifier Research	HFP-575-3/6-NM	NF201875106	N.C.R.
Coupler	Amplifier Research	DC2600A	306621	N.C.R.
Test S/W	SW1005 (Release 1.4)			

- Note:** (1). The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.
(2). N.C.R.= No Calibration required.

8.7.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-026)

The EUT shall be tested within its intended operating and climatic conditions.


The test shell performed with the test generator connected to each of the coupling and decoupling devices in turn, while the other non-excited RF input ports of the coupling devices are terminated by a 50-ohm load resistor.

The frequency range was swept from 150 kHz to 80 MHz, using the signal level established during the setting process and with a disturbance signal of 80 % amplitude. The signal was modulated with a 1 kHz sine wave, pausing to adjust the RF signal level or the switch coupling devices as necessary. The sweep rate was 1.5×10^{-3} decades/s. Where the frequency range is swept incrementally, the step size was 1 % of preceding frequency value from 150 kHz to 80 MHz.

The dwell time at each frequency was less than the time necessary for the EUT to be exercised, and able to respond. Sensitive frequencies such as clock frequency(ies) and harmonics or frequencies of dominant interest, was analyzed separately.

Attempts was made to fully exercise the EUT during testing, and to fully interrogate all exercise modes selected for susceptibility.

8.7.4. TEST SETUP



- Note:** (1). The EUT is setup 0.1m above Ground Reference Plane
 (2). The CDNs and / or EM clamp used for real test depends on ports and cables configuration of EUT.

- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

NOTE:

TABLE-TOP AND FLOOR-STANDING EQUIPMENT

The equipment to be tested was placed on an insulating support of 0.1 meters height above a ground reference plane. All relevant cables shall be provided with the appropriate coupling and decoupling devices at a distance between 0.1 meters and 0.3 meters from the projected geometry of the EUT on the ground reference plane.



8.7.5. TEST RESULTS

Temperature	24°C	Humidity	43% RH
Pressure	1010mbar	Tested by	Eddy Chung
Required Passing Performance		Criterion A	

Frequency Band (MHz)	Field Strength (Vrms)	Cable	Injection Method	Performance Criterion	Observation	Result
0.15 ~ 80	3	Power Line	CDN-M3	<input checked="" type="checkbox"/> A <input type="checkbox"/> B	Note 1	PASS

Note: (1). There was no change compared with initial operation during the test.



8.8. POWER FREQUENCY MAGNETIC FIELD

8.8.1. TEST SPECIFICATION

Basic Standard:	IEC 61000-4-8
Frequency Range:	50Hz,
Field Strength:	1 A/m
Observation Time:	1 minute
Inductance Coil:	Rectangular type, 1mx1m

8.8.2. TEST INSTRUMENT


Immunity Shield Room				
Name of Equipment	Manufacturer	Model	Serial Number	Calibration Due
Magnetic Field Tester	Haefely Trench	MAG100.1	081436-02	N.C.R.
Frequency Converter	Extech Electronics	CFC-105	810390	N.C.R.
Digital Multimeter	DHA	CM-312A	ET93C-06-208-01	05/30/2010
EMF Tester Electromagnetic Field	TES	1390	020401598	05/15/2010

Note: (1). The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.
 (2). N.C.R.= No Calibration required.

8.8.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-027)

- a) The equipment was configured and connected to satisfy its functional requirements. It shall be placed on the GRP with the interposition of a 0.1m-thick insulating support.
- b) The equipment cabinets shall be connected to the safety earth directly on the GRP via the earth terminal of the EUT.
- c) The power supply, input and output circuits shall be connected to the sources of power supply, control and signal.
- d) The cables supplied or recommended by the equipment manufacturer shall be used. 1 meter of all cables used shall be exposed to the magnetic field.

8.8.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

NOTE:

TABLETOP EQUIPMENT

The equipment shall be subjected to the test magnetic field by using the induction coil of standard dimension (1 m x 1 m). The induction coil shall then be rotated by 90 degrees in order to expose the EUT to the test field with different orientations.

FLOOR-STANDING EQUIPMENT

The equipment shall be subjected to the test magnetic field by using induction coils of suitable dimensions. The test shall be repeated by moving and shifting the induction coils, in order to test the whole volume of the EUT for each orthogonal direction. The test shall be repeated with the coil shifted to different positions along the side of the EUT, in steps corresponding to 50 % of the shortest side of the coil. The induction coil shall then be rotated by 90 degrees in order to expose the EUT to the test field with different orientations.



8.8.5. TEST RESULTS

Temperature	24°C	Humidity	43% RH
Pressure	1010mbar	Tested by	Eddy Chung
Required Passing Performance		Criterion A	

Direction	Field Strength (A/m)	Performance Criterion	Observation	Results
X	1	<input checked="" type="checkbox"/> A <input type="checkbox"/> B	Note 1	Pass
Y	1	<input checked="" type="checkbox"/> A <input type="checkbox"/> B	Note 1	Pass
Z	1	<input checked="" type="checkbox"/> A <input type="checkbox"/> B	Note 1	Pass

Note: (1). There was no change compared with the initial operation during the test.



8.9. VOLTAGE DIP & VOLTAGE INTERRUPTIONS

8.9.1. TEST SPECIFICATION

Basic Standard:	IEC 61000-4-11
Test duration time:	Minimum three test events in sequence
Interval between event:	Minimum 10 seconds
Angle:	0~360 degree
Step:	45 degree

8.9.2. TEST INSTRUMENT


Immunity shielded room				
Name of Equipment	Manufacturer	Model	Serial Number	Calibration Due
Dips/Interruption and Variations Simulator	Haefely Trench	PLINE 1610	081568-06	08/05/2010
Test S/W	WinPATS (V. 3.26)			

Note: The calibration interval of the above test instruments is 12 months and the calibrations are traceable to NML/ROC and NIST/USA.

8.9.3. TEST PROCEDURE (please refer to measurement standard or CCS SOP PA-028)

- a) The EUT and support units were located on a wooden table, 0.8 m away from ground floor.
- b) Setting the parameter of tests and then perform the test software of test simulator.
- c) Conditions changes to occur at 0 degree crossover point of the voltage waveform.
- d) Recording the test result in test record form.
- e) Removes the AC/DC Switching Adapter to test if any.

8.9.4. TEST SETUP



- For the actual test configuration, please refer to the related item – Photographs of the Test Configuration.

8.9.5. TEST RESULTS

Temperature	24°C	Humidity	42% RH
Pressure	1010mbar	Tested by	Eddy Cheng
Required Passing Performance	Criterion B: >95% reduction 0.5 period Criterion C: 30% reduction 25 period & >95% reduction 250 period		

Test Power: 230Vac, 50Hz				
Voltage (% Reduction)	Duration (Period)	Performance Criterion	Observation	Test Result
>95	0.5	<input checked="" type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C	Note 1	PASS
30	25	<input checked="" type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C	Note 1	PASS
>95	250	<input type="checkbox"/> A <input type="checkbox"/> B <input checked="" type="checkbox"/> C	Note 2	PASS

Note: (1). There was no change compared with initial operation during and after the test. No unintentional response was found during the test.