



**Quanser Accessories:**  
**UPM-15-03, UPM-24-05, and UPM-180-25B**

**Universal Power Module (UPM)**



**User Manual**

## Table of Contents

1. Introduction.....	1
2. Linear Amplifier Modules: UPM-15-03 and UPM-24-05.....	2
2.1. Specifications.....	2
2.2. System Description.....	3
2.3. Wiring.....	6
2.3.1. Cable Nomenclature.....	6
2.3.2. Common Connections.....	9
2.3.3. Circuit Schematic.....	9
3. PWM Module: UPM-180-25B.....	10
3.1. Specifications.....	10
3.2. Description.....	11
3.3. Safety Features.....	14
3.3.1. Limit Switches.....	14
3.3.2. Emergency Stop Switch.....	15
3.4. Typical Connections.....	15
3.4.1. Cable Nomenclature.....	16
3.4.2. Wiring Procedure.....	17
3.5. Using the UPM-180-25B.....	17
3.5.1. Initialization.....	17
3.5.1.1. Initialization Procedure using WinCon.....	18
3.5.1.2. Initialization Signals.....	19
3.5.1.3. Simulink Model: q_boot_upm_zz.mdl.....	20
3.5.2. Enabling.....	20
3.5.2.1. Enabling Signals.....	20
3.5.2.2. Simulink Model.....	21
3.5.3. Calibration.....	22
3.5.3.1. Calibration Signals.....	22
3.5.3.2. Simulink Model.....	23
3.6. Troubleshooting Guide.....	24
4. Obtaining Support.....	25
5. References.....	25

## 1. Introduction

The Quanser Universal Power Module (UPM) is a power amplifier that is designed to drive the actuators of various Quanser experiments. Every UPM consists of the following components:

- Power amplified analog output
- Regulated  $\pm 12$  V DC power supply at 1-Ampere
- Analog sensor inputs

Table 1 summarizes the different UPM models available and some general specifications.

<i>Model</i>	<i>Max Output Voltage (V)</i>	<i>Max Continuous Current (A)</i>	<i>Type</i>	<i>Mode</i>
UPM-15-03	$\pm 15.0$	3.0	Linear	Voltage
UPM-24-05	$\pm 24.0$	5.0	Linear	Voltage
UPM-180-25B	$\pm 169.7$	25.0	PWM	Current

Table 1 UPM models.

The UPM-15-03 and the UPM-24-05 are both linear voltage-controlled amplifiers. The UPM-15-03 device, pictured in Figure 1, is capable of delivering a maximum continuous voltage of  $\pm 15$  V and a maximum continuous current of 3 A. For actuators requiring more power, the UPM-24-05 has a maximum continuous voltage of  $\pm 24$  V and a maximum continuous current of 5 A.

In more high-powered applications such as the Quanser Shake Table II or the Quanser High-Fidelity Linear Cart, the UPM-180-25B shown in Figure 2 is used. The UPM's onboard current-controlled pulse-width modulated amplifier outputs pulse amplitudes of 169.7 V and it can deliver a maximum continuous current of 25 A.



Figure 1 Quanser UPM-15-03



Figure 2 Quanser UPM-180-25B

## 2. Linear Amplifier Modules: UPM-15-03 and UPM-24-05

In this section, the linear voltage-controlled amplifiers UPM-15-03, shown in Figure 1, and UPM-24-05 are described. As mentioned, the output of these module are made to be connected with the actuator of various Quanser experiments. Typically the output of the UPM is connected to a DC motor (with or without an internal gearbox) such as in the SRV02 or IP02 experiments. It can also be used to drive an electromagnet as in the Quanser Maglev plant or a pump like in the Quanser Coupled-Tanks experiment.

### 2.1. Specifications

The UPM-15-03 device has a linear power amplifier that is capable of supplying a continuous voltage of  $\pm 15$  V and continuous currents of up to 3 A. The amplifier is in voltage-mode thus an input voltage of 1 V results in a regulated voltage of  $K_v$  in the connected motor. See Table 2 for the main specifications associated with the UPM-15-03.

<i>Symbol</i>	<i>Parameter</i>	<i>Value</i>	<i>Units</i>
$K_v$	Amplifier Voltage Gain	1,3, or 5	V/V
$V_{max}$	Amplifier Maximum Continuous Voltage	$\pm 15$	V
$I_{a\_max}$	Amplifier Maximum Continuous Line DC Current	3	A
$V_{dc}$	DC Output Voltage Supply	$\pm 12$	V
$I_{dc\_max}$	DC Output Maximum Current Supply	1	A
$V_{in}$	Supply AC Voltage	100/120/ 230/240	V

Table 2 Specifications of the UPM-15-03 device.

The UPM-24-05 is a more powerful version of the UPM-15-03 that is capable of supplying a continuous voltage of  $\pm 24V$  and a maximum continuous current of 5 A. Its specifications are given in Table 3.

<i>Symbol</i>	<i>Parameter</i>	<i>Value</i>	<i>Units</i>
$K_v$	Amplifier Voltage Gain	1,3, or 5	V/V
$V_{max}$	Amplifier Maximum Continuous Voltage	$\pm 24$	V
$I_{a\_max}$	Amplifier Maximum Continuous Line DC Current	5	A
$V_{dc}$	DC Output Voltage Supply	$\pm 12$	V
$I_{dc\_max}$	DC Output Maximum Current Supply	1	A
$V_{in}$	AC Supply Voltage	100/120/ 230/240	V

Table 3 Specifications of the UPM-24-05 device.

## 2.2. System Description

The components on the front panel of the UPM-15-03 and the UPM-24-05 is depicted in Figure 3. Each component on the UPM has an identification number that corresponds to a the short description given in Table 4.



Figure 3 Front panel of UPM-15-03 / UPM-24-05.

<i>ID #</i>	<i>Description</i>	<i>ID #</i>	<i>Description</i>
1	Breadboard	11	Analog sensor input 3 connector.
2	UPM Power LED.	12	Analog sensor input 4 connector.
3	-12 V terminal of DC power supply.	13	Analog signals available to DAC device.
4	Ground terminal of DC power supply.	14	Input control signal from DAC.
5	12 V terminal of DC power supply.	15	Negative power amplifier input terminal.
6	Analog sensor input 1 terminal.	16	Positive power amplifier input terminal.
7	Analog sensor input 2 terminal.	17	Amplifier output terminal.
8	Analog sensor input 3 terminal.	18	Amplifier ground.
9	Analog sensor input 4 terminal.	19	Amplifier output connector to actuator.
10	Analog sensor input 1 and 2 connector.		

Table 4 Front panel components on UPM-15-03 / UPM-24-05.

As depicted in Figure 3, a breadboard (component #1) is mounted on top of each UPM. This can be used to construct analog circuits such as a low-pass filter using operational amplifiers. As previously mentioned, the UPM also contains an independent  $\pm 12$  power supply with three -12 V (ID #3), Ground (ID #4), and +12 V (ID #5) terminals. This can of course be used with the breadboard circuit to power an integrated circuit.

The "From Analog Sensors" connectors are used to connect analog sensors such as potentiometers, pressure sensors, and accelerometers. The UPM-15-03 and UPM-24-05 devices have three 6-pin mini DIN connectors labeled "S1 & S2", "S3", and "S4" with ID #10, 11, and 12, respectively. These connectors provide a  $\pm 12$  VDC bias to analog sensors and carry their voltage signals back to the UPM. The sensor signals can be measured from the four "Test Points" connectors, labeled #6-9 in Figure 3, or the "To A/D" connector, ID #13 in Figure 3. The "Test Points" connectors are useful when it is desired to interface the sensor signals with an analog circuit or monitor the signals externally using an oscilloscope. On the other hand, the "To A/D" connector is handy to connect the analog sensor signals to a data-acquisition terminal board.

The control signal that is outputted from the digital-to-analog output channel on the DAC board is usually connected to the UPM "From D/A" connector (ID #14). Alternatively, it may be easier to connect a control signal coming from an analog circuit to the "-", ID #15, and/or "+", ID #16, connectors underneath the "Power Amplifier #1" label in the front panel of the UPM. The resulting amplified signal is available at the "OUT" (ID #17) terminal and the "To Load" connector (ID #19). The "OUT" terminal may be used to feed the amplified signal to an analog circuit or to monitor external using a voltmeter. The "To Load" 6-pin-DIN connector is typically used to interface the amplified with the a Quanser plant.

The gain of the UPM-15-03 and the UPM-24-05 power amplifier, either 1, 3, or 5, is set by using the appropriate "To Load" gain cable of 1, 3, or 5. The cable contains the feedback resistor of the amplifier that effectively sets its amplification factor. See Table 5 in Section 2.3.1 for a description of the gain cables.



**CAUTION: Always ensure you are using the correct "To Load" gain cable!** The linear amplifier voltage gain in both the UPM-15-03 or the UPM-24-05 is set using the "To Load" cable. If the cable is labeled 3 or 5 then using that cable sets the amplifier gain to 3 V/V or 5 V/V, respectively.



**CAUTION: Always ensure a gain cable is connected to the "To Load" connector.** If the amplified signal is interfaced with an experiment though the "OUT" terminal of the UPM, make sure the correct "To Load" gain cable is connected. If no cable is connected to the "To Load" connector, the UPM will output its the maximum voltage to the attached

load, i.e. 15 V with the UPM-15-03 or 24 V with the UPM-24-05.

As indicated in Table 2, the UPM-15-03 and UPM-24-05 can be configured to accept an input AC voltage of 100 V, 120 V, 230 V, and 240 V. The module is usually configured for the designated country before being shipped. However, the setting can be changed by swapping the fuse situated on the back panel of the UPM, as shown in Figure 4.



Figure 4 Fuse on back panel of UPM-15-03/UPM-24-05.

## 2.3. Wiring

Section 2.3.1 summarizes the cables used with the UPMs and the typical connections with those cables are described in Section 2.3.2. See Section 2.3.3 for a schematic of the internal circuit in the UPM.

### 2.3.1. Cable Nomenclature

Table 5 provides a description of the standard cables that connect with the UPM-15-03 and UPM-24-05.






<i>Cable</i>	<i>Type</i>	<i>Description</i>
	5-pin-DIN to RCA	Connects the analog output of the data acquisition system to the UPM for amplification.
	4-pin-DIN to 6-pin-DIN	Connects the output of the UPM after amplification to the actuator of the experiment. The UPM-end of this cable has a resistor that sets the amplifier gain to either 1, 3, or 5. When the cable has no label and both connectors are black, as shown in Figure 6, the amplifier gain is set to 1.
	4-pin-DIN to 6-pin-DIN	See the description above. This cable resembles the gain 1 cable described previously except, as depicted in Figure 7, it is labeled "3". This cable sets the gain of the amplifier to 3.

Figure 5 "From Digital-to-Analog" cable

Figure 6 "To Load" cable with gain 1

Figure 7 "To Load" cable with gain 3




<i>Cable</i>	<i>Type</i>	<i>Description</i>
	<p>4-pin-DIN to 6-pin-DIN</p>	<p>See the description of the "To Load" cable with gain 1. This cable resembles the gain 1 cable described previously except, as depicted in Figure 8, it has a gray UPM-side connector and is labelled "5". This cable sets the gain of the amplifier to 5.</p>
	<p>6-pin-mini-DIN to 6-pin-mini-DIN</p>	<p>This cable can be used to connect any potential plant sensor to the UPM such as potentiometers and accelerometers. It provides a <math>\pm 12</math> VDC bias to analog sensors and carry their voltage signals back to the DAC via the UPM.</p>
	<p>5-pin-DIN to 4xRCA</p>	<p>Carries the analog signals from the UPM, which are connected to the S1 &amp; S2, S3, and S4 inputs, to the digital-to-analog input channel of the data-acquisition terminal board.</p>

Figure 8 "To Load" cable with gain 5

Figure 9 "From Analog Sensors" Cable

Figure 10 "To Analog-To-Digital" cable.

Table 5 Cables often used with the UPM-15-03 and UPM-24-05 systems.

### 2.3.2. Common Connections

Some typical connections on the UPM-1503 or UPM-2405 are and listed in Table 6.

<i>Cable Type</i>	<i>From</i>	<i>To</i>	<i>Function</i>
"From Digital-to-Analog" Cable: 5-pin-DIN to RCA	Analog Output (D/A) #0 on the Terminal Board	"From D/A" Connector on 1503/2405 UPM	Control signal generated by controller running on PC that needs to be amplified.
"To Load" Cable: 4-pin-DIN to 6-pin-DIN	"To Load" Connector on 1503/2405 UPM	Actuator Connector on plant.	Amplified control signal applied to experiment actuator.
"From Analog Sensors" Cable: 6-pin-mini-DIN to 6-pin-mini-DIN	Analog Input (A/D) #0 on the Terminal Board	"S1 & S2" Connector on the 1503/2405 UPM.	Connects the analog sensors to the UPM (provides bias and protection).
"To Analog-To-Digital" Cable: 5-pin-DIN to 4xRCA	"To A/D" connector on the UPM.	Analog Input Channels #0-3 on the Terminal Board.	Carries the analog signals from the sensors to the data-acquisition device.

Table 6 Common UPM connections.

### 2.3.3. Circuit Schematic

The power amplifier circuit yielded after connecting the UPM to a load, as described in Section 2.3.2, is shown in Figure 11 .




Figure 11 Power amplifier schematic of UPM-15-03 / UPM-24-05.

### 3. PWM Module: UPM-180-25B

As previously mentioned, the Universal Power Module model 180-25B that is shown in Figure 2 is used for more high-powered Quanser plants such as the Shake Table II and the High-Fidelity Linear Cart systems. It consists of a current-controlled power amplifier, an independent DC power supply, an analog input interface, and embedded safety circuitry. The UPM-180-25B specifications are detailed in Section 3.1 and a component overview is given in Section 3.2. Section 3.3 goes through the various safety features of the UPM. The typical connections that are used with a Quanser plant are discussed in Section 3.4. Lastly, Section 3.5 explains how to initialize, enable, and calibrate the UPM.

#### 3.1. Specifications

The UPM-180-25B device has a 3-phase PWM brushless power amplifier that is capable of supplying continuous currents up to 25 A. The amplifier is in current-mode thus an input voltage results in a controlled current through the connected load. Table 7 lists and

characterizes the main specifications associated with the UPM180-25B system.

<i>Symbol</i>	<i>Parameter</i>	<i>Value</i>	<i>Units</i>
$K_a$	PWM Amplifier Current Gain	5	A/V
$V_{bus}$	PWM Amplifier Bus Voltage	$\pm 169.7$	V
$I_{a\_max}$	PWM Amplifier Maximum Continuous Line DC Current	10	A
$I_{a\_peak}$	PWM Amplifier Peak Line DC Current	25	A
$V_{dc}$	DC Output Voltage Supply	$\pm 12$	V
$I_{dc\_max}$	DC Output Maximum Current Supply	1	A
$V_{in}$	UPM AC Supply Voltage	120	V

Table 7 UPM-180-25B specifications

The amplifier current gain,  $K_a$ , is given in Table 7. Thus applying one Volt at the amplifier input results in  $K_a$  Amperes in the attached motor. Note that the maximum voltage that is applied to the motor however is limited by the BUS voltage,  $V_{bus}$ , as specified in Table 7.

### 3.2. Description

The front panel of the UPM-180-25B is shown in Figure 12. The identification number of each component correspond to a short description in Table 8.



Figure 12 Front panel of UPM-180-25B.

<i>ID #</i>	<i>Description</i>	<i>ID #</i>	<i>Description</i>
1	UPM Power LED.	14	Safety override switch.
2	-12 V terminal of DC power supply.	15	Amplifier output connector to brushless motor.
3	Ground terminal of DC power supply.	16	Left limit LED.
4	+12 V terminal of DC power supply.	17	Home limit LED.
5	Analog sensor input #1 terminal.	18	Right limit LED.
6	Analog sensor input #2 terminal.	19	Calibrate mode LED.
7	Analog sensor input #3 terminal.	20	Amplifier driving OK LED.
8	Analog sensor input #4 terminal.	21	Enable mode LED.
9	Analog sensor input #1 6-pin-mini-DIN connector.	22	Connects to Quanser Q8 board for motor and sensor signals.

<i>ID #</i>	<i>Description</i>	<i>ID #</i>	<i>Description</i>
<b>10</b>	Analog sensor input #2 6-pin-mini-DIN connector.	<b>23</b>	Reset switch.
<b>11</b>	Analog sensor input #3 6-pin-mini-DIN connector.	<b>24</b>	Connects to plant circuit board to feedback sensor signals.
<b>12</b>	Analog sensor input #4 6-pin-mini-DIN connector.	<b>25</b>	E-Stop connector
<b>13</b>	Analog signals available to DAC device.		

Table 8 UPM-180-25B font panel component description.

Apart from driving the connected brushless DC motor, the UPM-180-25B also contains an independent 1-Ampere  $\pm 12$ -Volt regulated DC power supply. It has a three terminals: -12 V (ID #2), Ground (ID #3), and +12 V (ID #4) terminals that can be used to power instrumentation and/or external analog sensors such as accelerometers, strain gages, potentiometers, or also proximity sensors.

Analog sensors can be attached to the "S1", "S2", "S3", and "S4" 6-pin-mini-DIN connectors, labeled ID #9-12 in Figure 12. As explained in Section 2.2 for the UPM-15-03 / UPM-24-05, these connectors provide a  $\pm 12$  VDC bias to analog sensors and carry their voltage signals back to the UPM. The sensor signals are available to be read from the four terminals labelled #5-8 in Figure 12 or the "To A/D" connector, ID #13 in Figure 12. The terminals are useful to connect the sensor signals to an analog circuit, for instance, and the "To A/D" connector can be used to connect to a data-acquisition system.

The 3-phase "Motor" connector, ID #15, connects to a high-powered brushless motor. See Figure 14 in Table 10 for a description of this heavy-duty cable.

The "Safety Override" switch, ID #14, is used to enable or disable the safety features embedded in the UPM. The "Left", "Home", and "Right" LEDs identified with #16, #17, and #18, respectively, indicate when each corresponding proximity sensor has been engaged. For example, when the *Home* limit sensor is triggered the *Home* LED will be bright green. The *Left* and *Right* LEDs are also used to indicate whether the UPM has been initialized. If both LEDs are flashing then the UPM has to be initialized.

The "Cal", "OK", and "Enable" LEDs, shown in Figure 12 with ID #19, 20, and 21, describe the status of the amplifier. Table 9 describes the mode of UPM-180-25B based on the LEDs.

<i>Cal</i>	<i>OK</i>	<i>Enable</i>	<i>Mode</i>	<i>Description</i>
OFF	OFF	OFF	Not initialized.	<i>Left</i> and <i>Right</i> limit switches are flashing and amplifier is not ready-to-be-enabled.
OFF	OFF	ON	Ready-to-be enabled	Amplifier has been initialized and is ready to drive the motor.
OFF	ON	ON	Enabled	Motor is being driven. Amplifier is deactivated when the <i>Left</i> or <i>Right</i> sensor is triggered.
ON	ON	ON	Calibration	Motor is being driven. Amplifier is deactivated when the <i>Home</i> sensor is triggered.

Table 9 Status of UPM-180-25B based on *Cal*, *OK*, and *Enable* LEDs.

The "From MultiQ" connector, ID #22, is designed to connect easily with the Quanser Q8 Extended Terminal Board with the DB-25 parallel cable shown in Figure 16 in Table 10. The "To Device" connector, ID #24, attaches to the plant circuit board using the DB-15 parallel cable illustrated in Figure 15 in Table 10.

### 3.3. Safety Features

The UPM-180-25B is typically used to control high-powered devices that can achieve high accelerations and velocities. As a result, it has some safety features that disable the amplifier in case of emergency. Section 3.3.1 describes how the *Left*, *Right*, and *Home* proximity signals are used to disable the amplifier and Section 3.3.2 describes the Emergency Stop switch.

#### 3.3.1. Limit Switches

The UPM-180-25B has a PIC micro-controller circuit that performs several safety functions and helps prevent the connected plant from being damaged. These safety functions include:

1. Processing of the limit sensor signals. End of travel limit sensors (either *Left* or *Right*) disable the amplifier when in the *Enabled* mode (described in Table 9). The only way to reset the amplifier is then to trigger the *Home* proximity sensor by manually moving the system back to its mid-stroke position. The Shake Table II and High-Fidelity Linear cart systems have limit sensors installed that interface with the UPM-180-25B.
2. Conversely when the UPM is in *Calibration* mode the amplifier is instead



disabled when the table reaches the *Home* sensor. In this mode, the amplifier remains enabled when the *Left* or *Right* sensors are triggered, since the plant uses those for auto-centering.

3. After power up, the amplifier is ready-to-be-enabled only if a sequence of pulses originating from the DAC board is applied to the micro-controller. Refer to Section 3.5.1.1 for the procedure to initialize the UPM-180-25B.



**Keep the *Safety Override* switch in the OFF position.** Turning it on enables the UPM independently of any safety circuitry. It is intended only if the safety circuitry fails and you still want to perform some experiments. **With *Safety Override* ON, nothing protects the table from damage!**

### 3.3.2. Emergency Stop Switch

The UPM-180-25B amplifier can only be placed in the *Enabled* mode if the Emergency Stop, or E-Stop, switch is connected to the UPM as shown in Figure 13 and the knob is in the released, de-pressed position. The knob in the E-stop switch can be placed in the upright position by rotating it in the clockwise direction, as indicated by the arrows on the top of the red button, until it is released upwards.




Figure 13 Deadman Switch



**PRESS DOWN on the RED BUTTON of the E-Stop switch in case of emergency.** If something goes wrong during an experiment, pressing the red button of the Emergency Stop button disables the amplifier and shuts off the DC motor power.

## 3.4. Typical Connections

The UPM-180-25B interfaces with the Quanser Q8 Extended Terminal Board. The terminal

board connects the UPM with the Q4 or Q8 data-acquisition system. See Reference [1] for more information about the Q4 or Q8 control board.

### 3.4.1. Cable Nomenclature

Table 10, below, provides a description of the standard cables that connect with the UPM-180-25B.




<i>Cable</i>	<i>Description</i>
	<p>The "Motor" cable corresponds to the 3-phase motor power leads. This cable is designed to connect from the UPM-180-25B (i.e. the output of the power module after signal amplification) to the desired brushless DC motor.</p>
	<p>The "To Device" cable corresponds to a DB15 cable. It connects the plant circuit board to the UPM. It carries to the UPM all three proximity sensors' signals, the motor encoder signals, as well as the brushless motor hall sensor signals used by the amplifier for proper commutation. It also supplies the DC power required by the different sensors.</p>
	<p>The "From MultiQ" cable connects the UPM to the data acquisition card terminal board. It is compatible with Quanser's quick-connect system. It carries the motor encoder signals, limit sensor signals (right, left, and home), calibrate signal, and the S1, S2, S3, and S4 analog signals from the UPM. The cable also carries the control signal (to be amplified and sent to the cart motor) as well as the calibrate and enable digital signals sent from the DAC.</p>

Figure 14 "Motor" Cable

Figure 15 "To Device" Cable

Figure 16 "From MultiQ" Cable



<i>Cable</i>	<i>Description</i>
 <p data-bbox="264 678 605 705">Figure 17 "Emergency Stop" Cable</p>	<p data-bbox="740 331 1393 543">The "Emergency Stop" or E-Stop cable has a 6-pin-mini-DIN connector to be plugged into the side of the UPM. The UPM can be enabled if and only if E-Stop is connected to the UPM and the remote safety pushbutton switch is in the <i>depressed</i> position.</p>
 <p data-bbox="245 940 638 968">Figure 18 "From Analog Sensors" Cable</p>	<p data-bbox="740 722 1393 934">The "From Analog Sensors" cable is a 6-pin-mini-DIN-to-6-pin-mini-DIN cable that can be used to connect any potential plant sensor to the UPM such as accelerometers. It can provide a <math>\pm 12\text{VDC}</math> bias to analog sensors and carry their voltage signals to the DAC terminal board via the UPM.</p>

Table 10 Typical cables used with the UPM-180-25B.

### 3.4.2. Wiring Procedure

See the corresponding User Manual of the experiment for connection instructions.

## 3.5. Using the UPM-180-25B

### 3.5.1. Initialization

The UPM must first be initialized in order to be ready-to-be-enabled. When first powering the UPM, the Left and Right LEDs on the front panel should be blinking. To stop the LEDs from flashing follow the procedure given in Section 3.5.1.1. The signal required to initialize the UPM-180-25B is detailed in Section 3.5.1.2. The Simulink Model used to generate the initialization signals is presented in Section 3.5.1.3.

### 3.5.1.1. Initialization Procedure using WinCon

Before being able to run an experiment, the UPM180-25B must be started in the following sequence:

- Step 1. Ensure that the *Safety Override* switch, located on the UPM front panel, is OFF.
- Step 2. Connect the Emergency Stop cable to the connector on the side panel of the UPM, as shown in Figure 13. Pull up on the red knob until released in the upright position.
- Step 3. Connect the UPM to an AC outlet and turn on the main power switch, which is located at the back of the unit. The red LED on the top-left corner should be lit.
- Step 4. After power up, the UPM system is still not ready as there is no guarantee that it is connected to a computer. The *Left* and *Right* LEDs, on the UPM front panel, should be blinking. If the lights are NOT flashing turn off the power on the UPM, disconnect the "Terminal Board-To-UPM" cable, and then turn it back on again. The two LEDs should be blinking. If so, turn off the UPM, re-connect the "Terminal Board-To-UPM" cable, turn on the UPM, and proceed to the next step.
- Step 5. Load the WinCon Server software (typically placed under Quanser | WinCon in the Windows START menu).
- Step 6. Open the `q_boot_upm_zz.wcp` WinCon project that is supplied. The `zz` suffix denotes the type of data-acquisition card being used. For example, if `zz` is `q4` then the file is meant to be used with the Quanser Q4 control board. Alternatively, if `zz` is `q8` then the file is to be used with the Quanser Q8 data-acquisition system.
- Step 7. Run the initialization controller by clicking on the green START button in the WinCon Server window.
- Step 8. The *Left* and *Right* LEDs should stop flashing and the window shown in Figure 19 should be prompted. The UPM amplifier is now in the *ready-to-be-enabled* mode.




Figure 19 Message prompt after running `q_boot_upm_ZZ`

- Step 9. Another (and not recommended!) way to stop the flashing of the LEDs is to push the *Reset* button located on the UPM front panel. This bypasses the need for the previously described UPM initialization procedure. However, this is not the recommended way of operation as it overrides the UPM safety watchdog put in place to detect whether the UPM system is properly connected to your computer.

This initialization procedure does not enable the amplifier and therefore the motor cannot

be driven yet. The amplifier is only enabled when running the corresponding WinCon controller for the experiment. The amplifier is disabled when the WinCon controller terminates. The digital signals required to initialize the UPM and the signals used to enable the amplifier are described in Section 3.5.1.2.

### 3.5.1.2. Initialization Signals

The *q\_boot\_upm\_zz* WinCon controller generates and sends the enable and calibration signals shown in Figure 20 to the UPM's *AMP\_EN* and *AMP\_CAL* control lines, respectively. The enable and calibrate signals are both initialized at 0V in WinCon. The WinCon controller then brings the UPM's *AMP\_CAL* line high, connected to Digital Output #8, and sends a low pulse for 200 milliseconds. It also pulls the *AMP\_EN* line, connected to Digital Output #9, to low. WinCon automatically stops the real-time code after 0.5 seconds. This should stop the flashing and make the amplifier ready to be enabled. You can now exit WinCon without saving the project.




Figure 20 UPM Initialization Signals



**Attention MultiQ-3 Users:** The *AMP\_EN* and *AMP\_CAL* lines when using the MultiQ-3 data acquisition board are different than when using the Q4 or Q8 boards. The amplifier enable is on Digital Output Channel #0 and the amplifier calibration is on Digital Output Channel #1.

### 3.5.1.3. Simulink Model: *q\_boot\_upm\_zz.mdl*

The *q\_boot\_upm\_zz.wcp* WinCon Project file that is used to initialize the UPM-180-25B as described in Section 3.5.1.1 is built using a corresponding Simulink Model called *q\_boot\_upm\_zz.mdl*. For instance, to build *q\_boot\_upm\_q4.wcp* the Simulink Model shown in Figure 21 is used. For instructions on building a new WinCon Project see Reference [2].




Figure 21 Simulink model used to initialize UPM-180-25B.

## 3.5.2. Enabling

Once the UPM is initialized, it can be enabled and used to drive the experiment actuator. The signals required to enable the UPM-180-25B device are explained in Section 3.5.2.1 and the Simulink subsystem used to generate these signals is given in 3.5.2.2.

### 3.5.2.1. Enabling Signals

The UPM is in the *enable* state when the *Enable* and *OK* LEDs are lit and the signals required to place it in this mode are shown in Figure 22.




Figure 22 Digital signals needed to enable the UPM-180-25B device.

The UPM's *AMP\_CAL* line is connected to Digital Output #8 of the Q4/Q8 DAQ board and *AMP\_EN* line is connected to Digital Output #9 of the Q4/Q8 control card. The enable and calibrate signals are both initialized to 0V. The UPM's *AMP\_CAL* line is set to 0V for the duration of the controller running. The *AMP\_EN* is initially set to 1V and after 0.5 seconds is pulsed down to 0V for 200 milliseconds. The UPM amplifier remains enabled as long as *AMP\_CAL* sits at 0V and the *AMP\_EN* stays at 1V. The PIC in the UPM disables the amplifier when these lines values are changed, for example if *AMP\_CAL* and *AMP\_EN* are brought down to 0V, or if the *Left* or *Right* proximity sensors are activated.

**Note:** This series of signals is required to drive the motor of any experiment connected to the UPM180-25B and the amplifier is only enabled after 0.7 seconds.



**Attention MultiQ-3 Users:** The *AMP\_EN* and *AMP\_CAL* lines when using the MultiQ-3 data acquisition board are different than when using the Q4 or Q8 boards. The amplifier enable is on Digital Output Channel #0 and the amplifier calibration is on Digital Output Channel #1.

### 3.5.2.2. Simulink Model

The Simulink subsystem used to enable the UPM-180-25B device with the Q4 control board is shown in Figure 23. This subsystem needs to be included in the main Simulink model that generates a current to be fed to the connected motor.

The subsystem generates the enabling signals described in Section 3.5.2.1 and shown in



Figure 22. Upon controller exit, both digital outputs are brought down to 0V and this disables the amplifier.




Figure 23 Simulink subsystem used to enable UPM-180-25B using Q8 board.

### 3.5.3. Calibration

This section illustrates the sequence needed to place the UPM in *calibration* mode. In this mode, the PIC does not disable the amplifier when the *Left* or *Right* limit switch is triggered. For example, this is used to automatically center the stage of the Shake Table II system.

#### 3.5.3.1. Calibration Signals

The UPM is in *calibration* mode when its *Cal*, *Enable*, and *OK* LEDs are lit. In normal operation, the amplifier is disabled when the *Left* or *Right* proximity sensors are triggered. In this case, the amplifier is disabled when the *Home* sensor is activated. The enable and calibration signals needed to place the UPM in the calibration mode is depicted in Figure 24.






Figure 24 UPM Calibration Signals

The UPM's *AMP\_CAL* line is connected to Digital Output #8 of the Q4/Q8 DAQ board and *AMP\_EN* line is connected to Digital Output #9 of the Q4/Q8 control card. The enable and calibrate signals are both initialized at zero in WinCon. The WinCon controller brings the UPM's *AMP\_CAL* line to high and then brings it to 0V after 1.1 seconds. The *AMP\_EN* is initially set to 1V and after 1.2 seconds is pulsed down to 0V for 200 milliseconds. After this initial sequence, the amplifier in the UPM remains enabled as long as *AMP\_CAL* sits at 0V while *AMP\_EN* stays at 1V. The WinCon controller stops when the *Home* position has been reached and it sets the *AMP\_CAL* and *AMP\_EN* control lines back down to 0V before terminating, effectively disabling the amplifier.



**Attention MultiQ-3 Users:** The *AMP\_EN* and *AMP\_CAL* lines when using the MultiQ-3 data acquisition board are different than when using the Q4 or Q8 boards. The amplifier enable is on Digital Output Channel #0 and the amplifier calibration is on Digital Output Channel #1.

### 3.5.3.2. Simulink Model

The Simulink subsystem used to place the UPM-180-25B in calibration mode with the Q8 hardware-in-the-loop card is shown in Figure 25. This subsystem needs to be included in the main Simulink model that generates a current to be fed to the connected motor.

The subsystem generates the calibration signals described in Section 3.5.3.1 and shown in Figure 25. Upon controller exit, both digital outputs are brought down to 0V and this

disables the amplifier.




Figure 25 Simulink subsystem used to generate the calibration signals using the Q8 board.

### 3.6. Troubleshooting Guide

This section provides a list of issues that may be encountered when using the UPM-180-25B. More troubleshooting information may be offered in the user manual of the experiment being used with the amplifier.

- Q1. Why are the *Left* and *Right* LEDs on the UPM flashing?
  - The UPM has not been initialized yet. See Section 3.5.1.1 for the UPM180-25B initialization procedure.
- Q2. Why is the *Left* or *Right* LED lit after undergoing the UPM initialization procedure?
  - Either the *Left* or *Right* proximity sensors was triggered when the boot-up procedure was ran. See the corresponding experiment user manual for instructions on how to calibration the device (either using an automated program or simply moving the plant manually back to *Home* position).

- Q3. Why is the *OK* LED on the UPM not lit when running a WinCon controller?
- The Emergency Stop button is either pressed down (disabling the amplifier) or improperly connected to the UPM. Stop the WinCon controller and turn off the UPM. Then, verify that the E-Stop switch and the UPM are properly connected and ensure the E-stop button is in the released upright position.
- Q4. Why is the *Enable* LED on the UPM not lit when **running** a WinCon project?
- This indicates that the UPM amplifier is not *ready* to be enabled. Go through the UPM initialization procedure detailed in Section 3.5.1.1.

## 4. Obtaining Support

**Note that a support contract may be required to obtain technical support.** To obtain support from Quanser, go to <http://www.quanser.com> and click on the *Tech Support* link. Fill in the form with all requested software version and hardware information and a description of the problem encountered. Be sure to include your email address and a telephone number where you can be reached. A qualified technical support person will contact you.

## 5. References

- [1] Q4 or Q8 User Manual.
- [2] WinCon User Manual.