

**DRAFT FINAL  
OPERATION AND MAINTENANCE MANUAL  
OPERABLE UNIT 2  
GROUNDWATER REMEDY  
FORMER FORT ORD, CALIFORNIA**



**TOTAL ENVIRONMENTAL RESTORATION CONTRACT  
DACW05-96-D-0011  
TASK ORDER NO. 011**


**Submitted to:**

**Department of the Army  
Corps of Engineers  
1325 "J" Street  
Sacramento, California 95814-2922**

**Submitted by:**

**IT Corporation  
#4 All Pro Lane  
Former Fort Ord (Marina), California 93933-1698**

**Revision 1  
August 2002**



**DRAFT FINAL  
OPERATION AND MAINTENANCE MANUAL  
OPERABLE UNIT 2  
GROUNDWATER REMEDY  
FORMER FORT ORD, CALIFORNIA**

**TOTAL ENVIRONMENTAL RESTORATION CONTRACT II  
CONTRACT NO. DACW05-96-0011  
TASK ORDER NO. 011**

Submitted to:

U.S. Department of the Army  
Corps of Engineers, Sacramento  
1325 "J" Street  
Sacramento, California 95814-2922

Submitted by:

IT Corporation  
#4 All Pro Lane  
Marina (Former Fort Ord), California

Revision 1  
August 2002

Issued to: \_\_\_\_\_

Date: \_\_\_\_\_

Copy #: \_\_\_\_\_

☒ Controlled

☐ Uncontrolled

**DRAFT FINAL  
OPERATION AND MAINTENANCE MANUAL  
OPERABLE UNIT 2  
GROUNDWATER REMEDY  
FORMER FORT ORD, CALIFORNIA**

**TOTAL ENVIRONMENTAL RESTORATION CONTRACT II  
CONTRACT NO. DACW05-96-0011  
TASK ORDER NO. 011**

Revision 1  
August 2002

Approved by: Signature on File Date: 6/28/02  
Edwin E. Wing, P.E.  
Project Engineer

Approved by: Signature on File Date: 6/28/02  
Mike Oberwise  
Contractor Quality Control Systems Manager

Approved by: Signature on File Date: 6/28/02  
Peter Kelsall  
Project Manager

## PREFACE

IT Corporation prepared this Draft Final Operation and Maintenance Manual (O&M Manual) under the direction of the U.S. Department of the Army (Army) for the use by the Army and the signatories of the Federal Facilities Agreement, including the U.S. Environmental Protection Agency, the Department of Toxic Substances Control, and the Regional Water Quality Control Board - Central Coast Region. Since the information and drawings presented and/or referenced in this O&M Manual were prepared for the sole use of by the Army, no other party should rely on the information without prior written consent of IT Corporation.

This O&M Manual documents the procedures and methodology to safely and efficiently operate and maintain the Operable Unit 2 groundwater remedy. Information presented in this manual was gathered from different sources and organized to provide a concise manual for use by the operator.

## ***Table of Contents***

---

List of Tables .....	viii
List of Figures .....	viii
List of Acronyms .....	ix
Executive Summary .....	E-1
1.0 Introduction.....	1-1
1.1 Operations & Maintenance Manual Objectives.....	1-2
1.2 Organization of the Operation and Maintenance Manual.....	1-2
1.3 Other Related Documents .....	1-3
1.4 Site Location and Description.....	1-4
1.5 Chemicals of Concern.....	1-5
1.6 Operable Unit 2 Groundwater Remedy Objectives .....	1-5
1.7 Project Organization .....	1-6
1.7.1 Site Engineer .....	1-6
1.7.2 Groundwater Treatment Plant Operator .....	1-7
1.7.3 Site Safety and Health Officer.....	1-8
2.0 Overview of the Groundwater Remedy Operation .....	2-1
2.1 Process Overview and History.....	2-1
2.2 General Operational and Maintenance Philosophy.....	2-2
2.2.1 Environmental Protection .....	2-2
2.2.2 Safety .....	2-2
2.2.3 System Flowrates.....	2-2
2.2.4 Startup Utility Goal .....	2-3
2.2.5 On-line Utility Goal.....	2-3
2.2.6 Sampling Frequency .....	2-3
2.2.7 Troubleshooting Guide.....	2-3
2.2.8 Spare Parts Inventory .....	2-4
2.3 System Startup .....	2-4
2.3.1 Startup after a Major Groundwater Remedy Modification .....	2-4

## ***Table of Contents Continued***

---

2.3.2	Startup after a Shutdown or Minor Groundwater Remedy Modification	2-4
2.3.2.1	Visual and Instrument-Assisted Inspections .....	2-5
2.3.2.2	Mechanical and Electrical Completeness Test.....	2-5
2.3.2.3	Process Completeness .....	2-6
2.4	System Startup Procedures .....	2-6
2.4.1	Treatment Plant Startup Sequence.....	2-6
2.4.2	SCADA Cold Start .....	2-7
2.4.3	Normal SCADA Startup Procedure.....	2-7
2.5	System Shutdown.....	2-7
2.5.1	SCADA Controlled Shutdown .....	2-8
2.5.2	Routine and Emergency Manual Shutdown Procedures .....	2-8
2.5.3	Automatic Plant Shutdown Conditions .....	2-8
3.0	Groundwater Extraction System .....	3-1
3.1	Groundwater Extraction System Description .....	3-1
3.2	Pipeline and Extraction Well Nomenclature.....	3-1
3.3	Extraction Well Features.....	3-2
3.3.1	Original Extraction Wells.....	3-2
3.3.2	System Expansion Extraction Wells .....	3-3
3.3.3	Extraction Well Maintenance .....	3-3
3.4	Extraction Well Mechanical Features.....	3-4
3.4.1	Extraction Well Pump and Motor.....	3-4
3.4.2	Extraction Well Vault Construction .....	3-5
3.4.3	Original Extraction Wellhead.....	3-5
3.4.4	System Expansion Extraction Wellhead .....	3-6
3.4.5	Extraction Well Pump Maintenance.....	3-7
3.5	Extraction Conveyance Piping.....	3-8
3.5.1	Wye Vault.....	3-8
3.5.2	Extraction System Operation and Maintenance .....	3-8

## ***Table of Contents continued***

---

3.5.3	Conveyance Pipe Leak Detection.....	3-9
3.5.4	Leak Alert System .....	3-10
4.0	Groundwater Treatment Plant.....	4-1
4.1	Groundwater Treatment Plant Building and Containment .....	4-1
4.1.1	Building and Containment Foundation .....	4-1
4.1.2	Spill Control Areas .....	4-2
4.1.3	Stormwater Containment and Management .....	4-2
4.1.4	Containment Sump Pumps .....	4-2
4.2	Granular Activated Carbon Treatment System.....	4-2
4.2.1	Granular Activated Carbon Vessels .....	4-3
4.2.2	Adsorption Vessel Operation .....	4-4
4.2.3	Granular Activated Carbon Changeouts.....	4-4
4.2.4	Granular Activated Carbon Backwashing.....	4-5
4.2.4.1	Backwash Tank and Pump.....	4-6
4.2.4.2	Backwash Flow Velocity .....	4-6
4.2.4.3	Backwash Procedures.....	4-7
4.2.4.4	Recycling of Backwash Tank Water.....	4-8
4.2.4.5	Offsite Water Discharge.....	4-8
4.2.4.6	Bag and Cartridge Filter Changeout .....	4-9
4.3	Other Groundwater Treatment Plant Equipment .....	4-9
4.3.1	Influent Manifold.....	4-9
4.3.2	Flow Control Valve and Basket Strainer.....	4-9
4.3.3	Effluent Tank.....	4-10
4.3.4	Plant and Instrument Air .....	4-10
4.3.5	Potable Water .....	4-10
5.0	Treated Water Injection System.....	5-1
5.1	Injection Pumps and Injection Points .....	5-1
5.1.1	Northwest Injection .....	5-1

## ***Table of Contents continued***

---

5.1.2	Southwest Injection .....	5-1
5.1.3	Eastern and Site 2 Injection .....	5-1
5.2	Injection Wells .....	5-2
5.3	Infiltration Galleries .....	5-2
5.4	Operable Unit 2 Pipeline Extension .....	5-3
5.4.1	Pipeline Construction .....	5-3
5.4.2	Low and High Points .....	5-3
5.4.3	Piping Near Operable Unit 2 Treatment Plant .....	5-4
6.0	Electrical and Instrumentation Systems .....	6-1
6.1	Electrical Service Drop .....	6-1
6.1.1	Abrams/Imjin Wells Electrical Service .....	6-1
6.1.2	Landfill Wells Electrical Service .....	6-1
6.1.3	University Wells Electrical Service .....	6-2
6.1.4	Abrams (Original Eastern Network) Wells Electrical Service .....	6-2
6.1.5	Western Wells Electrical Service .....	6-2
6.2	Programmable Logic Controller Panel Assembly .....	6-3
6.2.1	Power Distribution Panel .....	6-3
6.2.2	Motor Starters .....	6-3
6.2.3	Low Voltage Transformers .....	6-3
6.3	Extraction Network Instrumentation and Control .....	6-4
6.3.1	Instrumentation and Control Wiring .....	6-4
6.3.2	Pipeline Leak Detection .....	6-4
6.3.3	PLC Panel Box Instrument Reset .....	6-5
6.3.4	Extraction Motor Run Relay .....	6-5
6.3.5	Direct Current Power Supply .....	6-5
6.3.6	Programmable Logic Controller .....	6-5
6.4	Extraction Network Control Narratives .....	6-6
6.4.1	Eastern Extraction Network Control Narrative .....	6-6



## ***Table of Contents continued***

---

6.4.2	System Expansion Extraction Network Control Narrative .....	6-7
6.4.3	Western Extraction Network Control Narrative.....	6-7
6.5	Groundwater Treatment Plant Control Narrative .....	6-8
6.5.1	Warning Conditions.....	6-8
6.5.2	Alarm Conditions .....	6-8
6.5.3	Tank Level Algorithm .....	6-9
6.5.3.1	Pump P-410 and P-420 Operation .....	6-9
6.5.3.2	Pump P-510 and P-520 Operation .....	6-10
6.5.3.3	Pump P-910 and P-920 Operation .....	6-10
6.5.4	Western Network Extraction Well Flow Shedding.....	6-10
6.6	Supervisory Control.....	6-10
6.6.1	Radio Link.....	6-11
6.6.2	Supervisory Control Hardware.....	6-11
6.6.3	Supervisory Control Software .....	6-11
6.6.4	Supervisory Control System Operation.....	6-11
6.6.4.1	Normal Run Mode .....	6-12
6.6.4.2	Hand Mode.....	6-12
6.6.4.3	Influent Control.....	6-12
6.6.4.4	System Expansion .....	6-13
6.6.4.5	Eastern and Western Networks .....	6-13
6.6.4.6	Groundwater Treatment Plant.....	6-13
6.6.4.7	Effluent Pump Control .....	6-13
6.6.5	Supervisory Monitoring, Control, and Expansion Capabilities.....	6-14
7.0	Health and Safety .....	7-1
7.1	Equipment Safety.....	7-1
7.2	Electrical Safety .....	7-1
7.3	Chemical Safety .....	7-2
7.4	Emergency Response/Spill Contingency Plan.....	7-2

## ***Table of Contents continued***

---

7.4.1	Lines of Authority .....	7-2
7.4.2	Safety Inspections.....	7-3
7.4.3	Potential Work Place Hazards .....	7-3
7.4.3.1	Hazardous Materials.....	7-4
7.4.3.2	Ignition Sources .....	7-4
7.4.3.3	Material Storage and Handling .....	7-4
7.4.4	Site Emergency Procedures .....	7-5
7.4.4.1	Spills and Leaks .....	7-5
7.4.4.2	Fire or Explosion.....	7-6
7.4.4.3	Earthquakes .....	7-6
7.4.4.4	Evacuation Routes and Procedures .....	7-7
7.4.5	Emergency Equipment and Location .....	7-7
7.4.6	Medical Emergencies .....	7-8
8.0	Recordkeeping, Performance Evaluation and Reporting.....	8-1
8.1	Routine Operation and Maintenance Logs .....	8-1
8.1.1	Field Activity Daily Log .....	8-1
8.1.2	Daily Flow Readings Log.....	8-1
8.1.3	Periodic Flow Readings Log .....	8-2
8.1.4	Periodic Inspection Checklist.....	8-3
8.1.5	Maintenance Checklist .....	8-4
8.2	Performance Monitoring.....	8-4
8.2.1	Discharge Standards .....	8-4
8.2.2	Operational Efficiency.....	8-5
8.2.3	System Optimization .....	8-5
8.2.3.1	Optimization Approach.....	8-5
8.2.3.2	Field Data Collection .....	8-6
8.2.3.3	Office Data Reduction/Evaluation .....	8-6
8.2.3.4	Performance of Groundwater Extraction Wells.....	8-6

## ***Table of Contents continued***

---

8.2.3.5	Performance of Granular Activated Carbon Treatment Unit..	8-7
8.2.3.6	Performance of Injection Points.....	8-7
8.2.3.7	Debottlenecking the Groundwater Remedy .....	8-7
8.3	Performance Evaluation.....	8-8
8.4	Reports to Regulatory Agencies .....	8-9
8.4.1	Quarterly Data Status Report.....	8-9
8.4.2	Annual or Semi-annual System Report .....	8-9
9.0	References.....	9-1
Appendix A	Construction Drawings	
Appendix B	Vendor Submittals	
Appendix C	Applicable or Relevant and Appropriate Requirements	
Appendix D	Groundwater Treatment Plant Operator Reports, Checklists, and Spare Parts List	
Appendix E	List of Manufacturers' Warranties	

## ***List of Tables***

---

<b><i>Table</i></b>	<b><i>Title</i></b>
1-1	Chemicals of Concern and Remediation Goals
2-1	Major Elements and Components
2-2	Well, Pump and System Capacities
3-1	Extraction Well, Injection Well, Pipeline, and Infiltration Gallery Concrete Vault Locations
6-1	Leak Detection Location Summary by Operational Function
6-2	Master Programmable Logic Controller Digital Inputs and Outputs
6-3	SCADA Status (December 2001)

## ***List of Figures***

---

<b><i>Figure</i></b>	<b><i>Title</i></b>
1-1	Drawing List and Location Map, OU2 Groundwater Remedy
1-2	Pipeline Routing and Trichloroethene Plume, A-Aquifer, OU2 Groundwater Remedy
1-3	Pipeline Routing and Trichloroethene Plume, Upper 180-foot Aquifer, OU2 Groundwater Remedy
2-1	Water Flow and Treatment Plant Sampling Schematic, OU2 Groundwater Remedy
6-1	SCADA Architecture, OU2 Groundwater Remedy

## ***List of Acronyms***

---

1,1-DCA	1,1-dichloroethane
1,2-DCA	1,2-dichloroethane
1,2-DCP	1,2-dichloropropane
ACL(s)	aquifer cleanup level(s)
ANSI	American National Standards Institute
ARAR(s)	applicable or relevant and appropriate requirement(s)
Army	U.S. Department of the Army
AWG	American wire gauge
CCR	California Code of Regulations
CFR	Code of Federal Regulations
CIH	Certified Industrial Hygienist
cis-1,2 DCE	cis-1,2-dichloroethene
COC(s)	chemical(s) of concern
EW	Extraction Well
FADL	field activity daily log
FFA	Federal Facilities Agreement
GAC	granular activated carbon
gpm	gallon(s) per minute
GWTP	groundwater treatment plant
HDPE	high density polyethylene
HLA	Harding Lawson Associates, now Harding ESE
INF	Infiltration Gallery
IT	IT Corporation
IW	Injection Well
MCL	maximum contaminant level
MRWPCA	Monterey Regional Water Pollution Control Agency
MW	Monitoring Well
NEMA	National Electrical Manufacturers Association
O&M	operation and maintenance
OU2	Operable Unit 2
OU2 System Expansion	OU2 Groundwater Remedy System Expansion
PCE	perchloroethene or tetrachloroethene
PG&E	Pacific Gas and Electric
PLC	programmable logic controller
PPE	personal protective equipment
psi(g)	pounds per square inch (gauge)
PVC (xx)	polyvinyl chloride schedule (xx = 40 or 80)
RAO	remedial action objective
RWQCB	Regional Water Quality Control Board
SCADA	supervisory control and data acquisition
Sites 2/12	Sites 2 and 12

## ***List of Acronyms continued***

---

SSHO	Site Safety and Health Officer
SSHP	Site Safety and Health Plan
TCE	trichloroethene
TERC II	Total Environmental Restoration Contract II
University	California State University, Monterey Bay
USACE	U.S. Army Corps of Engineers
USEPA	U.S. Environmental Protection Agency
VAC	volts alternating current
VDC	volts direct current
VOC	volatile organic compound

## ***Executive Summary***

---

IT Corporation has prepared this *Draft Final Operation and Maintenance Manual* (O&M Manual) on behalf of the U.S. Department of the Army. This O&M Manual addresses the operation and maintenance activities to be conducted during implementation of the Operable Unit 2 (OU2) groundwater remedy at the former Fort Ord, located north of Monterey, California. The O&M Manual was prepared for the signatories of the Federal Facilities Agreement (FFA), including the Army, the U.S. Environmental Protection Agency (USEPA), the California Department of Toxic Substances Control, and the California Regional Water Quality Control Board (RWQCB) - Central Coast Region. The FFA established the schedule for performing the selected remedial action that would be executed in accordance with the *Record of Decision, Operable Unit 2, Fort Ord Landfills, Fort Ord, California*, (OU2 ROD) (Army, 1994).

The OU2 ROD (Army, 1994) presents the required remedial action objectives (RAO) and the selected remedial action alternative used to execute and accomplish the groundwater remedy for the OU2 groundwater plume. The OU2 groundwater plume consists of 11 chlorinated volatile organic compounds (VOCs) that exceed federal or state maximum contaminant levels (MCL) or risk-based values. The original groundwater remedy commenced treatment operations on October 23, 1995.

The FFA stipulated that 5-year reviews of the groundwater remedy evaluate its effectiveness in achieving the RAOs. In preparation for the first 5-year review, aquifer modeling suggested that three areas in the A-aquifer and Upper 180-foot aquifers, located further east and south of the existing extraction wells, were not adequately being captured. The OU2 System Expansion, consisting of additional extraction wells and increased treatment capacity, was deemed necessary to satisfy the required RAOs. Initial components of the OU2 System Expansion commenced treatment operations on August 11, 2000, and the expanded system was fully operational in April 2001. The original system remained operational during the installation of the expansion components.

Portions of this manual update the original *Draft Final Operation and Maintenance Manual, Operable Unit 2, Pump and Treat* (original *OU2 O&M Manual*) (IT, 1997), with amendments suggested in the *Draft Effectiveness Evaluation, Technical Memorandum, OU2 Groundwater Remedy*, (Harding Lawson Associates, 1998), and incorporates applicable guidance from the USEPA's Fact Sheet, *Operation and Maintenance in the Superfund Program* (USEPA, 2001).

This O&M Manual presents information to meet the following objectives:

- Describes the operation and maintenance features for each installed component
- Provides adequate information for the groundwater treatment plant (GWTP) Operator to be able to safely and efficiently operate, maintain, and monitor the groundwater remediation system in each mode of operation
- Details the procedures for start-up
- Details the procedures for normal plant operation and maintenance
- Provides methodology for optimizing the groundwater remediation system and evaluating its effectiveness
- Describes health and safety requirements during plant operation and maintenance
- Details the record keeping and reporting requirements
- References as-built drawings and equipment data sheets relevant to groundwater remediation system operation.



## 1.0 Introduction

---

This *Draft Operation and Maintenance Manual* (O&M Manual) was prepared by IT Corporation (IT) under contract to the U.S. Department of the Army (Army) to document the procedures used to operate and maintain the Operable Unit 2 (OU2) groundwater remedy system (OU2 System) at the former Fort Ord, California. This O&M Manual was prepared for the signatories of the Federal Facilities Agreement (FFA), including the Army, the U.S. Environmental Protection Agency (USEPA), the California Department of Toxic Substances Control, and the California Regional Water Quality Control Board (RWQCB) - Central Coast Region. The FFA establishes the schedule for performing remedial investigations, feasibility studies, and remedial actions. The selected remedial action for groundwater is being executed in accordance with the *Record of Decision, Operable Unit 2, Fort Ord Landfills, Fort Ord, California*, (OU2 ROD) (Army, 1994).

The OU2 ROD (Army, 1994) presents the required remedial action objectives (RAO) and the selected remedial action alternative used to execute and accomplish the groundwater remedy for the OU2 groundwater plume. The OU2 groundwater plume consists of 11 chlorinated volatile organic compounds (VOCs) that exceed federal or state maximum contaminant levels (MCL) or risk-based values. The original groundwater remedy commenced treatment operations on October 23, 1995.

The FFA stipulated that 5-year reviews of the groundwater remedy evaluate its effectiveness in achieving the RAOs. In preparation for the first 5-year review, aquifer modeling suggested that three areas in the A-aquifer and Upper 180-foot aquifer, located further east and south of the existing extraction wells, were not adequately being captured. The OU2 System Expansion, consisting of additional extraction wells and increased treatment capacity, was deemed necessary to satisfy the required RAOs. Initial components of the OU2 System Expansion commenced treatment operations on August 11, 2000, and the expanded system was fully operational in April 2001. The original system remained operational during the installation of the expansion components.

Construction of the OU2 System Expansion is documented in the *Draft Final Construction Completion Report* (IT, 2001a). Construction was completed in accordance with the approved *Draft Final Groundwater Remedial Action Work Plan* (IT, 1999a) and *Draft Final Contractor Quality Control Plan* (IT, 1999b).

## **1.1 Operations & Maintenance Manual Objectives**

The objective of this O&M Manual is to provide adequate information for the groundwater treatment plant (GWTP) Operator to safely and efficiently operate, maintain, and monitor the groundwater remedy in each mode of operation. Modes of operation include batch startup, intermittent operations, and normal, automated operation. This manual also describes the procedures and the initial data requirements necessary to document that the RAOs are being met.

This O&M Manual must be periodically updated to reflect actual operating conditions. Changes in site conditions, system components, operating procedures, and experiences may also determine how the system is operated over the long term. Significant modifications will be documented in a Field Work Variance approved by the U.S. Army Corps of Engineers (USACE) and incorporated into subsequent revisions to this manual. In the future, groundwater remedy operation and maintenance may be transferred to another organization. Although the new organization may have different contractual requirements and procedures, the basic requirement to document changes will still apply.

## **1.2 Organization of the Operation and Maintenance Manual**

This manual is organized into the following sections and appendices:

- [Section 1.0](#) introduces the scope, intent, and organization of the O&M Manual, and describes organizational responsibilities.
- [Section 2.0](#) presents the overview of the OU2 groundwater remedy operations, including startup, shutdown, and general operating and maintaining philosophy.
- [Section 3.0](#) describes and details the operation and maintenance of the groundwater extraction system from each extraction well to the conveyance pipe.
- [Section 4.0](#) describes and details the operation and maintenance of the treatment plant building and processes from the inlet manifold to the effluent tank.
- [Section 5.0](#) describes and details the operations and maintenance of the treated water injection system from the injection pumps to each injection point.
- [Section 6.0](#) describes and details the operations and interconnections between the electrical system and the instrumentation and control system.
- [Section 7.0](#) covers health and safety requirements.
- [Section 8.0](#) describes records and record-keeping requirements, long-term performance requirements, and the data collection and optimization strategy for the groundwater remedy.
- [Section 9.0](#) lists references cited.

- [Appendix A](#) includes the construction drawing index and the field-surveyed drawing indexes for the original OU2 pipelines, the Sites 2 and 12 (Sites 2/12) pipelines, and the OU2 System Expansion pipelines. Detailed general, civil, process, mechanical, utility, electrical, and instrumentation drawings are in the *Draft Final Construction Drawings, Operable Unit 2, Groundwater Remedy System Expansion (Draft Final Construction Drawings)* (IT, 2002).
- [Appendix B](#) includes an index of the vendor submittals. Complete vendor documentation is included in the *Draft Vendor Submittals, Operable Unit 2, Groundwater Remedy System Expansion* (IT, 2001b).
- [Appendix C](#) includes selected from the applicable or relevant and appropriate requirement(s) (ARARs) for the remedy.
- [Appendix D](#) includes the GWTP Operator reports, checklists, and spare parts list.
- [Appendix E](#) includes the manufacturers' warranty section copied from [Appendix B](#).

### 1.3 Other Related Documents

Operation and maintenance of this groundwater remedy shall comply with the referenced ARARs ([Appendix C](#)). Portions of this manual update the original *Draft Final Operation and Maintenance Manual, Operable Unit 2, Pump and Treat* (original OU2 O&M Manual) (IT, 1997), with amendments suggested in the *Draft Effectiveness Evaluation, Technical Memorandum, OU2 Groundwater Remedy*, (Harding Lawson Associates, 1998). The manual incorporates applicable guidance from the USEPA's Fact Sheet, *Operation and Maintenance in the Superfund Program* (USEPA, 2001).

The original OU2 extraction well and injection well completion detail is documented in the *Draft Final Well Installation and Abandonment, Operable Unit 2, Pump and Treat Report* (IT, 1996). The OU2 System Expansion extraction well and infiltration gallery boring completion detail is documented in the *Draft Final Well Installation and Abandonment Report, Operable Unit 2, Groundwater Remedy System Expansion* (IT, 2001c). Treatment plant water sampling shall follow the *Draft Sampling and Analysis Plan, Operable Unit 1, Operable Unit 2, and Sites 2 and 12, Groundwater Treatment Systems* (Harding ESE, 2001). A discussion of specific OU2 System Expansion construction components, a more detailed description of construction activities, and startup parameters for the plant commissioning are documented in the *Draft Final Construction Completion Report* (IT, 2001a). The health and safety section is intended to supplement the *Site Safety and Health Plan* (SSHP) (IT, 2000), with groundwater remedy-specific issues.

#### **1.4 Site Location and Description**

The former Fort Ord is located in northwestern Monterey County, approximately 80 miles south of San Francisco, California (Figure 1-1). The former military installation covered about 28,000 acres, is bounded by Monterey Bay to the west and the Santa Lucia Range to the south, and is surrounded by the cities of Del Rey Oaks, Marina, Sand City, and Seaside. State Highway 1 and the Southern Pacific Railroad traverse through the western portion of the former Base, separating the Monterey Bay beach front from the rest of the installation. The installation served as a training and staging facility for infantry troops from its opening in 1917 until it closed in 1993. In 1990, the former Fort Ord was placed on the USEPA National Priority List, primarily due to VOCs found in the groundwater beneath the OU2 landfills.

Operable Unit 2 formerly included six landfill cells, one cell north and five cells south of Imjin Road, covering approximately 150 acres, including the immediate surrounding area and underlying impacted groundwater. As part of the OU2 landfill remedial activity, the contents of the landfill cell north of Imjin Road were moved to the southern landfill cells. The southern landfill cells were consolidated with fill from the north OU2 landfill and other Fort Ord soil remediation sites, and have been capped and revegetated.

The two groundwater aquifers of interest within OU2 are the unconfined A-aquifer and the confined Upper 180-foot aquifer. Both aquifers consist predominantly of fine- to coarse-grained sands. The two aquifers are separated by the Fort Ord-Salinas Valley aquiclude, which consists of blue-gray plastic clay with abundant shells and occasional thin beds of fine-grained sand. Depth to groundwater in the A-aquifer is approximately 100 to 180 feet below ground surface. Groundwater in this aquifer flows generally to the north and deviates to the west and east from a north-trending groundwater divide extending from the eastern portion of the OU2 landfills to Fritzsche Army Airfield. Depth to groundwater in the Upper 180-foot aquifer is between 110 and 220 feet below ground surface. Groundwater in the Upper 180-foot aquifer generally flows east toward the Salinas Valley (HLA, 1999).

Figures 1-2 and 1-3 show the extent of the contaminated plume in the A-aquifer and Upper 180-foot aquifer, respectively, as they were recorded prior to operation of the expanded system. Updated plume contours are included in the semi-annual or annual system reports (Section 8.4.2). These figures also show the locations of remedy components including extraction wells, pipelines, treatment plant and injection system.

A separate groundwater plume exists at Sites 2/12, located to the west of the OU2 landfills. Site 2 is west of State Highway 1 between the 8<sup>th</sup> and 12<sup>th</sup> Street bridges; Site 12 is located to the east of State Highway 1. This plume is relevant to the OU2 remedy because treated water from OU2 is transferred by pipeline for discharge above the plume at Site 2.

Saltwater intrusion, defined by a total dissolved solids concentration of greater than 3,000 milligrams per liter, is migrating from Monterey Bay into both aquifers. The saltwater intrusion is due, in part, to historical groundwater pumping in the Salinas Valley to the east, and to normal saltwater/freshwater interactions found in coastal aquifers. Saltwater intrusion extends as a wedge, thinning from west to east into the Upper 180-foot aquifer beneath Site 2. The easternmost extent of saltwater intrusion into the Upper 180-foot aquifer is approximately beneath State Highway 1.

### **1.5 Chemicals of Concern**

The OU2 groundwater plume, in the A-aquifer and Upper 180-foot aquifer, is defined by the occurrence of chlorinated VOCs present at concentrations that exceed aquifer cleanup levels (ACL) established in the OU2 ROD (Army, 1994). [Table 1-1](#), Chemicals of Concern and Remediation Goals, lists the 11 chemicals of concern (COC), the federal and state MCLs, ACLs, and treated water discharge limits. The 11 COCs include benzene, carbon tetrachloride, chloroform, 1,1-dichloroethane (1,1-DCA), 1,2-dichloroethane (1,2-DCA), cis-1,2-dichloroethene (cis-1,2-DCE), 1,2-dichloropropane (1,2-DCP), methylene chloride, tetrachloroethene (PCE), trichloroethene (TCE), and vinyl chloride. TCE is the most common and widespread of the COCs and is used in this report to illustrate plume extent in both the A-aquifer and Upper 180-foot aquifer ([Figures 1-2](#) and [1-3](#), respectively).

The Sites 2/12 groundwater plume, in the Upper 180-foot aquifer, is defined by the occurrence of eight COCs. No chlorinated VOCs have been detected above the ACLs in the Lower 180-foot aquifer. TCE is the most widespread of the eight COCs. The other seven COCs include chloroform, 1,1-dichloroethene, 1,2-DCA, cis-1,2-DCE, PCE, vinyl chloride, and total 1,3-dichloropropene.

### **1.6 Operable Unit 2 Groundwater Remedy Objectives**

The objective of the OU2 groundwater remedy is to extract impacted groundwater from the A-aquifer and Upper 180-foot aquifer, remove the COCs from the impacted water, and to produce an effluent that meets the ACLs and ARARs ([Table 1-1](#)). During normal operations, the

groundwater remedy shall achieve and maintain an adequate capture zone while minimizing groundwater effects that effect aquifer salt water intrusion.

To meet these goals, each unit operation must be monitored to achieve its intended function while maintaining maximum operation and control. Adequate equipment sizing, alarm devices, and process control are included in the design to provide a high degree of safety, reliability, and operational flexibility.

## **1.7 Project Organization**

The OU2 groundwater remedy was initially operated by Harding ESE under contract to IT under the Sacramento District Total Environmental Restoration Contract II (TERC II) organization and TERC II technical requirements. The operational scope of work under the TERC II contract, together with organizational roles, organizational responsibilities, and quality control requirements, are addressed in the *Work Plan, Operational Maintenance, Groundwater Treatment Systems* (HLA, 2000). Operation and maintenance of the remedy may periodically be transferred to a different organization. Although the new organization may apply different contractual requirements and procedures, the basic O&M roles and responsibilities described below will still apply.

Routine O&M of the groundwater remedy will be the responsibility of the Site Engineer and GWTP Operator, with oversight by the Site Safety and Health Officer (SSHO). Specific job descriptions and responsibilities for the Site Engineer, GWTP Operator and SSHO follow.

### **1.7.1 Site Engineer**

The Site Engineer is responsible for technical oversight of the remedy O&M. The Site Engineer requires specific in-depth knowledge of process control, hydrogeologic interpretation, and technical report generation.

The Site Engineer will be responsible for the quarterly data summary reports and the annual or semi-annual evaluation reports, and will initiate economic and technical evaluations as needed to monitor cost-effective system operation.

Typical evaluations include:

- Extraction well (EW) flow capacity, performance, and maintenance frequency
- Treatment plant flow capacity, performance and maintenance frequency

- Injection well (IW) flow capacity, performance, and maintenance frequency
- Infiltration gallery (INF) flow capacity, performance, and maintenance frequency
- Recommendations for improving the treatment system
- Recommendations for improving the process control and reporting criteria
- Recommendations for improving hydraulic capacity and hydraulic control.

### **1.7.2 Groundwater Treatment Plant Operator**

The GWTP Operator has day-to-day responsibility for groundwater remedy technical, operations, and maintenance issues. The groundwater remedy includes the extraction network, the GWTP, the injection network, and all ancillary components. The GWTP Operator will:

- Operate the groundwater remedy economically while meeting the referenced ARARs
- Monitor and record manual instrument interface readings and trends
- Monitor and record analog/digital signals and trends
- Monitor, record and address alarm conditions
- Monitor and record groundwater remedy and component performance
- Maintain logs, inspections and maintenance checklists
- Periodically calibrate and verify digital and analog signal inputs to the GWTP
- Perform routine sampling and sample shipment coordination
- Perform routine instrument, equipment and component maintenance
- Adjust treatment operations and components as necessary to meet objectives
- Troubleshoot operational problems and identify maintenance issues
- Schedule and supervise subcontracted repairs, service and non-routine maintenance
- Maintain inventory of spare parts and chemicals, and coordinate material replenishment
- Make recommendations for improvements
- Initiate all reports
- Coordinate and report deviations to the groundwater remedy operation.

The GWTP Operator shall have the ability and judgment to work independently, shall be familiar with continuously operating water treatment plant facility operations by formal training or by experience, and shall complement the Site Engineer on technical issues listed in this section and [Section 1.7.1](#) above. The GWTP Operator shall have substantive knowledge of the following:

- Potable water treatment plant safety
- Pipe fittings and valves
- Well and wellhead mechanical systems
- Pumps and motors
- Pressurized air systems
- Three-phase and single-phase electrical systems
- Electronic instrumentation and control
- Instrument calibration techniques
- Data acquisition and reduction
- NT Windows computer systems

Other minimum requirements include:

- California Drivers License
- 40-hour Hazardous Waste Operations and Emergency Response Training
- Site-specific orientation
- Site-specific chemical handling training for on-site chemicals requiring a materials safety data sheet

### **1.7.3 Site Safety and Health Officer**

The SSHO is responsible for implementation of the SSHP (IT, 2000). Future GWTP operations shall either comply with the current SSHP, as prepared by IT, or a revised SSHP as approved by the USACE. The SSHO will conduct periodic inspections to verify compliance with the SSHP, USACE contract requirements, and Occupational Safety and Health Administration regulations.

The SSHO has the authority to take immediate steps to correct unsafe or unhealthy conditions, including the termination of groundwater remedy operations. The SSHO may recommend select disciplinary actions while maintaining an open dialogue with subcontractor supervisory personnel to expedite the correction of safety deficiencies. The SSHO may communicate directly with site visitors or workers to correct hazardous conditions, assess potential unsafe conditions, and implement the requirements established in the SSHP.

The SSHO will have specialized training in personnel protective equipment (PPE), respiratory protective equipment, confined space program oversight, proper use of air monitoring



instruments, air sampling methods, and interpretation of results. In addition, the SSHO must have working knowledge of applicable federal, state, and local occupational health and safety regulations.

## 2.0 Overview of the Groundwater Remedy Operation

---

The purpose of this section is to present the process overview, and to provide general information for the GWTP Operator to safely startup and shutdown the groundwater remedy while complying with the operating guidelines. Specific equipment operation, detailed automatic control, and other operating and maintenance considerations, are described in subsequent sections.

### 2.1 Process Overview and History

The groundwater remedy is comprised of the groundwater extraction system, the GWTP, and the treated water injection system. [Figure 2-1](#) depicts the water flow schematic. The process flow diagrams, *Draft Final Construction Drawings* (IT, 2002), IT File Numbers 783751-E61 and -E62, show the process in more detail. Major elements and components are listed in [Table 2-1](#). The primary GWTP operation is VOC adsorption onto granular activated carbon (GAC). Continuous GWTP unit operations are automated through a master programmable logic controller (PLC) that is located at the GWTP. A supervisory control and data acquisition (SCADA) package is installed to monitor and control the functions of remotely installed PLCs. Secondary unit operations include process stream filtration, flow equalization, and backwash and filtration of the recycle stream. The secondary unit operations that are process stream determined are automated through the PLC.

The original groundwater remedy commenced operations on October 23, 1995 with treated water flows ranging up to 740 gallons per minute (gpm). Performance data, along with operation and maintenance issues are discussed in annual or semi-annual system reports as described in [Section 8.4](#). Original OU2 groundwater remedy process features and OU2 System Expansion construction-specific details are discussed in the *Draft Final Construction Completion Report* (IT, 2001a).

The OU2 System Expansion commenced treatment operations on August 11, 2000. Periodic reports, including performance data, along with operation and maintenance issues, are discussed in [Section 8.0](#), Reports to Regulatory Agencies.

The Sites 2/12 groundwater remedy treatment operation started on April 13, 1999, extracting up to 300 gpm of groundwater beneath Site 12 and recharging the aquifer beneath Site 2. A pipeline was installed between the two plants. Commencing on June 23, 1999 up to 350 gpm of excess

OU2 treated water began flowing from the existing OU2 GWTP to Site 2. The combined 650 gpm Sites 2/12 and OU2 treated water flow is conveyed west of State Highway 1 for aquifer recharge.

The treated water that is transferred from OU2 to Sites 2/12 is critical to the Sites 2/12 operation. In the event that the OU2 GWTP is shut down for an extended period (6 hours or more), the Sites 2/12 GWTP must also be shut down. At present this shutdown must be performed manually.

## **2.2 General Operational and Maintenance Philosophy**

General O&M philosophies following startup and during normal operations are discussed below.

### **2.2.1 Environmental Protection**

The design of the OU2 Groundwater Remedy includes features intended to protect human health and the environment in the event of failure of system components. These features include:

- The pipelines from the extraction wells to the treatment plant are double-contained. A failure in the primary, inside pipe will alarm the leak detection sensor in the secondary, outer pipe.
- The extraction well and isolation valve vaults provide containment for single-wall piping.
- Concrete vaults with leak detection are installed at the extraction wells and pipeline maintenance valve boxes where there is single-contained piping.
- The treatment areas are bermed and provide containment for the process piping and tanks. The concrete in the two containment areas is epoxy-coated to reduce environmental concrete breakdown.

### **2.2.2 Safety**

The GWTP Operator shall follow the safety procedures referenced in [Section 7.0](#) of this document during both operation and maintenance of the groundwater remedy.

### **2.2.3 System Flowrates**

The design flowrates for the extraction wells and recharge points are shown in [Table 2-2](#). System monitoring data will be evaluated to periodically adjust the individual flow rates as necessary.

Upon startup, extraction well pump networks should be energized sequentially. This will minimize the effects of water hammer while the system is gradually brought to a high flow rate.

Water hammer can cause premature and nuisance activation of pressure switches, and in extreme cases, cause pipeline failure.

#### **2.2.4 Startup Utility Goal**

The on-line goal following a major system modification will be 75 percent for the subsequent two weeks. Individual components, set points and alarm conditions may require frequent adjustment, and may result in frequent shutdowns. The moderate on-line goal will allow sufficient time to check and adjust individual pieces of equipment and to test their operating characteristics prior to placing the treatment system in a high on-line utility state.

To achieve the utility goal, the plant may need to operate 24 hours per day, seven days per week. The level of installed automation will allow the plant to run continuously without constant, 24 hour, GWTP Operator contact. After startup, or following periods of prolonged shutdown, the GWTP Operator will be in attendance as necessary during normal business hours to perform inspections and adjustments. As the treatment plant tracks to steady-state operation, the role of the GWTP Operator will decrease.

#### **2.2.5 On-line Utility Goal**

The system on-line utility goal is 95 percent. Routine O&M will be performed during normal business hours or on an as-needed basis to maintain groundwater remedy utility. It will consist of a visual inspection of process equipment and instruments, as well as scheduled maintenance procedures for all major components. The GWTP Operator will document O&M performed on standardized logs and checklists. The completed logs and checklists will be maintained in a binder located within the control room.

#### **2.2.6 Sampling Frequency**

Requirements regarding sampling frequency and other chemical data acquisition parameters can be found in the *Draft Final Sampling and Analysis Plan* (HLA, 2001). [Figure 2-1](#) shows the locations of sampling points in the GWTP.

#### **2.2.7 Troubleshooting Guide**

A summary of common problems that may occur with the operation of the groundwater remedy and its systems can be found in the individual vendor supplied O&M Manuals found in [Appendix B](#).

### **2.2.8 Spare Parts Inventory**

The spare parts inventory is included as [Appendix D](#). Inventory is kept low because the design philosophy employs 100 percent installed and operational spares for the primary process equipment. If one pump in the pair fails mechanically, electrically, or electronically, the second pump can be started immediately. The dual pumps are fully installed and operational backups, and therefore are not included in the spare parts list. If one pump fails, there should be adequate time to schedule replacement or repair of the failed component.

The spare parts list has a nominal inventory of spare pump parts. The long-term inventory should be based on the maintenance frequency, procurement lead time, and system criticality. Spare parts shall be replaced when used. No spare parts are inventoried for the submersible pumps, since pump parts are readily available. Maintenance pumps, including those pumps that are not operated continuously, do not have installed spares.

## **2.3 System Startup**

This section describes the general groundwater remedy startup procedures and philosophy. Specific groundwater remedy system startup and shutdown procedures are described below in [Section 2.4](#) and [2.5](#), respectively. Component operational procedures are discussed in later sections.

### **2.3.1 Startup after a Major Groundwater Remedy Modification**

If a major modification or replacement is implemented on the groundwater extraction, GWTP operations, and/or treated water injection systems, the initial shakedown section in the *Draft Final Construction Completion Report* (IT, 2001a) should be followed prior to commencing normal extraction and water treatment operations. Minor modifications and replacements should generally follow [Section 2.3.2](#) below. The number of and detail of system checks shall correspond to the level of modifications.

### **2.3.2 Startup after a Shutdown or Minor Groundwater Remedy Modification**

If a particular component or system is replaced or modified, only that component or system and those components directly influenced by the replacement or modification need to be checked for mechanical, process, electrical, and/or instrument-control congruity, as appropriate.

After an unexpected shutdown, the GWTP Operator shall take reasonable steps to stabilize the situation, if required, and shall notify the Site Engineer. The Site Engineer will determine the appropriate inspections, as detailed below, appropriate response (short term), and appropriate

corrective action (long term). For example, after a minor earthquake, the entire system should be monitored closely for changes in operating conditions, with pipeline gauges visually checked against standard conditions. A moderate earthquake may require more extensive visual inspections, with a pipeline pressure test prior to start-up. A large earthquake will require more thorough visual and instrument inspections of both above and below ground groundwater remedy components.

After an extended shutdown, or another event that has the potential to cause system or component damage, or when damage is suspected, a mechanical, process, electrical, and/or instrumentation completeness check shall be performed to verify the correct installation and proper operation of the connected equipment.

#### **2.3.2.1 Visual and Instrument-Assisted Inspections**

During the mechanical and process completeness check, a visual inspection of the installed system against the construction drawings will be made to confirm that equipment and ancillary items are in their proper locations, are appropriately connected, that all bolts have been tightened, and that all supports have been secured to support the intended weight.

During the electrical and instrumentation completeness check, electrical equipment and wiring will be visually checked against construction drawings to ensure proper installation and connections. After connecting to the intended power supply, the end terminations at the equipment shall be checked to insure proper voltage and signal output.

#### **2.3.2.2 Mechanical and Electrical Completeness Test**

Modified or replaced components shall be pressure tested separately with potable or treated water prior to being placed in normal operation. If the components are part of a larger system that cannot be mechanically isolated, then the larger system will require pressure testing. Untreated water shall not be allowed to enter the system until the component or system has been successfully pressure tested. Pressure testing shall follow the manufacturer's guidelines for the intended use of the equipment or system. Test guidelines should consider:

- Hydrostatically test the backwash tanks, effluent tank, and all gravity flow lines. Overflow lines need not be hydrostatically tested.
- Pressure test the GAC vessels, ancillary manifold, and all pressurized lines.
- Simulate individual equipment unit operations with potable or treated water.

- Set process set points and simulate operation of PLC controls. Modifications should initially be tested in the manual mode, with the instrumentation and control package either turned off or under limited operation.

### **2.3.2.3 Process Completeness**

After mechanical completeness is confirmed, the treatment of impacted water can begin. The objective of the process completeness test is to verify that treatment of the impacted water is occurring. This test need only be performed if there has been a material change in the treatment process. The following steps should be performed:

1. Verify that the effluent tanks have sufficient capacity.
2. Pump groundwater from operational extraction wells for at least 10 minutes.
3. Take one analytical sample each of the GAC vessel influent and GAC vessel effluent. The effluent analysis is scheduled to have a laboratory turnaround time of 24 hours.
4. If the treated water meets the discharge requirements, it can be discharged to the injection wells and/or infiltration galleries.

As soon as the analytical results obtained during batch testing confirm that the GAC is treating the water to below the effluent criteria, normal operations may begin.

## **2.4 System Startup Procedures**

This section contains the SCADA procedures to startup the groundwater remedy.

### **2.4.1 Treatment Plant Startup Sequence**

The groundwater remedy can be placed back in service with or without the SCADA system using the following sequence

1. Verify all valves are in their correct operating position by cross checking the GWTP Valve Positioning Checklist ([Appendix D](#)).
2. Verify all circuit breakers are in their correct operating position.
3. Press the “System Start” pushbutton. For safety purposes, pressing the “System Start” button automatically resets all equipment in “hand” to “auto” mode. Do not confuse this push button with the “virtual” pushbuttons located in the SCADA interface. SCADA activation should follow using the next two sections.
4. Verify pressure, system direction, and flowrate through each unit operation.
5. Adjust extraction wells, injection wells and infiltration galleries to the desired flow rates, as appropriate.

6. Verify the correct flow to the injection wells and infiltration galleries.

### **2.4.2 SCADA Cold Start**

The GWTP SCADA interface is equipped with an uninterruptible power supply (UPS), which provides nominal battery backup during a utility power outage. If the power outage exceeds the battery life, then upon power restoration the personal computer running the LookoutDirect™ SCADA software will reboot. A description of the personal computer and ancillary hardware and software is detailed in [Section 6.0](#).

After rebooting, the personal computer will prompt the operator for the user name, which gives the GWTP Operator access to all Windows NT functions, and the computer password. To launch the LookoutDirect™ software, simply double-click on the shortcut icon resembling a lighthouse. After launching, open the project file for the OU2 groundwater treatment plant, titled “OU2\_GWTP,” located on the C drive root directory, and backed up on the D drive. The project file is launched in the same way that a spreadsheet or word processor file is opened. Click the “Open” command from the “File” menu, or the Open dialog box.

### **2.4.3 Normal SCADA Startup Procedure**

The virtual Hand-Off-Auto slider switches are located on the treatment plant operator screen in the personal computer’s operator interface. SCADA operations are performed by clicking virtual switches or toggles with the computer’s mouse. Once the LookoutDirect™ software is running the “OU2\_GWTP,” the treatment plant may be started as follows:

1. Clear alarms. Alarms are described in [Section 6.0](#).
2. Place influent control valve virtual Hand-Off-Auto slider switches in “Automatic.”
3. Place appropriate effluent injection pump virtual Hand-Off-Auto slider switches in “Automatic.”
4. Place GWTP in the run mode by clicking the main system virtual “start” pushbutton.
5. Place appropriate extraction pump virtual Hand-Off-Auto slider switches in “Automatic.”

Detailed descriptions of the control logic are included in [Section 6.0](#).

## **2.5 System Shutdown**

This section contains the procedures to shut down the groundwater remedy. Conditions that will cause shutdown are also briefly discussed.



### **2.5.1 SCADA Controlled Shutdown**

A SCADA controlled shutdown of the OU2 groundwater extraction and treatment system may be initiated as follows:

1. Place each extraction well virtual Hand-Off-Auto slider switch, located on the extraction well screen of the operator interface personal computer, to “Off.”
2. Click the main system virtual “stop” pushbutton of the treatment plant operator interface panel. This will stop the effluent injection pumps and close the treatment plant influent valves.
3. Follow the mechanical procedures discussed above to secure valves and equipment.

### **2.5.2 Routine and Emergency Manual Shutdown Procedures**

Provided the groundwater remedy, at each local PLC, is being operated in the “automatic” mode, the GWTP, extraction and injection systems can be shut down without the use of the SCADA interface. To manually shutdown the groundwater remedy, perform the following procedures:

- For an orderly, routine shutdown, press the “System Stop” pushbutton at the master PLC,
- For an urgent and immediate shutdown, press the “Emergency Stop” pushbutton at the master PLC.

Either of the two actions will shut down the groundwater remedy. For safety purposes, during either of the two plant shutdown procedures listed above, the master PLC will reset process equipment in “hand” to “auto” mode. This action will remove all permissive run circuits. After a manual shutdown:

- Verify that flow to and within the system is slowing or has stopped. After water flow has stopped, close at least one butterfly valve on each parallel influent leg.
- Complete the GWTP Valve Checklist ([Appendix D](#)) for shutdown valve positions.
- If the plant is shut down for maintenance purposes, the power to the equipment associated with that system should be shut off at the local control panel or the specific trip at the motor control center. If required, the main power can be shut off at the motor control center; however, this will also de-energize power to the building lights and the instrumentation package. Lockout/tagout procedures shall be followed for maintenance work on any electrical equipment.

### **2.5.3 Automatic Plant Shutdown Conditions**

Provided the groundwater remedy, at each local PLC, is being operated in the “automatic” mode, the GWTP, extraction and injection systems will automatically shut down in response to pre-

programmed alarm conditions such as leak detection, high pressure, or high liquid levels. The following events may sequence into a plant shutdown or reduced flow conditions:

- Loss of primary power or a tripped main circuit breaker will cause GWTP or PLC Panel shutdown. Remember that the GWTP is electrically separate from each remote PLC Panel. A loss of electricity at one or more remote PLC Panel may not shut down the GWTP; however a loss of electricity at the GWTP must lead to a termination of water flow from each extraction well pump.
- Leak detection in one or more extraction conveyance lines will shut down the extraction wells in that portion of the conveyance line, reducing flow to the GWTP.
- Excessive influent manifold pressure, which must be set below 100 psig, will shut down the extraction well pumps. The plant will eventually shutdown. Pressing the treatment plant “start” button will not restart the plant until the pressure in the influent line decreases to below the setpoint of the pressure switch.
- Excessive water in the Effluent Tank, due to a failed ultrasonic level controller or variable speed controller, will shut down the extraction pumps.
- Excessive effluent pressure, currently set at 38 psi, will shut down the local injection pump. The plant will eventually shutdown due to the level switch high (LSH) in the Effluent Tank. Pressing the treatment plant start button will not restart the plant until the pressure in the effluent line decreases to below the setpoint of the pressure switch.

The next section provides a description of the groundwater remedy’s extraction system.

## 3.0 Groundwater Extraction System

---

This section presents the OU2 groundwater extraction network overview and description, including process, mechanical, civil, and instrumentation control features. Associated electrical power and the SCADA system are covered starting in [Section 6.0](#).

### 3.1 Groundwater Extraction System Description

The groundwater extraction system consists of 22 extraction wells arranged in two well networks, inter-connecting conveyance piping, and other ancillary equipment. Fifteen extraction wells distributed between the Western and Eastern Networks were installed as part of the original OU2 groundwater remedy. Seven extraction wells were installed in three clusters as part of the OU2 System Expansion and are mechanically connected to the Eastern Network at the Wye Vault. [Figures 1-2](#) and [1-3](#) show the extraction wells and inter-connecting conveyance pipeline. [Table 2-1](#) lists the major elements and components.

### 3.2 Pipeline and Extraction Well Nomenclature

The two distinctive networks, three well clusters, and their inter-connecting conveyance pipelines are named as follows

- The Western Extraction Network is composed of seven extraction wells adjacent to the OU2 GWTP. Three A-aquifer Extraction Wells, EW-OU2-01-A to EW-OU2-03-A, lie to the north of the OU2 GWTP, while three A-aquifer Extraction Wells, EW-OU2-04-A to EW-OU2-06-A, lie to the south. The two Western Network pipelines merge with Upper 180-foot aquifer Extraction Well EW-OU2-01-180 and are conveyed to the GWTP. A mechanical isolation valve exists at the GWTP.
- The original Eastern Extraction Network, or the Abrams well cluster is composed of eight extraction wells just north of Abrams Drive. Seven A-aquifer Extraction Wells, EW-OU2-07-A to EW-OU2-13-A, and Upper 180-foot aquifer Extraction Well EW-OU2-02-180, lie between 80<sup>th</sup> Artillery Court and Wally Court. The Eastern Network pipeline conveys groundwater to the OU2 GWTP. A mechanical isolation valve exists both just upstream of the Wye connection and at the GWTP. A 1740-foot portion of this pipeline was removed and replaced in year 2002 during the Twelfth Street Realignment. The replaced section lies between Vault Numbers 31 and 35.
- The Abrams/Imjin well cluster is composed of three extraction wells. The A-aquifer Extraction Well EW-OU2-16-A, and Upper 180-foot aquifer Extraction Wells EW-OU2-05-180 and EW-OU2-06-180 are located on the southwest corner of Abrams Drive and Imjin Road. The Abrams/Imjin pipeline conveys groundwater west between the south side of Imjin Road and the north end of OU2 Landfill Cell D. A mechanical isolation valve exists near the intersection with the Area A line.

- The California State University, Monterey Bay (University) well cluster is composed of two extraction wells. The A-aquifer Extraction Wells EW-OU2-14-A and EW-OU2-15-A are located east of Abrams Drive and south of Imjin Road. The University pipeline conveys groundwater west on the north side of OU2 Landfill Cell D, where it joins the Landfill line. A mechanical isolation valve exists at a high point near OU2 Landfill Cell D.
- The Landfill well cluster is composed of two extraction wells. The Upper 180-foot aquifer Extraction Wells EW-OU2-03-180 and EW-OU2-04-180 are located southwest of OU2 Landfill Cell C. The Landfill pipeline conveys groundwater between OU2 Landfill Cells B and C toward the north end of OU2 Landfill Cell D, where it joins with the University line. A mechanical isolation valve exists near the intersection with the University line.
- The Area A line extends from the combined Abrams/Imjin, Landfill, and University lines to the Eastern Extraction Network, where it combines with the original pipeline at the Wye vault just west of Extraction Well EW-OU2-10-A. Mechanical isolation valves exist just upstream and downstream of the Wye connection.

### **3.3 Extraction Well Features**

Original OU2 well installation information is detailed in the *Well Installation and Abandonment Report* (IT, 1996). Well locations are shown on [Figures 1-2](#) and [1-3](#), as well as in the *Draft Final Construction Drawings* (IT, 2002) as IT File Number 783751-E7 and -E8.

OU2 System Expansion well installation information, including the installation of Monitoring Well MW-OU2-78-180, is detailed in the *Draft Final Well Installation and Abandonment Report* (IT, 2001c). Typical extraction well schematics are illustrated in the *Draft Final Construction Drawings* (IT, 2002) as IT File Number 783751-E37. [Table 2-2](#) lists the estimated maximum theoretical flowrate for each extraction well.

#### **3.3.1 Original Extraction Wells**

Two wells were installed in the Upper 180-foot aquifer (Extraction Wells EW-OU2-01-180, and -02-180) and thirteen wells were installed in the A-aquifer (Extraction Wells EW-OU2-01-A, to -13-A) to depths between 129 and 174 feet below grade surface. Each extraction well was fitted with a carbon steel well casing; a stainless steel, type 304, continuous wire-wrapped slotted screen and end cap; and a 1-inch diameter, PVC schedule 40 (PVC 40) sand tube.

The six-inch diameter screens in the A-aquifer wells extend from the base of the A-aquifer to 5 feet above the water table. The ten-inch diameter screens in the Upper 180-foot aquifer wells extend from the intermediate 180-foot aquitard to the top of the aquifer. The open-ended sand

tube is placed outside the primary casing but inside the borehole, and extends into the top of the sand pack.

### **3.3.2 System Expansion Extraction Wells**

Four extraction wells were installed in the Upper 180-foot aquifer (Extraction Wells EW-OU2-03-180, -04-180, -05-180, and -06-180) and three were installed in the A-aquifer (Extraction Wells EW-OU2-14-A, -15-A, and -16-A) to depths between 115 and 323 feet below grade surface. Each extraction well was fitted with a PVC schedule 80 (PVC 80) well casing and sump; a stainless steel, type 304, 0.045-inch, continuous wire-wrapped slotted screen; a 1-inch diameter, PVC 40 sand tube; and a 1.5-inch diameter, PVC 40 piezometer tube.

The six-inch diameter screens in the A-aquifer wells extend from the base of the A-aquifer to 5 feet above the water table. The ten-inch diameter screens in the Upper 180-foot aquifer wells extend from the intermediate 180-foot aquitard to the top of the aquifer. A 5-foot-long bottom sump with end cap is attached to the bottom of each screen to collect sand and sediment that may accumulate during operation. The piezometer and sand tube were placed outside the primary casing but inside the borehole. The piezometer includes a 0.020-inch slotted PVC screen that extends over the same depth interval as the extraction well screen. The sand tube is open ended and extends 18 inches into the top of the sand pack.

### **3.3.3 Extraction Well Maintenance**

A loss of 25 percent or greater in specific capacity in an operational extraction well, when compared to the initial specific capacity of the well, is the metric to be used as an indicator for well rehabilitation. The initial specific capacities are listed in the *Draft Final Construction Completion Report* (IT, 2001a). Periodic checks of each well's specific capacity are not required; however, if a well's flowrate decreases substantially, there may be an operational requirement to rehabilitate the well to maintain the overall extraction system's performance.

The more common reasons for diminished specific capacity include biofouling and chemical encrustation. Biofouling events can be complex, may be caused by a variety of bacteria, and may form under the following four mechanisms: excretion of extracellular slimes, accumulation of soil particles and precipitated minerals within the slime, occlusion due to gas generation, and biological corrosion generating hydrogen sulfide or organic acids. The mechanism, appearance and odor of the biofouling must be taken into consideration before a treatment procedure is selected. Iron bacteria are suspected in some OU2 Eastern Network extraction wells, while adjacent wells are apparently not affected by iron bacteria. During wellhead pipe maintenance

performed in 1997, biofouling was noted at Extraction Wells EW-OU2-07-A and EW-OU2-11-A. Since biofouling was not noted at nearby extraction wells, a generalized approach to rehabilitating a low-flow well is not advised.

Chemical encrustation events can also be complex. Chemical interaction modeling performed for the Sites 2/12 groundwater remedy, suggests that calcite will be the dominant precipitant, with lesser amounts of ferric hydroxide, goethite, and manganese dioxide forming. Other calcium and magnesium compounds may also precipitate. Although calcite is soluble in acids, even strong acids may have little effect on ferric hydroxide, goethite and manganese dioxide. Except for the presence of brackish water, the Sites 2/12 geochemistry appears similar to OU2 geochemistry. During the OU2 Expansion pipeline and treatment plant renovations in 2000, chemical encrustation was noted on nearly all wetted surfaces.

### **3.4 Extraction Well Mechanical Features**

A submersible pump and motor, drop pipe, wellhead piping, ancillary instrumentation, and underground concrete vaults are installed at each extraction well. Associated electrical features are covered in [Section 6.0](#). [Table 2-2](#) lists the recommended operational flowrates for each extraction well.

#### **3.4.1 Extraction Well Pump and Motor**

A dedicated, stainless steel submersible pump, cast iron motor, shroud, and drop pipe are installed in each extraction well. The PVC shroud helps direct water flow over the motor. Drop pipes mechanically connect the pump and pump motors to the well cap, which is located at the top of each extraction well.

At each original Western Network A-aquifer extraction well, a 24 to 55 gpm, 5-horsepower submersible pump and 2-inch diameter drop pipe is installed. The Western Network Upper 180-foot aquifer extraction well is equipped with a 75 to 225 gpm, 20-horsepower submersible pump and 3-inch diameter drop pipe. Drop pipes are completed with type 304 stainless steel to just above the water table, and continues to the well cap as carbon steel.

At each original Eastern Network A-aquifer extraction well, a 18 to 32 gpm, 3-horsepower submersible pump and 1.5-inch diameter drop pipe are installed. The Eastern Network Upper 180-foot aquifer extraction well is equipped with a 150 to 290-gpm, 25-horsepower submersible pump and 3-inch diameter drop pipe. Except for rehabilitated wells EW-OU2-07A and EW-

OU2-11A which have all stainless piping, drop pipes are completed with type 304 stainless steel to just above the water table, and continues to the well cap as carbon steel.

The System Expansion extraction wells are completed alike. A 18 to 32-gpm, 3-horsepower submersible pump and 1.5-inch diameter stainless steel drop pipe are installed in each A-aquifer extraction well. A 100 to 220-gpm, 20-horsepower submersible pump and 3-inch diameter stainless steel drop pipe are installed in each Upper 180-foot aquifer extraction well. Drop pipes are completed with type 304 stainless steel continuously from the pump to the well cap.

### **3.4.2 Extraction Well Vault Construction**

Each extraction well is protected by an underground concrete vault, with top access at grade level through a traffic-rated lockable lid. The H-20 vault lids and frames are made of corrosion-resistant, type 6061 aluminum. The hinged lids are lockable to reduce unauthorized access, are designed with a built-in drainage channel, and are sealed to reduce seepage of water into the vaults during storm-related events. Since the well, pipe, and conduit penetrations through the concrete sides and bottom are finished with a watertight sealant, the vault and sump function as a containment area for the single-walled wellhead piping. Concrete vault locations are tabulated on [Table 3-1](#), Extraction Well, Pipeline, and Infiltration Gallery Concrete Vault Locations.

Original OU2 A-aquifer vaults are 4-foot by 5-foot by 4-foot deep, while the original OU2 180-foot aquifer vaults are 5-foot by 6-foot by 4-foot deep. Each vault has a solid concrete bottom.

The System Expansion A-aquifer vaults are 6-foot by 6-foot by 4-foot deep by 6-inch thick, while the System Expansion 180-foot aquifer vaults are 9-foot by 6-foot by 4-foot deep by 8-inch thick. The vaults have a solid concrete bottom with an 18-inch deep sump designed to contain minor water leaks or condensation that may occur within the well vault.

### **3.4.3 Original Extraction Wellhead**

Each original OU2 extraction wellhead contains a black iron well cap, check valve, mechanical flowmeter, and a globe valve. Secondary branches include an air release and vacuum valve, a manual reset pressure switch, a pressure gauge, and a sample port. A float switch is located near the electrical box and serves as the well vault leak detection. Two automatically-reset pressure switches, one in each network, provide redundant, high pressure shutoff. One switch is located at EW-OU2-01-180 and EW-OU2-02-180.

Each groundwater extraction pump is controlled both locally at the well vault, as well as remotely from the local PLC panel. Local electrical components are installed in a NEMA 3R enclosure located in each well vault. The hand-off-auto switch and on-off disconnect are mounted on the outside of the NEMA 3R enclosure. A manually resettable pressure switch installed on the process piping within the well vault will shut off the well pump under a high pressure condition in the automatic mode. In “hand” mode, the control instrumentation will be bypassed allowing for operational testing of the pump.

In automatic mode, the well pump is controlled at the local PLC panel based on the water level determined by sensors within the well. A discrete output signal originating from the local PLC is required to activate the submersible pump motor starter. Loss of this control signal will open the contacts on the motor starter preventing pump operation in either the manual or automatic mode. To minimize pump cycling and to obtain the necessary flowrate from the well, the globe valve within the well vault must be manually adjusted as required.

A mechanical flowmeter is installed within the well vault to measure the individual well flowrate. The flowmeter has a local display indicating instantaneous flowrate and the total recorded flow in gallons.

#### **3.4.4 System Expansion Extraction Wellhead**

Each OU2 System Expansion extraction wellhead contains a stainless steel well cap, check valve, analog output flowmeter, and an equal percentage globe valve. Secondary branches include an air release and vacuum valve, a manual reset pressure switch, a pressure gauge, and a stainless steel sample port. A float switch is located near the sump and serves as well vault leak detection. Three automatically-reset pressure switches provide redundant, high pressure shutoff. One switch for each system is located at EW-OU2-06-180, EW-OU2-15-A, and EW-OU2-04-180.

Each groundwater extraction pump is controlled both locally at the well vault, as well as remotely from the local PLC panel. Local electrical components are installed in a NEMA 4X enclosure located in each well vault. The hand-off-auto switch and on-off disconnect are mounted on the outside of the NEMA 4X enclosure. A manually resettable pressure switch installed on the process piping within the well vault will shut off the well pump under a high pressure condition in the automatic mode. In “hand” mode, the control instrumentation will be bypassed allowing for operational testing of the pump.



In automatic mode, the well pump is controlled at the local PLC panel based on the water level determined by pressure transducers within the well. A discrete output signal originating from the local PLC is required to activate the submersible pump motor starter. Loss of this control signal will open the contacts on the motor starter preventing pump operation in either the manual or automatic mode. To minimize pump cycling and to obtain the necessary flowrate from the well, the globe valve within the well vault must be manually adjusted as required.

An electronic flowmeter is installed within the well vault to measure the individual flowrate from each well. The flowmeter has a local display indicating instantaneous gpm and the total recorded flow in gallons. The flowmeter is electronically wired to send a flow-indicating 4-20 milliamp (mA) analog input signal to the local PLC for remote monitoring.

### **3.4.5 Extraction Well Pump Maintenance**

Indications that well pump maintenance is required may include reduced water flow, low wellhead pressure readings, excessive motor noise, and/or excessive power consumption. Each individual pump can be shut down by turning its extraction well control panel switch to the off position. Close the globe valve before performing pump or wellhead maintenance. If electrical power maintenance is performed, the electrical disconnect located at the local distribution panel should also be tagged and locked out.

Pump and motor wear will occur over time. Wear of the pump impellers may be accelerated due to abrasion from formation sand particles. The wetted surfaces of both the pump and motor are composed of stainless steel. If the pump or motor fail within the first three years of operation due to chloride attack, consideration should be given to procuring a pump and motor composed of a more chlorine-resistant metal.

Vapor lock can occur at high points within the wellhead piping and extraction pipeline. In smaller diameter pipe such as in the wellhead piping, increased head resistance and false flowmeter readings are indicative of excessive entrained air. The air/vacuum break valve, located at a high point, is placed to remove the majority of the produced air. The sample port, located at another high point within the wellhead, should be opened occasionally to remove entrained air. Entrained air can be removed within the buried pipeline by periodically opening the high point vents.

### **3.5 Extraction Conveyance Piping**

Figures 1-2 and 1-3 show the layout of the extraction network, excluding for clarity, modifications performed during the Twelfth Street Realignment. A list of the Twelfth Street Realignment construction drawings can be found on Figure 1-1 and in Appendix A, with the drawings included in the *Draft Final Construction Drawings* (IT, 2002). The conveyance pipeline ties each extraction well into a header that conveys process water back to the GWTP. Each line is double contained, with an integrated leak detection system.

#### **3.5.1 Pipeline Materials of Construction**

The original OU2 pipeline and pipe-to-pipe connections are predominantly composed of PVC80 for the carrier (inner) pipe, and PVC40 for the containment (outer) pipe. The System Expansion pipeline, and the Twelfth Street Realignment pipeline are predominantly composed of high-density polyethylene (HDPE) pipe for both the carrier and containment. Connections between the pipelines, at monitoring points, and at termination points are flanged with spool pieces predominantly of PVC80. Flanged, pipeline system connections for the System Expansion pipeline and the Twelfth Street Realignment are in accessible, locked concrete vaults with leak detection alarms.

#### **3.5.2 Twelfth Street Realignment**

About 1740 feet of 8-inch x 12-inch PVC pipe, along with the parallel single contained PVC pipeline and leak detection wiring, was removed from service between Vault No. 31 and 35 in Year 2002. A similar amount of HDPE pipe, single contained, double contained and control wire conduit, was placed north of the toe of the slope for the realigned Twelfth Street. The pipeline was procured, placed, and inspected following the previous System Expansion procedures and specifications.

#### **3.5.3 Wye Vault**

The System Expansion connects with the Eastern Network at a single-contained, fiberglass reinforced, PVC80 Wye connection, located just west of Extraction Well EW-OU2-10-A. Two manual valves, one a PVC80 butterfly valve, and one a stainless steel knife gate valve, provide network isolation capability. Access to the Wye connection is through the Wye vault. The vault is equipped with a liquid level sensor tied to the Eastern Network PLC panel.

#### **3.5.4 Extraction System Operation and Maintenance**

Evaluation over time of individual wellhead and GWTP flow and pressure measurements may reveal problems that can be isolated to a specific extraction well, wellhead piping, or extraction

pipeline, while providing initial indications of whether the problem is physical, electrical, mechanical, or process-control related.

Pipeline leaks may occur due to simple component aging (brittle gasket break), but are more likely to occur after the system has been stressed (weather/earthquake or manmade). The GWTP Operator must monitor for changes in flow or pressure trend lines, and assist the Site Engineer in establishing the root cause of all leaks.

Electrical- and process-control related manifestations usually occur suddenly, and are often associated with a step change in performance. For example, if a motor fails, there will be a step change decrease in both the individual wellhead and GWTP flowrate.

Physical- and mechanical-related manifestations are often associated with gradual changes in performance, usually occurring over days to months. Examples of physical- and mechanical-related manifestations include vapor lock, chemical encrustation, biofouling, aquifer formation plugging by fine grained particles, deterioration of the well screen, and general pump related performance issues.

### **3.5.5 Conveyance Pipe Leak Detection**

Extraction piping within the well vaults and the GWTP is single-contained. Between the well vaults and the GWTP boundary, the extraction pipelines are double contained. Liquid level sensors installed within the low-point collection assembly monitors for leaks or breaks in the primary line.

Within the Western and original Eastern Extraction and pipeline networks, if a leak is indicated, the sensor trips an electronic circuit at the local leak detection control panel. A visual display on the leak detection control panel indicates the location of the low point nearest the suspected leak. Each leak detection control panel is wired to the local PLC. There are two leak detection sensors in the Eastern network that are tied to the GWTP. Upon detection of a leak, the local PLC will shut down the Western Network extraction pumps. To restart the local pumps, the leak detection sensor must be cleared, or bypassed. Bypassing the leak detection sensors shall only occur during maintenance and troubleshooting activities related to the leak detection system.

Within the Abrams/Imjin, Landfill, and University Extraction and pipeline networks, if a leak is indicated, the sensor trips an electronic circuit directly to the local PLC. Upon detection of a leak, the local PLC will shut down the local extraction pumps and signal the master PLC at the

GWTP. To restart the local pumps, the leak detection sensor must be cleared, or bypassed. Bypassing the leak detection sensors shall only occur during maintenance and troubleshooting activities related to the leak detection system.

### **3.5.6 Leak Alert System**

The alarm to the leak detection system can be checked manually by pressing either the liquid or vapor button on the Leak Alert panel. Periodically test a representative leak detection probe by fully submerging in a container of water. This should alarm and shut down the corresponding networked extraction wells. As operational familiarity increases, the frequency of probe testing can decrease. Testing frequency should be reevaluated annually.

## **4.0 Groundwater Treatment Plant**

---

This section presents a description of the GWTP equipment, including process, mechanical, civil, and instrumentation control features. The GWTP contains four GAC adsorption vessels, two backwash tanks, one effluent tank, ancillary pumps, and connecting piping. Associated electrical power and the SCADA system are described in [Section 6.0](#).

### **4.1 Groundwater Treatment Plant Building and Containment**

The GWTP is divided into the eastern, northern, and building concrete containment areas, and a concrete pad on the east side of the building. The building and containment areas were installed in 1995. Surface modifications to the eastern containment, northern containment, and wings of the truck pad areas were performed in 2000 and are documented in the *Draft Final Construction Completion Report*, (IT, 2001a).

#### **4.1.1 Building and Containment Foundation**

A 40-foot by 60-foot by 14-foot 4-inch high clear-span metal building provides weather protection for the continuously operating process equipment, electrical distribution, and ancillary control instrumentation. The building's concrete foundation is integrated with the foundations for individual equipment and with the building's containment area and sump. The containment area is designed as a spill control area encompassing the entire floor of the building. The building conforms to the 1994 Uniform Building Code, with the following design parameters: live load rating of 20 pounds per square foot; wind loading of 70 miles per hour; and a seismic zone of 4.

The building's metallic shell and internal supports shall be inspected periodically ([Appendix D](#)) for corrosion wear and other surface damage. Areas of significant damage or wear on the building's metallic shell shall be replaced as appropriate to insure structural integrity and weather tightness. Areas of minor corrosion on the building's internal supports shall be periodically hand or machine brushed to bare metal, a good zinc-based primer added, followed with an appropriate topcoat matching the original surface paint. Areas of significant corrosion shall be inspected to insure structural integrity, repaired if required, and then primed and painted. Ancillary building components shall also be periodically inspected for corrosion and repaired as appropriate.

#### **4.1.2 Spill Control Areas**

The eastern and northern containment areas, which are outside of the GWTP building, are designed as spill control areas. Each area is sloped for more effective area drainage, has raised equipment pad surfaces, and has individual sumps. Each containment area will drain into the other if water levels exceed the floor of the pipe chase that physically connects the two areas. The truck apron drains into the eastern containment, allowing the truck pad to be free of standing water during minor spill events. Concrete surfaces in the containment areas (not including the truck pad) have been prepared and coated with a sealant. The sealant is intended to provide a long term, high strength protective surface under a light industrial setting and a marine coastal environment.

#### **4.1.3 Stormwater Containment and Management**

The eastern and northern containment areas are also designed to manage stormwater. The tank and equipment pad elevations are designed to place the top of the pads above the flood level during a 24-hour, 25-year storm event. The storage capacity of each containment area is also sufficient to contain the storage volume of the largest tank during a similar storm event.

#### **4.1.4 Containment Sump Pumps**

The three containment areas drain to their respective sumps. Each sump has a dedicated sump pump, which is automatically controlled to pump to the backwash tank. The sump pump is equipped with attached level low and level high switches. Water collected in the sumps is recycled through the treatment system as described in [Section 4.2.4.3](#).

The operation of the sump pump is tested manually by lifting the level switch to the high position. The pump should turn on. When the level switch is released and the level falls down, the pump should turn off. At the power switch the "1" is the on position and the "0" is the off position. If the pump is pumping at a reduced flowrate, the y-strainer could be filled with debris. The strainer should be removed and cleaned if necessary.

### **4.2 Granular Activated Carbon Treatment System**

The water treatment technology used is VOC adsorption onto GAC. Four vessels holding up to 20,000 pounds of GAC each are located to the north and east of the GWTP building. [Figure 2-1](#) is a generalized representation of the GAC treatment process.

#### **4.2.1 Granular Activated Carbon Vessels**

The eastern containment area contains two parallel vessels purchased from Calgon Carbon in 1995 and installed as part of the original OU2 groundwater remedy. The twin 10-foot diameter with 12-foot straight side vessels were manufactured by Downey Welding and Manufacturing Company of Downey, California, with tank serial numbers 5333 and 5334. Each vessel has a capacity to contain up to 20,000 pounds of GAC. Maximum design pressure is 125 pounds per square inch gauge (psig) at 150 degrees Fahrenheit. Minimum design temperature is 15 degrees Fahrenheit at 125 psig. In 2000, both vessels were internally sandblasted and relined with Plasite® 4110, and externally cleaned and epoxy coated. Two 125 psig rupture disks are installed on the adjacent PVC80 manifold. Each vessel's internal components and internal surfaces shall be periodically inspected, usually during carbon changeouts ([Section 4.2.3, Item Number 6](#)).

Each vessel's external surfaces shall be inspected periodically for corrosion wear and other surface damage. Areas of minor corrosion on the vessel's supports may be periodically hand or machine brushed to bare metal, a good zinc-based primer added, followed with an appropriate topcoat matching the original surface paint. The vessel may periodically require a complete sandblast, prime and paint. Areas of significant corrosion shall be inspected to insure structural integrity, repaired if required, and then primed and painted. Based on the corrosive effects of the marine coastal environment, consideration should be given to adding a passive or active cathodic protection system to minimize corrosive wear.

The northern containment area contains two parallel vessels purchased from Northwestern Carbon in 2000. The twin 10-foot diameter with 8-foot straight side vessels each have a capacity to contain up to 20,000 pounds of GAC. Interior tank lining is Plasite® 4110. Design pressure is 125 psig at 150 degrees Fahrenheit. Normal design temperature is 100 degrees, with a design maximum of 150 degrees. Two 125 psig rupture disks are installed on the adjacent manifold. The PVC80 pipe manifold is valved similarly to the manifold in the eastern containment.

The PVC 80 valve manifold between the two sets of vessels allows for lead-lag series service, parallel vessel service, or backwash maintenance flushes. The manifold contains four individually valved, stainless-steel sample ports, and both single point pressure gauges and differential pressure gauges.

#### **4.2.2 Adsorption Vessel Operation**

The GAC vessels shall be operated in series during normal operation. The valve assembly or manifold located between the GAC vessels allow for either bed to be valved as the lead or lag bed. Pressure indicators on the manifold are used to monitor the system's influent, midpoint, and effluent pressures. A rupture disk is provided downstream of each GAC vessel. Failure of the rupture disk redirects groundwater flow to the backwash tank, providing pressure relief of the main process line.

It is important to verify which bed is the lead bed and to verify that process water is flowing through both beds during normal operation. Improper valve operation may result in unanticipated changes in treatment efficiency producing an effluent concentration that may not meet discharge requirements. The valves shall be periodically inspected and logged to verify correct positioning, especially after each change of operation ([Appendix D](#)).

#### **4.2.3 Granular Activated Carbon Changeouts**

A GAC changeout will be scheduled when the COC concentration from the lead vessel's effluent approaches the discharge limits for treated water provided in [Table 1-1](#). For chloroform, 1,1-DCA, and cis-1,2-DCA, the maximum discharge limits need only meet the ACLs.

When analytical testing indicates that a changeout is required, the spent GAC will be replaced with either virgin or regenerated GAC. The spent GAC will be removed off site and regenerated or disposed of by the supplier, in accordance with federal, state, and local laws and regulations. The new bed will be backwashed, and then the bed sequence will be switched. The former lag bed will become the lead bed, and the bed with the fresh, activated carbon will become the lag bed.

Because the GWTP has two parallel GAC vessels, the groundwater remedy can be operated while one set of GAC vessels is being changed out. While the groundwater remedy is operating at a reduced flow, the GWTP operator shall take advantage and perform appropriate maintenance on in-line equipment.

The procedures listed below shall be followed as part of the GAC changeout. To minimize vendor standby time and cost, the first three items should be completed before the GAC supplier arrives onsite.

1. Verify that the 25-hp air compressor is operating properly at least one day prior to the changeout.



2. Reduce the liquid level or empty both backwash tanks to allow for maximum backwash water volume. If the other set of GAC vessels will not be operating during the changeout, fill the effluent tank with treated or potable water.
3. Prepare the GWTP for the changeout by inspecting the area around the GAC vessels, noting the availability and functionality of appropriate water and air lines, vessel fill and drain lines, vessel vent lines, and associated valves.
4. Reduce the extraction well water flow to the treatment plant to correspond to the treatment flow capacity of the remaining set of GAC vessels. If the other set of GAC vessels will not be operating during the changeout, stop all extraction well water flow.
5. Prepare the GAC vessels for the changeout by closing off the manifold valves at the appropriate vessel. If the other set of GAC vessels are to continue treatment operations during the changeout, periodically verify that the water flow is continuing, and that untreated water is not flowing to the effluent tank.
6. The GAC vendor shall transfer out the spent GAC. When the vessel is empty, remove the manway flange and visually inspect the interior of the bed from the outside. No internal access of the GAC vessel shall be allowed without a confined space entry permit and the associated safety procedures. Verify that minimal residual carbon remains and all internal equipment is in place. Photographs of the vessel should be taken at least once per year for maintenance review.
7. Once the manway flange is reinstalled, fill the GAC vessel with water to the level recommended by the manufacturer, and transfer in the virgin or regenerated carbon. Ensure excess air and water is vented to the backwash tank.
8. Perform a backwash on the vessel containing the replaced GAC, as detailed in the next section. After completion of the backwash, configure the manifold valves so that the bed containing the replaced carbon is in the lag position. Verify that all closed valves are fully closed to prevent untreated water bypass.
9. Following the groundwater remedy startup procedures ([Section 2.0](#)), verify that all valves are in their correct position, verify that water is flowing in the intended path, and the system is operating normally.
10. Additional GAC vessel backwashes may be required to reduce the pressure differential between the top and bottom of the bed. Backwash water should be managed as described in the following section.

#### **4.2.4 Granular Activated Carbon Backwashing**

GAC backwashing is required after changeouts, and may be required at other times to repack the bed, remove excessive GAC fines from the vessel, reduce COC channeling or reduce bed compaction. Backwash water may be directed to either of two backwash tanks, the northern

containment's 10,000-gallon carbon steel tank, or the eastern containment's 6,000-gallon stainless steel tank. The backwash water is filtered through a bag and cartridge filter located in the eastern containment prior to being recycled into the influent stream. If recycling is not possible the backwash water may be discharged to the sewer under permit.

#### **4.2.4.1 Backwash Tank and Pump**

A backwash tank and pump is installed in each outside containment area. The tanks and pumps are piped to allow liquid exchange. Each pump is controlled through a hand-off-automatic switch in the motor control center and a local on/off switch. In automatic mode the backwash pump cycles on when the backwash tank level switch high energizes and shuts off when the backwash tank level switch low is de-energized. Activation of the backwash line high-pressure switch shuts off the respective pump. Hand operation will override the low and high level sensor control.

#### **4.2.4.2 Backwash Flow Velocity**

Prior to backwashing a just-changed GAC bed, the GWTP Operator must ascertain the elapsed time that the GAC has been wetted, or the time allowed to soak in freestanding water. An 8 by 30 mesh GAC that has been wetted for 12 hours at 80 degrees Fahrenheit will be less than 89 percent wetted. At 72 hours, the same GAC will be about 95 percent wetted. Backwashing a low-wetted bed will increase the likelihood of significant solids carry-over, resulting in the loss of product-rated sized GAC to the backwash tanks.

The recommended flow velocity is dependent on a number of factors, including GAC size, percent wetted, water temperature, and other vessel specific features. Generally, the following guidelines should be observed for newly wetted GAC:

- Vessel backwashing shall not occur if the GAC has been wetted for less than 12 hours.
- Between 12 and 24 hours, backwashing may range up to 200 gallons per minute. Start at the lowest flowrate that generates GAC fine carry-over. Hold at this flowrate until the liquid begins to clear, but not less than 15 minutes, then increase flowrate by 10 percent every 10 to 15 minutes. Do not exceed 200 gallons per minute.
- Between 24 and 48 hours, backwashing may range up to 400 gallons per minute. Start at 50 to 75 percent of the previous backwash flowrate, hold until the liquid begins to clear, then increase the flowrate by 10 to 15 percent every 5 minutes. Do not exceed 400 gallons per minute.

- Between 48 and 96 hours, backwashing may range up to 600 gallons per minute. Start at 75 percent of the previous backwash flowrate, hold for 5 to 10 minutes, then increase the flowrate by 10 to 15 percent every 5 minutes. Do not exceed 600 gallons per minute.

#### **4.2.4.3 Backwash Procedures**

Follow the generalized GAC backwash flow velocities discussed in the previous section. The general backwashing procedures are as follows:

1. Verify that the backwash tank(s) has sufficient storage capacity for an adequate backwash duration.
2. Verify that the effluent tank contains adequate water for the backwash operation, or that flow to the effluent tank will be adequate to sustain the planned backwash operation.
3. Reduce the extraction well water flow to the treatment plant to correspond to the treatment flow capacity of the remaining set of GAC vessels. If the other set of GAC vessels will not be operating during the backwash, stop all extraction well water flow.
4. Terminate untreated extraction well water flow to the specific vessel being backwashed. Configure the valves for the backwash operation following the Valve Positioning Checklist ([Appendix D](#)). For additional backwashing information see the GAC vendor information in [Appendix B](#).
5. See the previous section for backwashing a newly wetted bed. Start the backwash at the lowest velocity that generates GAC fine carry-over or about 200 gallons per minute, whichever is less. Increase the flowrate by 50 gallons per minute every 5 to 10 minutes. Do not exceed the flow velocity that expands the bed to the point where the top of the fluidized GAC is carried to the backwash tank.
6. Allow the backwash to continue until the water level in the backwash tank reaches the high level as marked on the sight gauge. When this level is reached, turn off the injection pump by depressing the stop button located at the variable frequency drive for that pump.
7. Reconfigure the GAC vessel valves for the desired operation as detailed in the Valve Checklist ([Appendix D](#)). If a GAC changeout was performed, verify that the vessel with the replaced GAC is put into the lag position. Verify that all closed valves are fully closed to prevent untreated water bypass.
8. Before restarting the groundwater remedy, reset the injection pump to the “oper” mode located on the “Force Analog O/P” page and to the “auto” mode located on the “Remote Systems” page. Disengage the stop button at the variable frequency drive.
9. Follow the groundwater remedy startup procedures, and verify that all valves are in their correct position. Monitor the system to verify that water is flowing and the system is operating normally.

Additional GAC vessel backwashes may be required to reduce the pressure differential between the top and bottom of the bed.

#### **4.2.4.4 Recycling of Backwash Tank Water**

The first batch of backwash water that follows a changeout should be allowed to settle overnight, but may be filtered slowly and recycled if storage capacity is required. The following day, the water may be pumped through the backwash filters and recycled through the treatment plant. Subsequent backwash water batches, as necessary to remove fines, should be slowly filtered and recycled to free up storage capacity. Unloading and loading transfer water may be filtered and recycled the day of the changeout.

During normal operations, open the valves on the backwash tank line and start the backwash pump. Monitor the pressure downstream of the backwash pump and adjust the discharge valve until the desired flowrate is achieved. When the water in the backwash tank reaches the low level as marked on the sight gauge, turn off the backwash pump and close all valves on the backwash tank line. Periodically examine the filters to determine if replacement is necessary.

Monitor the pressure downstream of the backwash pump and adjust the discharge valve until the desired flowrate is achieved. When the water in the backwash tank reaches the low level as marked on the sight gauge, turn off the backwash pump and close valves on the backwash tank line. While filtering, the bag and cartridge filter pressure gauges must be periodically monitored. An increased pressure reading is indicative of a reduced water flow rate. Filter replacement may eventually be required.

#### **4.2.4.5 Offsite Water Discharge**

Backwash water discharged into the sewer requires a one time discharge permit obtained from the Monterey Regional Water Pollution Control Agency (MRWPCA). Discharged water should be minimized, and only performed when recycling is not possible or desirable. Filtered and treated water generated during GAC changeouts should be recycled. Should a sewer discharge following a GAC changeout be required, the permit should address the anticipated water volume, including typically:

- 5,000 gallons of decanted unloading water
- 4,000 gallons of filtered loading transfer water
- Two to four 10,000-gallon batches of filtered backwash water.

#### **4.2.4.6 Bag and Cartridge Filter Changeout**

Pressure gauges are a good indicator of when the bag filters and/or cartridge filters need to be changed. Excessive pressure indicates low flow and high pressure drop through the filter vessels. To change out the filter vessels, let the pressure in the backwash line down to 1 atmosphere through the bleed valve. Carefully loosen and remove cover bolts on top of the vessels. Remove the filters and replace with new ones. When you put the cover back on, be sure that the O-ring is placed in its proper position, and carefully retighten the cover bolts. Discard the filters as a hazardous waste until reclassified.

### **4.3 Other Groundwater Treatment Plant Equipment**

The influent pipeline is a primary process pipeline and conveys untreated water from the extraction wells to the GAC systems. Two pipelines enter the GWTP, one from the Eastern Network, and one from the Western Network.

#### **4.3.1 Influent Manifold**

The influent manifold combines flow from the Western and Eastern Networks. If one of the networks is not in operation, the butterfly valve for that network should be closed to reduce reverse flow back to the well vaults. Following a brief, scheduled plant shutdown, the influent manifold butterfly valves should be closed to isolate the treatment plant. Other valves downstream of the influent manifold may be left at their set positions to minimize adjustments during the subsequent startup.

#### **4.3.2 Flow Control Valve and Basket Strainer**

After entering the GWTP, the two untreated water lines convey past parallel mounted air-to-open flow control valves and two parallel basket strainers. Upon an alarm condition, one or both valves will close, shutting water flow to the GWTP. The basket strainer filters suspended solids that may affect the operation of downstream instrumentation or mechanical devices. Buildup of particles is indicated by an increased pressure drop, measured from two pressure gauges positioned before and after the basket strainer. A pressure switch is located upstream of the strainer. A high-pressure condition will send an alarm signal and shut down the extraction well pumps.

The two lines are mixed in an in-line static mixer, and split into two parallel streams, each with a flowmeter. The two streams are directed to either the northern containment or eastern containment GAC vessels. Treated water then flows to the Effluent Tank.

#### **4.3.3 Effluent Tank**

The stainless steel effluent tank, which has a nominal holding capacity of 10,000 gallons, is used primarily as a surge tank and is intended to be half-filled during normal operations.

The effluent tank has an ultrasonic level transmitter, as well as a level switch high and level switch low sensor installed. Both the switches send discrete digital signals to the master PLC. Upon switch activation, the master PLC will shut down the extraction pumps. Upon LSL activation the master PLC will shut down the injection pumps.

The ultrasonic level transmitter sends a 4-20 mA analog input signal to the master PLC for water level monitoring. The master PLC sends a 4-20 mA signal to the injection pump's variable speed controllers. The master PLC is programmed to maintain a near constant effluent tank water level by adjusting the injection pump's flowrate based on the tank's level.

Following a scheduled, brief plant shutdown, the valves at the effluent tank and the injection pumps should be closed to isolate the treatment plant. Gate and globe valves located downstream of the GWTP building may be left at their set positions to minimize remote adjustments during the next startup.

#### **4.3.4 Plant and Instrument Air**

A 25-horsepower, 460-volt single-stage air compressor provides the requisite air flow and pressure required during carbon changeouts. A 1.5-horsepower air compressor is staged in series with the larger air compressor. A particulate filter and an oil/water coalescer are installed in series after the discharge header. Plant air is additionally available through chicago-type fittings placed near the GAC vessels.

#### **4.3.5 Potable Water**

A 2-inch water line supplies the GWTP with potable water. The potable water line directs water to each of the three containment areas at hose bibs, restroom, two eyewash stations, and one combination safety shower and eyewash station.

## **5.0 Treated Water Injection System**

---

This section describes the OU2 treated water injection system, including process, mechanical, civil, and instrumentation control features. Associated electrical power and the SCADA system are covered in [Section 6.0](#). The treated water injection system consists of six parallel injection pumps, conveyance piping to the Sites 2/12 GWTP, two injection wells and two infiltration galleries, and other ancillary equipment. [Figures 1-2](#) and [1-3](#) show the layout of the treated water injection system.

### **5.1 Injection Pumps and Injection Points**

Variable speed controllers control the flow to each injection point. Each controller operates sequentially off the Effluent Tank. As the water level rises in the tank, the variable speed controllers increase the motor speed, conveying a higher flow rate to the injection point.

#### **5.1.1 Northwest Injection**

Injection Pumps, P-910 and P-920, convey water to the northwest injection point. The northwest injection point is composed of Infiltration Gallery INF-OU2-01-180 and Injection Well IW-OU2-01-180. The single-contained PVC40 pipeline and injection well were installed in 1995. The two pumps, infiltration gallery, and the PVC80 connection between the well and gallery were installed in 2000.

#### **5.1.2 Southwest Injection**

Injection Pumps, P-510 and P-520, convey water to the southwest injection point. The southwest injection point is composed of Infiltration Gallery INF-OU2-02-180 and Injection Well IW-OU2-02-180. The two pumps, single-contained PVC40 pipeline and injection well were installed in 1995. The infiltration gallery, and the PVC80 connection between the well and gallery, were installed in 2000.

#### **5.1.3 Eastern and Site 2 Injection**

Injection Pumps, P-410 and P-420, convey water to the eastern injection point or to Site 2. These pumps are also used to recycle treated water to the backwash tank for either set of GAC vessels. The two pumps, single-contained PVC40 pipeline and Injection Well IW-OU2-03-180 were installed in 1995. The single-contained HDPE pipeline to Site 2 was installed in 1999. In

Year 2002, a 1740-foot segment of PVC40 was removed and replaced with SDR11 HDPE as part of the Twelfth Street Realignment. The replaced segment is between Vault No. 31 and 35.

## **5.2 Injection Wells**

Injection Wells IW-OU2-01-180, IW-OU2-02-180, and IW-OU2-03-180 were installed as part of the original OU2 groundwater remedy. These three injection wells are not designed to operate continuously at the increased flowrates obtained with the additional 7 System Expansion wells. Injection well completion detail is documented in the *Draft Final Well Installation and Abandonment* Report (IT, 1996).

Well performance may be compromised by chemical encrustation, biofouling, aquifer formation plugging by fine-grained particles, deterioration of the well screen, and pump performance. A primary indicator of the need for well maintenance is a decrease in the well's specific capacity. A loss of 50 percent in specific capacity in an injection well, when compared to the specific capacity of the well determined following continuous operation, or subsequent injection well rehabilitation, will be the threshold value to be used to determine the need for well rehabilitation. A California-licensed drilling contractor will perform well maintenance.

## **5.3 Infiltration Galleries**

Two galleries, labeled Infiltration Gallery INF-OU2-01-180 and INF-OU2-02-180, are located adjacent to Injection Wells IW-OU2-01-180 and IW-OU2-02-180, respectively. Four 16-inch diameter borings were drilled below each gallery and filled with drain rock without screens. INF-OU2-02-180 borings were 137 to 140 feet deep, while INF-OU2-01-180 borings were 97 to 99 feet deep. The infiltration gallery and injection wells are shown on [Figures 1-2 and 1-3](#). A general profile of the infiltration galleries is shown in the *Draft Final Construction Drawings* (IT, 2002) as IT File Number 783751-E10.

Each infiltration gallery is equipped with a valve box containing a flowmeter, actuated ball valve, butterfly valve and air bleed plug. The actuated ball valve (on/off) is controlled by a high-level float switch located in the well. No electrical or control wiring exists between the OU2 GWTP and the two western injection wells. A 2-inch PVC conduit was installed between the valve vaults and the infiltration galleries. The mechanical copper linkage from the control valve uses the conduit between the valve and gallery vaults.

Gallery or piezometer performance may also be compromised by chemical encrustation, biofouling, or plugging by fine grained particles in the borings or aquifer. An indicator of the



need for gallery maintenance is a decrease in the gallery's specific capacity. A loss of 50 percent in specific capacity in a gallery, when compared to the specific capacity of the gallery determined following continuous operation, or subsequent gallery rehabilitation, is the threshold value to be used to determine the need for gallery rehabilitation. If required, the piezometer maintenance will be performed by a California-licensed drilling contractor.

#### **5.4 Operable Unit 2 Pipeline Extension**

This section summarizes the operation and maintenance associated with the pipeline extending from the OU2 GWTP to the Sites 2/12 GWTP. This pipeline conveys treated water to the Sites 2/12 GWTP where it is combined with treated water from the Sites 2/12 treatment system for discharge to infiltration galleries at Site 2.

##### **5.4.1 Pipeline Construction**

The OU2 extension pipeline was constructed of butt-fused, 8-inch, single-wall HDPE pipe. The only mechanical joints used were the termination flanges near the OU2 GWTP, Sites 2/12 GWTP, and at high and low points. The pipeline conveys treated water at flows up to 600 gpm.

##### **5.4.2 Low and High Points**

One high and one low point vault has been installed in the pipeline. A drain was installed at the low point and was placed inside a surface-completed 2-foot concrete vault. An air vent was installed at the high point and was placed inside a surface-completed 2-foot by 2-foot concrete vault.

The OU2 injection pump shall be monitored for increasing discharge pressure normalized to periodic flow adjustment. This monitoring must be performed by the OU2 GWTP Operator, since access to the OU2 building is required. If the discharge pressure begins to increase without a corresponding increase in flow, then the following shall be checked and corrected:

- appropriate pressure gauge operation
- aboveground piping at the OU2 GWTP is not partially obstructed
- air entrainment in the extension pipeline.

For air entrainment in the extension pipeline, periodically open the high point valve to allow excess air to escape. Close pipe when air has exited the pipeline.

#### **5.4.3 Piping Near Operable Unit 2 Treatment Plant**

The pipeline near OU2 splits with an 8-inch by 8-inch by 4-inch reducing Tee. The branch end is connected to OU2's eastern injection line, while the straight run side is connected to a blind flange intended for future connection. The injection water flow from the OU2 GWTP can be split between the eastern OU2 injection wells and injection at Site 2 via a 3-inch globe valve connected to the reducing Tee. A 4-inch flowmeter is installed downstream to monitor the flowrate. The pipeline remains as 4-inch PVC pipe until it connects with the 8-inch by 8-inch by 4-inch reducing Tee.

To convey treated water to the eastern injection network only, close the OU2 pipeline extension's Valve Number V-5810 located outside the OU2's building. To convey treated water to Site 2 only, close Valve Number V-440 upstream of the eastern infiltration gallery and Valve Number V-444 upstream of the eastern injection well IW-OU2-02-180.

To convey treated water to both the eastern injection network and to Site 2, open Valve Numbers V-432 and V-5810 until the desired flow split is achieved.

## **6.0 Electrical and Instrumentation Systems**

---

This section provides information on the electrical service drops, PLC panel boards, and SCADA operation.

### **6.1 Electrical Service Drop**

Electrical power is provided to the GWTP, Eastern Network, Abrams/Imjin and Landfill as 480 volts alternating current (VAC) three-phase 60-hertz, 4-wire service, while the University is provided at 240/120 VAC, three-phase 60-hertz 4-wire service. The Western Network is powered through the GWTP.

#### **6.1.1 Abrams/Imjin Wells Electrical Service**

Pacific Gas and Electric (PG&E) provides electrical service from an existing, underground 12 kilovolt line paralleling the northeast side of Abrams Road. This line is Tap 12 off Feeder 8 between Switch Numbers 6 and 8. Existing PG&E Tap 12 traverses 130 feet underground to a splice box located on the southwest side of the Abrams and Imjin intersection. About 50 feet of 4-inch conduit was installed from this splice box to the PG&E-approved transformer pad. The transformer pad was installed with two 4-inch (one spare) primary and two 3-inch (one spare) secondary termination conduits. The 3-inch conduit extends about 30 feet to the PLC panel pad. The PG&E meter is located within the PLC panel assembly. Power is supplied underground from the PLC panel through a NEMA 4X junction box to individual well pump motors. Junction boxes, which are located at each extraction well, have a door-mounted, NEMA 4X, three position, hand-off-auto power switch that provides local manual control of the extraction well pump.

#### **6.1.2 Landfill Wells Electrical Service**

PG&E provides electrical service from an existing, aboveground 12 kilovolt line off Power Pole Number 6-52. This line is Feeder Number 6, between Switch Numbers 8 and 1. About 75 feet of 4-inch conduit was installed from this pole to the PG&E-approved transformer pad. The transformer pad was installed with a 4-inch primary and a 3-inch secondary conduit. The 3-inch conduit extends about 30 feet to the service main pad. The PG&E meter is located on the service main pad. A 2-inch conduit extends about 200 feet from the service main pad to the PLC panel pad. Power is supplied underground from the PLC panel through a NEMA 4X junction box to individual well pump motors. Junction boxes, which are located at each extraction well, have a

door-mounted, NEMA 4X, three position, hand-off-auto power switch that provides local manual control of the extraction well pump.

### **6.1.3 *University Wells Electrical Service***

PG&E provides electrical service from an existing, underground 12 kilovolt line. This line is on Feeder Number 8, downstream of Switch Number 7. A splice box is between White Court and Combs Court has a line designated as Tap 2. About 100 feet of 4-inch conduit was installed from this splice box to the PG&E-approved transformer pad. The transformer pad was installed with a 4-inch primary and a 2-inch secondary conduit. The 2-inch conduit extends about 75 feet to the PLC panel pad. The PG&E meter is located on the PLC panel assembly. Power is supplied underground from the PLC panel through a NEMA 4X junction box to individual well pump motors. Junction boxes, which are located at each extraction well, have a door-mounted, NEMA 4X, three position, hand-off-auto power switch that provides local manual control of the extraction well pump.

### **6.1.4 *Abrams (Original Eastern Network) Wells Electrical Service***

PG&E provides electrical service from an existing, aboveground 12 kilovolt line off Power Pole Number 6-551. This line is Feeder Number 6, near Switch Number 7. About 250 feet of 4-inch conduit was installed from this pole to the PG&E-approved transformer pad and meter. A 225 kilovolt-amp pad mounted transformer supplies power at 480 volt, 3 phase, 60 hertz. The transformer pad was installed with a 4-inch primary and a 4-inch secondary conduit. The 4-inch conduit extends about 700 feet to the eastern distribution panel. Power is supplied underground from this distribution panel through a NEMA 3R junction box to individual well pump motors. Junction boxes, which are located at each extraction well, contain a lockable disconnect switch that provides local manual control of the extraction well pump.

### **6.1.5 *Western Wells Electrical Service***

PG&E provides electrical service from an existing, aboveground 12 kilovolt line between Power Pole Numbers 6-255 and 6-256. This line is on Feeder Number 6, between Switch Numbers 8 and 9. Primary power lines supply a 1500 kilovolt-amp pad mounted transformer located on the southeast side of the GWTP building. Secondary lines supply power at 480 volt, 3 phase, 60 hertz to the motor control center (MCC). Transformed power is available within the GWTP at 480, 208, 120, and 24 volts. Power is supplied underground from this distribution panel through a NEMA 3R junction box to individual well pump motors. Junction boxes, which are located at

each extraction well, contain a lockable disconnect switch that provides local manual control of the extraction well pump.

## **6.2 Programmable Logic Controller Panel Assembly**

Each PLC panel assembly has a PLC panel with lockable doors mounted on a concrete foundation and protected with a perimeter security fencing. Panels located at Abrams/Imjin, Landfill, and University enclose the local power distribution panel, motor starters, low voltage transformers, PLC, relays, leak detection panel, SCADA hookups, and other ancillary items. The Eastern Network assembly has an adjacent panel the contains the power distribution panel. The western PLC, relays, leak detection panel, and SCADA hookups are placed in separate panels within the GWTP.

### **6.2.1 Power Distribution Panel**

At the Abrams/Imjin and Landfill PLC panel, Siemens Catalog Number S2E18ML250CBS, type S2 distribution panel, with a 250 amp main lug was installed with type BQL circuit breakers. At the University PLC panel, Siemens Catalog Number S3B18ML225FBS, Type S3 distribution panel, with a 225 amp main lug, was installed with type BL circuit breakers. At the Eastern Network panel, Square D Catalog Number SB344WR, with a 400 amp main lug, was installed with type QOB circuit breakers. The Western Network power distribution panel is incorporated in the GWTP MCC.

### **6.2.2 Motor Starters**

Allen-Bradley National Electrical Manufacturers Association (NEMA) size 0 motor starters, Catalog Number 509, were installed for each A-aquifer extraction well pump. Allen-Bradley NEMA size 1 or 2 motor starters, Catalog Number 509, were installed for each Upper 180-foot aquifer extraction well pump. Full voltage, non-reversing starters have both a melting alloy and a class 20 relay overload. Three-phase motors have a heater on each phase. Heater Type W60 was installed for EW-OU2-14-A and EW-OU2-15-A; W47 for EW-OU2-16-A; W68 for EW-OU2-03-180 and EW-OU2-04-180; and W64 for EW-OU2-05-180 and EW-OU2-06-180.

### **6.2.3 Low Voltage Transformers**

Low voltage, 480/120 VAC transformers are installed in the Abrams/Imjin and Landfill PLC panels. The University panel is supplied with low voltage power, and does not require a separate source. The 120 VAC power is supplied to the leak detection panels, electrical plug-in outlets, Warrick Controller in EW-OU2-06-180, PLCs, and the 120/24 volts direct current (VDC) power

supply. The transformer is made by Acme Electrical Corporation, Style SR, and is rated at 240/480 VAC primary, 120/240 VAC secondary, 2 kilovolt-amp, 60 Hz, single phase.

### **6.3    *Extraction Network Instrumentation and Control***

Abrams/Imjin, Landfill, and University extraction well and wellhead instrumentation includes an analog output transducer that indicates water level, an analog output flowmeter that indicates water flowrate, and a digital output pressure switch that indicates high pressure. Well vault instrumentation include a digital output float switch which indicates high water level within the well vault. A digital output automatic reset pressure switch is located in EW-OU2-06-180, EW-OU2-15-A, and EW-OU2-04-180, and indicates a high network pipeline pressure.

A transducer was not installed in EW-OU2-06-180 because the piezometer is blocked; however, a transducer was placed in Monitoring Well MW-OU2-78-180, located near EW-OU2-06-180. EW-OU2-06-180, along with the fifteen Western and Eastern Network extraction wells, are each equipped with conductivity based water level sensors manufactured by Warrick Controls. Since the fifteen Western and Eastern Network wellhead are do not have analog input/output capability, each wellhead is equipped with a manual read flowmeter.

#### **6.3.1    *Instrumentation and Control Wiring***

Digital input/output and analog output signal wire are connected back to a terminal block within each extraction vault. Pressure switches and float switches with discrete (on/off) inputs were installed with normally closed circuits to the PLC. Instrumentation wire from each extraction well is conveyed back to the network PLCs via a separate PVC conduit, separate from the electrical power lines. Analog instruments use twisted shielded pair cables consisting of Number 16 American wire gauge (AWG) tinned copper conductors, with aluminum shield. Pressure and float switches use single conductor, type THHN, Number 14 AWG.

#### **6.3.2    *Pipeline Leak Detection***

The double-contained extraction pipeline has a leak detection system incorporated into the containment pipe. The leak detection system detects primary pipeline failure while reducing the potential of impacted groundwater flowing into the surrounding vadose zone. If a leak is detected, an alarm is triggered and the extraction well pumps associated with that leg of the pipeline are switched off.

A total of 87 leak detectors are installed, with 85 as part of the extraction system, including those in the well vaults: 14 in the Western Network, 15 in the original Eastern Network, 5 in the

Twelfth Street realignment, 10 in Area A line, 11 in the Imjin/Abrams line, 22 in the University line, and 8 in the Landfill line. Leak detection vault locations and numerical labeling is shown in the *Draft Final Construction Drawings* (IT, 2002) as IT File Number 837769-E001. Information is tabulated on [Table 6-1](#), Leak Detection Location Summary by Operational Function.

### **6.3.3 PLC Panel Box Instrument Reset**

A network header pressure switch reset pushbutton is installed in each PLC panel. The pushbutton is used to reset the PLC when a high pressure in the conveyance line occurs and then decreases below the adjustable setpoint.

### **6.3.4 Extraction Motor Run Relay**

The run permissive to each OU2 System Expansion motor starter is a 120 VAC circuit that is energized by a 24 VDC relay from the PLC. The 24 VDC double-pole, double-throw relays, Class 8501, Type KPD12V53, Series D, DIN rail mount, socket type, from the PLC allows the pump to turn on and off. The relay is wired normally open, such that when the 24 volts from the PLC output card is off or the relay is pulled from the socket, the pump will not run.

### **6.3.5 Direct Current Power Supply**

A 24 VDC power supply provides loop power to OU2 System Expansion flowmeter registers, pressure transducers, and to provide discrete inputs to the PLC for float and pressure switches. The 24 VDC positive was labeled as “4” with blue 14 AWG control wire. The 24 VDC negative was labeled as “9” with green 14 AWG control wire.

### **6.3.6 Programmable Logic Controller**

Each of the five extraction well networks operates independently from an electrical power and instrument perspective. This means that each network has its own electric power source, can monitor its own events, and can independently operate based on pre-programmed scenarios. The GWTP and each network contain a discrete PLC, manufactured by AutomationDirect, installed within the local PLC panel. The five extraction-network PLCs have the capability to monitor and control the local extraction well network.

The master PLC is responsible for PLC-automated control of the GWTP. The master PLC is also programmed to monitor process variables and to make process adjustments to connected equipment.

The following conditions may initiate additional master PLC events that may lead to a plant shutdown:

- Extraction pipeline leak detection
- Influent manifold high pressure
- GAC vessel manifold high pressure
- Effluent tank level switch high high or level switch low low
- Injection pipeline high pressure
- Depressing the manual emergency shutdown push button on the master PLC.

While operating under “PLC-automated” mode, the control logic is protective of human health and the environment. If an unsafe operating condition is detected, for example a high pipeline pressure, the local PLC will shut down the upstream pumps, relieving the condition that contributed to the high pressure.

#### **6.4    *Extraction Network Control Narratives***

The five installed PLCs are grouped into three basic control philosophies: the Eastern Network with one PLC; the OU2 System Expansion with three PLCs; and the GWTP with one master PLC. The master PLC at the GWTP also controls the Western Extraction Network.

##### **6.4.1    *Eastern Extraction Network Control Narrative***

The Eastern Network wells do not have transmitting flowmeters or liquid level transducers. Periodic flow and water level readings must be taken manually for each extraction well. The individual wellheads are locally controlled, but can be started and stopped from the local PLC, through one of two control loops. The digital outputs in the Eastern Network will not start the extraction pump motor starter directly, but will enable the motor starter.

Each extraction well is individually hard wired into a local wellhead control loop. The wellhead loop contains the hand-off-auto switch, wellhead pressure switch, vault containment water level switch and the water level controller. The wellhead loop requires a digital output from the local PLC to operate. The controller employs Warrick™ conductance probes and a locally installed Warrick™ relay wired directly to the well pump motor starter.



The local Eastern Network PLC monitors the local pipeline pressure switch and a high liquid level switch in the Wye Vault. The PLC determines whether to enable the individual starters based on the status of the pipeline pressure switch, and the Wye vault level switch.

#### **6.4.2 System Expansion Extraction Network Control Narrative**

Analog signals from the individual extraction wells to the local PLC for the Abrams/Imjin well cluster, Landfill well cluster, and the University well cluster include transmitting flowmeters and liquid level transducers. The analog signals are not recorded at the local PLC, but are available for local PLC or downstream monitoring. The analog level signal is processed by the local PLC to provide a pre-programmed based digital output to the respective well pump.

This digital output controls an interposing relay that energizes or de-energizes the individual motor starter, providing automated high/low water level control of the associated pump. The digital output energizes the motor starter directly. The local PLC determines whether to energize the starter based on the status of the hand-off-auto in the vault, the high level switch in the vault, the pressure switch in the vault, the pressure switch on the pipeline, and the level transducer.

The one exception is Extraction well EW-OU2-06-180, where the liquid level transducer used for water level monitoring is located in adjacent monitoring well MW-OU2-78-180, approximately 10 feet to the northeast. High/low level control in this extraction well employs Warrick™ conductance probes and a locally installed Warrick™ relay.

Several other digital signals are associated with the local PLCs at the Abrams/Imjin well cluster, Landfill well cluster, and the University well cluster. These digital signals either monitor or control the well vault hand-off-auto switch, the motor starter auxiliary contacts, the vault containment high water level switch, the pressure switch for each extraction well, and the pipeline pressure switch associated with the three well clusters.

#### **6.4.3 Western Extraction Network Control Narrative**

The Western Network wells do not have transmitting flowmeters or liquid level transducers. Periodic flow and water level readings must be taken manually for each extraction well. The individual wellheads are locally controlled, but can be started and stopped from the local PLC, through one control loop. The digital output in the Western Network will not start the extraction pump motor starter directly, but will enable the motor starter.

Each extraction well is individually hard wired into a local wellhead control loop. The wellhead loop contains the hand-off-auto switch, wellhead pressure switch, vault containment water level switch and the water level controller. The wellhead loop requires a digital output from the local PLC to operate. The controller employs Warrick™ conductance probes and a locally installed Warrick™ relay wired directly to the well pump motor starter.

The GWTP PLC monitors only a single digital input associated with the Western Network pressure switch. The PLC determines whether to enable the individual starters based on the status of the pipeline pressure switch. A single common digital output with interposing relays enables or disables the western network wells.

## **6.5 Groundwater Treatment Plant Control Narrative**

GWTP analog inputs consist of two influent flowmeters, three effluent flowmeters, and three tank level signals. Each analog signal terminates at the master PLC. Of these analog inputs, only the effluent tank level is used in the control logic. There are six analog outputs which control the six variable frequency drives which in turn control the six injection pumps.

Primary GWTP digital input and output designations are described below. All GWTP digital designations are listed in [Table 6-2](#), Master Programmable Logic Controller Digital Inputs and Outputs.

### **6.5.1 Warning Conditions**

A warning condition does not stop plant operation. It will energize the warning relay connected to the automatic telephone dialer (Y0) and energize the buzzer on the door of the PLC enclosure (Y15) provided the buzzer has not been disabled by the adjacent switch. The warning condition results when either the western or eastern leak detection system (X0 or X1) detects a leak for a duration of three minutes or longer, or when any of the six high pressure switches (X2, X11, X14, X15, X16, or X20) on the discharge of the six injection pumps exceeds the pressure setpoint.

### **6.5.2 Alarm Conditions**

An alarm condition prevents the plant from entering or remaining in the “run” mode. It will also energize the alarm relay (Y1) connected to the automatic telephone dialer and energizes the buzzer on the PLC enclosure provided the buzzer has not been disabled by the adjacent switch.

The alarm condition results from any of the following conditions:

- The influent manifold high pressure switches (X3 or X12) exceeds its setpoint.
- The four effluent tank level switches (X4, X5, X6, or X7) are not in its normal state.
- The four GAC differential pressure switches (X10, X22, X23, or X27) exceeds the setpoint.
- The eastern and western leak detection systems (X0 and X1) indicate a leak for a period of three minutes or longer.
- The injection pump discharge pressure switches (X2, X11, X14, X15, X16, or X20) simultaneously exceed the setpoint.

On activation of an alarm condition that requires a plant shutdown, an alarm message will be indicated on the PLC's operator interface panel, a local alarm circuit will be energized, the master PLC will remove "permissive run" circuits from appropriate process equipment, and the GWTP Operator will be notified by the autodialer. A manual pushbutton will reset the alarm.

A telephone dial-out package (autodialer) is installed at the GWTP. During an unattended shutdown or power outage, the master PLC is programmed to direct the autodialer to dial out, alerting the GWTP Operator and the operator's backups of the alarm condition.

### **6.5.3 Tank Level Algorithm**

To initiate normal automatic control of the effluent injection pumps, one of each motor pair must have its hand-off-auto in the automatic mode, the local/remote must be in the remote mode, and the tank's water level must exceed four feet. If the water level is below four feet, individual effluent pumps will not operate unless switched to the hand mode.

#### **6.5.3.1 Pump P-410 and P-420 Operation**

As the water level rises from four feet to seven feet, either Pump P-410 or P-420 will ramp its speed from zero percent up to the speed corresponding to the pump's potentiometer. If the potentiometer is set at 20, corresponding to 20 milliamps, the pump will operate at 100 percent of its rated speed at water levels above seven feet. If the potentiometer is set at 12, halfway between 4 and 20, the pump will operate at 50 percent of its rated speed at water levels above seven feet.

#### **6.5.3.2 Pump P-510 and P-520 Operation**

As the water level rises from seven feet to ten feet, either Pump P-510 or P-520 will ramp its speed from zero percent up to the speed corresponding to the pump's potentiometer. If the potentiometer is set at 20, the pump will operate at 100 percent of its rated speed at water levels above ten feet. If the potentiometer is set at 12, halfway between 4 and 20, the pump will operate at 50 percent of its rated speed at water levels above ten feet.

#### **6.5.3.3 Pump P-910 and P-920 Operation**

As the water level rises from eight feet to eleven feet, either Pump P-910 or P-920 will ramp its speed from zero percent up to the speed corresponding to the pump's potentiometer. If the potentiometer is set at 20, the pump will operate at 100 percent of its rated speed at water levels above eleven feet. If the potentiometer is set at 12, halfway between 4 and 20, the pump will operate at 50 percent of its rated speed at water levels above eleven feet.

#### **6.5.4 Western Network Extraction Well Flow Shedding**

The master PLC is also programmed to modulate the influent water flow based on the capacity of the injection flow. During normal automatic operation and when the water level of the effluent tank exceeds eleven feet, all three effluent injection pumps will be ramped to the maximum speed set by each respective potentiometer. If the effluent tank level continues to rise, the western network extraction wells are programmed to intermittently stop and start based on water level. When the tank level reaches approximately 11.3 feet, the Western Network extraction well pumps are de-energized. When the tank level drops below ten feet, the Western Network pumps are allowed to resume.

To maximize extraction and injection efficiency, this tank cycling should be minimized. The GWTP Operator must either decrease the influent flowrate or increase the value of the appropriate potentiometer to increase the injection flowrate. Downstream, the water levels at the discharge points must be subsequently monitored to insure that the water flow entering the injection points do not exceed the respective discharge capacities.

### **6.6 Supervisory Control**

Overlying the five individual PLC-controlled networks is a SCADA system, connected by wireless Ethernet™ (trademark of Xerox Corporation) links. As shown on [Figure 6-1](#), SCADA Architecture, the system is composed of four slave transceivers, one at each remote PLC panel assembly, communicating through a repeater to the master transceiver. The master transceiver is

located at the OU2 GWTP, and communicates by Ethernet™ patch with the GWTP master PLC. A SCADA operator interface is provided through a personal computer to access data and events.

#### **6.6.1 Radio Link**

The transceiver and ancillary antennae and coaxial cables, manufactured by Datalinc™, are installed at the GWTP, Abrams/Imjin, Eastern, Landfill, and University PLC panel assemblies. An Ethernet™ patch cord connects the transceiver to an Ethernet™ card placed within the PLC. The transceivers use frequency-hopping technology, transmitting data on frequencies between 902 and 928 megahertz at a power ranging up to 1 watt. The low power allows operation without a license in accordance with applicable Federal Communications Commission regulations. Except for the repeater station, the radios are PG&E powered. A solar-powered repeater station is used just north of OU2 Landfill Cell D to relay the signal back to the OU2 GWTP.

#### **6.6.2 Supervisory Control Hardware**

The personal computer is a mini-tower workstation with an 800 megahertz Pentium III processor, 256 kilobyte cache, 3Com™ Ethernet™ card, 128 megabyte internal memory, 56 kilobyte internal modem, 19-inch diagonal monitor, two 40 gigabyte hard drives, compact disk read only memory, compact disk read/write, and 3.5-inch floppy drive, using Windows NT Service Pack 5.

#### **6.6.3 Supervisory Control Software**

Software used is Lookout Direct™, an event-driven object-oriented package from National Instruments Lookout and marketed through Automation Direct (see [automationdirect.com](http://automationdirect.com)). The PC based software writes to the digital “bits” or analog memory addresses in the remote PLCs and polls the PLCs for the status of digital bits and analog memory addresses. This enables the operator to monitor and control the remote PLCs from the PC.

The Lookout Direct™ software is capable of simulating the operation of traditional real-time monitoring devices such as pilot lights and analog indicators; simulating the operation of control devices such as switches and potentiometers; and simulating traditional data logging devices such as strip chart recorders and elapsed time indicators.

#### **6.6.4 Supervisory Control System Operation**

Human machine interface (HMI) parameters are detailed in this section. SCADA GWTP startup, cold startup, and shutdown procedures are discussed in [Section 2.0](#). Unless stated otherwise, all

input/output analog signals and all input/output digital signals used in control operation that terminate at a local or master PLC are provided as a SCADA monitored event and can be viewed on the operator interface. Most other digital signals terminating at a PLC are available for maintenance viewing on the operator interface, but may be hidden behind an operating screen.

#### **6.6.4.1 Normal Run Mode**

The run mode enables the following:

- Influent pneumatic control valves may open with their HMI hand-off-auto in “automatic.”
- Extraction wells may run with local and HMI hand-off-auto in “automatic.”
- Injection pumps may run with the HMI hand-off-auto in “automatic.”

The run mode may be entered by either pressing the start pushbutton on the PLC enclosure (X24) or by clicking the HMI start pushbutton with the computer mouse provided there is no “alarm” condition. The run mode is disabled when an “alarm” condition occurs, by pressing the stop pushbutton on the PLC enclosure, or by clicking the HMI stop pushbutton with the computer mouse. Note that large red and green arrows on the effluent tank shown on the main treatment plant HMI screen indicate the plant is in run mode.

#### **6.6.4.2 Hand Mode**

The hand mode is the state the system is in when it is not in the run mode. The red and green circular arrows on the effluent tank symbol of the main treatment plant HMI screen is replaced by the word STOP when the system is in the hand mode.

The hand mode enables the following:

- Influent pneumatic control valves may open with their HMI hand-off-auto in “hand.”
- Extraction wells may run with HMI hand-off-autos in “hand” and local hand-off auto in “hand” or “automatic.”
- Injection pumps may run with the HMI hand-off-auto in “hand.”

#### **6.6.4.3 Influent Control**

The four extraction-network PLCs will operate independent of each other without the SCADA overlay. With the overlay, the following additions must be considered.

#### **6.6.4.4 System Expansion**

The digital output from the master PLC energizes the motor starters directly. The local PLC determines whether to energize the starter based on the status of the hand-off-auto in the vault, the high level switch in the vault, the pressure switch in the vault, the pressure switch on the pipeline, the level transducer, the hand-off-auto on the PC operator interface, and the treatment plant run status.

#### **6.6.4.5 Eastern and Western Networks**

Individual digital outputs with interposing relays are installed at the Eastern Network PLC. This enables the operator to start these wells individually from the operator interface. A single common digital output with interposing relays enables or disables the western network wells.

The digital outputs in the eastern network and the western network do not start the extraction pump motor starter directly. They enable the motor starter. That is, the digital output from the PLC is one of several conditions that are necessary for the pumps to run. The other hardwired interlocks include the high-low level control from the Warrick™ relay, the high level switch in the vault, and the hand-off-auto hardwired to the motor starter. The PLC determines whether to enable the starter based on the pipeline high-pressure switch, the Wye vault high level switch (in the eastern network), the hand-off-auto on the PC operator interface, and the plant run status.

#### **6.6.4.6 Groundwater Treatment Plant**

On activation of an alarm condition that requires a plant shutdown, an alarm message will be indicated on the operator interface panel, a local alarm circuit will be energized, the master PLC will remove “permissive run” circuits from appropriate process equipment, and the GWTP Operator will be notified by an autodialer. A manual pushbutton will reset the alarm.

#### **6.6.4.7 Effluent Pump Control**

The six injection pumps consist of three lead-standby pairs. The operator selects which pump is the lead and which is the standby using the HMI hand-off-auto switches. Normally, the hand-off-auto for either Pump P-410 or P-420 will be in the off position, the hand-off-auto for either Pump P-510 or P-520 will be in the off position, and the hand-off-auto for either Pump P-910 or P-920 will be in the off position. The normal position for the hand-off-auto switch of the pump selected for active duty is the automatic position. Operation of the pumps in the Hand mode disables the alarm shutdown interlocks for the pump and is not recommended for unattended operation.

The HMI local/remote switches determine whether the speed the effluent pump variable speed drives is set by the HMI potentiometer or by the tank level algorithm which is described in the following section.

The HMI potentiometer for each pump can be set by typing a number between 4 and 20 after first clicking the potentiometer display with the computer mouse. When the local/remote switch is in the local position, the entry four represents a 4-milliamp signal to the variable frequency drive, which corresponds to zero percent of full speed. The entry 20 represents a 20-milliamp signal to the variable frequency drive, which corresponds to 100 percent of full speed provided the local/remote is in the local position.

When the local/remote is in the remote position, the potentiometer setting represents the maximum signal to or speed of the variable frequency drive that will be possible as the signal and speed ramp up proportional to effluent tank level.

#### **6.6.5 Supervisory Monitoring, Control, and Expansion Capabilities**

Table 6-3, SCADA Status, lists the current (December 2001) status and use of each category of digital inputs, digital outputs, analog inputs, and analog outputs. A full digital input/output listing is included as Table 6-2.

SCADA was originally set-up to provide near-real-time monitoring and control of the extraction system, GWTP operations, and injection system. Although data acquisition is accomplished with nearly all signals being transmitted to the desktop computer, as of December 2001 data recording and data trending had not yet been programmed into the desktop. Table 6-3 also includes a description of future potential uses for each category of signals.



## **7.0 Health and Safety**

---

All personnel involved in the O&M of the groundwater remedy are required to be familiar with the SSHP (IT, 2000). The SSHP addresses health and safety requirements of all employees, subcontractors, and site visitors. The responsibilities of site personnel and specific procedures that are to be known and understood are presented such as emergency response, first aid, and injury prevention. General site hazards and typical chemical protection information are also presented. A copy of the SSHP shall be located at the GWTP's control room. The following information in this section is focused on specific safety procedures to follow during operation of the groundwater remedy and whenever maintenance is required.

### **7.1 Equipment Safety**

The following practices and procedures are to be observed to protect against operating equipment hazards:

- Follow instructions in this O&M Manual and in [Appendix B](#) vendor-supplied information
- Do not perform work on equipment while it is operating or energized.
- Wear the proper PPE whenever you may come in contact with untreated water or chemicals.
- Hard hat, safety glasses and steel-toed boots are required at all locations; hard hats and safety glasses are not required in the control room.

The SSHP may require PPE as necessary to complete a specific job. Personal protective equipment will be prescribed based on the hazards that are anticipated to be present. A full description of levels of protection practiced is provided in Section 5.0 of the SSHP (IT, 2000).

### **7.2 Electrical Safety**

The following practices and procedures are to be observed to protect against electrical hazards:

- Terminal boxes, enclosures, and covers shall be appropriately maintained to reduce accidental contact with energized circuits.
- Only authorized people are allowed to work near electrical equipment and fixtures.
- The grounding of insulated wiring, controls, equipment, and motors shall be maintained.

- Labels provided for circuit, voltage, or control identification should be legible and securely attached to the appropriate equipment.
- Follow lockout/tagout procedures for working on any electrical equipment.

### **7.3 Chemical Safety**

The following practices and procedures are to be observed to protect against chemical hazards:

- Safety glasses are required when working in the GWTP area.
- Proper protective equipment should be worn whenever work is done on any equipment handling chemicals or extracted groundwater.
- Any chemical brought on site must be accompanied by an MSDS, which should be included in the SSHP. The hazards of the chemicals should be discussed in the tailgate safety meeting for the day the chemicals are being used.
- MSDSs for chemicals used at the GWTP shall be placed in the control room for easy access.

### **7.4 Emergency Response/Spill Contingency Plan**

This Plan describes contingencies and emergency planning procedures to be implemented at the groundwater remedy. During the initial site indoctrination, training and site briefings will be held periodically. All employees will be trained in and reminded of emergency response/spill plan provisions, communication systems, and evacuation routes. The plan shall be reviewed and/or revised at least annually by the SSHO to ensure that it is current with prevailing site conditions. No change will be made without the consent of the SSHO.

Information on hazardous materials handled will be provided as appropriate to local police departments, fire departments, and local hospitals. Copies of the Contingency Plan will also be submitted to the organizations that may be called upon to provide emergency services.

#### **7.4.1 Lines of Authority**

The SSHO is the Emergency Coordinator and has primary responsibility for responding to and correcting emergency situations. This encompasses taking appropriate action, including activating the Contingency Plan and notifying management and the USACE of the potential need for increased involvement to ensure the safety of site personnel and the public. Possible actions may involve evacuation of personnel from the site area as well as evacuation of occupants from adjacent areas.

The GWTP Operator is responsible for ensuring that emergency and corrective measures have been implemented, appropriate authorities notified, and follow-up reports completed. The GWTP Operator has the authority to cease groundwater remedy operations if any unsafe condition requires immediate action.

It will be the responsibility of the SSHO to enforce and monitor the effectiveness of this plan. The SSHO will make regular observations of the groundwater remedy, adjacent work areas, and the surrounding site, as well as the behavior of the employees during work and non-work periods. Both the GWTP Operator and SSHO are responsible for reporting any non-standard conditions to management immediately upon discovery or as a result of routine plant inspections.

#### **7.4.2 Safety Inspections**

Safety inspections will address the following areas:

- Fire alarm systems and security for the GWTP building
- Building fire extinguisher(s)
- Electrical equipment, controls, and wiring
- Safety showers/eye wash stations
- Availability, use, and storage of PPE
- Storage and use of hazardous or combustible materials
- Housekeeping and labeling.

The SSHO will keep records of inspections and incident forms. An equipment safety and security checklist shall be prepared to document these inspections. The records will be used to document the need for improvements in procedures, equipment, or employee behavior. The SSHO has the authority to take quick corrective action and is responsible for taking immediate actions to respond to or mitigate emergency situations.

#### **7.4.3 Potential Work Place Hazards**

The groundwater remedy Operations Hazard Analysis (SSHP, 2000) contains a list of “Potential Hazards” and “Recommended Controls” for the following work place activities:

- Operation of groundwater remedy
- General/Ground maintenance and repair of groundwater remedy

- Welding and cutting
- Handling sharp objects
- Material storage
- Spent carbon replacement
- Water sampling.

Potential work place hazards are discussed below in the following three categories: hazardous materials, ignition sources, and material storage and handling.

#### **7.4.3.1 Hazardous Materials**

Work place fire hazards may exist at or near the groundwater remedy of which all personnel should be aware. Potential fire hazardous materials include

- Gasoline and/or diesel fuel (vehicles)
- Miscellaneous combustibles (such as paints and epoxies).

#### **7.4.3.2 Ignition Sources**

Potential ignition sources that require control on site include

- Faulty electrical systems
- Heat producing equipment
- Smoking
- Cutting, welding, and mechanical sparks
- Static electricity
- Compressed air.

Smoking is not permitted inside the GWTP or within 50 feet of the operations outside the building. No welding, cutting or spark generating tasks are permitted without a hot work permit authorized by the SSHO. All electrical systems must be grounded, as well as any potential sources of static electricity (e.g., steam cleaning of equipment and tanks).

#### **7.4.3.3 Material Storage and Handling**

Proper storage and handling of combustibles and flammables is necessary for fire prevention. Special storage areas on site include flammables storage cabinets, fuel storage tanks, and compressed gas storage racks. Flammable storage areas must be grounded to prevent static

discharge. Storage of flammables and combustibles shall meet all requirements of the National Fire Protection Association and the American National Standards Institute (ANSI).

#### **7.4.4 Site Emergency Procedures**

A list of emergency contact phone numbers will be posted near each site telephone and within each site vehicle. This list includes local emergency responders, medical facilities, and appropriate government officials.

Incidents may be mitigated through application of standard mitigation/control measures available to site personnel. When necessary, follow-up reporting will be made to the USACE and other appropriate authorities. If an incident on site becomes uncontrolled or is in excess of on-site capabilities, the Fire Department will be called, who will in turn notify the Federal Police and the Installation Response Team (IRT), who will oversee the emergency situation.

##### **7.4.4.1 Spills and Leaks**

In the event of a spill or leak of a hazardous substance, site personnel will immediately

- Inform the Emergency Coordinator
- Locate the source of the leak or spill and stop the flow if it can be done safely
- Notify the Fort Ord Fire Department if the spill cannot be safely contained within the designated secondary containment area(s)
- After the leak or spill has terminated, determine if the cause of the spill or leak is a damaged piece of equipment or tool. Determine if the spill or leak has caused, or will cause, damage to a piece of equipment or tool. If the answer to both questions is NO and the spill volume is less than one gallon of hazardous material, absorb with soda ash or diatomaceous earth, as appropriate.
- Describe the events leading to the spill or leak and detail the corrective measures to be taken to the Emergency Coordinator. Small spills of less than 10 gallons may be absorbed with soda ash or diatomaceous earth, as appropriate.
- Spills of greater than 10 gallons of hazardous materials will require immediate notification to management.

The location of emergency spill response equipment will be indicated on a drawing in the control room and discussed with site personnel during site indoctrination training and periodically in safety briefings.

Following an emergency, access to the affected area will be restricted. Depending upon the severity and location of the incident, physical barriers or warning tape will be used to delineate

restricted areas. For an uncontrolled occurrence, site control will be the responsibility of an outside team who will establish the new work area boundaries if necessary. For controlled occurrences, the O&M contractor will be responsible for site control.

#### **7.4.4.2 Fire or Explosion**

In the event of an uncontrolled fire or explosion, the Fire Department will be summoned immediately. This will occur concurrently with evacuation of appropriate personnel and accounting for personnel. Upon arrival of each fire unit, the GWTP Operator and SSHO will advise the fire commander of the location, nature, and identification of the hazardous materials on site. Providing it can be done safely, site personnel may

- Use fire extinguishers available on site to control or extinguish a small localized fire
- Remove or isolate flammable or other hazardous materials that may contribute to the fire
- Begin containment and recovery of the spilled materials.

The GWTP Operator and SSHO will determine in the interim whether corrective action may be attempted. Corrective action may only be attempted if personnel are adequately trained and it can be accomplished safely. Portable fire extinguishers of a sufficient number and appropriate type and size for potential fires will be kept on site and maintained according to applicable regulations and codes. At a minimum, a portable extinguisher must be placed in each area within 50 feet of any flammable liquid storage or dispensing area.

#### **7.4.4.3 Earthquakes**

The actual earth movement of an earthquake is seldom the direct cause of injury or death. Most casualties are caused by falling debris from collapsing buildings and other structures and by fires caused by broken gas mains.

During an earthquake, site personnel should:

- Remain calm and do not panic.
- If caught indoors, remain indoors. Take cover under a desk or table or against inside walls or doorways. Avoid windows and outside doors.
- Do not use or do anything that might be a source of ignition, e.g., smoking, cutting, or welding.
- If caught outdoors, move away from buildings and overhead utility lines.

- If in a moving vehicle, stop as quickly as safety permits, but stay in the vehicle. When driving after the earthquake, watch carefully for hazards created by the earthquake, e.g., undermined roads, weak bridges, or overpasses.

After an earthquake, site personnel should:

- Check for injuries. Do not move seriously injured personnel unless remaining where they would create danger of further injury.
- Check pipelines, wellheads, and utility lines for damage. Switch off power, water, and gas until a utility official has inspected the building and determined it is safe. Determine whether the plant can operate safely.
- Stay out of the building if it is severely damaged. Aftershocks are common and may cause their collapse.
- Assist emergency personnel, if requested.
- Be prepared for aftershocks, which may occur hours or days later.

#### **7.4.4.4 Evacuation Routes and Procedures**

In the event of an emergency evacuation of the GWTP, the following alarm procedures will be implemented:

- Verbal warning will be used to alert other site personnel of an evacuation emergency. Personnel will be told to exit the site and meet at a pre-designated safe meeting area that is upwind and hazardous free. The GWTP Operator will complete a head count. Further directions or response discussions will be coordinated at that point.
- The Fire Department and IRT will be notified, and they will determine if an area-wide evacuation is necessary. The proper communications will be made by radio and telephone to cue evacuation of the area.
- Normal traffic flow patterns will be in effect unless a local detour is required.

#### **7.4.5 Emergency Equipment and Location**

The following is a list of emergency equipment that will be available on site:

- Fire extinguishers (Control room, main plant area, and site vehicles)
- First Aid Kits (Control room, main plant area, and site vehicles)
- Safety shower inside building near control room
- Safety eyewash station in each outside containment area
- Spill Control Kits – as needed near the truck unloading area

The location of emergency equipment will be shown on site drawings and discussed with site personnel during site indoctrination training and periodically in safety briefings. The first-aid-kit location will be specially marked and stocked with adequate water and other supplies necessary to clean and decontaminate burns, wounds, or lesions. The inside of the GWTP building will be equipped with an approved eye wash and safety shower station in accordance with the ANSI Standard Z358.1, "Emergency Eye Wash and Shower Equipment" (ANSI, 1990).

At least one person certified in first aid techniques, which includes training in cardiopulmonary resuscitation, will be on the site whenever maintenance activities are scheduled. This individual may perform other duties, but must be immediately available to render first aid when needed.

#### **7.4.6 Medical Emergencies**

In the event of a medical emergency, the following procedures shall be implemented:

1. Call 911.
2. Identify location, request medical assistance, and provide name and telephone number.
3. Request assistance from emergency medical service and/or additional assistance.

Any person being transported to a clinic or hospital for treatment should take with them information on the chemical(s) they may have been exposed to at the site. The local hospital is

Community Hospital of Monterey Peninsula  
23625 Holman Highway  
Monterey, California 93942  
(831) 625-4900

A list of names and numbers in the following format shall be posted within the control room.

#### **LIST OF EMERGENCY CONTACT PHONE NUMBERS**

##### **O&M Contractor Contacts:**

1.	Name	Work Number	Home Number	Cell Number
2.	GWTP Operator (Alternate Emergency Coordinator)			
	Name	Work Number	Home Number	Cell Number
	Mark Fisler	(831) 384-3735	(408) 262-3664	(831) 277-1967

If you do not personally speak with designated contact #1 or #2, call the following:



3.	Project Manager			
	Name	Work Number	Home Number	Cell Number

Other emergency numbers include

- |  |                 |
|--|-----------------|
| • Fire Department                          | 911             |
| • Police Department                        | 911             |
| • Installation Response Team               | (831) 242-7932  |
| • Medical Emergencies                      | 911             |
| • Community Hospital of Monterey Peninsula | (831) 625-4900  |
| • National Response Center                 | (800) 424-8802  |
| • Poison Control Center                    | (800) 346-5922  |
| • California Office of Emergency Services  | (800) 852-7550. |

## **8.0 Recordkeeping, Performance Evaluation and Reporting**

---

Process operation records shall be accurately kept. Records are routinely used for troubleshooting system problems, completing reports to regulatory agencies, and long-range planning.

### **8.1 Routine Operation and Maintenance Logs**

Various O&M logs shall be completed on a routine basis (daily or weekly as appropriate). The data contained in these logs are used to generate the reports to regulatory agencies discussed later in this section. [Appendix D](#) includes copies of the following logs and reports:

- Field Activity Daily Log (FADL)
- Daily Flow Readings Log (when not automatically recorded)
- Periodic Flow Readings Log (SCADA confirmation)
- Periodic Inspection Checklist
- Periodic Maintenance Checklist.

#### **8.1.1 Field Activity Daily Log**

The FADL is the operator's diary and includes descriptions of daily activities and events, visitors on site, important telephone calls, and personnel on site. Additionally, emergency conditions, mitigating procedures or remedies, equipment failures, replacements, and repairs are noted on this form as they occur. A copy of the FADL is included in [Appendix D](#).

#### **8.1.2 Daily Flow Readings Log**

Meter readings shall be logged each normal business day whenever the readings are not automatically recorded. Precise flow readings shall be recorded near 0800 on the day of the reading and on the Flow Reading Log ([Appendix D](#)). The average flowrate shall be calculated by the difference between the current meter reading and the previous day's meter reading divided by the minutes elapsed from the current reading to the previous reading. All meters that are currently online shall be appropriately marked. Specific information logged includes:

- name of GWTP Operator and date of inspection
- totalizer meter readings
- instantaneous flowrates in gallons per minute

- time of day readings obtained
- notation of equipment that is running or not running at time of readings.

### **8.1.3 Periodic Flow Readings Log**

Periodic verification readings shall be logged and compared to the daily readings. The date and time of the readings and the instantaneous flowrate and total flowrate shall be recorded. The GWTP Operator will determine the period average flowrate in gallons per minute for each system logged. Other calculated items include:

- total throughput in gallons
- the operating interval in hours and minutes
- the flowrate percent difference for each system, based on the previous set of data.

The calculated values can then be compared with the SCADA flow readings to verify flow conditions and operability. Analysis of the flow conditions can be used to optimize the extraction and injection systems. The periodic report begins at 0800 of the day of the reading and ends at 0800 the following day and should include any changes to the following:

Time online	The time, in hours and minutes, that the specific piece of equipment is online in normal operation.
Time standby	The time, in hours and minutes, that the specific piece of equipment is offline but is available for immediate operation.
Time downtime	The time, in hours and minutes, that the specific piece of equipment is both offline and is not available for immediate operation.
Operating time	The amount of time, in hours and minutes, that the specific piece of equipment was in normal operation during the status report time period.
Flowrate	The current flowrate through the specific piece of equipment.
Series lead/lag	The configuration of the carbon beds during the status report time or parallel period.

Sampling events	The number, location, and analysis requested of groundwater remedy samples.
-----------------	---

Remarks/comments	Other changes in operations.
------------------	------------------------------

#### **8.1.4 Periodic Inspection Checklist**

Periodic equipment inspections shall be performed. The checklist is filled out weekly, with daily changes noted as they occur. Equipment to be inspected includes the following:

Air compressor	Ensure that air compressor is operating within the manufacturer's suggested operating range. Check oil level and drain accumulated condensate from holding tank.
Air vent valves	Open air vent valves on the carbon beds to release entrapped air. Verify that the valves are not plugged.
Air vent/vacuum	Verify that all air vent/vacuum valves have seated properly and valves have no leaks.
Backwash Tank	Verify tank capacity correctly shown on SCADA system.
Pipelines and valves	Examine aboveground pipeline, valves, and associated gaskets for cracks or leaks. Check for excessive vibration or noise.
Filters, aerosol	Inspect filters for cracks and any other damage. Drain filters to remove condensed water. Periodically replace filter cartridges.
Filters, air	Inspect filters for cracks and any other damage. If the pressure drop is larger than the pressure drop specified by the manufacturer, take the filters off line and clean or replace as necessary.
Filters, bag	Check the pressure drop through the bag filters. If the pressure drop is larger than the pressure drop specified by the manufacturer, take the filters off line and clean or replace as necessary.
Filters, cartridge	Check the pressure drop through the cartridge filters. If the pressure drop is larger than the pressure drop specified by the manufacturer, take the filters off line and clean or replace as necessary.
Filters, particulate	Inspect filters for cracks and any other damage. Drain filters to remove condensed water. Periodically replace filter cartridges.

Flowmeters	Verify that flowmeters are operating properly and that a digital reading is being recorded by the PLC/SCADA system.
Corrosion	Note the level of corrosion on all items in this section. Include building and other surfaces.
Pressure gauges	Verify that the gauges are operating properly. Record pressures readings.
Pressure switches	Verify that the switches are operating properly. Record switch pressure.
Pumps	Check for abnormal vibrations, overheating, noises, and low or high pressure readings. Minimize pump cycling. Verify operability correctly shown on the SCADA system.
Sumps	Check the condition and operability of the sump pump.
Tanks	Check atmospheric tanks and pressure vessels for damage or leaks. Verify that tank water heights are at their normal operating levels.
Valve positioning	Verify that all valves are in the correct positions for the desired operation.

#### **8.1.5 Maintenance Checklist**

At a minimum, the GWTP Operator shall perform scheduled maintenance on the equipment listed on the groundwater remedy Maintenance Checklist ([Appendix D](#)). As shown on the checklist, maintenance inspections are to be performed at least monthly for some items and quarterly, semi-annually or annually for others. The GWTP Operator must refer to the manufacturer's instruction manuals in [Appendix B](#), Vendor Submittals, for detailed instructions and maintenance procedures for these items.

### **8.2 Performance Monitoring**

Operating data will be collected to monitor and evaluate the performance system in meeting the RAO's.

#### **8.2.1 Discharge Standards**

During routine operations, treated water injection to areas overlying the groundwater plume must meet the discharge limits per [Table 1-1](#). For chloroform, 1,1-DCA, and cis-1,2-DCA, the maximum discharge limits need only meet the ACLs. Notification requirements that apply in the event of a discharge standard exceedance are provided in the *Work Plan* (HLA, 2000).

### **8.2.2 Operational Efficiency**

Including routine system modification and maintenance outages, the on-line goal for the groundwater remedy is 95 percent. To achieve this utility goal, single-event maintenance-related downtimes must be minimized.

Aggregate routine maintenance shutdowns and unanticipated system interruptions, are expected to total less than 5 percent, when calculated on an annual basis. For a given calendar year, this converts to a maximum annual cumulative downtime of 18 days and 6 hours. The only major routine item requiring a plant shutdown is a GAC changeout, which should average 4 hours in duration. Mechanical equipment, such as parallel pumps, can be individually mechanically and electrically isolated, and can usually be repaired without a plant shutdown. Aggregate routine maintenance shutdowns are expected to total less than 0.6 percent or less than two days per year.

Unanticipated system interruptions fall into two categories. The first involves mechanical, electrical, or process-control repairs to the plant. A simple pipe repair may result in a plant shutdown of more than one day to allow the pipe glue to dry properly. The second involves interrupted electric power, involving one or more of the three supplied phases. An electric service power surge, or an unexpected power dip may result in a phase imbalance or inadequate voltage that leads to a treatment system shutdown. If the shutdown occurs at night, or during inclement weather, the operator may choose to inspect the plant's electrical systems more thoroughly during daylight hours, or with a qualified electrician, before placing the plant back on-line. The aggregate unanticipated system interruptions are expected to average up to 16 days per year.

### **8.2.3 System Optimization**

Optimization of the groundwater remedy after installation and startup will be conducted to increase the overall system's effectiveness in remediating the desired constituents at a lower cost. The following subsections discuss the primary focus areas for an effective optimization program.

#### **8.2.3.1 Optimization Approach**

Prior to evaluation, raw information will be collected and formatted. Performance-data collection and evaluation are divided into two separate but dependent categories: (1) field data collection and (2) data reduction/evaluation. During the field data collection category, the GWTP Operator will collect and log the required data. During the data reduction/evaluation category, the field data are reviewed for completeness, the data are reduced to a form that can be evaluated and/or compared, and suggestions are formulated. Suggestions may include modifications to

injection and extraction flowrates, valve configurations, and equipment settings. The following subsections discuss in more detail the data collection and dissemination efforts towards optimizing the groundwater remedy.

#### **8.2.3.2 Field Data Collection**

Data will be collected and entered on standardized forms ([Section 8.1](#)). The standardized forms allow data reduction to take place in a timely and orderly fashion. These forms are to be updated as new information, including either additions or omissions about the groundwater remedy, extraction wells, and injection wells are obtained. The field data collection effort should be collected within similar time increments to allow for meaningful comparisons.

The aquifer monitoring schedule includes individual flowrates, pressures and water levels for each extraction well, injection well and infiltration gallery. Depending on the area of the aquifer being evaluated, time or access constraints, not all field measurements are required. Water levels for nearby monitoring wells may also be logged.

#### **8.2.3.3 Office Data Reduction/Evaluation**

Collected data are reduced to a reportable format using standardized spreadsheets and charts. Most of this effort shall be programmed into the SCADA system. The various charts and/or diagrams will allow the engineer to use graphical and analytical methods along with rational decisions with regard to optimizing system performance. Typical varying parameters include increasing the flowrate at a particular well while decreasing another or adjusting extraction and/or discharge rates to minimize cyclical pumping action. Carbon changeouts or other maintenance activities requiring system shutdown will be scheduled concurrently to minimize down times.

#### **8.2.3.4 Performance of Groundwater Extraction Wells**

Technical information regarding system installation is required before system optimization. Extraction well-water levels, flowmeter readings, pressure readings, and electrical consumption will be monitored on a regular basis. As data are evaluated, the pump and/or level controls will be adjusted to reduce cycle frequency, which will create a greater zone of capture. Nearby monitoring wells will also be monitored. The data could also be used to calculate individual well mass removal rates.

#### **8.2.3.5 Performance of Granular Activated Carbon Treatment Unit**

The GAC treatment unit consists primarily of two parallel sets of two 20,000-pound GAC beds and associated valving. To optimize the performance of the GAC beds, routine maintenance shall be performed as specified by the manufacturer. Where practical, routine maintenance shall be scheduled in conjunction with routine monitoring of pressure, system influent, and system effluent concentrations and flowrates through each carbon bed. These data are used to estimate carbon changeout and backwash cycles.

#### **8.2.3.6 Performance of Injection Points**

Infiltration gallery and injection well water levels, flowmeter readings and pressure readings will be monitored on a regular basis. As data are evaluated, the injection pump, injection level control, injection valves and/or nearby valves will be adjusted. Adjusting nearby valves will change the pressure dynamics of the system and will alter the amount of water flow to the injection well versus the nearby infiltration gallery. Infiltration gallery flowrates will be periodically adjusted to ensure adequate plume capture, while minimizing the effects of salt water intrusion.

#### **8.2.3.7 Debottlenecking the Groundwater Remedy**

Debottlenecking is the process of identifying, defining, and engineering a solution around a hydraulic or process bottleneck. Debottlenecking of the groundwater remedy will commence after initial shakedown and normal operation commences. A hydraulic bottleneck is a condition or situation that obstructs, restrict, or slows down water flow. A process bottleneck is a condition or situation that prevents the increase in hydraulic throughput without compromising the integrity of the effluent stream. In other words, increasing water throughput may cause the plant's effluent to exceed permitted discharge constituent concentrations.

The primary bottleneck that limits system flow capacity is the Eastern Network pipe diameter. Increasing water flow corresponds to an increase in pipeline pressure, and could result in exceeding a shutdown condition setpoint.

Secondary bottlenecks will be identified by analyzing the following:

- Extraction well construction details: top of casing, depth to water, pump intake elevation, and level sensor elevation.
- Extraction wells performance summary: flowrates, water level, drawdowns, specific capacity, capture zone, and pressure.



- GAC system performance summary: influent and effluent COC concentrations, pressure drop, and flowrates.
- Summary of groundwater remedy performance: system influent, middle, and effluent concentrations; flowrates; total energy consumption; and mass removed.
- Injection well construction details: list top of casing, depth to water, well screen elevation, and level sensor elevation.
- Infiltration gallery construction details and level sensor elevation.
- Injection well performance summary: injection flowrates, water level, well buildup, specific capacity, radii of injection influence, flow field, and pressure.
- Infiltration gallery performance summary: flowrates, depth of water, and adjacent well water levels.
- Miscellaneous performance data, including, effluent-tank cycling rates, injection-well pump cycling rates, and other gauges and readings as determined in the field.

### **8.3 Performance Evaluation**

A groundwater monitoring program has been established for evaluating system performance. This program includes water level measurement, sample collection, and chemical analysis. The data will be used to assess the near and long-term performance of the groundwater remedy. The monitoring program addresses the following:

- Hydraulic containment: Does the groundwater remedy capture the entire impacted plume?
- Plume remediation: Are COC concentrations being reduced as expected?

Water levels are measured at the wells and piezometers at appropriate frequencies. Hydraulic containment will be evaluated by posting and contouring groundwater-level elevations on maps and interpreting the capture area. If appropriate, the Fort Ord groundwater flow model may also be re-run using the newly acquired water-level monitoring data, and evaluated to determine the extent of the capture zone. Such data can also be used to determine the appropriate flowrates of each extraction well.

The COC analytical results will be used to assess aquifer cleanup progress. Based on the data obtained, the sampling frequency from individual wells may be reduced or released from further testing. A variable sampling frequency approach will be implemented for COC sampling. The variable frequency approach allows for wells with COC concentrations that have dropped below cleanup levels to be sampled less frequently, for example once a year. This approach will not be

implemented until after 1 year of system operation in order to establish a baseline for COC concentrations.

In addition to monitoring COC concentrations over time, groundwater general chemistry parameters will also be monitored. This will allow for an ongoing evaluation of changes to inorganic aquifer water quality associated with saltwater intrusion, including salinity, TDS, and chloride concentrations.

#### **8.4 Reports to Regulatory Agencies**

Two reports are submitted to regulatory agencies on a routine basis: the Quarterly Status Report and the Annual (or semi-annual) System Report. Reports are sent to the following regulatory agencies:

- California Regional Water Quality Control Board, Central Coast Region  
81 Higuera Street, Suite 200, San Luis Obispo, California 93401
- State of California - Environmental Protection Agency  
Department of Toxic Substances Control - Region I, 10151 Croydon Way, Suite 3  
Sacramento, California 95827-2106
- U.S. Environmental Protection Agency - Region IX, 75 Hawthorne Street  
San Francisco, California 94105-3901

##### **8.4.1 Quarterly Data Status Report**

The Quarterly Data Status Report will be completed on a quarterly basis, and will be submitted 60 days after completion of each quarterly operating period. This report will summarize current operating conditions, general trends and likely solutions. A more thorough analysis of problems and solutions will be included in the Annual System Report.

The Quarterly Data Summary report will contain

- analytical data
- quarterly water-level data
- weekly and cumulative production and injection water flow rates.

##### **8.4.2 Annual or Semi-annual System Report**

During normal operations an Annual System Report will be submitted on March 31 and will include the 12-month period ending the previous December 31. This report will analyze current

operating conditions, general trends and likely solutions summarized in the previous four Quarterly Data Summary Reports.

The Annual Evaluation Reports will include the following information:

- treatment configuration with figure
- analytical summary data with tables and figures
- production and injection information with tables and figures
- calculated COC removal with tables
- COC capture effectiveness and groundwater elevation contour maps
- overall operation evaluation, including a description and summary of work performed and a discussion of work to be performed, issues/difficulties encountered, and the proposed response, including system modification
- recommendations for future action
- recommendations for changes to approved plans
- quality control and data summary report as an appendix.

The groundwater remedy operating factors to be evaluated include

- Carbon bed performance
  - Mass loading versus time (or gallons treated)
  - COC breakthrough versus time (or gallons treated).

Hydrogeologic operating factors to be evaluated include

- Well performance
  - Extraction well on-line efficiency
  - Flowrate versus change in water level or specific capacity.
- Aquifer COC distribution, with isoconcentration plots
  - COC capture effectiveness
  - Water-elevation contour maps
  - Flow model results.

After any major system modification a semi-annual System report will be submitted for the six-month period following the completion of the modification. This schedule may be modified with agency approval to bring the reporting schedule in line with the normal calendar year frequency. Following the System Expansion, a System report will be prepared for the period April 2001 through December 2001.

## 9.0 References

---

American National Standards Institute, 1990, Standard Z358.1, “Emergency Eye Wash and Shower Equipment.”

Harding Lawson Associates (HLA), 1998, *Draft Effectiveness Evaluation, Technical Memorandum, OU2 Groundwater Remedy, Fort Ord, California*, Novato, California.

HLA, 1999, *Draft Final Revised Treatment System Plan, OU2 Groundwater Remedy, Fort Ord, California*, Novato, California.

HLA, 2001, *Draft Final Sampling and Analysis Plan, Operable Unit 1, Operable Unit 2, and Sites 2 and 12, Groundwater Treatment Systems, Former Fort Ord, Revision 0*, Novato, California.

ICF Kaiser, 1998, *Draft Final Program Contractor Quality Control Plan*, Revision 0, Oakland, California.

HLA, 2000, *Work Plan, Operable Unit 1, Operable Unit 2, Sites 2 and 12 Groundwater Treatment Systems, Former Fort Ord, California*, Revision B, Fort Ord, California.

IT Corporation (IT), 1996, *Draft Final Well Installation and Abandonment, Operable Unit 2, Pump and Treat, Fort Ord, California*, Revision 0, Sacramento, California

IT, 1997, *Draft Final Operation and Maintenance Manual, Operable Unit 2, Pump and Treat, Fort Ord, California*, Revision 1, Marina, California.

IT, 1999a, *Draft Final Groundwater Remedial Action Work Plan, Operable Unit 2, Groundwater Remedy System Expansion, Fort Ord, California*, Revision 0, Fort Ord, California.

IT, 1999b, *Draft Final Contractor Quality Control Plan, Operable Unit 2, Groundwater Remedy System Expansion, Fort Ord, California*, Revision 0, Fort Ord, California.

IT, 2000, *Site Safety and Health Plan, Fort Ord, California*, Revision 6, Fort Ord, California.

IT, 2001a, *Draft Final Construction Completion Report, Operable Unit 2, Groundwater Remedy System Expansion, Fort Ord, California*, Revision 0, Fort Ord, California.

IT, 2001b, *Draft Final Vendor Submittals, Operable Unit 2, Groundwater Remedy System Expansion, Volumes I, II and III*, Fort Ord, California.

IT, 2001c, *Draft Final Well Installation and Abandonment Report, Operable Unit 2, Groundwater Remedy System Expansion*, Revision 0, Fort Ord, California.

IT, 2002, *Draft Final Construction Drawings, Operable Unit 2, Groundwater Remedy System Expansion*, Revision 1, Fort Ord, California.

U.S. Army (Army), 1994, *Record of Decision, Operable Unit 2, Fort Ord Landfills, Fort Ord, California*, Fort Ord, California.

Army, 1997, *Installation-Wide Multispecies Habitat Management Plan for Former Fort Ord, California*, prepared by the U.S. Army Corps of Engineers, Sacramento District and Jones and Stokes Associates, Inc., Sacramento, California, April 1997.

USEPA, 2001, *Operation and Maintenance in the Superfund Program*, EPA 540-F-01-004.

## TABLES

**Table 1-1****Chemicals of Concern and Remediation Goals<sup>a</sup>  
Operable Unit 2 Groundwater Remedy**

<b>Chemical of Concern</b>	<b>Federal MCL<sup>b</sup> (µg/L)<sup>c</sup></b>	<b>State MCL (µg/L)</b>	<b>Aquifer Cleanup Level (µg/L)</b>	<b>Discharge Limits for Treated Water (µg/L)</b>
Benzene	5.0	1.0	1.0	0.5
Carbon Tetrachloride	5.0	0.5	0.5	0.5
Chloroform	100	-	2.0 <sup>d</sup>	0.5 <sup>e</sup>
1,1-Dichloroethane	—	5.0	5.0	0.5 <sup>e</sup>
1,2-Dichloroethane	5.0	0.5	0.5	0.5
cis-1,2-Dichloroethene	70	6.0	6.0	0.5 <sup>e</sup>
1,2-Dichloropropane	5.0	—	1.0	0.5
Methylene Chloride	5.0	—	5.0	0.5
Tetrachloroethene	5.0	5.0	3.0 <sup>d</sup>	0.5
Trichloroethene	5.0	5.0	5.0	0.5
Vinyl Chloride	2.0	0.5	0.1 <sup>d</sup>	0.1

<sup>a</sup> Reference from Table 1 - U.S. Department of the Army (Army), 1994, *Record of Decision, Operable Unit 2, Fort Ord Landfills, Fort Ord, California*.

<sup>b</sup> maximum contaminant level.

<sup>c</sup> microgram per liter.

<sup>d</sup> Aquifer cleanup goals lower than federal or state MCL(s) are based on risk calculations in Dames & Moore, 1993, *Fort Ord Baseline Risk Assessment*. The estimated combined excess cancer risk from exposure to all chemicals at the levels listed in Table 1 is  $6 \times 10^{-5}$ . This cumulative risk is within the acceptable risk range and is health protective.

<sup>e</sup> Discharge limits for chloroform, 1,1-dichloroethane, and cis-1,2-dichloroethene to areas overlying the contaminated groundwater plume need only meet cleanup levels. Harding Lawson Associates (HLA) 1999, *Draft Final Revised Treatment System Plan, Operable Unit 2, Groundwater Remedy, Fort Ord, California*; prepared for USACE, January 29.



**Table 2-1**

**Major Elements and Components  
Operable Unit 2 Groundwater Remedy**

<b>Location</b>	<b>Quantity</b>	<b>Project<sup>a</sup></b>	<b>Component</b>	<b>Specification</b>	<b>Model Number</b>	<b>Manufacturer</b>
EW <sup>b</sup> -OU2-01-A	1	Original	5 horsepower pump	44 gpm <sup>c</sup> at 300 ft head 3450 rpm <sup>d</sup>	40S50-15	Grundfos
EW-OU2-02-A	1	Original	5 horsepower pump	44 gpm at 300 ft head 3450 rpm	40S50-15	Grundfos
EW-OU2-03-A	1	Original	5 horsepower pump	44 gpm at 300 ft head 3450 rpm	40S50-15	Grundfos
EW-OU2-04-A	1	Original	5 horsepower pump	44 gpm at 300 ft head 3450 rpm	40S50-15	Grundfos
EW-OU2-05-A	1	Original	5 horsepower pump	44 gpm at 300 ft head 3450 rpm	40S50-15	Grundfos
EW-OU2-06-A	1	Original	5 horsepower pump	44 gpm at 300 ft head 3450 rpm	40S50-15	Grundfos
EW-OU2-07-A	1	Original	3 horsepower pump	25 gpm at 300 ft head 3450 rpm	25S30-15	Grundfos
EW-OU2-08-A	1	Original	3 horsepower pump	25 gpm at 300 ft head 3450 rpm	25S30-15	Grundfos
EW-OU2-09-A	1	Original	3 horsepower pump	25 gpm at 300 ft head 3450 rpm	25S30-15	Grundfos
EW-OU2-10-A	1	Original	3 horsepower pump	25 gpm at 300 ft head 3450 rpm	25S30-15	Grundfos
EW-OU2-11-A	1	Original	3 horsepower pump	25 gpm at 300 ft head 3450 rpm	25S30-15	Grundfos
EW-OU2-12-A	1	Original	3 horsepower pump	25 gpm at 300 ft head 3450 rpm	25S30-15	Grundfos
EW-OU2-13-A	1	Original	3 horsepower pump	25 gpm at 300 ft head 3450 rpm	25S30-15	Grundfos
EW-OU2-14-A	1	Expansion	3 horsepower pump	18 gpm at 312 ft head 3450 rpm	25S30-15	Grundfos
EW-OU2-15-A	1	Expansion	3 horsepower pump	18 gpm at 315 ft head 3450 rpm	25S30-15	Grundfos
EW-OU2-16-A	1	Expansion	3 horsepower pump	24 gpm at 293 ft head 3450 rpm	25S30-15	Grundfos
EW-OU2-01-180	1	Original	25 horsepower pump	250 gpm at 300 ft head 3450 rpm	225S250-10	Grundfos
EW-OU2-02-180	1	Original	15 horsepower pump	150 gpm at 300 ft head 3450 rpm	135S150-9	Grundfos
EW-OU2-03-180	1	Expansion	20 horsepower pump	125 gpm at 416 ft head 3450 rpm	150S200-10	Grundfos
EW-OU2-04-180	1	Expansion	20 horsepower pump	125 gpm at 427 ft head 3450 rpm	150S200-10	Grundfos
EW-OU2-05-180	1	Expansion	20 horsepower pump	125 gpm at 416 ft head 3450 rpm	150S200-10	Grundfos
EW-OU2-06-180	1	Expansion	20 horsepower pump	125 gpm at 406 ft head 3450 rpm	150S200-10	Grundfos
INF <sup>e</sup> -OU2-01-180	1	Expansion	Infiltration gallery	328 gpm nominal flow 462 gpm maximum flow	Not applicable	Not applicable
INF-OU2-02-180	1	Expansion	Infiltration gallery	325 gpm nominal flow 458 gpm maximum flow	Not applicable	Not applicable
GWTP <sup>f</sup>	2	Expansion	New carbon adsorption vessel	20,000 pound GAC <sup>g</sup> treatment vessels	HP-1020S-6	US Filter / Westates

**Table 2-1**

**Major Elements and Components  
Operable Unit 2 Groundwater Remedy**

Location	Quantity	Project <sup>a</sup>	Component	Specification	Model Number	Manufacturer
GWTP	2	Original; Expansion modified	Refurbished carbon adsorption vessel	20,000 pound GAC treatment vessels	Model 10	Calgon unit; refurbished by US Filter / Westates
GWTP	1	Expansion	New backwash Tank	Carbon steel 10,000 gal working volume 12-ft diam by 14-ft high	Dwg D10004	BH Tank Works
GWTP	1	Original; Expansion modified	Refurbished backwash tank	304 stainless steel 6,000 gal 9-ft 9-in by 11-ft 1-in high	Dwg 16998	Solarchem unit; refurbished by BH Tank Works
GWTP	1	Expansion	Effluent tank	304 stainless steel 10,000 gal working volume 11-ft diam by 16-ft high	Not applicable	BH Tank Works
GWTP	1	Expansion	Backwash pump	10 horsepower centrifugal 50 gpm 175 ft head 1800 rpm	3x1.5x13 GRP	Ingersoll-Dresser Pumps
GWTP	2	Original	Sites 2/12 & eastern injection pumps P-410 & 420	40 horsepower centrifugal ___ gpm 220 ft head 3450 rpm	4x3x6.5	ITT-AC
GWTP	2	Original; Expansion service	Southwestern injection pumps P-510 & 520	10 horsepower centrifugal 300gpm 28 ft head 1170 rpm	4x3x11	ITT-AC
GWTP	2	Expansion	Northwestern injection pumps P-910 & 920	7.5 horsepower centrifugal 300 gpm 59 ft head 3450 rpm	4x3x8F D800	Ingersoll-Dresser Pumps
GWTP	3	Expansion	Sump pump	½ horsepower submersible 20 gpm 25 ft head	1-½ inch dewater 1DW51C1EA	Goulds Pumps
GWTP	1	Expansion	Backwash cartridge filter	with CMMF02020 cartridges (20 micron by 20-in long)	FSC-1220	Filter Specialists, Inc.
GWTP	1	Original; Expansion relocation	Influent static mixer	316L stainless steel 8-in diam by 8-ft long	ID M-186	Reused Solarchem unit
GWTP	2	Original	Sites 2/12 & eastern injection pump variable frequency drives	40 horsepower 460 volt 3 phase NEMA 1 enclosure	AF 5000	Eaton
GWTP	2	Original	Southwestern injection pump variable frequency drives	10 horsepower 460 volt 3 phase NEMA 1 enclosure	AF 5000	Eaton
GWTP	2	Expansion	Northwestern injection pump variable frequency drives	10 horsepower 460 volt 3 phase NEMA 1 enclosure	VLT 5000 Aqua	Danfoss Electronic Drives
GWTP	40 feet	Expansion	2-inch building pipe	Single-contained polyvinyl chloride pipe, schedule 80	Not applicable	Various
	240 feet	Expansion	6-inch building pipe			
	20 feet	Expansion	12-inch building pipe			

**Table 2-1**

**Major Elements and Components  
Operable Unit 2 Groundwater Remedy**

Location	Quantity	Project <sup>a</sup>	Component	Specification	Model Number	Manufacturer
Extraction pipeline	710 feet	Expansion	2-inch x 4-inch	Double-contained high-density polyethylene pipe SDR 11 inner and SDR 17 outer	Not applicable	Santa Fe Industrial Products
	5,300 feet	Expansion	3-inch x 6-inch			
	790 feet	Expansion	4-inch x 8-inch			
	1,950 feet	Expansion	6-inch x 10-inch			
	4,800 feet	Expansion	8-inch x 12-inch			
	40 feet	Expansion	4, 6, and 8-inch	Single-contained polyvinyl chloride pipe, schedule 80 installed in vault	Not applicable	Various
	1,740 feet	12 <sup>th</sup> Street	8-inch x 12-inch	Double-contained high-density polyethylene pipe SDR 11 inner and SDR 17 outer	Not applicable	Santa Fe Industrial Products
	8 feet	12 <sup>th</sup> Street	8-inch	Single-contained polyvinyl chloride pipe, schedule 80 installed in vault	Not applicable	Various
Injection pipeline	110 feet	Expansion	6-inch	Single-contained polyvinyl chloride pipe, schedule 80	Not applicable	Various
	1740 feet	12 <sup>th</sup> Street	8-inch	Single-contained high-density polyethylene pipe SDR 11	Not applicable	Santa Fe Industrial Products
	8 feet	12 <sup>th</sup> Street	8-inch	Single-contained polyvinyl chloride pipe, schedule 80	Not applicable	Various

<sup>a</sup> Original – installed in 1995/1996; Expansion – installed in 1999/2000; Expansion modified – originally installed in 1995/1996 but modified/replaced and reinstalled in 1999/2000; 12<sup>th</sup> Street – installed in 2002.

<sup>b</sup> Extraction Well

<sup>c</sup> gallons per minute

<sup>d</sup> revolutions per minute

<sup>e</sup> Infiltration gallery

<sup>f</sup> Groundwater Treatment Plant

<sup>g</sup> granular activated carbon

**Table 2-2**

**Well, Pump and System Capacities  
Operable Unit 2 Groundwater Remedy**

<b>Extraction Well</b>	<b>Well Capacity<sup>a</sup> (gpm)<sup>b</sup></b>	<b>Pump Capacity<sup>c</sup> (gpm)</b>	<b>System Operating Capacity (gpm)</b>
EW <sup>d</sup> -OU2-01-A	50 (09/96)	51	45
EW-OU2-02-A	50 (10/96)	51	30
EW-OU2-03-A	50 (10/96)	51	30
EW-OU2-04-A	50 (09/96)	51	35
EW-OU2-05-A	50 (10/96)	51	35
EW-OU2-06-A	50 (10/96)	51	30
EW-OU2-07-A	30 (07/01)	30	25
EW-OU2-08-A	30 (07/01)	30	25
EW-OU2-09-A	30 (07/01)	30	20
EW-OU2-10-A	30 (10/96)	30	20
EW-OU2-11-A	30 (10/96)	30	20
EW-OU2-12-A	30 (07/01)	30	25
EW-OU2-13-A	23 (08/96)	30	20
EW-OU2-01-180	225 (07/01)	280	150
EW-OU2-02-180	160 (08/01)	172	120
EW-OU2-03-180	227 (08/01)	210	125
EW-OU2-04-180	151 (05/01)	210	115
EW-OU2-05-180	178 (07/01)	210	115
EW-OU2-06-180	621 (07/01)	210	135
EW-OU2-14-A	28 (07/01)	30	20
EW-OU2-15-A	28 (07/01)	30	20
EW-OU2-16-A	27 (05/01)	30	20
<b>Total Extraction Capacity</b>	Not applicable	Not applicable	<b>1180</b>

<b>Recharge Point</b>			
IW <sup>e</sup> -OU2-01-180	100	Not applicable	70
IW-OU2-02-180	150	Not applicable	70
IW-OU2-03-180	80	Not applicable	60
INF <sup>f</sup> -OU2-01-180 <sup>g</sup>	400	Not applicable	300
INF-OU2-02-180	280	Not applicable	270
Site 2 recharge	670, less Sites 2 and 12 extraction well rate	Not applicable	410
<b>Total Recharge Capacity</b>	Not applicable	Not applicable	<b>1180</b>

<sup>a</sup> Extraction rates by specific capacity evaluation; recharge rates by experience; (bracket) last evaluation date.

<sup>b</sup> gallons per minute instantaneous flow rate.

<sup>c</sup> Pump curve capacity at 240-foot head.

<sup>d</sup> Extraction Well.

<sup>e</sup> Injection Well.

<sup>f</sup> Infiltration Gallery.

<sup>g</sup> Five INF-OU2-XX-A wells (01, 02, 03, 04, and 05) were decommissioned in March 2000.

**Table 2-2**

**Well, Pump and System Capacities  
Operable Unit 2 Groundwater Remedy**

<b>Extraction Well</b>	<b>Well Capacity<sup>a</sup> (gpm)<sup>b</sup></b>	<b>Pump Capacity<sup>c</sup> (gpm)</b>	<b>System Operating Capacity (gpm)</b>
EW <sup>d</sup> -OU2-01-A	50 (09/96)	51	45
EW-OU2-02-A	50 (10/96)	51	30
EW-OU2-03-A	50 (10/96)	51	30
EW-OU2-04-A	50 (09/96)	51	35
EW-OU2-05-A	50 (10/96)	51	35
EW-OU2-06-A	50 (10/96)	51	30
EW-OU2-07-A	30 (07/01)	30	25
EW-OU2-08-A	30 (07/01)	30	25
EW-OU2-09-A	30 (07/01)	30	20
EW-OU2-10-A	30 (10/96)	30	20
EW-OU2-11-A	30 (10/96)	30	20
EW-OU2-12-A	30 (07/01)	30	25
EW-OU2-13-A	23 (08/96)	30	20
EW-OU2-01-180	225 (07/01)	280	150
EW-OU2-02-180	160 (08/01)	172	120
EW-OU2-03-180	227 (08/01)	210	125
EW-OU2-04-180	151 (05/01)	210	115
EW-OU2-05-180	178 (07/01)	210	115
EW-OU2-06-180	621 (07/01)	210	135
EW-OU2-14-A	28 (07/01)	30	20
EW-OU2-15-A	28 (07/01)	30	20
EW-OU2-16-A	27 (05/01)	30	20
<b>Total Extraction Capacity</b>	Not applicable	Not applicable	<b>1180</b>

<b>Recharge Point</b>			
IW <sup>e</sup> -OU2-01-180	100	Not applicable	70
IW-OU2-02-180	150	Not applicable	70
IW-OU2-03-180	80	Not applicable	60
INF <sup>f</sup> -OU2-01-180 <sup>g</sup>	400	Not applicable	300
INF-OU2-02-180	280	Not applicable	270
Site 2 recharge	670, less Sites 2 and 12 extraction well rate	Not applicable	410
<b>Total Recharge Capacity</b>	Not applicable	Not applicable	<b>1180</b>

<sup>a</sup> Extraction rates by specific capacity evaluation; recharge rates by experience; (bracket) last evaluation date.

<sup>b</sup> gallons per minute instantaneous flow rate.

<sup>c</sup> Pump curve capacity at 240-foot head.

<sup>d</sup> Extraction Well.

<sup>e</sup> Injection Well.

<sup>f</sup> Infiltration Gallery.

<sup>g</sup> Five INF-OU2-XX-A wells (01, 02, 03, 04, and 05) were decommissioned in March 2000.

Table 3-1

**Extraction Well, Injection Well, Pipeline, and Infiltration Gallery Concrete Vault Location<sup>a</sup>**  
**Operable Unit 2 Groundwater Remedy**

**Original Remedy with Site 2 Injection and 12<sup>th</sup> Street Installation**

Vault Location	Vault, 4-foot by 5-foot	Vault, 5-foot by 6-foot	Vault, 6-foot by 6-foot	High Point Vent	Low Point Drain	Leak Detection	Pullbox 11-inch by 17-inch	Total
Western Extraction	6	1	0	0	0	9	0	<b>16</b>
Abrams Extraction	7	1	0	0	0	4	0	<b>12</b>
12 <sup>th</sup> Street Realignment	0	0	2	1	2	0	2	<b>7</b>
Northwestern Injection	1	0	0	2	0	0	0	<b>3</b>
Southwestern Injection	1	0	0	1	1	0	0	<b>3</b>
Eastern Injection	1	0	0	3	3	0	0	<b>7</b>
Treated Water to Site 2 Injection	0	0	0	1	1	0	0	<b>2</b>
<b>Total</b>	<b>16</b>	<b>2</b>	<b>2</b>	<b>8</b>	<b>7</b>	<b>13</b>	<b>2</b>	<b>50</b>

**System Expansion Installation**

Vault Location	Vault, 2-foot by 2-foot			Pull Box				Isolation Valve	Infiltration Gallery	Valve Box	Extraction Well		Wye Vault	Total
	Low Point	High Point	Leak Detection	2-foot Square	11-inch by 17-inch	17-inch by 30-inch	2-foot by 3-foot	4-foot Diameter	4-foot Square	4-foot by 8-foot	6-foot Square	6-foot by 9-foot	8-foot by 10-foot	
University	4	4	11	0	10	0	1	1	0	0	2	0	0	<b>33</b>
Landfill	1	0	4	0	2	2	1	1	0	0	0	2	0	<b>13</b>
Imjin/Abrams	1	1	4	1	3	2	1	1	0	0	1	2	0	<b>17</b>
Area A	2	1	7	0	4	0	0	0	0	0	0	0	1	<b>15</b>
Infiltration	0	0	0	0	0	0	0	0	2	2	0	0	0	<b>4</b>
<b>Sub Total</b>	<b>8</b>	<b>6</b>	<b>26</b>	<b>1</b>	<b>19</b>	<b>4</b>	<b>3</b>	<b>3</b>	<b>2</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>1</b>	<b>82</b>
<b>Total</b>	<b>40</b>			<b>27</b>				<b>3</b>	<b>2</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>1</b>	<b>82</b>

<sup>a</sup> Where concrete vault has multiple functions, the vault is accounted for in the first appropriate cell encountered.

**Table 6-1****Leak Detection Location Summary by Operational Function  
Operable Unit 2 Groundwater Remedy**

<b>Location</b>	<b>Extraction Well Vault</b>	<b>Pipeline High Point Vent</b>	<b>Pipeline Low Point Drain</b>	<b>Pipeline Leak Detection</b>	<b>Pipeline Isolation Valve</b>	<b>Contained Area, not otherwise listed</b>	<b>Subtotal</b>
Groundwater Treatment Plant	0	0	0	0	0	2	<b>2</b>
Western Network	7	0	0	7	0	0	<b>14</b>
Eastern Network/Abrams	8	0	0	6	1	0	<b>15</b>
12 <sup>th</sup> Street Realignment	0	1	1	1	0	2	<b>5</b>
University Expansion	2	4	4	11	1	0	<b>22</b>
Landfill Expansion	2	0	1	4	1	0	<b>8</b>
Imjin/Abrams Expansion	3	1	1	5	1	0	<b>11</b>
Area A Expansion	0	1	2	7	0	0	<b>10</b>
Leak Detection Locations	<b>22</b>	<b>7</b>	<b>9</b>	<b>41</b>	<b>4</b>	<b>4</b>	<b>87</b>

**Table 6-1****Leak Detection Location Summary by Operational Function  
Operable Unit 2 Groundwater Remedy**

<b>Location</b>	<b>Extraction Well Vault</b>	<b>Pipeline High Point Vent</b>	<b>Pipeline Low Point Drain</b>	<b>Pipeline Leak Detection</b>	<b>Pipeline Isolation Valve</b>	<b>Contained Area, not otherwise listed</b>	<b>Subtotal</b>
Groundwater Treatment Plant	0	0	0	0	0	2	<b>2</b>
Western Network	7	0	0	7	0	0	<b>14</b>
Eastern Network/Abrams	8	0	0	6	1	0	<b>15</b>
12 <sup>th</sup> Street Realignment	0	1	1	1	0	2	<b>5</b>
University Expansion	2	4	4	11	1	0	<b>22</b>
Landfill Expansion	2	0	1	4	1	0	<b>8</b>
Imjin/Abrams Expansion	3	1	1	5	1	0	<b>11</b>
Area A Expansion	0	1	2	7	0	0	<b>10</b>
Leak Detection Locations	<b>22</b>	<b>7</b>	<b>9</b>	<b>41</b>	<b>4</b>	<b>4</b>	<b>87</b>



**Table 6-2**  
**Master Programmable Logic Controller Digital Inputs and Outputs**  
**Operable Unit 2 Groundwater Remedy**

Input/Output	PLC Address	ISA Tag	Description
Input	X0	LSH-281	Western leak detection system.
	X1	LSH-282	Eastern leak detection system.
	X2	PSH-922	Pump P-920 high discharge pressure.
	X3	PSH-327	Eastern extraction influent high pressure.
	X4	LSLL-691	Effluent tank low-low level switch.
	X5	LSL-691	Effluent tank low-level switch.
	X6	LSH-691	Effluent tank high level switch.
	X7	LSHH-691	Effluent tank high-high level switch.
	X10	PDSH-614	East-North GAC Vessel A high pressure drop
	X11	PSH-522	Pump P-520 high discharge pressure.
	X12	PSH-307	Western extraction influent high pressure.
	X13	N/A	Not used.
	X14	PSH-412	Pump P-410 high discharge pressure.
	X15	PSH-422	Pump P-420 high discharge pressure.
	X16	PSH-512	Pump P-510 high discharge pressure.
	X17	LSH-396	Building containment sump high level.
	X20	PSH-912	Pump P-910 high discharge pressure.
	X21	N/A	Not used.
	X22	PDSH-664	North-West GAC Vessel C high pressure drop.
	X23	PDSH-665	North-East GAC Vessel D high pressure drop.
	X24	N/A	System Start button on PLC panel door.
	X25	N/A	System Stop button on PLC panel door.
	X26	N/A	Acknowledge button on PLC panel door.
	X27	PDSH-615	East-South GAC vessel B high pressure drop.
	X30	ISH-201	OU2-01-A current switch run feedback.
	X31	ISH-202	OU2-02-A current switch run feedback.
	X32	ISH-203	OU2-03-A current switch run feedback.
	X33	LSH-395	Northern containment berm high level.
	X34	ISH-204	OU2-04-A current switch run feedback.
	X35	ISH-205	OU2-05-A current switch run feedback.
	X36	ISH-206	OU2-06-A current switch run feedback.
	X37	ISH-180	OU2-04-A current switch run feedback.

**Table 6-2**  
**Master Programmable Logic Controller Digital Inputs and Outputs**  
**Operable Unit 2 Groundwater Remedy**

Input/Output	PLC Address	ISA Tag	Description
<b>Output</b>	Y0	N/A	Autodialer Warning
	Y1	N/A	Autodialer Alarm.
	Y2	V-324	Opens eastern network pneumatic valve.
	Y3	V-304	Opens western network pneumatic valve.
	Y4	P-510	Starts P-510 VFD.
	Y5	P-520	Starts P-520 VFD.
	Y6	P-410	Starts P-410 VFD.
	Y7	P-420	Starts P-420 VFD.
	Y10	P-920	Starts P-910 VFD.
	Y11	P-910	Starts P-920 VFD.
	Y12	P-385	Starts backwash pump P-385.
	Y13	P-345	Starts backwash pump P-345.
	Y14	N/A	Not used.
	Y15	N/A	Buzzes buzzer on door of PLC panel.
	Y16	N/A	Starts EW-OU2-01-A thru EW-OU2-06-A.
	Y17	N/A	Starts EW-OU2-01-180 well.

**Table 6-3**

**SCADA Status (December 2001)  
Operable Unit 2 Groundwater Remedy**

Function <sup>a</sup>	Signal	HMI <sup>b</sup>	Digital/ Analog	Current Use	Remarks	Future Potential Use
Extraction Well Pump Operation (Number of data points)						
West (7)	Current switch	Yes	Digital	Current indication	Cannot automatically start individual wells	Elapsed time metering; trends at PC <sup>c</sup>
	Flow rate	No	---	Manual read only		
	Pressure switch	No	Digital	Local control	Switch activation stops local well pump	
	Vault water level switch	No	Digital	Local control	Switch activation stops local well pump	
	Well water level switch	No	Digital	Local control		
East (8)	Control switch (2)	Yes	Digital	Control activation	Cannot automatically start individual wells	
	Current switch	No	---	Not operational	Replace/rewire 8 current switches	Elapsed time metering; trends at PC
	Flow rate	No	---	Manual read only		
	Pressure switch	Yes	Digital	Local control	Switch activation stops local well pump	
	Vault water level switch	Yes	Digital	Local control	Switch activation stops local well pump	
	Well water level switch	No	Digital	Local control		
Abrams/Imjin (3)	Motor control	Yes	Digital	Starter activation	Can automatically start individual wells	Elapsed time metering; trends at PC
	Flow rate	Yes	Analog	PC data input	Verify calibration	Instantaneous, total flow, trends at PC
	Pressure switch	Yes	Digital	Local PLC control	Switch activation stops local well pump	Alarm and trends at PC
	Vault water level switch	Yes	Digital	Local PLC control	Switch activation stops local well pump	Alarm and trends at PC
	Well water transducer	Yes	Analog	PC data input	Used for local well control only. Verify calibration	Near realtime water level, trends at PC
Landfill (2)	Motor control	Yes	Digital	Starter activation	Can automatically start individual wells	Elapsed time metering; trends at PC
	Flow rate	Yes	Analog	PC data input	Verify calibration	Instantaneous, total flow, trends at PC
	Pressure switch	Yes	Digital	Local PLC control	Switch activation stops local well pump	Alarm and trends at PC
	Vault water level switch	Yes	Digital	Local PLC control	Switch activation stops local well pump	Alarm and trends at PC
	Well water transducer	Yes	Analog	PC data input	Used for local well control only. Verify calibration	Near realtime water level, trends at PC

**Table 6-3**

**SCADA Status (December 2001)  
Operable Unit 2 Groundwater Remedy**

Function	Signal	HMI	Digital/ Analog	Current Use	Remarks	Future Potential Use
University (2)	Motor control	Yes	Digital	Starter activation	Can automatically start individual wells	Elapsed time metering; trends at PC
	Flow rate	Yes	Analog	PC data input	Verify calibration	Instantaneous, total flow, trends at PC
	Pressure switch	Yes	Digital	Local PLC control	Switch activation stops local well pump	Alarm and trends at PC
	Vault water level switch	Yes	Digital	Local PLC control	Switch activation stops local well pump	Alarm and trends at PC
	Well water transducer	Yes	Analog	PC data input	Used for local well control only Verify calibration	Near realtime water level, trends at PC
Pipeline Leak Detection						
West	7 zones	Yes	Digital	PC data input/alarm	Located at GWTP	
East near GWTP	2 zones	Yes	Digital	PC data input/alarm	Located at GWTP	
12 <sup>th</sup> Street	5 zones	Yes	Digital	PC data input/alarm	Located at Abrams PLC panel	
Abrams	11 zones	Yes	Digital	PC data input/alarm	Located at Abrams PLC panel	
Abrams/Imjin	8 zones	Yes	Digital	PC data input/alarm	Located at Abrams/Imjin PLC panel	
Landfill	6 zones	Yes	Digital	PC data input/alarm	Located at Landfill PLC panel	
University	20 zones	Yes	Digital	PC data input/alarm	Located at University PLC panel	
Cell A	10 zones	Yes	Digital	PC data input/alarm	Located in Abrams PLC panel	
Groundwater Treatment Plant (Number of data points)						
Influent (2)	Flowmeter	Yes	Analog	PC data input	Verify calibration	Instantaneous, total flow, trends at PC
Effluent (3)	Flowmeter	Yes	Analog	PC data input		Instantaneous, total flow, trends at PC
Leak detection (2)	Containment area leak	Yes	Digital	PC data input/alarm		
Tank level (3)	Level indicator	Yes	Analog	SCADA input		Water level, trending at PC
Motor (6)	Variable speed controller	Yes	Analog	SCADA input		Elapsed time metering; trends at PC

<sup>a</sup> See Table 6-3, Master PLC Inputs/Outputs for other digital detail. This table was updated to reflect Year 2002 12<sup>th</sup> Street Realignment details only.


<sup>b</sup> Human-machine interface

<sup>c</sup> Personal computer

## FIGURES








**LEGEND**

- EXTRACTION WELL (EW)
- INJECTION WELL (IW)
- INFILTRATION GALLERY (INF)
- ← EXTRACTION PIPELINE (ARROW INDICATES FLOW DIRECTION)
- ← INJECTION PIPELINE (ARROW INDICATES FLOW DIRECTION)
- - - SYSTEM EXPANSION PIPELINE (ARROW INDICATES FLOW DIRECTION)
- - - SITES 2 AND 12 TRICHLOROETHENE (TCE) ISOCONCENTRATION CONTOUR IN MICROGRAMS PER LITER (ug/L)
- OPERABLE UNIT 2 TRICHLOROETHENE (TCE) ISOCONCENTRATION CONTOUR IN MICROGRAMS PER LITER (ug/L)




FEET




NOTE:  
TRICHLOROETHENE ISOCONCENTRATION CONTOURS  
ARE BASED ON SEPTEMBER 2000 ANALYTICAL DATA.  
THE CONTOURS GENERALLY REPRESENT CONDITIONS  
EXISTING PRIOR TO STEADYSTATE PUMPING OF THE  
OPERABLE UNIT 2 SYSTEM EXPANSION WELLS.  
OTHER VISUAL INTERPRETATIONS MAY BE POSSIBLE.

<b>IT CORPORATION</b>		DEPARTMENT OF THE ARMY SACRAMENTO DISTRICT, CORPS OF ENGINEERS SACRAMENTO, CALIFORNIA	
DESIGNED: PCK	FORT ORD		CALIFORNIA
DRAWN: KAB	<b>FIGURE 1-3</b> <b>PIPELINE ROUTING AND TRICHLOROETHENE PLUME</b> <b>UPPER 180-FOOT AQUIFER</b> <b>OPERABLE UNIT 2 GROUNDWATER REMEDY</b> <b>FORMER FORT ORD, CALIFORNIA</b>		
CHECKED:			
SUBMITTED:	DATE APPROVED:	SCALE:	SPEC. No.
		SHEET	FILE No. N:/cad/dwg/FortOrd/ Fort_Ord_GIS/TCEupper180.mxd






- LEGEND**
- EXTRACTION WELL (EW)
  - INJECTION WELL (IW)
  - INFILTRATION GALLERY (INF)
  - EXTRACTION PIPELINE (ARROW INDICATES FLOW DIRECTION)
  - INJECTION PIPELINE (ARROW INDICATES FLOW DIRECTION)
  - - - SYSTEM EXPANSION PIPELINE (ARROW INDICATES FLOW DIRECTION)
  - - - SITES 2 AND 12 TRICHLOROETHENE (TCE) ISOCONCENTRATION CONTOUR IN MICROGRAMS PER LITER (ug/L)
  - OPERABLE UNIT 2 TRICHLOROETHENE (TCE) ISOCONCENTRATION CONTOUR IN MICROGRAMS PER LITER (ug/L)



NOTE:  
TRICHLOROETHENE ISOCONCENTRATION CONTOURS ARE BASED ON SEPTEMBER 2000 ANALYTICAL DATA. THE CONTOURS GENERALLY REPRESENT CONDITIONS EXISTING PRIOR TO STEADYSTATE PUMPING OF THE OPERABLE UNIT 2 SYSTEM EXPANSION WELLS. OTHER VISUAL INTERPRETATIONS MAY BE POSSIBLE.

<b>IT CORPORATION</b>		DEPARTMENT OF THE ARMY SACRAMENTO DISTRICT, CORPS OF ENGINEERS SACRAMENTO, CALIFORNIA	
DESIGNED: PCK	FORT ORD		CALIFORNIA
DRAWN: KAB	<b>FIGURE 1-2</b> <b>PIPELINE ROUTING AND TRICHLOROETHENE PLUME</b> <b>A-AQUIFER</b> <b>OPERABLE UNIT 2 GROUNDWATER REMEDY</b> <b>FORMER FORT ORD, CALIFORNIA</b>		
CHECKED:			
SUBMITTED:	DATE APPROVED:	SCALE:	SPEC. No.
		SHEET	FILE No. N:\cad\dwg\FortOrd\Fort_Ord_GIS/TCEa_aquifer.mxd





### LEGEND

GAC

GRANULAR ACTIVATED CARBON

TS-OU2-EFF

SAMPLE LOCATION/SAMPLE IDENTIFICATION



FLOW SPLITTER



FLOW PATH

### ARRANGEMENT SHOWN

- ☐ GAC PARALLEL FLOW
- ☒ GAC SERIES, SOUTH LEAD
- ☐ GAC SERIES, NORTH LEAD
- ☐ GAC SERIES, WEST LEAD
- ☒ GAC SERIES, EAST LEAD

REVISION	DATE	DESCRIPTION	BY	BY
		4005 FORT CHICAGO HIGHWAY CONCORD, CALIFORNIA 94520 (925) 288-9898		
DESIGNED: R. HAYASHI		DEPARTMENT OF THE ARMY SACRAMENTO DISTRICT, CORPS OF ENGINEERS SACRAMENTO, CALIFORNIA		
DRAWN: TRS 12/4/01		FORT ORD FIGURE 2-1 CALIFORNIA		
CHECKED:		WATER FLOW AND TREATMENT PLANT SAMPLING SCHEMATIC OPERABLE UNIT 2 GROUNDWATER REMEDY		
APPROVED:		DATE APPROVED:		SCALE: AS NOTED SHEET: 1 OF 1
				SPEC No. FILE No. 783751-A43



## **APPENDIX A**

### **As-Built Construction Drawings**

Note: This Appendix includes only the list of As-built Construction Drawings. The actual drawings are included in the *Draft Final Construction Drawings, Operable Unit 2 Groundwater Remedy System Expansion, Fort Ord, California (IT, 2001b)*.

A complete set of full-size drawings is maintained at the GWTP and at the USACE and IT offices.

## ***Appendix A List of Drawings***

---

PROJECT NUMBER	SHEET NUMBER	REVISION NUMBER	TITLE
<b><u>Operable Unit 2 Expansion As-Built Construction Drawings (41)</u></b>			
<b><u>General (G)</u></b>			
783751-E9	G-1	0	Cover Sheet
837769-E9	G-2	1	Drawing List and Location Map
783751-E23	G-3	0	Standard Symbols and Legends
783751-E7	G-4	0	Trichloroethene Plume, Upper 180-foot Aquifer
783751-E8	G-5	0	Trichloroethene Plume, A Aquifer
<b><u>Process Civil (C)</u></b>			
783751- E61	C-1	0	Process Flow Diagram, No. 1
783751- E62	C-2	0	Process Flow Diagram, No. 2
783751- E17	C-3	0	Piping and Instrumentation Diagram, No. 1
783751- E86	C-4	0	Piping and Instrumentation Diagram, No. 2
783751- E87	C-5	0	Piping and Instrumentation Diagram, No. 3
783751- E18	C-6	0	Piping and Instrumentation Diagram, No. 4
783751- E19	C-7	0	Piping and Instrumentation Diagram, No. 5
783751- E21	C-8	0	Piping and Instrumentation Diagram, No. 6
783751- E5	C-9	0	Treatment Plant Location and Layout
783751- E38	C-10	0	Pipe Trench Details and Well Vault Details
783751- E57	C-11	0	Concrete Floor and Stair Details
783751- E55	C-12	0	Concrete and Sump Details
837769- E002	C-13	0	Pipeline Plan and Profile View No. 1
837769- E003	C-14	0	Pipeline Plan and Profile View No. 2
837769- E004	C-15	0	Pipe Trench and Utility Vault Details No. 1
837769- E005	C-16	0	Pipe Trench and Utility Vault Details No. 2
<b><u>Utility (U)</u></b>			
783751-E39	U-1	0	Utility Flow Diagram
<b><u>Mechanical (M)</u></b>			
783751- E37	M-1	0	Extraction Well Details
783751- E6	M-2	0	Mechanical Plan
783751- E13	M-3	0	Mechanical Sections and Details No. 1
783751- E58	M-4	0	Mechanical Sections and Details No. 2
783751- E10	M-5	0	Infiltration Gallery Details
<b><u>Electrical (E)</u></b>			
837769- E001	E-1	1	Electrical Site Plan and Vault Layout
783751- E26	E-2	0	Main Cell Electrical Plan
783751- E27	E-3	0	Landfill Cell Electrical Plan
783751- E501	E-4	0	University Cell Electrical Plan
783751- E505	E-5	0	Treatment Plant PLC Terminal Wiring

## ***Appendix A List of Drawings (Continued)***

---

PROJECT NUMBER	SHEET NUMBER	REVISION NUMBER	TITLE
-------------------	-----------------	--------------------	-------

### **Electrical (E) (Continued)**

783751- E506	E-6	0	Power and Instrumentation Plan
783751- E507	E-7	0	Motor Schematics and Details
783751- E508	E-8	0	Miscellaneous Electrical Details
783751- E504	E-9	0	Treatment Plant PLC Terminal Wiring
783751- E503	E-10	0	Treatment Plant PLC Diagram No. 1
783751- E511	E-11	0	Treatment Plant PLC Diagram No. 2
783751- E512	E-12	0	Treatment Plant PLC Diagram No. 3
783751- E88	E-13	0	Abrams/Imjin Cell PLC Diagram No. 1
783751- E89	E-14	0	Abrams/Imjin Cell PLC Diagram No. 2
783751- E90	E-15	0	Landfill Cell PLC Diagram No. 1
783751- E91	E-16	0	Landfill Cell PLC Diagram No. 2
783751- E92	E-17	0	University Cell PLC Diagram No. 1
783751- E93	E-18	0	University Cell PLC Diagram No. 2
837769- E006	E-19	0	Abrams Power and Equipment Layout
837769- E007	E-20	0	Abrams PLC Diagram No. 1
837769- E008	E-21	0	Abrams PLC Diagram No. 2

### **Bestor Operable Unit 2 Original Remedy As-Built Survey Drawings (3)**

5562.02	1 of 3	(General Layout and Eastern Injection)
5562.02	2 of 3	(Eastern Extraction and GWTP/Northwestern Injection/Northern Part of Western Extraction)
5562.02	3 of 3	(Southwestern Injection/Southern Part of Western Extraction)

### **Bestor Sites 2/12 Remedy As-Built Survey Drawings (3)**

5562.04	1 of 1	Site 2 (Injection Wells and Infiltration Galleries)
5562.04	1 of 2	Site 12 (Extraction Wells and GWTP)
5562.04	2 of 2	Site 12 (Excess Water Line from OU2)

### **Bestor Operable Unit 2 Expansion As-Built Survey Drawings (9)**

5562.02	1 of 9	(General Layout)
5562.02	2 of 9	(Cell A Pipeline)
5562.02	3 of 9	(Imjin Crossing and Branches to Abrams/Imjin, Landfill, and University Pipelines)
5562.02	4 of 9	(Abrams/Imjin Pipeline/Extraction Wells and Western Portion of University Pipeline)
5562.02	5 of 9	(Landfill Pipeline/Extraction Wells)
5562.02	6 of 9	(Middle Portion of University Pipeline)
5562.02	7 of 9	(Eastern Portion of University Pipeline and Extraction Wells)
5562.02	8 of 9	(Northwest and Southwest Injection Wells/ Infiltration Galleries)
5562.02	9 of 9	(GWTP Property Lines and Containment Area Layouts)

## **APPENDIX B**

### Vendor Submittals (Index Only)

Note: This Appendix contains the vendor submittal index only.

The complete vendor submittal appendix is maintained at the GWTP and in the USACE and IT offices.

Appendix B  
VENDOR SUBMITTAL INDEX  
Operable Unit 2 Groundwater Remedy  
Former Fort Ord, California

Section	Equipment	Vendor	Manufacturer/Supplier	Submittal	Subject	Remarks
<b>Vol. 1</b>						
1.0	Anchor Bolts (at Well Vaults and Building Piping & Equipment)	Clement Support Services	Powers Fasteners, Inc. Powers Fasteners, Inc. Powers Fasteners, Inc. Powers Fasteners, Inc. Powers Fasteners, Inc.	SD-01 SD-06 SD-06 SD-06 SD-06	MSDS Power-Fast Epoxy Injection Gel Product Description Material Properties Dispensing Guidelines Installation Guidelines	
2.0	Asphalt Paving Repair (at Road Crossings & GWTP Driveways)	Monterey Peninsula Engineering	Graniterock	SD-05	1/2 inch Asphaltic Concrete Mix Design	
3.0	Bag Filter and Bags	Filter Specialists, Inc.	Filter Specialists, Inc. Filter Specialists, Inc. Filter Specialists, Inc. Filter Specialists, Inc. Filter Specialists, Inc.	SD-01 SD-02 SD-02 SD-06 SD-19	Bag Filter Housing Data Sheet Bag Filter Catalogue Cut Reorder Bag Filter Information Installation Instructions O&M Manual	With O&M
4.0	Banding, S/S	Fastenal	Band-It	SD-01	Metals Data Sheet	316 Stainless Steel
5.0	Biological Survey (for Extraction Wells & Pipeline Route)	Harding Lawson Associates	Harding Lawson Associates Harding Lawson Associates	SD-09 SD-09	OU2 Pipeline Expansion Report Follow-up OU2 Pipeline Expansion	With 11x17 color plate 07/05/00
6.0	Cartridge Filter	Filter Specialists, Inc.	Filter Specialists, Inc. Filter Specialists, Inc. Filter Specialists, Inc. Filter Specialists, Inc. Filter Specialists, Inc.	SD-01 SD-02 SD-02 SD-06 SD-19	Multi-Cartridge Housing Data Sheet Multi-Cartridge Filter Catalogue Cut Reorder Cartridge Filter Information Installation Instructions O&M Manual	With O&M
7.0	Chemical Removal and Chemical Tank Decontamination	Philip Industrial Services	Allwaste / Philip Allwaste / Philip Allwaste / Philip Allwaste / Philip	SD-18 SD-18 SD-18 SD-18	4,000 gallons 25% sodium hydroxide 5 poly drums 98% sulfuric acid 3 poly drums 50% hydrogen peroxide 12 poly drums 50% hydrogen peroxide	01/15/00 01/22/00 01/22/00 01/29/00
8.0	Concrete, Cast-in-Place	IT Corporation	Larsen Products Corp IT Corporation Graniterock Graniterock D&M Consulting Engineers, Inc. D&M Consulting Engineers, Inc.	SD-02 SD-04 SD-05 SD-05 SD-10 SD-12	Weld-Crete Bonding Agent Truck Pad Profile & Section Drawings 3,000 psi Concrete Design Mixes 4,000 psi Concrete Design Mixes N Housekeeping Pad Strength Results Wye Vault Floor Slump Results	With e-mail approval Stamped Three Mixes Three Mixes Exception with IT eval Exception with IT eval

Appendix B  
VENDOR SUBMITTAL INDEX  
Operable Unit 2 Groundwater Remedy  
Former Fort Ord, California

Section	Equipment	Vendor	Manufacturer/Supplier	Submittal	Subject	Remarks
9.0	Concrete Pull Boxes, Traffic Rated	Christy Concrete Products, Inc.	Christy Concrete Products, Inc. Christy Concrete Products, Inc. Christy Concrete Products, Inc.	SD-04 SD-04 SD-04	B1017 Box H/20 Loading B1730 Box H/20 Loading B24" x 36" Box H/20 Loading	With extension With extension With extension
10.0	Concrete Pull Box Lids Concrete Reinforcement (Rebar)	Valley Fabrication	Valley Fabrication	SD-01 SD-04	Procurement Requisition Rebar Location	Holes Drilled by Field See Cast Concrete As-builts
11.0	Concrete Repair (Cast-in-Place Surfaces)	White Cap	Burke Burke Burke Burke Burke Lyons Manufacturing, Inc. Lyons Manufacturing, Inc.	SD-01 SD-01 SD-01 SD-01 SD-01 SD-01 SD-01	MSDS BurkEpoxy Mortar - A 0.3 CF MSDS BurkEpoxy Mortar - B MSDS BurkEpoxy Mortar - C Multi-Purpose Grout Product Info MSDS Multi-Purpose Grout Patchcrete Product Information MSDS Patchcrete #1000	43210 4322 4323 03600 7030 4/99 02/15/92
12.0	Concrete Replacement (Curbs, Gutters & Sidewalks)	Monterey Peninsula Engineering	Graniterock Graniterock	SD-05 SD-05	3/8 inch Concrete Pump Mix Design 3/4 inch Concrete Mix Design	
13.0	Concrete Vaults & Lids: A-Aquifer Extraction Well  180-ft Aquifer Extraction Well   High & Low Point / Leak Detect  Infiltration Gallery   Infiltration Valve  Isolation Valve 12th Street Vault No. 31 and 35	Santa Rosa Cast Products  Santa Rosa Cast Products  Santa Rosa Cast Products  Santa Rosa Cast Products  Santa Rosa Cast Products  Santa Rosa Cast Products  Santa Rosa Cast Products  Utility Vault Company	Santa Rosa Cast Products Nystrom Building Products Santa Rosa Cast Products Nystrom Building Products Santa Rosa Cast Products Santa Rosa Cast Products Santa Rosa Cast Products Nystrom Building Products Xypex Chemical Corp MA Industries Santa Rosa Cast Products Nystrom Building Products Santa Rosa Cast Products Utility Vault Company Nystrom Building Products	SD-04 SD-04 SD-04 SD-04 SD-04 SD-04 SD-04 SD-04 SD-04 SD-02 SD-02 SD-04 SD-04 SD-04 SD-04 SD-04	6'x6' Extraction Well Vault, 14,000 lbs 6'x6' Vault Hatches 6'x9' Extraction Well Vault, 22,000 lbs 6'x9' Vault Hatches Extraction Well Vault Field Pour Collar Cover to Vault Wall Detail 2'x2' HP, LP, Leak Detection Vaults 2'x2' Vault Hatches 4'x4' Infiltration Gallery Vault INF Vault Hatches Concrete Waterproofing Specs Polypropylene Step Information 4'x8' Valve Vault, 16,500 lbs 4'x8' Vault Hatches 4' Diam Manway Vault Assembly 6'x6' Mechanical Connection Vault 6'x6' Vault Hatches	3 Req'd, 01/24/00 01/23/00 4 Req'd, Rev 03/15/00 01/23/00 03/28/00 Dwg X, 03/15/00 41 Req'd, Rev 02/10/00 01/23/00 2 Req'd, Rev 03/16/00 03/16/00 Pgs 3, 4, 5, 8 PS-1-PF 2 Req'd, 01/24/00 01/23/00 3 Req'd, Sketch 2 locations, installed in 2002 2 locations, installed in 2002



Appendix B  
VENDOR SUBMITTAL INDEX  
Operable Unit 2 Groundwater Remedy  
Former Fort Ord, California

Section	Equipment	Vendor	Manufacturer/Supplier	Submittal	Subject	Remarks
	General Information		Henry Company Nystrom Building Products Nystrom Building Products Nystrom Building Products Nystrom Building Products Nystrom Building Products Santa Rosa Cast Products	SD-02 SD-05 SD-05 SD-06 SD-13 SD-13 SD-13	Ram-Nek Flexible Plastic Gaskets BGA-H20 Features & Specifications FGA-H20 Features & Specifications Installation Instructions for Hatches Aluminum Lid Warranty 5 Year Performance Standard Certificate of Compliance	For 2-Section Vaults 24"x24" Hatches All Other Hatches  03/16/00 03/16/00 SF-27
14.0	Concrete Vault Bolts, Tamper Proof (at Christy Boxes)	Pentagon Aerospace Group, Inc.	Pentagon Aerospace Group, Inc.	SD-02	No information	
15.0	Concrete Vault Lids: Wye Vault	Nystrom Building Products	Nystrom Building Products Nystrom Building Products Nystrom Building Products Nystrom Building Products	SD-01 SD-04 SD-04 SD-04	Performance Data Wye Vault Layout Wye Vault Opening Detail Wye Vault Beam Support Detail	
	Original OU2 EW & IW Vaults		Nystrom Building Products	SD-04	OU2 4'x5' Opening Detail	
16.0	Conduit, Buried	Consolidated Electrical Supply	PWPipe	SD-01	Specifications & Data	Conduit & Fittings
17.0	Control Valve (Proposed Future Wye Vault Addition)	Bermad	Bermad Bermad	SD-01 SD-02	Description / Operation Control 710-01 710 Electrical Remote Control Valve	Electric Remote Control
18.0	Drilling Site Clearance	Subdynamic Locating Services	Subdynamics Subdynamics	SD-04 SD-12	Diagrams Where Utilities Located Field Report / Findings	2 Locations 7 Extraction & 2 Infiltration
19.0	Electrical & Instrumentation Cable	Consolidated Electrical Supply	Futronix Systems  General Cable	SD-05  SD-05	16 AWG Twisted Pair Control Cable Other Control, Feeder, Leak Detection & Power Cables, Type THHN	FX1602SVNTC  Pg 15

Appendix B  
VENDOR SUBMITTAL INDEX  
Operable Unit 2 Groundwater Remedy  
Former Fort Ord, California

Section	Equipment	Vendor	Manufacturer/Supplier	Submittal	Subject	Remarks
20.0	Electrical Subcontract (EW PLCs and Transformer Pads)	Superior Electric	Central Wholesale Elect Distrib Gaylord Mfg Co PG&E  Circle AW Circle AW PG&E Siemens Electrical Products Siemens Electrical Products Siemens Energy & Automation Siemens Energy & Automation Siemens Energy & Automation Acme Transformer Acme Transformer National Electrical Mfg Assn  Acme Transformer National Electrical Mfg Assn	SD-02 SD-02 SD-02 SD-02 SD-02 SD-02 SD-02 SD-02 SD-02 SD-02 SD-02 SD-04 SD-06 SD-06  SD-19 SD-19	Transmittal Letter Type 4X 2-door Floor Standing Encl Pad for Pad-Mounted Transformer Dry-Type Distribution Transformer Test Block Bypass MTBPMS15 Test Block Bypass MTBP Series Concrete Pad for 3-Phase Transformer Special Safety Switches / Non-metal Special Safety Switches / Non-metal 480/277 Volt Panel A 480/277 Volt Panel B 240/120 Volt Panel C EW PLC Electric Connection Diagrams EW PLC Transformer Instructions EW PLC Panelboard Instructions Installation and O&M of Dry Type Transformers, at EW PLC EW PLC Panelboard Instructions for Installation, Operation, Maintenance	05/10/00 "A" -- N4XFLDDS "B" 064309 pg 3/5, Rev 4 "C" -- pg 9 "D" -- pg 60 "E" -- pg 38 "F" -- 045292 pg 5/5, Rev 3 "G1" Speedfax 2000 pg 19 "G1" Speedfax 2000 pg 19 "H" "I" "K"  B-111703-C See Transformer O&M See Panelboard O&M Instruction Sheet A1 Part A- 701953-A  NEMA Pub PB-1.1-1996
	Epoxy Paint; for Concrete					See Paint, Epoxy
21.0	Eyewash Station	IT Corporation	PM Engineer Aug 2000	SD-05	Changes to Emergency Shower & Eyewash Stds, ANSI Z358.1-1998	Pgs 26 & 27
22.0	Fencing (at EW PLC Panels)	Peninsula Fence Company	PDS Fence Products American Tube Company, Inc. Master Fexce Fittings, Inc.	SD-02 SD-05 SD-05	Privacy Decorative Slating Specifications for TUF-40 Tubing Material Fencing Std Specs G-82	02830 / ABP, # 5044 Rev. 5/90 Form: 1034
23.0	Fire Alarm System (Original at GWTP Building)	Fire-Lite Alarms, Inc.	Fire-Lite Alarms, Inc. Fire-Lite Alarms, Inc. Fire-Lite Alarms, Inc.  Fire-Lite Alarms, Inc.	SD-04 SD-06 SD-13  SD-19	DIM-485 Product Installation Dwg Programming Instructions Limited Warranty Program, Install, Maintenance and Operations Manual	#50380 Rev A With O&M Manual   #51003 Rev A1
24.0	Flowmeter	SantaFe Industrial Products	ABB Water Meters, Inc. ABB Water Meters, Inc. ABB Water Meters, Inc. ABB Water Meters, Inc.	SD-02 SD-02 SD-06 SD-19	Catalog Cuts, 1-3" & 4-8" sizes Catalog Cut Electronic Register (ER) ER Programming ER User Manual	See User Manual

Appendix B  
VENDOR SUBMITTAL INDEX  
Operable Unit 2 Groundwater Remedy  
Former Fort Ord, California

[illegible]

Appendix B  
VENDOR SUBMITTAL INDEX  
Operable Unit 2 Groundwater Remedy  
Former Fort Ord, California

Section	Equipment	Vendor	Manufacturer/Supplier	Submittal	Subject	Remarks
<b>Vol. II</b>						
28.0	Granular Activated Carbon (GAC), Refurbished Calgon Units	US Filter/Westates	Plasite Protective Coatings, Inc. Carboline Co. Carboline Co. Plasite Protective Coatings, Inc. IT Corporation IT Corporation IT Corporation Carboline Co. Plasite Protective Coatings, Inc. Plasite Protective Coatings, Inc.	SD-01 SD-01 SD-01 SD-01 SD-04 SD-05 SD-05 SD-06 SD-06 SD-06	Plasguard 4110 Product Data MSDS Carboline 893, Parts A & B MSDS Carbothane 134 HG, Part A MSDS Plasite 4110, Parts A, B & C Modified Leg Cross Brace Detail Seismic Calcs for Supports Anchor Bolt Drilling Calculation Product Data Sheet Technical Bulletin Plasite Specifications	Formerly Plasite 4110 Exterior Primer Exterior Topcoat Federal Blue For Interior Recoating 9/11/00 (8-1/2 x 11) 5 + 1 page, Stamped 2/23/01 Carbothane 134 HG Plasite 4110 PA-3
29.0	Grating, Trench and Sump	McNichols Company	IT Corporation McNichols Company McNichols Company	SD-01 SD-02 SD-02	Description Safe-T-Span 1" x 1-1/2" for Trenches Safe-T-Span 2" x 1" for Sumps	STSI-6010-MISOFR STST-5020-MISOFR
30.0	Grating Clips	Mercury Metals	IT Corporation IT Corporation	SD-01 SD-05	Description Design Calculations	
31.0	Grout, Non-Shrink	White Cap	Sika Corporation Sika Corporation	SD-01 SD-05/06	MSDS Sikaflex - 1a Technical Information & Instructions	09/09/99 3/00
32.0	Handrails	Tubular Specialties Mfg	Tubular Specialties Mfg	SD-04 SD-04 SD-04 SD-04 SD-04	Ramp Barrier Pipe Chase Railing NE North Containment Railing NW North Containment Railing NE & SE East Containment Railing	Sheet 1 of 5 Sheet 2 of 5 Sheet 3 of 5 Sheet 4 of 5 Sheet 5 of 5
33.0	Ladders, (INF and Original OU2 EW / IW Vaults)	Ladder Man	Ladder Man Strongwell	SD-02 SD-04	Series 399 Fixed FRP Ladder Drawings #1/2/3-B-18277	11 x 17
34.0	Leak Detection System	Superior Electric	Bestor Universal Sensors & Devices Universal Sensors & Devices	SD-04 SD-06 SD-19	Leak Detection Zones Special Installation Sensor Package Operation Instruction Manual	See Survey, OU2 Expan LALS-2 Dual Liquid LA-08 System
35.0	Level Probe, EW-OU2-06-180	Water Development Corp	Warrick Controls IT Corporation	SD-02 SD-06	Catalog Cut Installation Instructions	
36.0	Level Switches 12th Street Realignment 12th Street Realignment	SantaFe Industrial Products Gems Sensors Flowline, Inc.	Gems Sensors Gems Sensors Flowline, Inc.	SD-02 SD-02 SD-02	Catalog Cut Stainless steel float Vertical buoyancy float	Installed in 2002 Installed in 2002

Appendix B  
VENDOR SUBMITTAL INDEX  
Operable Unit 2 Groundwater Remedy  
Former Fort Ord, California

[illegible]

Appendix B  
VENDOR SUBMITTAL INDEX  
Operable Unit 2 Groundwater Remedy  
Former Fort Ord, California

Section	Equipment	Vendor	Manufacturer/Supplier	Submittal	Subject	Remarks
45.0	Pressure Transducer, Industrial Influent Manifold (NOT INSTALLED)	SantaFe Industrial Products	KPSI KPSI KPSI KPSI KPSI	SD-02 SD-04 SD-05 SD-06 SD-10 SD-19	Series 27, 28 & 30 Industrial Certification Drawings Series 27, 28 & 30 Specifications Installation Instructions Calibration Reports O&M Manual	See Submersible, below  See Submersible, below  See Submersible, below
46.0	Pressure Transducer, Submersible EW-OU2-03/04/05-180 EW-OU2-14/15/16-A MW-OU2-78-180	SantaFe Industrial Products	KPSI KPSI KPSI KPSI KPSI KPSI	SD-02 SD-04 SD-05 SD-06 SD-10 SD-19	Series 300S Small Bore Submersible Certification Drawings Series 300S Specifications Installation Instructions Calibration Reports O&M Manual	Dwg #600229, 2 pages  With O&M 7 items
47.0	Programmable Logic Controller (PLC), (at new EWs): Level Switch Motor Saver Motor Starter  PLC Module Panel  Power Supply, 24 v DC Power Transformer, 120 v AC	Superior Electric	Gems Sensors SymCon, Inc Allen-Bradley Allen-Bradley Allen-Bradley PLC Direct Gaylord Mfg. Co. Gaylord Mfg. Co. Facts Engineering Inc. Acme Transformer Acme Transformer	SD-06 SD-06 SD-04 SD-06 SD-06 SD-06 SD-02 SD-06 SD-02 SD-04 SD-19	Instructions Single-Station Installation Instructions Magnetic Motor Controller Dwg Heater Element Selection Table Heater Element Selection Table DL205 Installation & Safety Cut Sheet Instructions FA-24PS, 24 volt DC Electrical Conneciton Diagrams Installation, Operation & Maintenance	Bulletin 72947 Model 355 40050-502-1-H 40050-503-02(D) 40052-284-02(B) April 1994  October 1999 B-111703-C A-701953-A
48.0	PLC Modifications (GWTP)	Superior Electric	PLC Direct Square D Square D Superior Electric Automation Direct  Direct Soft Direct Soft 32 Direct Soft 32 Direct Logic  Direct Logic Square D	SD-01 SD-06 SD-06 SD-08 SD-13  SD-19 SD-19 SD-19 SD-19  SD-19 SD-19	DL 405 Safety Considerations Instruction Class 9001 Contact Block Instruction Oil-Tight Push Button Op Guarantee for PLC Modifications Standard License  DDE Server User Manual Program Software User Manual Program Software Quick-Start Manual DL 405 User Manual  DL405 Analog I/O Modules Instruction Bulletin Selector Switches	7942030-1 Jan 1994 30072-100-02B 30072-100-01F 02/14/00  DA-DDE-M, cover Manual at GWTP Cover, manual at GWTP Cover, manual at GWTP Cover, manual at GWTP D4-ANLG-M, cover Manual at GWTP 65013-002-18M, 10/97

Appendix B  
VENDOR SUBMITTAL INDEX  
Operable Unit 2 Groundwater Remedy  
Former Fort Ord, California

Section	Equipment	Vendor	Manufacturer/Supplier	Submittal	Subject	Remarks
49.0	PLC Software, (New EW PLCs)	PLC Direct	PLC Direct	SD-06	Direct Soft QuickStart Programming Manual	QS-DSOFT-M Cover and index only
50.0	Pump, Centrifugal, Backwash P - 385	SantaFe Industrial Products	US Motors Ingersoll-Dresser Pumps Ingersoll-Dresser Pumps Ingersoll-Dresser Pumps Ingersoll-Dresser Pumps Ingersoll-Dresser Pumps Ingersoll-Dresser Pumps Ingersoll-Dresser Pumps Ingersoll-Dresser Pumps US Motors Santa Fe Industrial Products Ingersoll-Dresser Pumps Ingersoll-Dresser Pumps US Motors	SD-01 SD-02 SD-02 SD-02 SD-04 SD-05 SD-05 SD-05 SD-05 SD-06 SD-06 SD-07 SD-19 SD-19 SD-19	Name Plate Information Type GRP GRP A Closer Look GRP Details General Arrangement Drawing Construction Data Sheet Hydraulic Data Sheet Typical GRP Noise Data Pump Installation Instructions Motor Installation Instructions Schedule Spare Parts List Pump O&M Manual Motor O&M Manual	0572-W0000, Rev. A  With O&M manual With O&M manual
51.0	Pump, Centrifugal, Injection P - 510, P - 520	SantaFe Industrial Products	US Motors Ingersoll-Dresser Pumps Ingersoll-Dresser Pumps  CJI Process Systems Ingersoll-Dresser Pumps Ingersoll-Dresser Pumps Santa Fe Industrial Products Santa Fe Industrial Products Flowserve Division of I-D Pumps US Motors	SD-01 SD-02 SD-04  SD-04 SD-05 SD-05 SD-05 SD-07 SD-19 SD-19	Name Plate Information Type D-800 Centrifugal Pumps General Arrangement Drawing Base Plate, Motor Mount & Coupling Guard Hydraulic Data Sheet Typical D-814 Noise Data Motor Noise Data Schedule D814 Pump Installation and O&M Motor O&M Manual	2012-4 Page 11  4x3x8F D-800 2012-5 Page 11 Fax 5/2/00  CPK 1123A-050100_EN
52.0	Pump, Submersible EW-OU2-03/04/05/06-180 EW-OU2-14/15/16-A	Pac Machine Co., Inc.	Franklin Electric Grundfos Reed's Manufacturing & Pump Co. Grundfos Franklin Electric Franklin Electric Pac Machine Co., Inc. Grundfos Franklin Electric	SD-01 SD-02 SD-04 SD-06 SD-06 SD-06 SD-08 SD-19 SD-19	Replacement Motor Data Pump Curves & Technical Data Pump Well Sleeve Drawing Installation Instructions, Pumps Installation Instructions, Motors Replacement Motor Instructions Pump Guarantee O&M Manual, S/S Pumps O&M Manual, Submersible Motors	EW-OU2-05 & -06-180 25S30-15 & 150S200-10 8-1/2 x 11 With O&M manual With O&M manual

Appendix B  
VENDOR SUBMITTAL INDEX  
Operable Unit 2 Groundwater Remedy  
Former Fort Ord, California

Section	Equipment	Vendor	Manufacturer/Supplier	Submittal	Subject	Remarks
<b>Vol III</b>						
53.0	Pump, Sump (East, North, GWTP) P-375, P-395, P-495	SantaFe Industrial Products	Goulds Pumps SJE Rhombus Goulds Pumps SJE Rhombus Santa Fe Industrial Products SJE Rhombus Lowara, A Goulds Pump Company	SD-02 SD-02 SD-06 SD-06 SD-07 SD-13 SD-19	Series 1DW 1-1/2" Dewatering Pump Super Single Pump Switch Installation Instructions Installation Instructions Schedule Pump Switch Warranty O&M Manual	With O&M  Installation and Usage
	Rupture Disk					See GAC, New
54.0	Static Mixer, Influent	SolarChem	(No SolarChem Info or Drawings)	SD-05	Static Mixer Modification	ID: Static Mixer M-186 in Original OU2 UV System
	Sump Design					See As-built Drawings
55.0	Sump Liners	B.H. Tank Works	IT Corporation	SD-04	Stainless Steel Sump	Sketch
56.0	Supervisory Control and Data Acquisition (SCADA): Ethernet Program  Antenna      Photovoltaic (PV / Solar Power)	Various	Automation Direct  PolyPhaser Corporation  Radiall / Larson  Maxrad, Inc. US Consumer Product Safety Com.  Data-Linc Group  Data-Linc Group Data-Linc Group Data-Linc Group Solar Depot, Inc. Solar Depot, Inc. Unirac, Inc. Morningstar Corporation	SD-06  SD-06 & 13 SD-01 & 06 SD-06 & 13 SD-06 SD-01 & 04 SD-01 & 04 SD-04 SD-06 SD-06 SD-02 SD-04 SD-06 SD-19	Information Ethernet Communications IS-B50 Series Impulse Suppressor Safety, Installation & Warranty YA Series Yagi Direction Antenna Specifications and Installation MBS-800 Base Station Adapter Kit Installation and Warranty Antenna Safety Information Yagi Directional Antenna Specifications and Dimensions Omni Directional Antenna Specifications and Dimensions Antenna / Coaxial Cable System Ethernet Radio Modem User's Guide Radio Modem User's Manual Catalog Component Information 240 Wp Photovoltaic Module Assembly Instructions Prostar PV Operator's Manual	H24-ECOM-M, Index Only  Eng-F-016 12/97  12/97 5192.5000  MIS-MBSADAPTER 1982-522-053/3905  Model A-YB, 6 dB  Model A-OB, 3 dB Antenna Coax Diagram SRM6200E PN 161-10002-001 Selected Pages TC240.cdr Series U-PT Panel Rack R1 - April 1996



Appendix B  
VENDOR SUBMITTAL INDEX  
Operable Unit 2 Groundwater Remedy  
Former Fort Ord, California

Section	Equipment	Vendor	Manufacturer/Supplier	Submittal	Subject	Remarks
	Operator Interface		Dell Dell Dell Dell Dell Dell PLC Direct Intel	SD-05 SD-06 SD-06 SD-06 SD-06 SD-06 SD-06 SD-13	Specifications WorkStation Information Guide Setup & Quick Reference Guide WorkStation Installation Guide Sony CD Documentation Update FastTrak100 User's Manual Lookout Direct Learning Guide Three Year Processor Warranty	02/06/01 P/N 8638P RevA01Cover Only P/N 31GKV Rev A00 Cover Only P/N 4760R Rev A03 Cover Only P/N 6454R Rev A01 Index PC-LKD-DEV Index Only P/N 00706 A00
57.0	Survey, As-Built Site 2 (West of Rt 1) Site 12 (East of Rt 1) OU2 Origianal OU2 Expansion New EW / PZ Coordinates Site 2 INF PZ Coordinates	Bestor	Bestor Bestor Bestor Bestor Bestor Bestor Bestor	SD-04 SD-04 SD-04 SD-04 SD-04 SD-12 SD-12	As-Built Drawings Site 2 West of Highway One Site 12 East of Highway One Original OU2 Groundwater Remedy OU2 Groundwater System Expansion Extraction Wells & Piezometers Site 2 INF Piezometers	All Drawings D Size 1 Dwg in Dwg Appendix 2 Dwgs in Dwg Appendix 3 Dwgs in Dwg Appendix 9 Dwgs in Dwg Appendix Coord & Elevations Coord & Elevations
<b>Vol. B4</b>						
58.0	Tank, Backwash, New	B.H. Tank Works	Tnemec Tnemec Tnemec B.H. Tank Works John Schock, P.E.	SD-01 SD-01 SD-01 SD-04 SD-05	Rota-Pox Plus Series 140 Tnemec-Zinc 90-97 Endura-Shield Series 74 11,400 Gallon Backwash Tank Vessel Calculations	Interior Coating Exterior Primer Exterior Top Coat Dwg 10004, Rev A/B Stamped
59.0	Tank, Backwash, Refurbished (Former UV H2O2 Tank)	B.H. Tank Works	B.H. Tank Works Solar-Chem IT Corporation	SD-04 SD-05 SD-05	Refurbish SS Backwash Tank Original Vessel Calculations Refurbished Anchor Bolt Analysis	Dwg 16998, 12/21/00 Tank #3, H2O2 50% 02/22/01
60.0	Tank, Effluent, Replacement	B.H. Tank Works	B.H. Tank Works	SD-04 SD-05 SD-12	10,000 Gallon Effluent Tank Vessel Calculations Tank Inspection Report	Dwg 10102, Rev B Stamped 03/29/01
	Thrust Block					See As-built Drawings

Appendix B  
VENDOR SUBMITTAL INDEX  
Operable Unit 2 Groundwater Remedy  
Former Fort Ord, California

Section	Equipment	Vendor	Manufacturer/Supplier	Submittal	Subject	Remarks
61.0	Transformer, at Imjin/Abrams Wells	Pacific Gas and Electricity (PG&E)	Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) USACE Pacific Gas and Electricity (PG&E)	SD-01 SD-02 SD-02 SD-04 SD-04 SD-05 SD-08 SD-09 SD-13	General Information Concrete Pad for 3-Phase Transformer Underground Conduits Installation Map Standard Trench Drawing Service Planning Sheet Signed Application Documents Meter Installation Inspection Agreement to Perform Work	UG-1 045292 Rev.3 UG-1 062288 Rev.1, p 4&6 PM: 30124192 (16x20) 8-1/2 x 11 Rev. 7/11/00 Transmitted 5/8/00 07/11/00 05/09/00
62.0	Transformer, at Landfill Wells	Pacific Gas and Electricity (PG&E)	Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) USACE Pacific Gas and Electricity (PG&E)	SD-01 SD-02 SD-02 SD-04 SD-04 SD-05 SD-08 SD-08 SD-09 SD-13	General Information Concrete Pad for 3-Phase Transformer Underground Conduits Installation Map Standard Trench Drawing Service Planning Sheet Signed Application Documents Notification of Completion Meter Installation Inspection Agreement to Perform Work	UG-1 045292 Rev.3 UG-1 062288 Rev.1, p 4&6 PM: 30120004 (16x20) 8-1/2 x 11 Rev. 7/11/00 Transmitted 5/8/00 06/29/00 07/11/00 05/09/00
63.0	Transformer, at University Wells	Pacific Gas and Electricity (PG&E)	Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) Pacific Gas and Electricity (PG&E) USACE	SD-01 SD-02 SD-02 SD-04 SD-05 SD-08 SD-08 SD-09	General Information Concrete Pad for 3-Phase Transformer Underground Conduits Installation Map Service Planning Sheet Signed Application Documents Notification of Completion Meter Installation Inspection	UG-1 064309 Rev.4 UG-1 062288 Rev.1, p 4&6 PM: 30124189 (11x17) Rev. 7/11/00 Transmitted 4/21/00 06/29/00 07/11/00
64.0	Valves, at Infiltration Galleries	SantaFe Industrial Products	Bermad Bermad Bermad Bermad	SD-02 SD-06 SD-06 SD-08	Bi-Level Float Control Valve 750-66 750-60 Float Valve - Modulating Model 66 Float Control - Non-modulating Buy American Act Compliance	general info Specs, data, control diag, 10/99 Data, installation 10/99 06/09/00
65.0	Valves, at Isolation Vaults	Santa Fe Industrial Products USACE	Asahi / America Santa Fe & Asahi / America USACE	SD-02 SD-06 SD-08	Non-Rising System Gate Valve, PVC Bolt Torque Information Waiver to Purchase Non Buy American	Rev. V-97/B 06/22/00 SPK-2-11-006, 05/06/00

Appendix B  
VENDOR SUBMITTAL INDEX  
Operable Unit 2 Groundwater Remedy  
Former Fort Ord, California

Section	Equipment	Vendor	Manufacturer/Supplier	Submittal	Subject	Remarks
66.0	Variable Frequency Drives	Avatar Engineering	Danfoss Electronic Drives Danfoss Electronic Drives Danfoss Electronic Drives Danfoss Electronic Drives Danfoss Electronic Drives Danfoss Electronic Drives  Danfoss Electronic Drives  Danfoss Electronic Drives Danfoss Electronic Drives Danfoss Electronic Drives	SD-01 SD-02 SD-04 SD-04 SD-04 SD-04  SD--05  SD-06 SD-06 SD-13	Design Features, Specs, Op Interface VLT 5000 Aqua Drive Schematic Diagram Std Drive Customer Connection Diagram Installation Drawing, NEMA 1 NEMA 1 (IP20) Dimensions  Performance Information  Instructions Service Standard Warranty	Dwg 19-7542-00, Rev A Dwg 19-7544-11, Rev D Dwg 12-6786-00, Rev B VLT 5011 (460 VAC) Input, output, noise, derating, efficiency Introduction, installation, programming, other
	Video Logging:  EW-OU2-06-180-(Initial) EW-OU2-16-A	Welenco	 Welenco Welenco	 SD-12 SD-12	Videos 03/23/00 and 04/12/00 (2) Prior to compl as MW-OU2-78-180 Video 02/02/01	No Section  One copy ea QC / Proj File One copy ea QC / Proj File
67.0	Well Caps	SantaFe Industrial Products	CJI Process Systems CJI Process Systems Santa Fe Industrial Products	SD-04 SD-04 SD-08	Well Cap Drawings Drawing Approvals, as Noted Buy American Statement	2 Dwgs & 2 Bills of Mat'l Letter 4/28/00 Letter 6/12/00
68.0	Well Drilling	Water Development, Inc.	Water Development, Inc. Water Development, Inc. Water Development, Inc. Colorado Silica Sand, Inc. Colorado Silica Sand, Inc. Colorado Silica Sand, Inc. Colorado Silica Sand, Inc. Colorado Silica Sand, Inc. Lone Star Industries, Inc. SRI SRI  IT Corporation	SD-06 SD-07 SD-08 SD-10 SD-10 SD-10 SD-10 SD-10 SD-10 SD-10 SD-10 SD-10	Drilling Instructions / Bore Hole Calcs Original Schedule Proposed Personnel Testing Sieve Guide 8 - 16 Sand Oglebay Norton Ind Well-Pack Sand Chemical Analysis Results Physical Characteristics Typical Grading Parameters SRI Supreme #3 Sand SRI Supreme 3/4-inch Sand  Well Logs	                  See Well Installation and Abandonment Report
69.0	Well Pump Installation	THF Drilling	IT Corporation IT Corporation	SD-12 SD-18	Well Test Report Well Pump Installation Records	7 EW

## **APPENDIX C**

Excerpts from Applicable or Relevant and Appropriate Requirements,  
extracted from the *Draft Final Groundwater Remedial Action Work Plan,  
Operable Unit 2 Groundwater Remedy System Expansion, Fort Ord,  
California* (IT, 1999a)

## **Operable Unit 2 Applicable or Relevant and Appropriate Requirements**

This appendix presents applicable or relevant and appropriate requirements (ARARs) for the OU2 groundwater remedy as extracted from the *Draft Final Groundwater Remedial Action Work Plan, Operable Unit 2, Groundwater Remedy System Expansion, Fort Ord, California*, Revision 0, Fort Ord, California (IT, 1999a).

### **C-1.0 Remedial Action Objectives**

Remedial action objectives provide the basis from which ARARs are developed and remediation goals are established. The RAOs stated in the *Record of Decision, Operable Unit 2, Fort Ord Landfills, Fort Ord, California*, (OU2 ROD) (Army, 1994) and the subsequent *Explanation of Significant Differences, Operable Unit 2, Fort Ord Landfills, Fort Ord, California*, (OU2 ESD) (Army, 1995) are to

- Reduce risks to human health and the environment
- Comply with federal and state ARARs.

### **C-2.0 Applicable or Relevant and Appropriate Requirements**

The ARARs described below are chemical-, location-, and action-specific for the groundwater remedy. The ARARs are identical to those used during the original OU2 groundwater remedy, and are “applicable” or “relevant and appropriate.” These standards are designed to be protective of human health and the environment and to be technically achievable with existing analytical and treatment technologies. Protocols and measures that will be implemented to comply with the ARARs during the remedial action are also presented below.

#### **C-2.1 Chemical-Specific Applicable or Relevant and Appropriate Requirements**

VOCs regulated by the state and federal governments are present in the groundwater beneath OU2. The following chemical-specific ARARs were identified in the OU2 ROD (Army, 1994) for COCs present

- *Central Coast Region Water Quality Control Plan* (RWQCB, 1994)

Portions of the *Central Coast Region Water Quality Control Plan* are ARARs, and groundwater is classified according to beneficial uses. Groundwater at OU2 is considered a potential drinking water source. The *Central Coast Region Water Quality Control Plan* establishes water quality standards, including beneficial-use designations, water-quality objectives to protect these uses, and implementation programs to meet the objectives.

- “National Primary Drinking Water Standards,” Title 40 *Code of Federal Regulations* (CFR), Part 141

Two chemical-specific drinking water standards exist that contain MCLs and have been promulgated under the Safe Drinking Water Act. Maximum contaminant level goals (MCLG) were also promulgated under the Safe Drinking Water Act. The MCLGs above zero are considered chemical-specific ARARs under the National Contingency

Plan (40 CFR §300.430[e][2][I][B]). When MCLGs are equal to zero, the MCL is considered to be a chemical-specific ARAR instead of the MCLG (40 CFR §300.430[e][2][I][C]). Table 1-1 lists national primary drinking water standards for OU2 COCs.

- “State Primary Drinking Water Standards,” *Title 22 California Code of Regulations* (CCR), Chapter 15

California primary drinking water standards establish enforceable limits for chemicals that may affect public health or the aesthetic qualities of drinking water; however, only those state requirements that are more stringent than federal standards are ARARs. The State MCLs are summarized in Table 1-1.

- “Land Disposal Restrictions, Title 22 CCR, Chapter 16

The Land Disposal Restrictions prohibit land disposal of specified untreated hazardous wastes and provides special requirements for handling such wastes. If listed or characteristic hazardous wastes are generated as part of the treatment process, then this requirement applies.

Compliance with these chemical-specific ARARs is presented in Section C-3.1.

### **C-2.2 Location-Specific Applicable or Relevant and Appropriate Requirements**

Environmentally sensitive locations were identified during the OU2 Expansion biological survey. Endangered plant and animal species were also identified. The following are location-specific ARARs

- Endangered Species Act (ESA), Title 16, United States Code, Section 1531 et seq., as promulgated by Title 50 CFR Part 402, Section 7

The ESA requires that any action authorized, funded, or carried out by a federal agency must ensure that it is not likely to jeopardize the continued existence of any endangered species or result in the destruction or adverse modification of habitat of such species that is determined to be critical. Fort Ord consulted with the Fish and Wildlife Service in accordance with the ESA.

- Fish and Game Code, Chapter 15, Article 15, Section 2090

The Code requires written finding from the State Department of Fish and Game regarding the impact of disturbances on the viability of an endangered population.

Compliance with these location-specific ARARs is discussed in Section C-3.2.

### **C-2.3 Action-Specific Applicable or Relevant and Appropriate Requirements**

Action-specific requirements apply to implementation of remedial activities, such as groundwater treatment and discharge, and soil handling, such as for trenches for conveyance piping or foundation excavations. The following are action-specific ARARs

- Monterey Bay Unified Air Pollution Control District (MBUAPCD), Regulations II and X, and National Primary and Secondary Air Quality Standards, Title 40 CFR, Part 150

These regulations and standards establish requirements for sources of air pollution and the appropriate level of air abatement technology to be applied for specific chemicals that may be generated as toxic air contaminants. The remedial action must meet the substantive requirements of these regulations.

- “Standards Applicable to Generators of Hazardous Waste,” Title 22 CCR, Chapter 12

These standards are applicable if hazardous waste is generated at the site. The substantive portions of this regulation will apply and be complied with.

- State Water Resources Control Board, Resolution No. 88-63

Resolution No. 88-63 specifies that all ground and surface water is an existing or potential source of drinking water unless total dissolved solids are greater than 3,000 milligrams per liter, the well yield is less than 200 gallons per day from a single well, or the groundwater is unreasonable to treat using best management practices or best economically achievable treatment practices. Under this resolution, the Upper 180-foot aquifer at OU2 is a potential drinking source.

- State Water Resources Control Board, Resolution No. 92-49

Resolution No. 92-49 establishes policies and procedures for the investigation, cleanup, and abatement of waste. In accordance with these requirements, cleanup levels must be set at background levels or, if background levels are not technologically or economically feasible, at the lowest levels that are achievable. The USACE completed an economic and technical feasibility analysis pursuant to Resolution No. 92-49 and determined that cleanup to the MCLs is reasonable and satisfies this requirement.

- State Water Resources Control Board, Resolution No. 68-16

Resolution No. 68-16 establishes goals for the maintenance of existing groundwater quality. It also requires best practical control technology for discharges to high-quality water. Discharge levels were chosen by considering site-specific conditions, including the contaminants to be discharged, and the designated beneficial uses of the receiving water, available treatment technologies, and cost.

- Federal Safe Drinking Water Act, Title 40 CFR, Part 144, and California Toxic Injection Well Act, California Health and Safety Code §25159.24.

Title 40 CFR Part 144 and the California Toxic Injection Well Act prohibit injection of contaminated water into or above a drinking water formation. Injection of treated groundwater into the source aquifer for the purpose of aquifer cleanup is exempted. For OU2, treated groundwater may be injected to the aquifer provided injected groundwater does not contain chemical concentrations above the ACLs (Table 1-1).

Compliance with action-specific ARARs is described in Section C-3.3.

### **C-3.0 Compliance with Applicable or Relevant and Appropriate Requirements**

Implementing the OU2 groundwater remedy is protective of human health risks associated with potential exposure to groundwater and complies with the ARARs as specified in the OU2 ROD (Army, 1994) as presented in Section 2 above.

#### **C-3.1 Chemical-Specific Applicable or Relevant and Appropriate Requirement Compliance**

Implementing the RAOs will lower the 11 COCs in the A-aquifer and Upper 180-foot aquifer so that human health risks are reduced and the ARARs are satisfied. Compliance with the chemical-specific ARARs during remedial action activities are discussed below:

- *Central Coast Region Water Quality Control Plan* (RWQCB, 1994)

The remediation system will lower concentrations of the COCs in the groundwater to drinking water quality standards or better, as shown on Table 1-1.

- “National Primary Drinking Water Standards,” Title 40 CFR, Part 141

Six of 11 COCs listed on Table 1-1 have ACLs set at the lower value of either the federal or state drinking water MCLs. These COCs are benzene, carbon tetrachloride, 1,1-DCA, 1,2-DCA, cis-1,2-DCE, and TCE.

Chloroform, 1,2-DCP, dichloromethane, PCE, and vinyl chloride ACLs are lower than either the federal or state MCLs based on risk calculation in the *Fort Ord Baseline Risk Assessment* prepared by Dames and Moore (1993).

The cumulative risk is within the acceptable risk range and is health protective.



- State Primary Drinking Water Standards, Title 22 CCR, Chapter 15

Six of 11 COCs listed on Table 1-1 have ACLs set at the lower value of either the federal or state drinking water MCLs. These COCs are benzene, carbon tetrachloride, 1,1-DCA, 1,2-DCA, cis-1,2-DCE, and TCE.

Chloroform, 1,2-DCP, dichloromethane, PCE, and vinyl chloride ACLs are lower than either the federal or state MCLs based on risk calculation in the *Fort Ord Baseline Risk Assessment* prepared by Dames and Moore (1993).

The cumulative risk is within the acceptable risk range and is health protective.

- Land Disposal Restrictions, Title 22 CCR, Chapter 16

The waste classification of materials generated will be determined prior to disposal. It is expected that the waste will be classified to be non-Resource Conservation Recovery Act hazardous waste. Should any waste generated on site be determined as hazardous waste, it will be manifested and disposed of appropriately.

The following discusses compliance with location-specific ARARs.

### **C-3.2 Location-Specific Applicable or Relevant and Appropriate Requirement Compliance**

Environmentally-sensitive locations were identified in the biological survey. Endangered plant and animal species were identified. Construction and remedial activities avoided these locations and were protective of threatened and endangered species and habitats. A biologist was available to provide biological mitigation services during remediation activities on an as-needed basis. Location-specific ARARs and compliance measures are as follows:

- ESA, Title 16, United States Code, Section 1531, et seq., as promulgated by Title 50 CFR Part 402, §7

Mitigation measures for the protection of threatened and endangered species and sensitive habitat will be in accordance with the *Installation-Wide Multispecies Habitat Management Plan for Former Fort Ord, California* (Army, 1997) and the ESA.

- Fish and Game Code, Chapter 15, Article 15, §2090

Mitigation measures for the protection of threatened and endangered species and sensitive habitat will be in accordance with the *Installation-Wide Multispecies Habitat Management Plan for Former Fort Ord, California* (Army, 1997) and the ESA.

The following discusses compliance with action-specific ARARs.

### **C-3.3 Action-Specific Applicable or Relevant and Appropriate Requirement Compliance**

Groundwater treatment and discharge, excavation, and soil handling associated with activities such as construction of wells or conveyance piping were completed in accordance with the following regulations and standards

- MBUAPCD, Regulations II and X, and National Primary and Secondary Air Quality Standards, Title 40 CFR Part 150

During groundwater treatment, excavation, soil handling, and construction, appropriate measures, such as emissions abatement and dust suppression, were implemented to meet air abatement requirements.

The design addresses fugitive air emissions of inlet COCs that can become a source of toxic air contamination. No air abatement is required.

- “Standards Applicable to Generators of Hazardous Waste,” Title 22 CCR, Chapter 12

These standards are applicable if hazardous waste is generated. Should spent carbon or any other waste generated on site be determined as hazardous waste, it will be manifested for disposal or treatment.

- State Water Resources Control Board, Resolution No. 88-63

The water will be treated to remove COCs to below ACLs.

- State Water Resources Control Board, Resolution No. 92-49

The USACE completed an economic and technical feasibility analysis pursuant to Resolution No. 92-49 and determined that OU2 cleanup to the MCLs is reasonable and satisfies cleanup requirements.

- State Water Resources Control Board, Resolution No. 68-16

The COC discharge limits for OU2 treated water are below the ACL for eight COCs (benzene, chloroform, 1,1-DCA, cis-1,2-DCE, 1,2-DCP, dichloromethane, PCE, and TCE) and equal to the ACL for three COCs (carbon tetrachloride, 1,2-Dichloroethane, and vinyl chloride). These discharge levels will maintain the existing groundwater quality.

**APPENDIX D**

**GROUNDWATER TREATMENT PLANT  
OPERATOR REPORTS,  
CHECKLISTS, AND SPARE PARTS LIST**

- D 1 Field Activity Daily Log
- D 2 Daily Flow Readings Log
- D 3 (Periodic) Flow Readings Log
- D 4 (Periodic) Inspection Checklist
- D 5 (Periodic) Maintenance Checklist
- D 6 Valve Positioning
- D 7 Granular Activated Carbon Valve Positioning
- D 8 Spare Parts Inventory List

## Appendix D-1

# FIELD ACTIVITY DAILY LOG

DAILY LOG	DATE			
	NO.			
	SHEET OF			

[illegible]

**Appendix D 2**  
**DAILY FLOW READINGS LOG**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Date: \_\_\_\_\_

Operator: \_\_\_\_\_

Location	Meter Number	Meter Reading	Time	Meter GPM <sup>a</sup>	Operator Comments <sup>b</sup>
Eastern Containment	FI-325				
Northern Containment	FI-679				
Recycle	FI-357				
Sites 2 and 12 Injection	FI-431				
Northwestern Injection	FI-531				
Southwestern Injection	FI-541				

**ADDITIONAL REMARKS:**

Notes:

<sup>a</sup> gallons per minute

<sup>b</sup> Start/Stop times, number of extraction wells on/off line, flow adjustments

**Appendix D 3**  
**FLOW READINGS LOG**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Date: \_\_\_\_\_

Operator: \_\_\_\_\_

Location	Meter Number	Meter Reading	Time	Meter (gpm)	Water Level (ft)	Comments
<b>Western Influent</b>						
EW-OU2-03-A	FI-215					
EW-OU2-01-A	FI-225					
EW-OU2-02-A	FI-235					
EW-OU2-01-180	FI-245					
EW-OU2-04-A	FI-275					
EW-OU2-05-A	FI-215					
EW-OU2-06-A	FI-255					
<b>Eastern Influent</b>						
EW-OU2-07-A	FI-185					
EW-OU2-08-A	FI-175					
EW-OU2-09-A	FI-165					
EW-OU2-10-A	FI-155					
EW-OU2-02-180	FI-145					
EW-OU2-11-A	FI-135					
EW-OU2-12-A	FI-125					
EW-OU2-13-A	FI-115					
<b>University Influent</b>						
EW-OU2-15-A	FI-715					
EW-OU2-14-A	FI-725					
<b>Abrams/Imjin Influent</b>						
EW-OU2-06-180	FI-815					
EW-OU2-16-A	FI-735					
EW-OU2-05-180	FI-845					
<b>Landfill Influent</b>						
EW-OU2-04-180	FI-825					
EW-OU2-03-180	FI-835					

**APPENDIX D 4**  
**INSPECTION CHECKLIST**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Appendix B Tab	Item	Identification	Security	Safety	Frequency*	Date	Initials	Comments
1	Anchor Bolts							
	All Anchored Equipment	Various		X	Semi-annual**			
3	Bag Filter	F-348						
	Lifting Threads			X	Semi-annual			
N/A	Building							
	Doors/locks/windows		X	X	Semi-annual			
	Inside supports		X	X	Semi-annual			
	Outside shell		X	X	Semi-annual			
6	Cartridge Filter	F-350						
	Lifting Threads			X	Semi-annual			
8	Concrete, Cast-in-Place							
	Floors			X	Semi-annual			
	Housekeeping Pads			X	Semi-annual			
	Truck Pad			X	Semi-annual			
	Vault Sumps	7 EW Vaults		X	Semi-annual			
9 & 10	Concrete Pull Boxes & Aluminum Lids							
	Christy 10x17	Tbl 2-2 (19)	X	X	Semi-annual			
	Christy 17x30	Tbl 2-2 (4)	X	X	Semi-annual			
	Christy 24x36	Tbl 2-2 (3)	X	X	Semi-annual			

**APPENDIX D 4**  
**INSPECTION CHECKLIST**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Appendix B Tab	Item	Identification	Security	Safety	Frequency*	Date	Initials	Comments
13 & 15	Concrete Vaults & Lids							
	A-Aquifer EW	Table 2-2 (3)	X	X	Semi-annual			
	180-ft Aquifer EW	Table 2-2 (4)	X	X	Semi-annual			
	High Point, Low Point, Leak Detect 24x24	Table 2-2 (40+1)	X	X	Annual			
	INF Gallery	Table 2-2 (2)	X	X	Semi-annual			
	INF Valve	Table 2-2 (2)	X	X	Semi-annual			
	Isolation	Table 2-2 (3)	X	X	Annual			
	OU2 EW/IW Replacement	15 + 3	X	X	Semi-annual			
	Wye	Table 2-2 (1)	X	X	Semi-annual			
14	Tamper Proof (Pentagon) Vault Lid Bolts							
	Christy 10x17	Tbl 2-2 (19)	X		Annual			
	Christy 17x30	Tbl 2-2 (4)	X		Annual			
	Christy 24x36	Tbl 2-2 (3)	X		Annual			
20 & 47	Electrical Panelboards							
	Abrams		X	X	Semi-annual			
	Abrams/Imjin		X	X	Semi-annual			
	Landfill		X	X	Semi-annual			
	Repeater		X	X	Semi-annual			
	University		X	X	Semi-annual			
	Wellhead (operating only)		X	X	Semi-annual			
21	Eyewash/Shower Station							
	Building Containment, Flush Supply Line			X	Quarterly			
	N & E Containment, Flush Supply Line			X	Quarterly			
	N & E Containment, Functional Checkout			X	Semi-annual			



**APPENDIX D 4**  
**INSPECTION CHECKLIST**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Appendix B Tab	Item	Identification	Security	Safety	Frequency*	Date	Initials	Comments
22	Fencing							
	Abrams PLC		X	X	Semi-annual			
	Abrams/Imjin PLC		X	X	Semi-annual			
	Landfill PLC		X	X	Semi-annual			
	Repeater Station		X	X	Semi-annual			
	University PLC		X	X	Semi-annual			
	GWTP		X	X	Semi-annual			
23	Fire Alarm System GWTP							
	Functional Checkout		X	X	Semi-annual			
27	GAC, Northern Containment Area							
	Integrity Checkout			X	Semi-annual			
28	GAC, Eastern Containment Area							
	Integrity Checkout			X	Semi-annual			
29	Grating, Trench and Sump							
	Building			X	Semi-annual			
	East Containment			X	Semi-annual			
	North Containment			X	Semi-annual			
30	Grating Clips							
	East Containment			X	Semi-annual			
	North Containment			X	Semi-annual			

**APPENDIX D 4**  
**INSPECTION CHECKLIST**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Appendix B Tab	Item	Identification	Security	Safety	Frequency*	Date	Initials	Comments
32	Handrails & Chains							
	East Containment			X	Semi-annual			
	North Containment			X	Semi-annual			
33	Ladders							
	Expansion EW Vaults	7		X	Semi-annual			
	Expansion INF Vaults	2		X	Semi-annual			
	Expansion Valve Vaults	2		X	Semi-annual			
	Expansion Wye Vault	1		X	Semi-annual			
	Original EW Vaults	15		X	Semi-annual			
	Original IW Vaults	3		X	Semi-annual			
42	Pipe Supports							
	GWTP			X	Semi-annual			
	Vault			X	Semi-annual			
49	PLC Software							
	Abrams PLC		X		Semi-annual			
	Abrams/Imjin PLC		X		Semi-annual			
	Landfill PLC		X		Semi-annual			
	University PLC		X		Semi-annual			
	GWTP		X		Semi-annual			
50	Pump, Centifugal, Backwash							
	Electrical/Mechanical/Guard	P-385		X	Semi-annual			

**APPENDIX D 4**  
**INSPECTION CHECKLIST**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Appendix B Tab	Item	Identification	Security	Safety	Frequency*	Date	Initials	Comments
51	Pump, Centifugal, Injection							
	Electrical/Mechanical/Guard/VFD	P-410		X	Semi-annual			
	Electrical/Mechanical/Guard/VFD	P-420		X	Semi-annual			
	Electrical/Mechanical/Guard/VFD	P-510		X	Semi-annual			
	Electrical/Mechanical/Guard/VFD	P-520		X	Semi-annual			
	Electrical/Mechanical/Guard/VFD	P-910		X	Semi-annual			
	Electrical/Mechanical/Guard/VFD	P-920		X	Semi-annual			
53	Pump, Sump							
	Eastern Electrical/Mechanical	P-375		X	Semi-annual			
	Northern Electrical/Mechanical	P-395		X	Semi-annual			
	Inside GWTP Electrical/Mechanical	P-495		X	Semi-annual			
55	Sump Liner (Integrity)							
	Building			X	Semi-annual			
	East Containment			X	Semi-annual			
	North Containment			X	Semi-annual			

Notes: \* Any discrepancy should be noted for correction when found during normal operations

\*\* Semi-annual checks ensure the timely inspection of all items.

**APPENDIX D 5**  
**MAINTENANCE CHECKLIST**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Appendix B Tab	Item	Identification	Task	Frequency Mo/Qtr/SA/Ann/Oth	Date	Initials	Comments
3	Bag Filter	F-348	Keep lifting threads clean and lubricated; replace when worn	Annual			
6	Cartridge Filter	F-350	Keep lifting threads clean and lubricated; replace when worn	Annual			
20 & 47	Electrical Panelboards	5 offsite PLC Panels and each wellhead electrical panel	Hot surface after 3 seconds; may indicate trouble	Periodic			
			Vacuum or wipe surfaces to remove dust accumulation	Semi-annual			
			Spray surfaces to dewater and to reduce corrosion potential	Semi-annual			
			Service of licensed electrician	After short circuit or other electrical damage			
24	Flowmeters						
	Landfill EW-OU2-03-180	FI-835	Monitor for low voltage battery warning; replace if necessary	During periodic confirmation reading			
	Landfill EW-OU2-04-180	FI-825					
	Abrams/Imjin EW-OU2-05-180	FI-845					
	Abrams/Imjin EW-OU2-06-180	FI-815					
	Abrams/Imjin EW-OU2-16-A	FI-735					
	University EW-OU2-14-A	FI-725					
	University EW-OU2-15-A	FI-715					
	Eastern Calgon GAC Influent	FI-325					
	Northern USFilter GAC Influent	FI-679					
	Southwestern Injection	FI-541					
27	GAC, Northern Containment Area	TK-600C/D	Inspect for complete carbon discharge & vessel internals	Each carbon changeout			
28	GAC, Eastern Containment Area	TK-600A/B	Inspect for complete carbon discharge & vessel internals	Each carbon changeout			

**APPENDIX D 5**  
**MAINTENANCE CHECKLIST**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Appendix B Tab	Item	Identification	Task	Frequency Mo/Qtr/SA/Ann/Oth	Date	Initials	Comments
34	Leak Detection System	Abrams PLC	Integrity check	Verify connection from each node during first year; annual checks thereafter			
		GWTP PLC					
		Imjin/Abrams PLC					
		Landfill PLC					
		University PLC					
36	Level Switches, Vault		Lift level switch and check electronic response	Semi-annual			
	Landfill EW-OU2-03-180	LSH-834					
	Landfill EW-OU2-04-180	LSH-824					
	Abrams/Imjin EW-OU2-05-180	LSH-844					
	Abrams/Imjin EW-OU2-06-180	LSH-814					
	Abrams/Imjin EW-OU2-16-A	LSH-734					
	University EW-OU2-14-A	LSH-724					
	University EW-OU2-15-A	LSH-714					
	Wye Vault	LSH-192					
44	Pressure Switches, Extraction Well		Throttle valves to simulate high pressure in pipeline, compare with pressure setpoint	Semi-annual			
	Landfill EW-OU2-03-180	PSH-733					
	Landfill EW-OU2-04-180	PSH-723					
	Abrams/Imjin EW-OU2-05-180	PSH-843					
	Abrams/Imjin EW-OU2-06-180	PSH-813					
	Abrams/Imjin EW-OU2-16-A	PSH-733					
	University EW-OU2-14-A	PSH-723					
	University EW-OU2-15-A	PSH-713					
44	Pressure Switches, Header		Throttle valves to simulate high pressure in pipeline, compare with pressure setpoint	Semi-annual			
	Landfill EW-OU2-04-180	PSH-822					
	Abrams/Imjin EW-OU2-06-180	PSH-812					
	University EW-OU2-15-A	PSH-712					

**APPENDIX D 5**  
**MAINTENANCE CHECKLIST**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Appendix B Tab	Item	Identification	Task	Frequency Mo/Qtr/SA/Ann/Oth	Date	Initials	Comments
50	Pump, Centrifugal, Backwash						
	Pump	P-385	Grease bearings	4000 Run Hours or Every 3 Years			
	10 HP Motor	P-385	0.2 oz grease, ea 2 bearings	Every 3 Years			
51	Pump, Centrifugal, Injection						
	Pump	P-510 & P-520	Bearings sealed for life	NA			
	7.5 HP Motor	P-510	0.2 oz grease, ea 2 bearings	Every 3 Years			
	7.5 HP Motor	P-520					
53	Pump, Sump						
	Eastern Containment Pump	P-375	Clean suction grate and impeller	As Needed			
	Northern Containment Pump	P-395					
	Inside GWTP Building Pump	P-495					
	Eastern Containment Level Switch	LC-375	Lift level switch and check electronic response	Semi-annual			
	Northern Containment Level Switch	LC-395					
	Inside GWTP Building Level Switch	LC-495					
64	Valves, at Infiltration Galleries						
	INF-OU2-01-180	LSH-539	With confined space permit only, lift level switch and check electronic response	Semi-annual			
	INF-OU2-01-180	LSH-555					

**Appendix D 6**  
**VALVE POSITIONING**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Valve	Description	Normal Flow	TK-340 Full	TK-380 Full	Temporay Shutdown Valve Position	Longterm Shutdown Valve Position
Influent Manifold						
V-301	West influent 6-inch butterfly valve	open			open	closed
V-302	West manifold 2-inch valve to LLNL	closed			closed	closed
V-303	West manifold 6-inch check valve	open			closed	closed
V-304	West manifold 6-inch air actuated valve	open			closed	closed
V-319	Manifold 6" butterfly bypass valve	closed			closed	closed
V-307	West manifold 2-inch PI valve	open			open	open
V-308	West manifold 6-inch butterfly valve	open			open	closed
V-321	East influent 6-inch butterfly valve	open			open	closed
V-322	East manifold 2-inch valve to LLNL	closed			closed	closed
V-323	East manifold 6-inch check valve	open			closed	closed
V-324	East manifold 6-inch air actuated valve	open			closed	closed
V-327	East manifold 2-inch PI valve	open			open	open
V-328	East manifold 6-inch butterfly valve	open			open	closed
V-315	Manifold mixer sample port valve	closed			closed	open
Sump to Backwash Tank						
V-378	East sump 2-inch check valve	open	closed	closed	closed	closed
V-376	East sump 2-inch isolation valve	open	open	open	open	closed
V-379	East sump 2-inch valve to TK-340	open	closed	open	closed	closed
V-374	East sump 2-inch valve to P-495	closed	open	open	open	open
V-496	Building sump 2-inch isolation valve	open	open	open	open	closed
V-497	Building sump 2-inch clean-out valve	closed	closed	closed	closed	open
V-498	Building sump 2-inch check valve	open	closed	closed	closed	closed
V-396	Northern sump 2-inch isolation valve	open	open	open	open	closed
V-397	Northern sump 2-inch clean-out valve	closed	closed	closed	closed	open
V-398	Northern sump 2-inch check valve	open	closed	closed	closed	closed
V-399	Northern sump 2-inch valve to TK-380	open	open	closed	closed	closed
Backwash Tank to Manifold						
V-339	TK-340 backwash influent 6-inch valve	open	closed		open	closed
V-341	TK-340 backwash effluent 4-inch valve	open	open		open	closed
V-342	East backwash 2-inch clean-out valve	closed	closed		closed	open
V-347	East 2-inch check valve	open	open		closed	closed
V-346	East air bleed valve	closed	closed		closed	open
V-344	East 2-inch valve to TK-380	closed	closed		closed	closed
V-349	Cartridge 2-inch influent valve	open	open		open	closed
V-352	Cartridge 2-inch influent drain valve	closed	closed		closed	open
V-353	Cartridge 2-inch effluent drain valve	closed	closed		closed	open
V-351	Cartridge 2-inch effluent valve	open	open		open	closed
V-352	Cartridge 2-inch influent valve	open	open		open	closed
V-354	Cartridge 2-inch influent bypass valve	closed	closed		closed	closed
V-356	Cartridge 2-inch bypass drain valve	closed	closed		closed	closed
V-355	Cartridge 2-inch effluent bypass valve	closed	closed		closed	closed
V-359	Backwash filter 2-inch valve to manifold	open	open		closed	closed

**Appendix D 6**  
**VALVE POSITIONING**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Valve	Description	Normal Flow	TK-340 Full	TK-380 Full	Temproyary Shutdown Valve Position	Longterm Shutdown Valve Position
V-389	TK-380 backwash influent 6-inch valve	open		closed	closed	closed
V-381	TK-380 backwash effluent 3-inch valve	open		open	open	closed
V-382	North backwash 2-inch clean-out valve	closed		closed	closed	open
V-387	North 2-inch check valve	open		open	closed	closed
V-385	North air bleed valve	closed		closed	closed	open
V-388	North 2-inch valve to TK-340	open		closed	closed	closed
Effluent Manifold						
V-689	TK-690 influent 10-inch valve	open			closed	closed
V-692	TK-690 effluent 12-inch valve	open			closed	closed
V-694	TK-690 effluent drain line	closed			closed	closed
V-417	8-inch butterfly isolation valve	open			open	closed
V-923	P-920 4-inch gate valve	open			open	closed
V-924	P-920 2-inch drain valve	closed			closed	open
V-927	P-920 4-inch check valve	open			open	closed
V-928	P-920 2-inch drain valve	closed			closed	open
V-929	P-920 4-inch gate valve	open			open	closed
V-912A	P-920 pressure gauge valve	open			open	closed
V-912B	P-920 pressure switch valve	open			open	closed
V-913	P-910 4-inch gate valve	open			open	closed
V-914	P-910 2-inch drain valve	closed			closed	open
V-917	P-910 4-inch check valve	open			open	closed
V-918	P-910 2-inch drain valve	closed			closed	open
V-919	P-910 4-inch gate valve	open			open	closed
V-922	P-910 pressure gauge valve	open			open	closed
V-923	P-910 pressure switch valve	open			open	closed
V-530	P-910/920 isolation valve	open			open	closed
V-532	Northwestern air bleed valve	open			open	open
V-533	Northwestern isolation valve	open			closed	closed
V-413	P-410 4-inch gate valve	open			open	closed
V-414	P-410 2-inch drain valve	closed			closed	open
V-412A	P-410 pressure gauge valve	open			open	closed
V-412B	P-410 pressure switch valve	open			open	closed
V-417	P-410 4-inch check valve	open			open	closed
V-418	P-410 2-inch drain valve	closed			closed	open
V-419	P-410 4-inch butterfly valve	open			open	closed
V-423	P-420 4-inch gate valve	open			open	closed
V-424	P-420 2-inch drain valve	closed			closed	open
V-422A	P-420 pressure gauge valve	open			open	closed
V-422B	P-420 pressure switch valve	open			open	closed
V-427	P-420 4-inch check valve	open			open	closed
V-428	P-420 2-inch drain valve	closed			closed	open
V-429	P-420 4-inch butterfly valve	open			open	closed
V-440	Sites 2 and 12 to LLNL valve	closed				closed



**Appendix D 6**  
**VALVE POSITIONING**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Valve	Description	Normal Flow	TK-340 Full	TK-380 Full	Temporary Shutdown Valve Position	Longterm Shutdown Valve Position
V-430	P-410/420 isolation valve	open			open	closed
V-434	Sites 2 and 12 air bleed valve	open			open	open
V-433	Sites 2 and 12 isolation valve	open			open	closed
V-432	Eastern injection isolation valve	closed			closed	closed
V-513	P-510 4-inch gate valve	open			open	closed
V-514	P-510 2-inch drain valve	closed			closed	open
V-512A	P-510 pressure gauge valve	open			open	closed
V-512B	P-510 pressure switch valve	open			open	closed
V-517	P-510 4-inch check valve	open			open	closed
V-518	P-510 2-inch drain valve	closed			closed	open
V-519	P-510 4-inch butterfly valve	open			open	closed
V-523	P-520 4-inch gate valve	open			open	closed
V-524	P-520 2-inch drain valve	closed			closed	open
V-522A	P-520 pressure gauge valve	open			open	closed
V-522B	P-520 pressure switch valve	open			open	closed
V-527	P-520 4-inch check valve	open			open	closed
V-528	P-520 2-inch drain valve	closed			closed	open
V-529	P-520 4-inch butterfly valve	open			open	closed
V-540	P-510/520 isolation valve	open			open	closed
V-546	Southwestern air bleed valve	open			open	open
V-542	Southwestern isolation valve	open			open	closed

**Appendix D 7**  
**GRANULAR ACTIVATED CARBON VALVE POSITIONING**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Valve	Description	Series Flow		Parallel Flow	TK-600A Backwash, Lowflow and Online TK-600B	TK-600A Backwash, Highflow and Offline TK-600B	Longterm Shutown Valve Position
		TK-600A lead	TK-600B lead				
V-601	Eastern GAC <sup>3</sup> manifold valve	open	closed	open	closed	closed	closed
V-602	Eastern GAC manifold valve	closed	open	open	open	closed	closed
V-603	Eastern GAC manifold valve	closed	closed	closed	open	open	closed
V-604	Eastern GAC manifold valve	closed	closed	closed	closed	closed	closed
V-605	Eastern GAC manifold valve	closed	open	open	closed	closed	closed
V-606	Eastern GAC manifold valve	open	closed	open	closed	closed	closed
V-607	Eastern GAC manifold valve	closed	open	closed	closed	closed	closed
V-608	Eastern GAC manifold valve	open	closed	closed	closed	closed	closed
V-609	Eastern GAC manifold valve	open	closed	closed	open	open	closed
V-610	Eastern GAC manifold valve	closed	open	closed	open	closed	closed
V-611	Eastern GAC backwash influent	closed	closed	closed	closed	open	closed
V-612	Sample port valve	closed	closed	closed	closed	closed	closed
V-613	Sample port valve	closed	closed	closed	closed	closed	closed
V-614A	Eastern pressure differential valve	open	open	open	open	closed	open
V-614B	Eastern pressure differential valve	open	open	open	open	closed	open
V-615A	Eastern pressure differential valve	open	open	open	open	closed	open
V-615B	Eastern pressure differential valve	open	open	open	open	closed	open
V-616	Eastern GAC Rupture Disc	closed	closed	closed	closed	closed	closed
V-617	Eastern GAC Rupture Disc	closed	closed	closed	closed	closed	closed
V-618	Sample port valve to LLNL	closed	closed	closed	closed	closed	closed
V-619	Sample port valve to LLNL	closed	closed	closed	closed	closed	closed
V-626A	TK-600A air/water valve	closed during normal operation					closed
V-627A	TK-600A GAC unload valve						closed
V-626B	TK-600B air/water valve						closed
V-627B	TK-600B GAC unload valve						closed
V-633A	TK-600A Sample port valve						closed
V-633B	TK600B Sample port valve						closed
V-634A	TK-600A air/water valve						closed
V-635A	TK-600A GAC unload valve						closed
V-636A	TK-600A air/water valve						open
V-634B	TK-600B air/water valve						open
V-635B	TK-600B GAC unload valve						closed
V-636B	TK-600B air/water valve						closed

**Appendix D 7**  
**GRANULAR ACTIVATED CARBON VALVE POSITIONING**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Valve	Description	Series Flow		Parallel Flow	TK-600D Backwash, Lowflow and Online TK-600B	TK-600C Backwash, Highflow and Offline TK-600B	Longterm Shutown Valve Position
		TK-600D lead	TK-600C lead				
V-630C	Northern GAC <sup>a</sup> sampling valve	closed during normal operation					closed
V-631C	Northern GAC sampling valve						closed
V-632C	Northern GAC sampling valve						closed
V-630D	Northern GAC sampling valve						closed
V-631D	Northern GAC sampling valve						closed
V-632D	Northern GAC sampling valve						closed
V-634	TK-600D air bleed valve						open
V-635	TK-600D air/water valve						closed
V-636	TK-600D air/water valve						closed
V-644	TK-600C air bleed valve						open
V-645	TK-600C air/water valve						closed
V-646	TK-600C air/water valve						closed
V-651	Northern GACa manifold valve	open	closed	open	closed	closed	closed
V-652	Northern GAC manifold valve	closed	open	open	open	closed	closed
V-653	Northern GAC manifold valve	closed	closed	closed	open	open	closed
V-654	Northern GAC manifold valve	closed	closed	closed	closed	closed	closed
V-655	Northern GAC manifold valve	closed	open	open	closed	closed	closed
V-656	Northern GAC manifold valve	open	closed	open	closed	closed	closed
V-657	Northern GAC manifold valve	closed	open	closed	closed	closed	closed
V-658	Northern GAC manifold valve	open	closed	closed	closed	closed	closed
V-659	Northern GAC manifold valve	open	closed	closed	open	open	closed
V-660	Northern GAC manifold valve	closed	open	closed	open	closed	closed
V-661	Northern GAC backwash influent	closed	closed	closed	closed	open	closed
V-662	Sample port valve	closed	closed	closed	closed	closed	closed
V-663	Sample port valve	closed	closed	closed	closed	closed	closed
V-664A	Northern pressure differential valve	open	open	open	open	closed	open
V-664B	Northern pressure differential valve	open	open	open	open	closed	open
V-665A	Northern pressure differential valve	open	open	open	open	closed	open
V-665B	Northern pressure differential valve	open	open	open	open	closed	open
V-666	Northern GAC Rupture Disc	closed	closed	closed	closed	closed	closed
V-667	Northern GAC Rupture Disc	closed	closed	closed	closed	closed	closed
V-668	Sample port valve to LLNL	closed	closed	closed	closed	closed	closed
V-669	Sample port valve to LLNL	closed	closed	closed	closed	closed	closed
V-666C	TK-600C air/water valve	closed during normal operation					closed
V-667C	TK-600C GAC unload valve						closed
V-668C	TK-600C air/water valve						closed
V-666D	TK-600D air/water valve						closed
V-667D	TK-600D GAC unload valve						closed
V-668D	TK-600D air/water valve						closed
V-675C	TK-600C GAC unload valve						closed
V-676C	TK-600C air/water valve						closed
V-675D	TK-600D GAC unload valve						open
V-676D	TK-600D air/water valve	open					

GAC<sup>a</sup> granular activated carbon

**Appendix D 8**  
**SPARE PARTS INVENTORY LIST**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

There were no identified spare parts purchased as part of the Operable Unit 2 System Expansion. Critical components, such as in-line process pumps, are provided as 100 percent spares. Non-critical components are readily available and may be taken off-line and refurbished or replaced as necessary. However, as the Groundwater Treatment Operator acquires a spare parts inventory, this appendix reserves space for the listing.

**Appendix D 6**  
**VALVE POSITIONING**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Valve	Description	Normal Flow	TK-340 Full	TK-380 Full	Temproyary Shutdown Valve Position	Longterm Shutdown Valve Position
V-389	TK-380 backwash influent 6-inch valve	open		closed	closed	closed
V-381	TK-380 backwash effluent 3-inch valve	open		open	open	closed
V-382	North backwash 2-inch clean-out valve	closed		closed	closed	open
V-387	North 2-inch check valve	open		open	closed	closed
V-385	North air bleed valve	closed		closed	closed	open
V-388	North 2-inch valve to TK-340	open		closed	closed	closed
Effluent Manifold						
V-689	TK-690 influent 10-inch valve	open			closed	closed
V-692	TK-690 effluent 12-inch valve	open			closed	closed
V-694	TK-690 effluent drain line	closed			closed	closed
V-417	8-inch butterfly isolation valve	open			open	closed
V-923	P-920 4-inch gate valve	open			open	closed
V-924	P-920 2-inch drain valve	closed			closed	open
V-927	P-920 4-inch check valve	open			open	closed
V-928	P-920 2-inch drain valve	closed			closed	open
V-929	P-920 4-inch gate valve	open			open	closed
V-912A	P-920 pressure gauge valve	open			open	closed
V-912B	P-920 pressure switch valve	open			open	closed
V-913	P-910 4-inch gate valve	open			open	closed
V-914	P-910 2-inch drain valve	closed			closed	open
V-917	P-910 4-inch check valve	open			open	closed
V-918	P-910 2-inch drain valve	closed			closed	open
V-919	P-910 4-inch gate valve	open			open	closed
V-922	P-910 pressure gauge valve	open			open	closed
V-923	P-910 pressure switch valve	open			open	closed
V-530	P-910/920 isolation valve	open			open	closed
V-532	Northwestern air bleed valve	open			open	open
V-533	Northwestern isolation valve	open			closed	closed
V-413	P-410 4-inch gate valve	open			open	closed
V-414	P-410 2-inch drain valve	closed			closed	open
V-412A	P-410 pressure gauge valve	open			open	closed
V-412B	P-410 pressure switch valve	open			open	closed
V-417	P-410 4-inch check valve	open			open	closed
V-418	P-410 2-inch drain valve	closed			closed	open
V-419	P-410 4-inch butterfly valve	open			open	closed
V-423	P-420 4-inch gate valve	open			open	closed
V-424	P-420 2-inch drain valve	closed			closed	open
V-422A	P-420 pressure gauge valve	open			open	closed
V-422B	P-420 pressure switch valve	open			open	closed
V-427	P-420 4-inch check valve	open			open	closed
V-428	P-420 2-inch drain valve	closed			closed	open
V-429	P-420 4-inch butterfly valve	open			open	closed
V-440	Sites 2 and 12 to LLNL valve	closed				closed

**Appendix D 6**  
**VALVE POSITIONING**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Valve	Description	Normal Flow	TK-340 Full	TK-380 Full	Temporay Shutdown Valve Position	Longterm Shutdown Valve Position
V-430	P-410/420 isolation valve	open			open	closed
V-434	Sites 2 and 12 air bleed valve	open			open	open
V-433	Sites 2 and 12 isolation valve	open			open	closed
V-432	Eastern injection isolation valve	closed			closed	closed
V-513	P-510 4-inch gate valve	open			open	closed
V-514	P-510 2-inch drain valve	closed			closed	open
V-512A	P-510 pressure gauge valve	open			open	closed
V-512B	P-510 pressure switch valve	open			open	closed
V-517	P-510 4-inch check valve	open			open	closed
V-518	P-510 2-inch drain valve	closed			closed	open
V-519	P-510 4-inch butterfly valve	open			open	closed
V-523	P-520 4-inch gate valve	open			open	closed
V-524	P-520 2-inch drain valve	closed			closed	open
V-522A	P-520 pressure gauge valve	open			open	closed
V-522B	P-520 pressure switch valve	open			open	closed
V-527	P-520 4-inch check valve	open			open	closed
V-528	P-520 2-inch drain valve	closed			closed	open
V-529	P-520 4-inch butterfly valve	open			open	closed
V-540	P-510/520 isolation valve	open			open	closed
V-546	Southwestern air bleed valve	open			open	open
V-542	Southwestern isolation valve	open			open	closed

**Appendix D 7**  
**GRANULAR ACTIVATED CARBON VALVE POSITIONING**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Valve	Description	Series Flow		Parallel Flow	TK-600A Backwash, Lowflow and Online TK-600B	TK-600A Backwash, Highflow and Offline TK-600B	Longterm Shutown Valve Position
		TK-600A lead	TK-600B lead				
V-601	Eastern GAC <sup>3</sup> manifold valve	open	closed	open	closed	closed	closed
V-602	Eastern GAC manifold valve	closed	open	open	open	closed	closed
V-603	Eastern GAC manifold valve	closed	closed	closed	open	open	closed
V-604	Eastern GAC manifold valve	closed	closed	closed	closed	closed	closed
V-605	Eastern GAC manifold valve	closed	open	open	closed	closed	closed
V-606	Eastern GAC manifold valve	open	closed	open	closed	closed	closed
V-607	Eastern GAC manifold valve	closed	open	closed	closed	closed	closed
V-608	Eastern GAC manifold valve	open	closed	closed	closed	closed	closed
V-609	Eastern GAC manifold valve	open	closed	closed	open	open	closed
V-610	Eastern GAC manifold valve	closed	open	closed	open	closed	closed
V-611	Eastern GAC backwash influent	closed	closed	closed	closed	open	closed
V-612	Sample port valve	closed	closed	closed	closed	closed	closed
V-613	Sample port valve	closed	closed	closed	closed	closed	closed
V-614A	Eastern pressure differential valve	open	open	open	open	closed	open
V-614B	Eastern pressure differential valve	open	open	open	open	closed	open
V-615A	Eastern pressure differential valve	open	open	open	open	closed	open
V-615B	Eastern pressure differential valve	open	open	open	open	closed	open
V-616	Eastern GAC Rupture Disc	closed	closed	closed	closed	closed	closed
V-617	Eastern GAC Rupture Disc	closed	closed	closed	closed	closed	closed
V-618	Sample port valve to LLNL	closed	closed	closed	closed	closed	closed
V-619	Sample port valve to LLNL	closed	closed	closed	closed	closed	closed
V-626A	TK-600A air/water valve	closed during normal operation					closed
V-627A	TK-600A GAC unload valve						closed
V-626B	TK-600B air/water valve						closed
V-627B	TK-600B GAC unload valve						closed
V-633A	TK-600A Sample port valve						closed
V-633B	TK600B Sample port valve						closed
V-634A	TK-600A air/water valve						closed
V-635A	TK-600A GAC unload valve						closed
V-636A	TK-600A air/water valve						open
V-634B	TK-600B air/water valve						open
V-635B	TK-600B GAC unload valve						closed
V-636B	TK-600B air/water valve						closed

**Appendix D 7**  
**GRANULAR ACTIVATED CARBON VALVE POSITIONING**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Valve	Description	Series Flow		Parallel Flow	TK-600D Backwash, Lowflow and Online TK-600B	TK-600C Backwash, Highflow and Offline TK-600B	Longterm Shutown Valve Position
		TK-600D lead	TK-600C lead				
V-630C	Northern GAC <sup>a</sup> sampling valve	closed during normal operation					closed
V-631C	Northern GAC sampling valve						closed
V-632C	Northern GAC sampling valve						closed
V-630D	Northern GAC sampling valve						closed
V-631D	Northern GAC sampling valve						closed
V-632D	Northern GAC sampling valve						closed
V-634	TK-600D air bleed valve						open
V-635	TK-600D air/water valve						closed
V-636	TK-600D air/water valve						closed
V-644	TK-600C air bleed valve						open
V-645	TK-600C air/water valve						closed
V-646	TK-600C air/water valve						closed
V-651	Northern GACa manifold valve	open	closed	open	closed	closed	closed
V-652	Northern GAC manifold valve	closed	open	open	open	closed	closed
V-653	Northern GAC manifold valve	closed	closed	closed	open	open	closed
V-654	Northern GAC manifold valve	closed	closed	closed	closed	closed	closed
V-655	Northern GAC manifold valve	closed	open	open	closed	closed	closed
V-656	Northern GAC manifold valve	open	closed	open	closed	closed	closed
V-657	Northern GAC manifold valve	closed	open	closed	closed	closed	closed
V-658	Northern GAC manifold valve	open	closed	closed	closed	closed	closed
V-659	Northern GAC manifold valve	open	closed	closed	open	open	closed
V-660	Northern GAC manifold valve	closed	open	closed	open	closed	closed
V-661	Northern GAC backwash influent	closed	closed	closed	closed	open	closed
V-662	Sample port valve	closed	closed	closed	closed	closed	closed
V-663	Sample port valve	closed	closed	closed	closed	closed	closed
V-664A	Northern pressure differential valve	open	open	open	open	closed	open
V-664B	Northern pressure differential valve	open	open	open	open	closed	open
V-665A	Northern pressure differential valve	open	open	open	open	closed	open
V-665B	Northern pressure differential valve	open	open	open	open	closed	open
V-666	Northern GAC Rupture Disc	closed	closed	closed	closed	closed	closed
V-667	Northern GAC Rupture Disc	closed	closed	closed	closed	closed	closed
V-668	Sample port valve to LLNL	closed	closed	closed	closed	closed	closed
V-669	Sample port valve to LLNL	closed	closed	closed	closed	closed	closed
V-666C	TK-600C air/water valve	closed during normal operation					closed
V-667C	TK-600C GAC unload valve						closed
V-668C	TK-600C air/water valve						closed
V-666D	TK-600D air/water valve						closed
V-667D	TK-600D GAC unload valve						closed
V-668D	TK-600D air/water valve						closed
V-675C	TK-600C GAC unload valve						closed
V-676C	TK-600C air/water valve						closed
V-675D	TK-600D GAC unload valve						open
V-676D	TK-600D air/water valve	open					

GAC<sup>a</sup> granular activated carbon



**Appendix D 8**  
**SPARE PARTS INVENTORY LIST**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

There were no identified spare parts purchased as part of the Operable Unit 2 System Expansion. Critical components, such as in-line process pumps, are provided as 100 percent spares. Non-critical components are readily available and may be taken off-line and refurbished or replaced as necessary. However, as the Groundwater Treatment Operator acquires a spare parts inventory, this appendix reserves space for the listing.

**APPENDIX E**

**MANUFACTURERS' WARRANTIES**

**Appendix E**  
**STATEMENT & WARRANTY INDEX**  
**Operable Unit 2 Groundwater Remedy**  
**Former Fort Ord, California**

Section	Equipment	Vendor	Manufacturer/Supplier	Submittal	Subject	Remarks
13.0	Concrete Vaults & Lids:	Santa Rosa Cast Products	Nystrom Building Products	SD-13	Aluminum Lid Warranty	03/16/00
			Nystrom Building Products	SD-13	5 Year Performance Standard	03/16/00
			Santa Rosa Cast Products	SD-13	Certificate of Compliance	SF-27
23.0	Fire Alarm System	Fire-Lite Alarms, Inc.	Fire-Lite Alarms, Inc.	SD-13	Limited Warranty	
25.0	Gaskets, Viton	Down Time	Pacific Mechanical Supply	SD-13	Cert of Conformance / Compliance	
26.0	Geotextile	FML Linings, Inc.	Amoco Fabrics and Fibers Co.	SD-13	QC Certificate	
27.0	Granular Activated Carbon	US Filter/Westates	US Filter/Westates	SD-13	Buy American Act Certification	
				SD-13	Warranty Statement	1 year parts, 90 days labor
48.0	Programmable Logic Controller Modifications	Superior Electric	Superior Electric	SD-08	Guarantee for PLC Modifications	2/14/00
			Automation Direct	SD-13	Standard License	
52.0	Pump, Submersible	Pac Machine Co., Inc.	Pac Machine Co., Inc.	SD-08	Pump Guarantee	
56.0	Supervisory Control and Data Acquisition (SCADA)	Antenna	PolyPhaser Corporation	SD-06 & 13	IS-B50 Series Impulse Suppressor Safety, Installation & Warranty	Eng-F-016 12/97
		Antenna	Maxrad, Inc.	SD-06 & 13	MBS-800 Base Station Adapter Kit Installation and Warranty	MIS-MBSADAPTER
		Operator Interface	Intel	SD-13	Three Year Processor Warranty	P/N 00706 A00
61.0	Transformer, at Imjin/Abrams Wells	Pacific Gas and Electricity (PG&E)	Pacific Gas and Electricity (PG&E)	SD-13	Agreement to Perform Work	5/9/00
62.0	Transformer, at Landfill Wells	Pacific Gas and Electricity (PG&E)	Pacific Gas and Electricity (PG&E)	SD-13	Agreement to Perform Work	5/9/00
64.0	Valves, at Infiltration Galleries	Santa Fe Industrial Products	Bermad	SD-08	Buy American Act Compliance	6/9/00
65.0	Valves, at Isolation Vaults	Santa Fe Industrial Products	USACE	SD-08	Waiver to Purchase Non Buy American	SPK-2-11-006, 05/06/00
66.0	Variable Frequency Drives	Avatar Engineering	Danfoss Electronic Drives	SD-13	Standard Warranty	
67.0	Well Caps	Santa Fe Industrial Products	Santa Fe Industrial Products	SD-08	Buy American Statement	Letter 6/12/00

DISTRIBUTION LIST FOR: **DRAFT FINAL OPERATION AND MAINTENANCE MANUAL, OPERABLE UNIT 2,  
GROUNDWATER REMEDY, FORMER FORT ORD, CALIFORNIA, REVISION 1**

No. of Copies	Name	Company	Address	City and State	Zip Code	Controlled Yes or No
1	Doug Stanley	Department of the Army USACE	1325 "J" Street	Sacramento, CA	95814-2922	Yes
1	Glen Mitchell	Department of the Army USACE	1325 "J" Street	Sacramento, CA	95814-2922	Yes
1*	Gary Kamei	Department of the Army USACE	Project Office	Presidio of Monterey, CA	93944-5000	Yes
1	Dave Eisen	Department of the Army USACE	BRAC, Bldg. #4463 Gigling Road	Monterey, CA	93944-5004	Yes
1	Edwin E. Wing	IT Corporation	4005 Port Chicago Highway	Concord, CA	94520-1120	Yes
1	Peter Kelsall	IT Corporation	9201 East Dry Creek Road	Centennial, CO	80112	Yes
1	Mike Oberwise	IT Corporation	P.O. Box 1698	Marina, CA	93933	Yes
1	John Chesnutt	U.S. Environmental Protection Agency	75 Hawthorne Street, Mail SFD-8-3	San Francisco, CA	94105	Yes
1	Rizgar Ghazi	California Department of Toxic Substances Control	8800 California Center Drive	Sacramento, CA	95826	Yes
1	Jeff Raines	Tech Law, Inc.	90 New Montgomery Street Suite 1010	San Francisco, CA	94105	No
1	Grant Himebaugh	California Regional Water Quality Control Board	81 Higuera Street, Suite 200	San Luis Obispo, CA	93401-5414	No
1*	Ron Hayashi	IT Corporation	4005 Port Chicago Highway	Concord, CA	94520-1120	Yes
1*	Kara Romero	AHTNA	OU2 Groundwater Treatment Plant	Fort Ord, CA	93933	Yes
1	Don Smallbeck	Harding Lawson Associates	90 Digital Drive	Nevato, CA	94949	Yes
3	Tina Fischl	Administrative Records	BRAC, Bldg #4463 Gigling Road	Monterey, CA	93944-5004	No
1*	Project File	IT Corporation	PO Box 1698	Marina, CA	93933	Yes
1	Program File (Kathy Grider)	IT Corporation	4005 Port Chicago Highway	Concord, CA	94520-1120	Yes

Approved: \_\_\_\_\_

Glen Mitchell, USACE Project Manager

<b>TRANSMITTAL OF SHOP DRAWINGS, EQUIPMENT DATA, MATERIAL SAMPLES, OR MANUFACTURER'S CERTIFICATES OF COMPLIANCE</b> <i>(Read Instructions on the reverse side prior to initiating this form)</i>				DATE August 29, 2002		TRANSMITTAL NO.: <div style="text-align: right;">041</div>		
Section I - REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS <i>(This Section will be initiated by the contractor)</i>								
TO: Doug Stanley U.S. Army Corps of Engineers 1325 "J" Street Sacramento, CA 95814-2922			FROM: Peter Kelsall IT Corporation P.O. Box 1698 Marina, CA 93933-1698		CONTRACT NO. DACW05-96-D-0011  T.O. # 011		WAD # 02   CHECK ONE: <div style="text-align: center;"> <input checked="" type="checkbox"/> THIS IS A NEW TRANSMITTAL   <input type="checkbox"/> THIS IS A RESUBMITTAL OF TRANSMITTAL         </div>	
SPECIFICATION NO. (Cover only one section with each transmittal)			PROJECT TITLE AND LOCATION: FORMER FORT ORD, CALIFORNIA					
I T E M  N O a.	DESCRIPTION OF ITEM SUBMITTED <i>(Type, size, model number, etc.)</i>  b.	MFG. OR CONTR. CAT., CURVE DRAWING OR BROCHURE NO. <i>(See Instruction No. 8)</i> c.	NO. OF COPIES  d.	CONTRACT REFERENCE DOCUMENT <div style="display: flex; justify-content: space-around; font-size: small;"> <div>SPEC. PARA. NO. e.</div> <div>DRAWING SHEET NO. f.</div> </div>		FOR CONTRACTOR USE CODE  g.	VARIATION <i>(See Instruction No. 6)</i>  h.	FOR C E USE CODE  i.
052	Draft Final, Operation and Maintenance Manual, Operable Unit 2, Groundwater Remedy Expansion, Former Fort Ord, California, Revision 1 (For Your Information Only)	N/A	19	SOP17		F		
053	DRF for the Draft Final, Operation and Maintenance Manual, Operable Unit 2, Groundwater Remedy Expansion, Former Fort Ord, California, Revision 1 (For Your Information Only)	N/A	19	SOP17		F		
REMARKS cc: <b>CONTRACTOR QUALITY CONTROL SYSTEMS MANAGER</b> IT CORPORATION See Distribution List <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Approved with corrections as noted on submittal data and/or attached sheet(s).  SIGNATURE: _____ TITLE: <u>CONTRACTOR QUALITY CONTROL SYSTEM MANAGER</u>				I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as otherwise stated.  <div style="text-align: right;">IT CORPORATION</div>  <div style="text-align: right;">_____/PETER KELSALL</div> NAME AND SIGNATURE OF CONTRACTOR				
Section II - APPROVAL ACTION								
ENCLOSURES RETURNED (List by Item No.)			NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY				DATE	