

Interfacing a Data Acquisition System to the DSP56303

Application Note

by
*Mihai V. Micea
Vladimir Cretu
and Dan Chiciudean*

AN2087/D
Rev. 0, 12/2000



Home Page:

www.freescale.com

email:

support@freescale.com

USA/Europe or Locations Not Listed:

Freescale Semiconductor
Technical Information Center, CH370
1300 N. Alma School Road
Chandler, Arizona 85224
(800) 521-6274
480-768-2130

support@freescale.com

Europe, Middle East, and Africa:

Freescale Halbleiter Deutschland GmbH
Technical Information Center
Schatzbogen 7
81829 Muenchen, Germany
+44 1296 380 456 (English)
+46 8 52200080 (English)
+49 89 92103 559 (German)
+33 1 69 35 48 48 (French)
support@freescale.com

Japan:

Freescale Semiconductor Japan Ltd.
Headquarters
ARCO Tower 15F
1-8-1, Shimo-Meguro, Meguro-ku
Tokyo 153-0064, Japan
0120 191014
+81 2666 8080
support.japan@freescale.com

Asia/Pacific:

Freescale Semiconductor Hong Kong Ltd.
Technical Information Center
2 Dai King Street
Tai Po Industrial Estate,
Tai Po, N.T., Hong Kong
+800 2666 8080
support.asia@freescale.com

For Literature Requests Only:

Freescale Semiconductor
Literature Distribution Center
P.O. Box 5405
Denver, Colorado 80217
(800) 441-2447
303-675-2140
Fax: 303-675-2150
LDCForFreescaleSemiconductor@hibbertgroup.com

Information in this document is provided solely to enable system and software implementers to use Freescale Semiconductor products. There are no express or implied copyright licenses granted hereunder to design or fabricate any integrated circuits or integrated circuits based on the information in this document. Freescale Semiconductor reserves the right to make changes without further notice to any products herein. Freescale Semiconductor makes no warranty, representation or guarantee regarding the suitability of its products for any particular purpose, nor does Freescale Semiconductor assume any liability arising out of the application or use of any product or circuit, and specifically disclaims any and all liability, including without limitation consequential or incidental damages. "Typical" parameters which may be provided in Freescale Semiconductor data sheets and/or specifications can and do vary in different applications and actual performance may vary over time. All operating parameters, including "Typicals" must be validated for each customer application by customer's technical experts. Freescale Semiconductor does not convey any license under its patent rights nor the rights of others. Freescale Semiconductor products are not designed, intended, or authorized for use as components in systems intended for surgical implant into the body, or other applications intended to support or sustain life, or for any other application in which the failure of the Freescale Semiconductor product could create a situation where personal injury or death may occur. Should Buyer purchase or use Freescale Semiconductor products for any such unintended or unauthorized application, Buyer shall indemnify and hold Freescale Semiconductor and its officers, employees, subsidiaries, affiliates, and distributors harmless against all claims, costs, damages, and expenses, and reasonable attorney fees arising out of, directly or indirectly, any claim of personal injury or death associated with such unintended or unauthorized use, even if such claim alleges that Freescale Semiconductor was negligent regarding the design or manufacture of the part.

Abstract and Contents

This paper discusses the hardware and software aspects of interfacing a data acquisition system (DAQ) to the DSP56303 digital signal processor. Included are descriptions of a generic DAQ system, a particular DAQ system connected to the DSP56303, and a case study of this system that emulates the function of a digital oscilloscope.

1	Introduction	1
2	Description of a Generic DAQ System	2
2.1	DAQ Operation	2
2.2	ADC Performance Parameters	3
3	Example DAQ-DSP System—Overview	5
3.1	General System Architecture	5
3.2	DAQ System Architecture and Operation	5
4	Example DAQ-DSP System—Implementation Details	8
5	Case Study: Digital Oscilloscope Using the DSP56303	12
5.1	General Features	12
5.2	Graphical User Interface	13
5.2.1	Signal Display Window	14
5.2.2	Signal Spectrum Window	15
5.2.3	Control Panel	15
5.3	Digital Oscilloscope Implementation on the DSP56303	15
5.3.1	Initialization	15
5.3.2	Main Program	17
5.3.3	Oscilloscope Routines	19
5.4	Communication with the Host Computer	23
6	Conclusions	24
7	About the Authors	24
8	References	24

1 Introduction

Digital data processing and control systems have become ubiquitous in modern daily life. Information from a wide variety of environmental sources, including sound waves, light, temperature, gas pressure, radiation, and mechanical movement, is converted to digital signals which are processed so that they can communicate with intelligent user interface devices or embedded systems.

A typical approach for interfacing digital processing systems with the environment uses a modular architecture shown in Figure 1. This figure shows a bidirectional flow of signals—the system can acquire information from the outside (input) and can operate on the environment (output).




Figure 1. General Architecture of a Digital Processing System Interface

The transducer module converts non-electric environmental input signals into analogous electric signals. The data acquisition (DAQ) module contains one or more analog-to-digital converters (ADCs), which sample the analog input signals and quantize the samples into binary coded (digital) signals. A bidirectional system also contains at least one digital-to-analog converter (DAC) and a transducer that can convert analog signals back to the corresponding environmental signals.

In most cases the electric signals generated by the transducers are not suitable for direct input to the ADC. A signal conditioning block is required to adjust signal levels and impedance. This block can be included in either the transducer or DAQ module. Many systems send the data processed by the DAQ-DSP system to a host computer to provide an interactive user interface.

This paper discusses techniques for interfacing a unidirectional (input only) DAQ system to the DSP56303 digital signal processor. Both the hardware and software aspects of the interface are detailed. A generic data acquisition system is described, followed by the details involved in connecting an example DAQ system to the DSP56303. Finally, a case study is presented in which the example DAQ system and DSP56303 are used to control a simple digital oscilloscope. In this case study a host computer, which provides the display and control mechanisms (interactive user interface) of the oscilloscope, receives the processed data from the DAQ system through an Extended Capability Port (ECP) standard interface.

2 Description of a Generic DAQ System

This section describes the operation of a generic DAQ system and the parameters used to evaluate DAQ system performance.

2.1 DAQ Operation

Figure 2 is a block diagram of a generic input-only data acquisition system. The primary components of this system are an ADC and a data buffer that latches the ADC output and sends the data to the DSP. The signals in this system include:

- V_{IN} —Analog input voltage from the transducer module
- $\overline{STC}$ —Start of Conversion command to the ADC
- $\overline{EOC}$ —End of Conversion signal from the ADC
- Data—ADC output, binary-coded result of conversion
- n —Number of output bits
- $\overline{WR}$ —Data buffer write enable
- $\overline{RD}$ —Data buffer read enable
- $\overline{RD}_{DSP}$ —Read signal issued by the DSP
- DBus—DSP data bus
- $\overline{IRQ}$ —Interrupt signal to the DSP.




Figure 2. Generic DAQ System Connection Diagram

System operation is a cycle consisting of the following basic steps:

1. The DSP asserts (pulls low) the $\overline{RD}_{DSP}$ line, which triggers two events:
 - a) The ADC Start of Conversion input is asserted, initiating a new conversion cycle.
 - b) The data buffer read enable input is asserted, and the results of the previous conversion are output on the DSP data bus.
2. After an amount of time referred to as the ADC conversion time ($T_{conversion}$) has elapsed, two ADC events occur:
 - a) The result code of the new conversion is output on the ADC data lines.
 - b) The ADC acknowledges the end of conversion cycle by asserting (pulling low) the End of Conversion signal.

3. Asserting $\overline{\text{EOC}}$ has the following two results:
 - a) The data buffer's write enable signal is asserted, latching the new conversion result in the data buffer.
 - b) The DSP interrupt signal ($\overline{\text{IRQ}}$) is asserted.

The DSP interrupt handler responds to the interrupt by asserting $\overline{\text{RD}}_{\text{DSP}}$ to read the conversion result and initiate the next conversion (step 1), and the cycle repeats.

This is a simple, asynchronous system operating at maximum speed. It does not allow for variable sampling/conversion rates and requires that the controlling DSP is fast enough to retrieve and store the conversion results in one ADC cycle ($T_{\text{conversion}}$ period). Therefore, this system can usually be found in relatively low-to-medium speed data acquisition and digital processing products.

2.2 ADC Performance Parameters

The performance of a DAQ system in the frequency and amplitude domains is usually evaluated in terms of a few simple ADC parameters. In the frequency domain, these parameters are:

- **F_s** —The **sampling rate** is the number of times per second the analog input signal is sampled and converted to digital representation.
- **$T_{\text{conversion}}$** —The **conversion time** is the amount of time allotted per sample and is equal to the reciprocal of the sampling rate:

$$F_s = \frac{1}{T_{\text{conversion}}} \text{ [Hz]} \quad \text{Eqn. 1}$$

- **$f_{\text{max in}}$** —The **maximum input frequency** that can be processed without aliasing. According to the Nyquist Theorem of Sampling, this frequency must be less than half of the sampling frequency:

$$f_{\text{max in}} < \frac{F_s}{2} \text{ [Hz]} \quad \text{Eqn. 2}$$

Thus, the sampling rate is the limiting parameter of the ADC in the frequency domain.

Parameters in the amplitude domain include:

- **FSR**—The **full scale range** is the difference between the minimum and maximum current or voltage allowed at the analog input lines. Typical values of full scale range for voltage-input ADCs are listed in Table 1.

Table 1. Typical Voltage FSR

FSR	Bipolar Input	Unipolar Input
20	-10 to +10	0 to 20
10	-5 to +5	0 to 10
5	-2.5 to +2.5	0 to 5

- **n** —The **number** of bits in the encoded ADC conversion result. The larger n is, the better the precision of the ADC output.
- **LSB**—The **least significant bit** of the digital output indicates the resolution or granularity of the ADC:

$$\text{LSB} = \frac{\text{FSR}}{2^n} \text{ [V or A]} \quad \text{Eqn. 3}$$

Table 2 lists the parameters for a particular ADC.

Table 2. Parameters for a Particular ADC

Parameter	Initial Specification	Derived Specifications
Sampling Rate	$F_s = 100 \text{ kHz}$	$T_{\text{conversion}} = 10 \mu\text{s}$ $f_{\text{maxIN}} < 50 \text{ kHz}$
Full Scale Range	$\text{FSR} = 10 \text{ V}$	Bipolar input: $-5 \text{ to } +5\text{V}$ Unipolar input: $0 \text{ to } +10\text{V}$
Resolution	$n = 10 \text{ bits}$	$\text{LSB} = 9.76 \text{ mV}$

One example of an actual ADC which is used on the DSP56303 and DSP56307 Evaluation Modules (EVMs) is Crystal Semiconductor's CS421x audio CODEC family. The specifications for these devices are listed in Table 3.

Table 3. Parameters for the CS421x CODEC Family

Parameter	Specifications	Unit
ADC type	Multimedia Audio CODEC	—
Operating principle	64x oversampling delta-sigma	—
Sampling rate	$F_s = 4 \text{ to } 50$	kHz
Conversion period	$T_{\text{conversion}} = 250 \text{ to } 20$	μs
Maximum input frequency	$f_{\text{maxIN}} < 2 \text{ to } 25$	kHz
Conversion resolution	$n = 8 \text{ or } 16$	bit
Full scale range	$\text{FSR} = 2.8$	V_{pp}
Least significant bit (resolution)	$\text{LSB} = 10.93 \text{ or } 0.04$	mV

These devices are suitable for audio applications. Applications requiring higher sampling rates or larger input signal ranges require higher performance ADCs.

3 Example DAQ-DSP System—Overview

This paper proposes a data acquisition and processing system based on the DSP56303 processor. The analog signal acquisition and conversion operation is performed by a particular DAQ system under the direct control of the DSP. Although the ADC in the DSP56303 Evaluation Module (the Crystal Semiconductor's CS4215 Multimedia Audio CODEC) is limited to the audio frequency range, the principles illustrated here can be extended to provide a simple solution for data acquisition and processing systems requiring higher performances than audio applications.

3.1 General System Architecture

A block diagram of the proposed system is shown in Figure 3. It features three main components:

- A DAQ system, described in the remainder of this section.
- A DSP56303-based board which controls overall system operation and performs all the digital data processing needed for a particular application.
- A host computer which functions as a graphical user interface and provides an interactive system control platform.

The DAQ-DSP connection is described in detail in this paper. The DSP-host computer connection is described in Motorola application note, *ECP Standard Parallel Interface for DSP56300 Devices* (order number AN2085/D).




Figure 3. Example System Block Diagram

3.2 DAQ System Architecture and Operation

Figure 4 on page 6 is a diagram of the DAQ employed in the proposed system.




Figure 4. Example System DAQ Architecture

The Burr-Brown ADS774 was selected as the analog-to-digital component of the DAQ because of its simple interface and command requirements as well as performance that is very well-suited to illustrate the DAC—DSP interconnection described in Section 1. Table 4 lists the parameters of the ADS774. The parameters in bold type are the ones selected for the example system.

Table 4. ADS774 Main Parameters

Parameter	Specification	Unit
Operating principle	Successive approximation with capacitor array	—
Conversion resolution	n = 12 or 8	bit
Minimum conversion time	T _{conversion} = 8 or 5.5	μs
Maximum sampling rate	F _S = 117 or 125	kHz
Full scale range Bipolar input voltage Unipolar input voltage Full scale range Bipolar input voltage Unipolar input voltage	FSR = 20 -10 to +10 0 to +20 FSR = 10 -5 to +5 0 to +10	V
Internal reference voltage	V _{REF} = 2.5	V

Because the ADC is configured for 12-bit conversion resolution and 20-volt FSR, the resolution of the system expressed in terms of the LSB is

$$LSB = \frac{FSR}{2^n} = \frac{20}{2^{12}} = 4.88 \text{ mV} \quad \text{Eqn. 4}$$

Two 74LS245-type octal bus transceivers, connected in parallel, serve as the 12-bit data buffer. These devices were selected because they can shift the voltage level between the ADS774 5 V outputs and the DSP56303 3.3 V inputs.

The DAQ system is configured to operate according to the timing diagram shown in Figure 5 and the specifications in Figure 5 (source: Burr-Brown Corporation, *Data Conversion Products*, 1995).




Figure 5. ADS774 Timing Diagram

Table 5. ADS774 Timing Specifications

Symbol	Parameter	Unit	Minimum	Maximum
t_{HRL}	Low $R/\overline{C}$ pulse width	ns	25	—
t_{DS}	Status delay from $R/\overline{C}$	ns	—	200
$T_{conversion}$	Conversion time	μs	8	—
t_{HDR}	Data valid after $R/\overline{C}$ low	ns	25	—
t_{HS}	Status delay after data valid	ns	75	375

The ADS774 Status pin, which acknowledges the end of a conversion cycle, is not used in this system. Instead, the timer interrupt routine on the DSP determines the desired conversion time, which is longer than the $T_{conversion}$ of the ADS774. This routine also initiates the conversion cycle and retrieves the data result from the data buffer.

4 Example DAQ-DSP System—Implementation Details

The interface between the DSP56303 and the DAQ in the example system is shown in Figure 6. The interface uses the DSP's Port A lines as follows:

- A Read signal, $\overline{RD}$, simultaneously initiates a new conversion cycle on the DAQ and enables the output of the DAQ data buffer to read the current conversion result.
- DSP Data Bus lines 8–19 (DDB_{8–19}) receive the 12-bit conversion result. (Lines DDB_{0–7} are used by the DSP56303 Evaluation Module to transfer data from the on-board EEPROM.)




Figure 6. Example System DAQ-DSP Connection

Figure 7 is a general timing diagram of the example system operation.




Figure 7. Example System Timing Diagram

The falling edge of $\overline{RD}$ triggers a new conversion cycle on the ADC and simultaneously loads the ACQ buffers with the previous conversion result.

The rising edge of $\overline{RD}$ strobes the buffered data to the DDB8–19 lines for storing into a predefined data buffer in the DSP.

After a $T_{\text{conversion}}$ delay, the result code of the current conversion cycle is available at the data output lines of the ADC, ready to be buffered.

The full $\overline{RD}$ cycle period must be long enough to include the ADC conversion period (8 μs) plus a small delay to allow for the data transfer from the buffer to the DSP. The $\overline{RD}$ period is about 9 μs in the example system.

Data acquisition is fully controlled by DSP software. Code Example 1 provides a general framework for a data acquisition and processing program on the DSP56303. This program initializes chip parameters (chip clock and PLL, interrupts and Port A access), sets up a 512-word data buffer to store conversion result codes, and initializes Timer0, which controls the overall data acquisition cycle by issuing a level 2 interrupt every 9 μ s. Other user-defined routines can be added to process the acquired data when the buffer is full.

Code Example 1. Data Acquisition and Processing Program on the DSP56303

```

I_RESET      equ    $000000      ; Hardware RESET Vector.
M_PCTL       equ    $FFFFFFD     ; PLL Control Register.

M_IPRP       equ    $FFFFFFE     ; Interrupt Priority Register Peripheral

M_BCR        equ    $FFFFFFB     ; Bus Control Register.
M_AAR1       equ    $FFFFFF8     ; Address Attribute Register 1.

M_TCSR0      equ    $FFFF8F     ; Timer0 Control/Status Register.
M_TLR0       equ    $FFFF8E     ; Timer0 Load Register.
M_TCPR0      equ    $FFFF8D     ; Timer0 Compare Register.
I_TIM0C      equ    $000024     ; Timer0 Compare Interrupt Vector.

BUFFER       equ    $000000      ; Data Buffer for conversion results.
BUFFLEN      equ    511         ; Length of data buffer.
BUFFFULL     equ    $0007FF     ; Flag set when the data buffer is full.
DAQ          equ    $002000     ; DAQ address mapped on the external X memory
                                ;; space.

;
; Other variables can be defined here as required.
;

; Main program:

                org    P:I_RESET
                jmp     start

                org    P:I_TIM0C      ; Timer0 interrupt handler setup.
                jsr     intr_t0

start          org    P:$100          ; Start of the main program.

                movep   #$060003,X:M_PCTL ; Enable and set PLL: 16.934 MHz on-board clk
                                ;; with MF=4. The resulting DSP internal clk =
                                ;; 67.736 MHz.

                movep   #$11,X:M_AAR1  ; Initialize Port A: external access type,
                                ;; AAR1 pin positive polarity to avoid EEPROM
                                ;; selection.

                bset    #5,X:M_BCR      ; Enable external X data space, number of wait
                bset    #6,X:M_BCR      ;; states = 31.
                bset    #7,X:M_BCR
                bset    #8,X:M_BCR
                bset    #9,X:M_BCR

                bset    #8,X:M_IPRP     ; Set Timer0 interrupt priority level to 2.
                bset    #9,X:M_IPRP

                bclr    #9,sr           ; Unmask all interrupts after RESET.
                bclr    #8,sr

                move     #BUFFER,R6     ; Initialize the R6 register as current data
                                ;; pointer in BUFFER.
                move     #0,BUFFFULL    ; Initialize the flag used in the main

```

Code Example 1 (Continued). Data Acquisition and Processing Program on the DSP56303

```
                                ;; program to indicate that the data
                                ;; data buffer is full.

    movep  #305,X:M_TCPRO        ; Initialize Timer0 compare value so that
                                ;; timer interrupt = 111.04 kHz
                                ;; (timer period = 9.00 µsec).
    movep  #$302a05,X:M_TCSR0    ; Initialize Timer0 Control Register and start
                                ;; timer.

;
; Other routines can be added here to process the data acquired in the
;; 512-word buffer that starts at X:$000000 address. BUFFULL flag
;; can be used to test if the buffer is available for processing.
;
```

Timer0 issues a level 2 interrupt every 9 µs to read a new conversion result into the DAQ data buffer and simultaneously initiate a new ADC conversion cycle. The Timer0 interrupt handling routine in Code Example 2 acquires data from the DAQ buffer through the Port A interface and writes the result into its own data buffer, called BUFFER. The BUFFULL flag is used to alert the main program that the data buffer is full and ready for further processing.

The Timer0 interrupt handler first checks BUFFER to see if it is full. If the buffer is full, the BUFFULL flag is set and the handler terminates. If the buffer is not full, the interrupt handler reads another conversion result code through the Port A DDB₈₋₁₉ lines and stores it in the next location in the buffer, using the R6 register as a pointer. For reasons described later, the handler extracts the 8 most significant bits from each 12-bit conversion result; other applications can use the full 12-bit resolution for an improved data processing precision.

Code Example 2. Timer0 Interrupt Handler

```
intr_t0      jset   #0,X:BUFFULL,intr_end    ; Test if the buffer is already full. If
                                                ;; so, exit the handler.

              move   X:DAQ,B                 ; Read the current conversion result into B
                                                ;; accumulator, and initiate a new conversion
                                                ;; cycle.
              extractu #$8024,B,A            ; Extract the 8 most significant bits from the
                                                ;; conversion result.
              clr    B A0,X:(R6)+            ; Store current result into data buffer.
              clr    A                       ; If the data buffer pointer (R6) reaches the
                                                ;; end of buffer, set the BUFFULL flag.

              move   #BUFLen,A0
              move   R6,B0
              cmp    A,B
              jgt    intr_end                ; BUFFER is not full.

              move   #1,X:BUFFULL            ; Set BUFFULL flag.
intr_end      rti
```

The timer interrupt approach was selected for two important reasons:

1. This approach offers an easy and relatively exact timing solution, both for acquiring data from the DAQ system and for commanding the conversion cycles, without requiring external hardware such as timer or counters in the DAQ system to drive the sampling rate. The acquisition period can easily be modified to accommodate the requirements of a particular application by reprogramming the Timer0 Load Register (TLR0) to a new counting period.
2. DSP processing resources are freed up during the acquisition cycle and available for use by other user-defined routines in the main program.

The data buffer in this program can be configured and used in several ways. One simple approach is to use two data buffers—one for current acquisition and storing operations in the timer interrupt handler, and one for data processing in the main program. When a buffer is filled, the interrupt handler sets the `BUF_FULL` flag to signal the main program that the buffer is ready for processing, and switches to the other buffer for storing subsequent acquired data. The two buffers can be defined at the same base address, one in X memory and one in Y memory.

Another approach is a circular buffer which allows access from the main program (read) and from the interrupt handler (write).

5 Case Study: Digital Oscilloscope Using the DSP56303

To illustrate the practical application of our example system, this section describes the design of a digital oscilloscope using the DSP56303, with a host computer providing a graphical user interface and general control panel.

5.1 General Features

The general architecture of the oscilloscope is based on the block diagram in Figure 3 on page 5. The analog voltage input to the oscilloscope is applied to the DAQ system described in Section 3.2 on page 5, which features the Burr-Brown Analog ADS774 ADC. The digitized, buffered ADC output is transferred to the DSP56303 via Port A.

The DSP performs all of the processing required to provide the functions which a typical oscilloscope applies to a periodic input signal:

- Signal synchronization
- Minimum and maximum amplitude
- Frequency and period
- Fast Fourier Transform

A flexible and intuitive graphical user interface for the digital oscilloscope was designed using a host computer. Data display windows, buttons, and slide bars provide a control panel that is easy to use. To maximize throughput while maintaining system flexibility, the ECP standard parallel interface is used to connect the DSP to the host computer.

Table 6 summarizes the main functional parameters of the digital oscilloscope.

Table 6. Digital Oscilloscope Parameters

Parameter	Specification or Description
Analog Signal Interface	
Input signal voltage range	-10 to +10 V -5 to +5 V 0 to 10 V 0 to 20 V
Sampling rate	112K samples per second maximum.
Input signal frequency range	0 to 55.5 kHz
Input channels	1
Input impedance	12 k Ω (10 V _{pp} input) 50 k Ω (20 V _{pp} input)
Conversion resolution	12 bits
Least significant bit (LSB)	2.44 mV (10 V _{pp} input) 4.88 mV (20 V _{pp} input)

Table 6. Digital Oscilloscope Parameters (Continued)

Parameter	Specification or Description
Graphical User Interface	
General features	Real-time graphical display of acquired signal – time domain. Real-time graphical display of acquired signal – frequency domain. Basic signal parameters calculation – automatic or manual modes.
Signal display modes	RUN Mode—real-time display FREEZE Mode—static display of a captured signal
Variable time base	256 stages ranging from 588 to 123,460 μ s per division
Synchronization modes	Rising edge Falling edge Variable threshold in the -10 to $+10$ V range
Amplitude calculation	Automatic Mode: minimum and maximum amplitude values displayed for 512 signal samples Manual Mode: two mouse-controlled horizontal amplitude cursors.
Frequency/period calculation	Two vertical time cursors moved with the mouse. Oscilloscope calculates automatically the corresponding time and frequency values.
Parameters calculated and displayed continuously	Current time base in μ s/DIV Sampling frequency in Sps (Samples per second) Synchronization threshold level in V Instant values corresponding to the two horizontal amplitude cursors in V. Instant period and frequency values corresponding to the two vertical time cursors, in seconds and Hz. Signal frequency spectrum (FFT coefficients). Instant frequency value corresponding to the vertical cursor in the spectrogram, in Hz

5.2 Graphical User Interface

The graphical user interface emulates the display and control panel of an actual oscilloscope. It combines the features of an analog oscilloscope with the advantages of digital processing:

- Continuous calculation of signal parameters (amplitude, frequency, period)
- Calculations performed either automatically or with the use of special, interactive, mouse-controlled cursors
- Facilities for changing the oscilloscope time base and synchronization modes
- Memory capability
- Real-time FFT calculation and graphic display of the corresponding frequency spectrum

The GUI program was developed under the LINUX platform using the SVGALib (Super VGA graphical library) in console mode. Figure 8 on page 14 is a screen capture showing the GUI layout.




Figure 8. Digital Oscilloscope Graphical User Interface

The oscilloscope GUI has separate windows for the signal, frequency spectrum, and control panel.

5.2.1 Signal Display Window

The signal display window displays the acquired signal in both real-time mode (RUN Mode) and as a static image (FREEZE Mode). A grid is also displayed for better signal viewing.

Two sets of interactive cursors are available to calculate signal parameters—a pair of horizontal red cursors for amplitude, and a pair of green vertical cursors for frequency/period. Each cursor can be placed anywhere over the displayed signal using the mouse (the mouse pointer is colored in white) or with the slide bars provided in the control panel.

A sliding arrow on the left side of the display grid indicates the current signal synchronization level, which can be modified over the -10 V to $+10\text{ V}$ range using the corresponding slide bar in the control panel.

The following parameters of the current signal and oscilloscope are displayed below the signal:

- Synchronization level (V)
- Sampling frequency (samples per second)
- Time per division (μs)
- Time period and frequency of vertical cursors (μs)
- Amplitudes of lower and upper horizontal cursors (V)

5.2.2 Signal Spectrum Window

The oscilloscope calculates a FFT over a 512-sample buffer and displays the frequency components on the signal spectrum window. An interactive vertical cursor, which can be manipulated by either the mouse or a slide bar in the control panel, can be placed anywhere on the displayed frequency spectrum. The frequency at which the cursor is placed is also displayed.

5.2.3 Control Panel

The interactive control panel provides an easy way to change the functional parameters of the oscilloscope.

- The Trigger Level slide bar adjusts the signal synchronization level to any point in the signal input range (–10 V to +10 V).
- The Time/DIV slide bar controls the time base.
- The Time Cursor 1 and Time Cursor 2 slide bars manipulate the vertical time cursors in the signal display window.
- The Ampl. Cursor 1 and Ampl. Cursor 2 slide bars control the position of the horizontal amplitude cursors.
- The Pos Trg button selects the rising or falling edge of the input signal for synchronization.
- The Automatic/Manual button selects the trigger for calculating the point-to-point signal amplitude. In automatic mode, the oscilloscope calculates the minimum and maximum signal amplitude values over a buffer of 512 samples, and positions the horizontal cursors accordingly in the signal display window.
- The Run/Freeze button toggles the signal display between real-time mode and a 512-sample snapshot.

5.3 Digital Oscilloscope Implementation on the DSP56303

The digital oscilloscope program on DSP56303 is composed of four main modules: an initialization sequence, the main program module, oscilloscope-specific digital signal processing routines, and communication routines with the host computer.

5.3.1 Initialization

Code Listing 1 is the initialization module of the oscilloscope program. It declares the various equates, macro includes and variables used by the program, initializes the DSP, and sets up the timer interrupt handler routine needed for data acquisition operations.

Code Listing 1. Oscilloscope Initialization

```

M_PCTL      equ    $FFFFFD          ; PLL Register.
I_RESET     equ    $000000          ; Interrupt setup equates.
I_TIM0C     equ    $000024
M_IPRC      equ    $FFFFFF
M_IPRP      equ    $FFFFFE

M_TCSR0     equ    $FFFF8F          ; Timer0 Registers.
M_TCPR0     equ    $FFFF82
M_TLR0      equ    $FFFF8E
M_TCPR0     equ    $FFFF8D
M_TCR0      equ    $FFFF8C

M_HPCR      equ    $FFFFC4          ; HI08 Port Registers.
M_HDDR      equ    $FFFFC8
M_HDR       equ    $FFFFC9

M_BCR       equ    $FFFFFB          ; Bus Interface Registers.
M_AAR1      equ    $FFFFF8
;

```

Code Listing 1 (Continued). Oscilloscope Initialization

```

; Variables used in the program.
;
BUFFER      equ      $000000      ; Data buffer for acquired samples.
BUFFLEN     equ      511
DAQ         equ      $002000      ; DAQ System address mapped on the
                                   ;; external X: memory space.

HOSTCLK     equ      8            ; ECP communication variables
PERIPHCLK   equ      9
PERIPHACK   equ      10
nACKREVERSE equ      11
HOSTACK     equ      12
nREVERSEREQUEST equ 13

SAMPLE_RDY  equ      $7FF        ; Flag set by the timer interrupt
                                   ;; handler when a new conversion result
                                   ;; is ready to be read from DAQ.
TRIG_TYPE   equ      $7FE        ; Parameter to set the trigger type.
SYNC_LEVEL  equ      $7FD        ; Sets the synchronization level for
                                   ;; signal acquisition.
MAX_VAL     equ      $7FC        ; Stores the maximum sample value from
                                   ;; the data buffer.
MIN_VAL     equ      $7FB        ; Stores the minimum sample value.

POINTS      equ      512        ; Variables used by the 'fftr2a' macro.
COEF        equ      $400

;
; Macros included for calculating the FFT.
;
        include 'siggen'
        include 'sincos'
        include 'outdata'
        include 'bitrev'
        include 'fftr2a'

        sincos POINTS, COEF      ; Initializes the sin-cos tables.
;
; P: memory space setup
;
        org      P:I_RESET      ; Reset vector.
        jmp      Oscilloscope
        org      P:I_TIM0C      ; Timer0 interrupt vector setup.
        jsr      Intr_T0
        org      p:$100        ; Base of the Oscilloscope Program.
Oscilloscope
        movep    #$060003, X:M_PCTL ; Enable PLL: DSP internal clock
                                   ;; 67.736 MHz.
        move     #0, VBA        ; Interrupts setup: Timer0 will have
        bset     #8, X:M_IPRP    ;; the IPL=2.
        bset     #9, X:M_IPRP
        bclr     #9, SR
        bclr     #8, SR
        movep    #$11, X:M_AAR1  ; Port A initialization
        bset     #5, X:M_BCR     ; Enable external X data space, number
        bset     #6, X:M_BCR    ;; of wait states = 31.
        bset     #7, X:M_BCR
        bset     #8, X:M_BCR
        bset     #9, X:M_BCR
        movep    #0, X:M_TLR0    ; Timer0 setup sequence.
        movep    #$302a04, X:M_TCSR0
        bsr      ECP_init       ; Initialize the ECP data link to the
                                   ;; host.
;
; Timer0 interrupt handling routine. Sets the SAMPLE_RDY flag to inform the
;; acquisition routine ('Acq_sample') that a new conversion cycle can begin.
;
Intr_T0
        bset     #0, X:SAMPLE_RDY
        rti

```

5.3.2 Main Program

Code Listing 2 is a listing of the main program for the digital oscilloscope. Figure 9 on page 17 is a flowchart of the main program. The jagged arrows in the figure represent asynchronous events, which imply wait states on the receiving side. These events include:

- ECP data transactions between DSP and the host.
- DSP timer interrupts which acknowledge sample acquisition operations.




Figure 9. Oscilloscope Main Program Flowchart

Code Listing 2. Oscilloscope Main Program

```

;
; Main program.
;
Main
    move    #BUFFER,R0                ; Set R0 as the pointer to the
                                      ;; acquisition buffer.
    jsr     ECP_init                  ; Initialize the ECP data link to host.
    jsr     Host_sync                 ; Communication synchronization with
                                      ;; the host computer.
    jsr     ECP_read                  ; Read first byte-wide parameter
    move    A0,X:TRIG_TYPE            ; from host: Signal
                                      ;; synchronization trigger type.
    jsr     ECP_read                  ; Read the next parameter:
    move    A0,X:SYNC_LEVEL           ; Signal synchronization level.
    jsr     ECP_read                  ; Read the next parameter: Current
    clr     B                         ; oscilloscope timebase value.
    insert  #$8008,A0,B               ; Setup the counting period
    move    B0,X:M_TCPR0              ; for Timer0.

;
; Oscilloscope starts the input signal sampling and its specific processing
;; procedures.
;
    jsr     Syncro                    ; Signal synchronization routine.
    jsr     Acq_buffer                ; Acquire a buffer of input samples.
    jsr     Min_max                   ; Calculate the minimum and maximum
                                      ;; values of acquired samples
                                      ;; in BUFFLEN.

;
; Send the results of processing back to host computer.
    move    #BUFFER,R0                ; Send the acquired data buffer.
    do      #BUFFLEN,_send_buffer
    move    X:(R0)+,A0
    bsr     ECP_write
_send_buffer

    move    X:MAX_VAL,A0               ; Send the maximum calculated value
    jsr     ECP_write                  ; over a buffer of acquired samples.

    move    X:MIN_VAL,a0               ; Send the minimum calculated value
    jsr     ECP_write                  ; over a buffer of acquired samples.

;
; Start the FFT calculation for a buffer of acquired input samples
;
    clr     A                         ; Initialize a buffer in Y: memory
    move    #BUFFER,R0                ; corresponding to BUFFER
    do      #BUFFLEN,_init_ybuf       ; for FFT algorithm.
    move    A0,Y:(R0)+
_init_ybuf

    fftr2a POINTS,BUFFER,COEF          ; Call the 'fftr2a' macro developed by
    nop                               ; Motorola, Incorporated, to calculate
                                      ;; the FFT on DSP56300 family.
                                      ;; Macro inputs:
                                      ;;   POINTS—number of FFT points;
                                      ;;   BUFFER—start of input data buffers
                                      ;;         (normally ordered)
                                      ;;   COEF—start of sine/cosine table.
                                      ;; Macro outputs: POINTS locations
                                      ;; (NOTE: Output data is bit-reversed.)
                                      ;;   X:BUFFER—real values
                                      ;;   Y:BUFFER—imaginary values
    bitrev POINTS,BUFFER               ; Call the 'bitrev' macro developed by
                                      ;; Motorola, Incorporated, for the

```

Code Listing 2 (Continued). Oscilloscope Main Program

```

; DSP56300 family, to unscramble the
; results from 'fft2ra' macro.
;
; Send the results of FFT to host computer
;
    move    #BUFFER,R0                ; Base of the X: and Y: result buffers.
    do      #BUFFLEN,_send_fft
;
    move    X:(R0),A0                ; Send the real part of a coefficient.
    bsr     ECP_write
    extract #8008,A,A
    bsr     ECP_write
;
    move    Y:(R0)+,A0                ; Send the imaginary part of a
    bsr     ECP_write                ; coefficient.
    extract #8008,A,A
    bsr     ECP_write
_send_fft
;
; Loop back to acquire and process the next buffer of samples.
;
    jmp     Main

```

5.3.3 Oscilloscope Routines

The main program calls specific routines to perform the basic oscilloscope functions. These functions, in the order in which they are called, are:

1. **Syncro**—Synchronizes the input signal on the rising or falling edge at a specified voltage level.
2. **Acq_buffer**—Buffers a set of input signal samples.
3. **Min_max**—Calculates the minimum and maximum values in the buffer.
4. **fftr2a** and **bitrev**—DSP56300 library routines developed by Motorola to perform FFT calculations.

The Syncro and Acq_buffer routines also call the **Acq_sample** routine, which acquires a single input signal sample.

5.3.3.1 Synchronizing the Oscilloscope to the Input Signal

The Syncro routine attempts to synchronize to the input signal using the following input parameters:

- **TRIG_TYPE**—Determines whether synchronization occurs while the signal is rising or falling.
- **SYNC_LEVEL**—The voltage level of the signal at which synchronization begins.

The synchronization procedure acquires input signal samples and ignores them until both of the following conditions are met:

1. The signal is rising or falling according to the TRIG_TYPE parameter, and
2. The voltage level of the input signal is within a predefined tolerance of SYNC_LEVEL.

When these conditions are met, the routine exits successfully. If these conditions are not met before 2048 samples are acquired, it is assumed that the input signal is not periodic over 512 samples, which is the size of the data buffer defined by the variable BUFFLEN, and the routine exits without synchronizing.

Figure 10 on page 20 illustrates the synchronization procedure on a periodic sine wave.




Figure 10. Signal Synchronization Procedure

The Syncro routine is given in Code Listing 3.

Code Listing 3. Signal Synchronization Routine (Syncro)

```

Syncro
    move    #0,X0                                ; X0 is the sample counter used by the
                                                ;; 'Counts' routine, which forces
                                                ;; Syncro to abort when X0 = 2048
                                                ;; samples.
    move    X:TRIG_TYPE,A0
    jset    #0,A0,_neg_value1

_pos_value1
    move    #0,X0
    jsr     Pozitive
_neg_value1
    move    #0,X0
    jsr     Negative
_pos_value2
    move    #0,X0
    jsr     Pozitive
    move    X:TRIG_TYPE,A0
    jclr    #0,A0,_continue
_neg_value2
    move    #0,X0
    jsr     Negative
_continue
    rts

Pozitive
                                                ; Acquire input samples and ignore them
                                                ;; as long as they are higher than the
                                                ;; synchronization level, SYNC_LEVEL.
    jsr     Counts
    jset    #0,B,_end_counts
    jsr     Acq_sample                        ; See Code Listing 6 on page 23.
    clr     B
    move    X:SYNC_LEVEL,B0
    dec     B
    cmp     B,A
    jgt     Pozitive
_end_pozitive
    rts

```

Code Listing 3 (Continued). Signal Synchronization Routine (Syncro)

```

Negative                                     ; Acquire input samples and ignore them
                                           ;; as long as they are lower than the
                                           ;; synchronization level, SYNC_LEVEL.

        jsr    Counts
        jset   #0,B,_end_negative
        jsr    Acq_sample                  ; See Code Listing 6 on page 23.
        clr    B
        move   X:SYNC_LEVEL,B0
        inc    B
        cmp    B,A
        jle    Negative
_end_negative
        rts

Counts                                       ; Increment sample counter X0.
                                           ;; If X0 = 2048, set bit 0 of
                                           ;; accumulator B as a flag to abort
                                           ;; Syncro routine.

        clr    A
        move   X0,A0
        inc    A
        nop
        move   A0,X0
        clr    B
        move   #2048,B0
        cmp    B,A
        jle    _end_counts
_end_counts
        bset   #0,B
        rts

```

5.3.3.2 Buffering Acquired Input Data Samples

After the signal synchronization routine has been completed, the main program calls the Acq_buffer routine to acquire BUFFLEN (512) samples and store them in a data buffer in X memory starting at address BUFFER. This routine is listed in Code Listing 4.

Code Listing 4. Buffer Routine (Acq_buffer)

```

Acq_buffer
        move   #BUFFER,R0
        do     #BUFFLEN,_acq_buff
        jsr    Acq_sample                  ; See Code Listing 6 on page 23.
        move   A0,X:(R0)+
_acq_buff
        rts

```

5.3.3.3 Calculating Minimum and Maximum Values

The Min_max routine listed in Code Listing 5 calculates the minimum and maximum sample values in the data buffer starting at X address BUFFER. The results are stored in the variables MIN_VAL and MAX_VAL.

Code Listing 5. Minimum / Maximum Routine (Min_max)

```
Min_max
    clr    A
    nop
    move   A0,X:MAX_VAL
    move   #$FF,A0
    move   A0,X:MIN_VAL
    move   #BUFFER,R0
    do     #BUFFLEN,_minmax
    clr    A
    move   X:(R0)+,A0
    clr    B
    move   X:MAX_VAL,B0
    cmp    B,A
    jle    _lower
    move   A0,X:MAX_VAL
_lower
    clr    B
    nop
    move   X:MIN_VAL,B0
    cmp    B,A
    jgt    _higher
    move   A0,X:MIN_VAL
_higher
_minmax
    rts
```

5.3.3.4 FFT Calculations

The main program calls the `fftr2a` and `bitrev` macros developed by Motorola to perform fast Fourier calculations for devices in the DSP56300 family.

The `fftr2a` macro uses the following variables:

- Inputs:
 - **POINTS**—The number of FFT points (512 in this application).
 - **BUFFER**—The base address of the data buffers (normally ordered) used by the macro in both X and Y memory spaces.
 - **COEF**—The base address of the sine/cosine table.
- Outputs:
 - **X: BUFFER**—The real values of the FFT results.
 - **Y: BUFFER**—The imaginary values of the FFT results.

Because the output of the `fftr2a` macro is bit-reversed, the `bitrev` macro is called to unscramble the data in BUFFER.

5.3.3.5 Acquiring a Single Data Sample

The `Acq_sample` routine listed in Code Listing 6 acquires a single input signal sample from the DAQ system through the DSP56303 Port A peripheral. This second-level routine is called by the `Syncro` and `Acq_buffer` routines.

When Acq_sample is called, Timer0 is enabled to count down the time base delay. The program then polls the SAMPLE_RDY flag until it is set by the interrupt handler which is called when Timer0 counts to zero. The routine then reads the current conversion result from the DAQ and extracts the 8 least significant bits. This is done to accommodate the other data processing routines, which all work with byte-wide data. The 8-bit result is returned in the A0 accumulator.

Code Listing 6. Acquiring a Single Data Sample (Acq_sample)

```

Acq_sample      bclr    #0,X:SAMPLE_RDY      ; Clear the acquisition flag.
                bset    #0,X:M_TCSR0        ; Start the timer to count down a
                                                ;; time base delay.
_sample_wait    move    X:SAMPLE_RDY,A0      ; Wait for the timer to issue an
                jclr    #0,A0,_sample_wait  ;; interrupt and set the flag.
                bclr    #0,X:M_TCSR0        ; Stop the timer.
                clr     A
                move    X:DAQ,B              ; Read the conversion result from DAQ
                                                ;; into accumulator B and start
                                                ;; a new conversion cycle.
                extractu #$8024,B,A          ; Extract the 8 least significant bits.
                rts

```

5.4 Communication with the Host Computer

Because of the relatively high transfer rates needed to set the functional parameters of the oscilloscope on the DSP and to communicate the results back to the host computer, the Extended Capabilities Port (ECP) parallel interface standard is used as the communication between the DSP56303 and the host computer. A more complete description of the implementation of this interface can be found in Motorola application note, *ECP Standard Parallel Interface for DSP56300 Devices* (order number AN2085/D).

6 Conclusions

Digital signal processors such as the DSP56303 provide a convenient and efficient link between a data acquisition (DAQ) system and the user interface provided by a host computer. The example system described here illustrates the hardware and software considerations involved in implementing DAQ-DSP communication. The principles illustrated here can be extended to higher-performance systems by selecting an ADC with a faster sampling rate and extending the software algorithms to accommodate larger data widths.

7 About the Authors

Mihai V. Micea is a lecturer at the Computer Software and Engineering Department at the Politehnica University of Timisoara, and Executive Director of the DSP Applications Lab Timisoara (DALT) sponsored by Digital DNA from Motorola.

Vladimir Cretu is a professor and Director of the Computer Software and Engineering Department at the Politehnica University of Timisoara, and Director of the DSP Applications Lab Timisoara (DALT) sponsored by Digital DNA from Motorola.

Dan Chiciudean is a student at the Automation and Computer Science Faculty at the Politehnica University of Timisoara, and a member of the research and development team at DALT.

Contacts:

- micha@dsplabs.utt.ro
- <http://dsplabs.utt.ro/dalt/>

8 References

DSP56000 24-bit Digital Signal Processor Family Manual (order number DSP56KFAMUM/AD), Motorola, 1995.

DSP56300 24-bit Digital Signal Processor Family Manual (order number DSP56300FM/D), Motorola, 1997

DSP56303 User's Manual (order number DSP56303UM/AD), Motorola, 1996.

DSP56303 Evaluation Module User's Manual (order number DSP56303EMUM/AD), Motorola, 1999.

Motorola DSP Assembler Reference Manual, Motorola, 1999.

Digital Signal Processing Principles, Algorithms and Applications, A J. G. Proakis and D. G. Manolakis, 3rd edition, Prentice-Hall, 1996.

Digital Signal Processing: A Practical Approach, E. C. Ifeachor, B. W. Jervis, Addison-Wesley Publishing Company, 1993.

Burr-Brown IC Data Book, Data Conversion Products - 1995", Burr-Brown Corporation, 1995.

ADS774, Microprocessor-Compatible Sampling CMOS Analog-to-Digital Converter, Product Data Sheet 1109F, Burr-Brown Corporation, 1995.

Coding Schemes Used with Data Converters, Jason Albanus, Application Note AN-175, Burr-Brown, 1991.

IEEE Standard Signaling Method for a Bidirectional Parallel Peripheral Interface for Personal Computers, Draft D1.1, November 5, 1999, Institute of Electrical and Electronic Engineers, Inc.

Interfacing the PC. Interfacing the Extended Capabilities Port, Craig Peacock, February 28, 2000, Internet Resource.