

Mitsubishi Programmable Controller



MELSEC-L Ethernet Interface Module User's Manual (Basic)

-LJ71E71-100





(Read these precautions before using this product.)

Before using this product, please read this manual and the relevant manuals carefully and pay full attention to safety to handle the product correctly.

In this manual, the safety precautions are classified into two levels: "/!\ WARNING" and "/!\ CAUTION".

!WARNING

Indicates that incorrect handling may cause hazardous conditions, resulting in death or severe injury.

!CAUTION

Indicates that incorrect handling may cause hazardous conditions, resulting in minor or moderate injury or property damage.

Under some circumstances, failure to observe the precautions given under "_____CAUTION" may lead to serious consequences.

Observe the precautions of both levels because they are important for personal and system safety.

Make sure that the end users read this manual and then keep the manual in a safe place for future reference.

[Design Precautions]

WARNING

- For the operating status of each station after a communication failure, refer to relevant manuals for each network. Incorrect output or malfunction due to a communication failure may result in an accident.
- To prevent the malfunction of the programmable controller system due to harmful e-mails, take
 preventive measures (such as antivirus measures) so that the mail server for this module does not
 receive harmful e-mails.
- To maintain the safety of the programmable controller system against unauthorized access from external devices via the network, take appropriate measures. To maintain the safety against unauthorized access via the Internet, take measures such as installing a firewall.
- When connecting a peripheral with the CPU module or connecting an external device, such as a personal computer, with an intelligent function module to modify data of a running programmable controller, configure an interlock circuit in the program to ensure that the entire system will always operate safely. For other forms of control (such as program modification or operating status change) of a running programmable controller, read the relevant manuals carefully and ensure that the operation is safe before proceeding. Especially, when a remote programmable controller is controlled by an external device, immediate action cannot be taken if a problem occurs in the programmable controller due to a communication failure. To prevent this, configure an interlock circuit in the program, and determine corrective actions to be taken between the external device and CPU module in case of a communication failure.
- Do not write any data to the "system area" and "write-protect area" (R) of the buffer memory in the intelligent function module. Also, do not use any "use prohibited" signals as an output signal from the CPU module to the intelligent function module. Doing so may cause malfunction of the programmable controller system.

[Design Precautions]

CAUTION

- Do not install the control lines or communication cables together with the main circuit lines or power cables. Keep a distance of 100mm or more between them. Failure to do so may result in malfunction due to noise.
- When changing the operating status of the CPU module (such as remote RUN/STOP) from the external device, select "Always wait for OPEN (Communication possible at STOP time)" for the "Initial timing" setting in the network parameter. The communication line will be closed when "Do not wait for OPEN (Communications impossible at STOP time)" is selected and the remote STOP is executed from the external device. Consequently, the CPU module cannot reopen the communication line, and the external device cannot execute the remote RUN.

[Installation Precautions]

! CAUTION

- Use the programmable controller in an environment that meets the general specifications in the Safety Guidelines included with the MELSEC-L series CPU module.
 - Failure to do so may result in electric shock, fire, malfunction, or damage to or deterioration of the product.
- To interconnect modules, engage the respective connectors and securely lock the module joint levers until they click. Incorrect interconnection may cause malfunction, failure, or drop of the module.
- Shut off the external power supply (all phases) used in the system before mounting or removing a
 module. Failure to do so may result in electric shock or cause the module to fail or malfunction.
- Do not directly touch any conductive parts and electronic components of the module. Doing so can cause malfunction or failure of the module.

[Wiring Precautions]

CAUTION

- Securely connect the connector to the module. Poor contact may cause malfunction.
- Place the cables in a duct or clamp them. If not, dangling cable may swing or inadvertently be pulled, resulting in damage to the module or cables or malfunction due to poor contact.
- When disconnecting the communication and power cables from the module, do not pull the cables by hand. For the cable with connector, hold the connector part of the cable. Pulling the cable connected to the module may result in malfunction or damage to the module or cable.
- Prevent foreign matter such as dust or wire chips from entering the module. Such foreign matter can cause a fire, failure, or malfunction.
- A protective film is attached to the top of the module to prevent foreign matter, such as wire chips, from entering the module during wiring. Do not remove the film during wiring. Remove it for heat dissipation before system operation.

[Startup and Maintenance Precautions]

WARNING

 Shut off the external power supply (all phases) used in the system before cleaning the module. Failure to do so may result in electric shock.

[Startup and Maintenance Precautions]

CAUTION

- Do not disassemble or modify the module. Doing so may cause failure, malfunction, injury, or a fire.
- Shut off the external power supply (all phases) used in the system before mounting or removing the module. Failure to do so may cause the module to fail or malfunction.
- After the first use of the product (module and display unit), the number of connections/disconnections
 is limited to 50 times (in accordance with IEC 61131-2). Exceeding the limit may cause malfunction.
- Before handling the module, touch a conducting object such as a grounded metal to discharge the static electricity from the human body. Failure to do so may cause the module to fail or malfunction.

[Operating Precautions]

<u>^</u>CAUTION

• When changing data and operating status, and modifying program of the running programmable controller from a personal computer connected to an intelligent function module, read relevant manuals carefully and ensure the safety before operation. Incorrect change or modification may cause system malfunction, damage to the machines, or accidents.

[Disposal Precautions]



When disposing of this product, treat it as industrial waste.

CONDITIONS OF USE FOR THE PRODUCT

- (1) Mitsubishi programmable controller ("the PRODUCT") shall be used in conditions;
 - i) where any problem, fault or failure occurring in the PRODUCT, if any, shall not lead to any major or serious accident; and
 - ii) where the backup and fail-safe function are systematically or automatically provided outside of the PRODUCT for the case of any problem, fault or failure occurring in the PRODUCT.
- (2) The PRODUCT has been designed and manufactured for the purpose of being used in general industries.

 MITSUBISHI SHALL HAVE NO RESPONSIBILITY OR LIABILITY (INCLUDING, BUT NOT LIMITED TO ANY AND ALL RESPONSIBILITY OR LIABILITY BASED ON CONTRACT, WARRANTY, TORT, PRODUCT LIABILITY) FOR ANY INJURY OR DEATH TO PERSONS OR LOSS OR DAMAGE TO PROPERTY CAUSED BY the PRODUCT THAT ARE OPERATED OR USED IN APPLICATION NOT INTENDED OR EXCLUDED BY INSTRUCTIONS, PRECAUTIONS, OR WARNING CONTAINED IN MITSUBISHI'S USER, INSTRUCTION AND/OR SAFETY MANUALS, TECHNICAL BULLETINS AND GUIDELINES FOR the PRODUCT.

("Prohibited Application")

Prohibited Applications include, but not limited to, the use of the PRODUCT in;

- Nuclear Power Plants and any other power plants operated by Power companies, and/or any other cases in which the public could be affected if any problem or fault occurs in the PRODUCT.
- Railway companies or Public service purposes, and/or any other cases in which establishment of a special quality assurance system is required by the Purchaser or End User.
- Aircraft or Aerospace, Medical applications, Train equipment, transport equipment such as Elevator and Escalator, Incineration and Fuel devices, Vehicles, Manned transportation, Equipment for Recreation and Amusement, and Safety devices, handling of Nuclear or Hazardous Materials or Chemicals, Mining and Drilling, and/or other applications where there is a significant risk of injury to the public or property.

Notwithstanding the above, restrictions Mitsubishi may in its sole discretion, authorize use of the PRODUCT in one or more of the Prohibited Applications, provided that the usage of the PRODUCT is limited only for the specific applications agreed to by Mitsubishi and provided further that no special quality assurance or fail-safe, redundant or other safety features which exceed the general specifications of the PRODUCTs are required. For details, please contact the Mitsubishi representative in your region.

INTRODUCTION

Thank you for purchasing the Mitsubishi MELSEC-L series programmable controllers. This manual describes the operating procedure, system configuration, parameter settings, functions, programming, and troubleshooting of the LJ71E71-100 Ethernet interface module (hereafter referred to as E71).

Before using this product, please read this manual and the relevant manuals carefully and develop familiarity with the functions and performance of the MELSEC-L series programmable controller to handle the product correctly. When applying the program examples introduced in this manual to an actual system, ensure the applicability and confirm that it will not cause system control problems.

Please make sure that the end users read this manual.



Unless otherwise specified, this manual describes the program examples in which the I/O numbers of X/Y00 to X/Y1F are assigned for an E71.

For I/O number assignment, refer to the following.

MELSEC-L CPU Module User's Manual (Function Explanation, Program Fundamentals)

COMPLIANCE WITH EMC AND LOW VOLTAGE DIRECTIVES

(1) Method of ensuring compliance

To ensure that Mitsubishi programmable controllers maintain EMC and Low Voltage Directives when incorporated into other machinery or equipment, certain measures may be necessary. Please refer to one of the following manuals.

- · MELSEC-L CPU Module User's Manual (Hardware Design, Maintenance and Inspection)
- · Safety Guidelines (This manual is included with the CPU module.)

The CE mark on the side of the programmable controller indicates compliance with EMC and Low Voltage Directives.

(2) Additional measures

To ensure that this product maintains EMC and Low Voltage Directives, please refer to one of the manuals listed under (1).

RELEVANT MANUALS

The manuals related to this product are listed below. Please place an order as needed.

(1) E71 relevant manual

Manual name <manual (model="" code)="" number=""></manual>	Description
MELSEC-Q/L Ethernet Interface Module User's Manual (Application) <sh-080010, 13jl89=""></sh-080010,>	E-mail function, communication function (communications via CC-Link IE Controller Network, CC-Link IE Field Network, MELSECNET/H, or MELSECNET/10, and communications by using the data link instructions), and file transfer (FTP server) function of the E71
MELSEC-Q/L Ethernet Interface Module User's Manual (Web function) <sh-080180, 13jr40=""></sh-080180,>	Web function of the E71
MELSEC Communication Protocol Reference Manual <sh-080008, 13jf89=""></sh-080008,>	Details of MELSEC communication protocol (MC protocol) that is used for data communication between a target device and a CPU module

(2) CPU module user's manual

Manual name <manual (model="" code)="" number=""></manual>		Description	
MELSEC-L CPU Module User's Manual (Hamaintenance and Inspection)	ardware Design, <sh-080890eng, 13jz36=""></sh-080890eng,>	Specifications of the CPU modules, power supply modules, display unit, branch module, extension module, SD memory cards, and batteries, information on how to establish a system, maintenance and inspection, and troubleshooting	
MELSEC-L CPU Module User's Manual (Fu Fundamentals)	inction Explanation, Program <sh-080889eng, 13jz35=""></sh-080889eng,>	Functions and devices of the CPU module, and programming	

(3) Operating manual

Manual name <manual (model="" code)="" number=""></manual>	Description
GX Works2 Version 1 Operating Manual (Common) <sh-080779eng, 13ju63=""></sh-080779eng,>	System configuration, parameter settings, and online operations of GX Works2, which are common to Simple projects and Structured projects
GX Works2 Version 1 Operating Manual (Intelligent Function Module) <sh-080921, 13ju69=""></sh-080921,>	Parameter settings for intelligent function modules, monitoring operations, and the predefined protocol support function of GX Works2

CONTENTS

CONDITION INTRODUC' COMPLIANO RELEVANT MANUAL PATERMS PACKING LI	RECAUTIONS IS OF USE FOR THE PRODUCT TION CE WITH EMC AND LOW VOLTAGE DIRECTIVES MANUALS AGE ORGANIZATION	
CHAPTER	1 FEATURES	19
CHAPTER :	2 PART NAMES	25
CHAPTER:	3 SPECIFICATIONS	27
3.1	General Specifications	27
3.2	Performance Specifications	27
3.3	Function List	29
	3.3.1 Function list	
	3.3.2 Use with other functions	31
3.4	List of I/O Signals	32
3.5	Buffer Memory	34
	3.5.1 Configuration of the buffer memory	34
	3.5.2 List of buffer memory addresses	35
CHAPTER 4	4 PROCEDURES BEFORE OPERATION	54
CHAPTER	5 SYSTEM CONFIGURATION	56
5.1	Overall System Configuration	56
5.2	Network Components	57
5.3	Applicable Systems	59
CHAPTER (6 INSTALLATION AND WIRING	60
6.1	Installation	60
6.2	Wiring	61
OLIADTED :	Z COMMUNICATION PROCEDURE	
CHAPTER	7 COMMUNICATION PROCEDURE	63
7.1	Setting Parameters Required for Communications	64
	7.1.1 Parameter list	
	7.1.2 Basic setting	
	7.1.3 Ethernet Operation Setting.	
	7.1.4 Open Setting	
7.2	TCP/IP Communications	
	7.2.1 Establishing a connection	
	7.2.2 Communication process	

	7.2.3 Active open procedure	
	7.2.4 Passive open procedure	76
7.3	UDP/IP Communications	78
	7.3.1 Communication process	
	7.3.2 Open procedure	
CHAPTER 8	CONNECTING MELSOFT PRODUCTS AND A GOT	81
8.1	Applications	81
8.2	Data Communication Procedure	82
CHAPTER 9	MC PROTOCOL COMMUNICATIONS	84
9.1	Applications	84
9.2	Communication Structure	85
9.3	Data Communication Procedure	86
9.4	Parameter Setting	87
CHAPTER 1	0 SLMP COMMUNICATIONS	88
10.1	Applications	88
10.2	Communication Structure	
10.3	Data Communication Procedure.	
10.4	Parameter Setting.	
10.5	Available command list	
10.0	, wallaste communa list.	02
CHAPTER 1	1 DATA COMMUNICATIONS USING THE PREDEFINED PROTO	COL 94
11.1	Data Communication Procedure	96
11.2	Communication Type of Protocols	99
11.3	Packet Elements	100
11.4	Execution Condition of Predefined Protocol Communication	107
11.5	Example of Predefined Protocol Communications	110
	11.5.1 System configuration example	110
	11.5.2 Parameter Setting	111
	11.5.3 Program example	
CHAPTER 1	2 COMMUNICATIONS USING A FIXED BUFFER	119
12.1	Applications	
. . . =	12.1.1 Differences between the "Procedure Exist" and "No Procedure" control methods .	
12.2	Communication Structure	
12.3	Data Sending Procedure	
12.4	Data Receiving Procedure	
	12.4.1 Data receiving using the main program (BUFRCV instruction)	
	12.4.2 Data receiving using an interrupt program (BUFRCVS instruction)	
12.5	Parameter Setting	129
	12.5.1 Parameter setting when using an interrupt program	130

12.6 L	Data Format	132
12	.6.1 Header	132
12	2.6.2 Application data	132
12.7 F	Pairing Open	138
12	2.7.1 Applications	138
12	2.7.2 Parameter setting	139
12.8 E	Broadcast Communications	140
12	8.1 Sending/receiving procedures	140
12	8.2 Parameter setting	142
12	.8.3 Precautions	144
12.9 E	Example of Communications Using a Fixed Buffer	145
	9.1 System configuration	
12	9.2 Parameter setting	145
12	.9.3 Program	149
	· ·	
HΔPTER 13	COMMUNICATIONS USING A RANDOM ACCESS BUFFER	153
13.1	Applications	153
13.2	Communication Structure	154
13	2.2.1 How data is read from a connected device	155
13	3.2.2 How a connected device writes data	155
13.3 F	Parameter Setting	156
13.4	Data Format	157
13	.4.1 Header	157
13	.4.2 Application data	158
13	.4.3 Examples of command and response formats	162
13.5 F	Precautions when Creating Programs	166
13.6 F	Physical and Logical Addresses of a Random Access Buffer	166
13.7 E	Example of Communications Using a Random Access Buffer	167
HAPTER 14	OTHER FUNCTIONS	168
		100
	Router Relay Function	
	.1.1 Applications	
	.1.2 Parameter settings	
	Communications Using an Auto-open UDP Port	
	.2.1 Application	
	Remote Password	
	.3.1 Application	
	.3.2 Remote password setting processes (unlock and lock processes)	
	.3.3 Remote password check procedure	176
14	.3.4 Differences in functions according to the remote password check status	
	(enabled/disabled)	
	.3.5 Precautions	
14	.3.6 Parameter settings	183
14.4 H	Hub Connection Status Monitor Function	184
14 5 I	P Address in Use Detection Function	185


HAPTER 1	5 DEDICATED INSTRUCTIONS	189
15.1	List of Dedicated Instructions	189
15.2	Parameter Settings for Using Dedicated Instructions	190
	15.2.1 When using data link instructions	190
15.3	Precautions for Dedicated Instructions	191
15.4	Organization of the Dedicated Instruction Sections	191
15.5	ZP.OPEN	192
15.6	ZP.CLOSE	196
15.7	GP.ECPRTCL	199
15.8	ZP.BUFSND	209
15.9	ZP.BUFRCV	213
	Z.BUFRCVS	
	ZP.ERRCLR.	
	ZP.ERRRD.	
	ZP.UINI	
HAPTER 16	3 TROUBLESHOOTING	232
16.1	Before Troubleshooting	232
16.2	Troubleshooting Procedure	232
16.3	Checking with the Module Error Collection Function	234
16.4	Checking the LEDs	235
	16.4.1 If the RUN LED turns off	235
	16.4.2 If the ERR. LED or COM.ERR. LED turns on	235
	16.4.3 If the SD/RD LED does not flash when data is sent	236
16.5	Checking with a Display Unit	237
16.6	Troubleshooting by Symptom	238
	16.6.1 Communications cannot be performed with the connected device	238
	16.6.2 The E71 frequently fails to receive a message sent from the connected device	239
	16.6.3 A dedicated instruction is not completed	239
	16.6.4 MC protocol communications cannot be performed	240
	16.6.5 Communications using SLMP cannot be performed	24′
	16.6.6 Communications using the predefined protocol cannot be performed	24′
	16.6.7 The protocol setting data cannot be read or written	242
	16.6.8 Data cannot be sent with communications using a fixed buffer	243
,	16.6.9 Data cannot be received with communications using a fixed buffer	244
	16.6.10 Communications using a random access buffer cannot be performed	24
,	16.6.11 An e-mail cannot be sent	246
	16.6.12 An e-mail cannot be received	
	16.6.13 Communications using data link instructions cannot be performed	248
16.7	Error Code List	
	16.7.1 End codes returned to a connected device during data communications	
	16.7.2 Abnormal codes returned during communications using an A-compatible 1E frame	
,	16.7.3 Error codes stored in the buffer memory	264

	16.8 Ethernet Diagnostics	290
	16.9 Checking the Status of the E71 with the System Monitor	291
	16.10 How to Turn Off the COM.ERR. LED	293
PPEN	DICES	294
	Appendix 1 Processing Time	294
	Appendix 2 Port Numbers Used for the E71	299
	Appendix 3 New and Improved Functions	300
	Appendix 4 Initial Process	301
	Appendix 4.1 Setting the initial process	
	Appendix 4.2 Reinitialization process	
	Appendix 5 Line Status Check	312
	Appendix 5.1 PING test	312
	Appendix 5.2 Loopback test	
	Appendix 6 Self-Diagnostic Tests	
	Appendix 6.1 Self-loopback test	
	Appendix 6.2 Hardware test (H/W Test)	
	Appendix 7 Differences from Ethernet Modules of Other Series	324
	Appendix 7.1 Differences from a built-in Ethernet port LCPU	
	Appendix 7.2 Differences from Q series modules	
	Appendix 7.3 Differences from QnA/A series modules	
	Appendix 8 Operation Image and Data Structure of Predefined Protocol	329
	Appendix 8.1 Operation image of each communication type of protocol	
	Appendix 8.2 Verification operation of receive packet	
	Appendix 8.3 Data examples of packet elements	
	Appendix 9 Sample Program on the Connected Device Side	340
	Appendix 9.1 When Visual C++ ^(R) .NET is used	
	Appendix 9.2 When Visual Basic ^(R) .NET is used	
	Appendix 10 Checking the Serial Number, Function Version, and MAC address	360
	Appendix 11 External Dimension Diagram	361
	Appendix 12 ASCII Code List	362
NDEX		363
WARR	IONSANTY	367


MANUAL PAGE ORGANIZATION

In this manual, pages are organized and the symbols are used as shown below.

The following illustration is for explanation purpose only, and should not be referred to as an actual documentation.




*1 The mouse operation example (for GX Works2) is provided below.



Pages describing instructions are organized as shown below.

The following illustration is for explanation purpose only, and should not be referred to as an actual documentation.



• Instructions can be executed under the following conditions.

Any time	During on	On the rising edge	During off	On the falling edge
No symbol				 _

• The following devices can be used.

Internal device		File vegietev	Constant	
Bit ^{*1}	Word	File register	K, H	\$
X, Y, M, L, F, V, B	T, ST, C, D, W	R, ZR	K□, H□	\$□

*1 For bit data, a bit-specified word device can be used. For example, Word device.Bit No. is used for the bit specification of a word device. (The bit number is specified in hexadecimal.)

For example, the bit 10 of D0 is specified by D0.A. However, bit specification cannot be used for timer (T), retentive timer (ST), and counter (C).

For details on each device, refer to the following.

User's manual (function explanation, program fundamentals) for the CPU module used The following data types can be used.

Data type	Description	
Bit	Bit data or the start number of bit data	
BIN 16-bit	16-bit binary data or the start number of word device	
BIN 32-bit	32-bit binary data or the start number of double-word device	
BCD 4-digit	Four-digit binary-coded decimal data	
BCD 8-digit	Eight-digit binary-coded decimal data	
Real number	Floating-point data	
Character string	Character string data	
Device name	Device name data	

TERMS

Unless otherwise specified, this manual uses the following terms.

Term	Description				
ARP	The abbreviation for Address Resolution Protocol. This protocol is used to obtain the MAC address of Ethernet from an IP address.				
Buffer memory	A memory in an intelligent function module, where data (such as setting values and monitoring values) exchanged with a CPU module are stored				
Buffer memory address	An address that indicates the storage location of data assigned to the buffer memory in an intelligent function module				
BUFRCV	The abbreviation for ZP.BUFRCV				
BUFRCVS	The abbreviation for Z.BUFRCVS				
BUFSND	The abbreviation for ZP.BUFSND				
C24	Another term for the L series serial communication module				
CLOSE	The abbreviation for ZP.CLOSE				
Dedicated instruction	An instruction that simplifies programming for using functions of intelligent function modules				
Device	A device (X, Y, M, D, or others) in a CPU module				
DNS	The abbreviation for Domain Name System. This system is mainly used to convert host names on the Internet or domain names used for e-mails to IP addresses.				
E71	Another term for the LJ71E71-100				
E71-connected station	The abbreviation for the station where the E71 is connected				
ECPRTCL	The abbreviation for GP.ECPRTCL				
ERRCLR	The abbreviation for ZP.ERRCLR				
ERRRD	The abbreviation for ZP.ERRRD				
FTP	The abbreviation for File Transfer Protocol. This protocol is used to transfer data files over a network.				
GX Developer					
GX Works2	The product name of the software package for the MELSEC programmable controllers				
НТТР	The abbreviation for Hyper Text Transfer Protocol. This protocol is used to send and receive content, such as HTML files, between a Web browser and a Web server.				
ICMP	The abbreviation for Internet Control Message Protocol. This protocol is used to exchange messages of errors in an IP network or other information related to an Ethernet network.				
Intelligent function module	A module that has functions other than an input or output, such as an A/D converter module and D/A converter module				
IP	The abbreviation for Internet Protocol				
MAC address	A unique identifier assigned to each external device on a network. This address is also known as an Ethernet hardware address.				
MC protocol	The abbreviation for MELSEC Communication Protocol. This protocol is used to access MC protocol supporting modules, such as the C24 and E71, or programmable controllers connected to MC protocol supporting modules from external devices.				
MELSECNET/10	The abbreviation for a MELSECNET/10 network system				
MELSECNET/H	The abbreviation for a MELSECNET/H network system				
MELSECNET/H remote I/O station	A generic term for the QJ72LP25-25, QJ72LP25G, and QJ72BR15				
MRECV	The abbreviation for ZP.MRECV				
MSEND	The abbreviation for ZP.MSEND				
MX Component	The abbreviation for MX Component (SW0D5C-ACT-E or later)				
OPEN	The abbreviation for ZP.OPEN				
POP3	The abbreviation for Post Office Protocol Ver.3. This protocol is used to transfer e-mails from a mail server to a local computer.				

Term	Description				
Predefined protocol support function	A function of GX Works2. This function sets protocols appropriate to each external device and reads/writes protocol setting data from/to the flash ROM of the E71.				
Programming tool	Another term for GX Works2				
READ	The abbreviation for JP.READ and GP.READ				
RECV	The abbreviation for JP.RECV and GP.RECV				
RECVS	The abbreviation for Z.RECVS				
REQ	The abbreviation for J.REQ, JP.REQ, G.REQ, and GP.REQ				
SEND	The abbreviation for JP.SEND and GP.SEND				
The abbreviation for Seamless Message Protocol. SLMP This protocol is used to access an SLMP-compatible device or a programmable conconnected to an SLMP-compatible device from an external device.					
SMTP The abbreviation for Simple Mail Transfer Protocol. This protocol is used to transfer the Internet.					
SREAD	The abbreviation for JP.SREAD and GP.SREAD				
Subnet mask	A number used to logically divide one network into multiple subnetworks and manage them easily. The following Ethernet network systems can be configured: • A small-scale Ethernet network system in which multiple network devices are connected • A medium- or large-scale network system in which multiple small-scale network systems are connected via routers or other network communication devices				
SWRITE	The abbreviation for JP.SWRITE and GP.SWRITE				
UINI	The abbreviation for ZP.UINI				
WRITE	The abbreviation for JP.WRITE and GP.WRITE				
ZNRD	The abbreviation for J.ZNRD and JP.ZNRD				
ZNWR	The abbreviation for J.ZNWR and JP.ZNWR				

PACKING LIST

The following items are included in the package of this product. Before use, check that all the items are included.

LJ71E71-100






LJ71E71-100

Before Using the Product

CHAPTER 1 FEATURES

An Ethernet module (hereafter abbreviated as E71) is an interface module on the programmable controller side for connecting a programmable controller system to the host system, such as a personal computer and a workstation, over Ethernet. The module can collect and modify programmable controller data, monitor and control CPU operating status, and exchange data in TCP/IP or UDP/IP.




The E71 has the following basic functions.

- · Connection with MELSOFT products and a GOT
- · Collection and modification of CPU module data from connected devices (MC protocol communications)
- · Communications using SLMP
- Data communications using the predefined protocol (predefined protocol support function)
- · Exchange of data with connected devices (communications using a fixed buffer and random access buffer)
- · Prevention of unauthorized access through a remote password
- E-mail sending/receiving (e-mail function)
- · Data sending/receiving using the Web function


(1) Connection with MELSOFT products and a GOT

In Ethernet, a programming tool can create programming of a programmable controller and monitor a programmable controller (MELSOFT connection), and the GOT can monitor and test a programmable controller. Remote operations making full use of the Ethernet capability, long-distance connectivity and high-speed communications, are achieved.



(2) Collection and modification of CPU module data from connected devices (MC protocol communications)

The MC protocol enables connected devices to access MC protocol supporting modules over Ethernet. The E71 can communicate with a personal computer and HMI (Human Machine Interface) as long as the connected devices can receive/send messages in the MC protocol control procedure. By using a separately sold communication support tool (MX Component), a communication program for the host system can be created without considering detailed protocols (communication procedures). (Fig. Page 84, CHAPTER 9)




(3) Communications using SLMP

SLMP is a protocol that enables connected devices to access SLMP supporting devices over Ethernet. SLMP communications are available among devices that can receive/send messages in the SLMP control procedure. (Fig. Page 88, CHAPTER 10)

(4) Data communications using the predefined protocol (predefined protocol support function)


Registering protocol data in advance using GX Works2 allows communications by executing only an ECPRTCL instruction program. In addition, the protocol setting required to communicate with the connected device, such as a measuring instrument or a bar code reader, can be configured easily using the Predefined Protocol Support Function of GX Works2. (FF Page 94, CHAPTER 11)



(5) Exchange of data with connected devices (communications using a fixed buffer and random access buffer)


(a) Communications using a fixed buffer

Up to 1K-word data can be exchanged among programmable controllers or between a programmable controller and the host system. While MC protocol communications are passive, communications using a fixed buffer are an active protocol. If an error occurs in equipment or certain conditions are met, the programmable controller can send data to the host system. Using an interrupt program allows the CPU module to quickly read received data. (Fig. Page 119, CHAPTER 12)



(b) Communications using a random access buffer

Up to 6K-word data can be communicated. This buffer is useful when the data size is too large for communications using a fixed buffer (capacity: 1K word). (Fig. Page 153, CHAPTER 13)



(6) Prevention of unauthorized access through a remote password

This function prevents unauthorized remote access to the CPU module. The E71 checks an entered remote password in data communications from a connected device using remote password-protected connection. (Fig. Page 174, Section 14.3)

(7) E-mail sending/receiving (e-mail function)

This function sends and receives e-mails to and from a connected device in a remote location via the Internet. For details, refer to the following.

MELSEC-Q/L Ethernet Interface Module User's Manual (Application)

(a) E-mail sending/receiving through the CPU module


The following data can be sent and received using the MSEND/MRECV instructions.

- The CPU module can receive/send up to 6K-word data from/to a personal computer or other E71 modules as an e-mail attachment.
- The CPU module can send up to 960-word data to a personal computer or portable terminal as the main text of an e-mail.

(b) E-mail sending using the programmable controller CPU monitoring function

Notification conditions (CPU module status or device values) that have been set using parameters are regularly monitored. When the conditions are met, up to 960-word data can be sent by either of the following data formats.


- Attachment
- · Main text



(8) Data sending/receiving using the Web function


The system administrator can monitor a CPU module in a remote location via the Internet using a Web browser. For details, refer to the following.

MELSEC-Q/L Ethernet Interface Module User's Manual (Web function)



CHAPTER 2 PART NAMES

This chapter describes the E71 parts.



No.	Nam	e	Application
1)	Module joint leve	er	A lever to fix modules
	_		Indicates operating status.
	RUN	ON	In normal operation
		OFF	An error has occurred. (FF Page 235, Section 16.4.1)
		_	Indicates initial process status.
	INIT.	ON	Normal completion
		OFF	Not processed
		_	Indicates open process status.
2)	OPEN*1	ON	An open process normally completed (connection open)
		OFF	An open process normally completed (no connection)
		_	Indicates hardware failure status.
	ERR.	ON	A hardware failure has occurred.
	OFF		Normal
		_	Indicates whether a communication failure has occurred.
	COM.ERR.*2	ON	A communication failure has occurred. (Fig. Page 235, Section 16.4.2)
		OFF	Normal communications in progress

No.	Name		Application
		_	Indicates a transmission speed.
	SPEED	ON	100Mbps
		OFF	10Mbps or a cable not connected
			Indicates data communication status.
3)	SD/RD	ON	Data communications in progress
		OFF	Data not sent or not received (FF Page 236, Section 16.4.3)
	10BASE-T/100BASE-TX communication connector (RJ45)		A connector to connect an E71 to the 10BASE-T or 100BASE-TX network (An E71 judges whether to connect to the 10BASE-T or 100BASE-TX network based on the hub.)
4)	Serial number display		A display indicating the serial number printed on the rating plate
5)	DIN rail hook		A hook to install the module on a DIN rail

^{*1} The OPEN LED turns on and off depending on the open status of user connections 1 to 16. (The open status of the system connections (e.g. automatic open UDP port) is not included.)

^{*2} If the COM.ERR. LED is on, it does not turn off even if the error cause is eliminated. For how to turn off the LED, refer to "How to Turn Off the COM.ERR. LED". (Page 293, Section 16.10)

3.1 General Specifications

CHAPTER 3 SPECIFICATIONS

This chapter describes the performance specifications, functions, CPU module I/O signals, and buffer memory areas of an E71.

3.1 General Specifications

For the general specifications of an E71, refer to the following.

"Safety Guidelines", the manual included with the CPU module

3.2 Performance Specifications

The following table lists the performance specifications of an E71.

			Specifi	cations		
Item			LJ71E71-100			
			100BASE-TX	10BASE-T		
	Data tran	smission speed	100Mbps	10Mbps		
	Interface		RJ45 (AUTC) MDI/MDI-X)		
	Commun	ication mode	Full-duplex/Half-duplex	Half-duplex		
Transmission specifications	Transmis	sion method	Base	band		
specifications	Maximun	n segment length	100m (length between	n a hub and a node) ^{*1}		
	Maximum number of cascade connections		Cascade connection (maximum of 2 levels)*2	Cascade connection (maximum of 4 levels)*2		
	Number of simultaneous open connections		16 connections (Connections usable on a program)			
Sending/receiving	Fixed buffer		1k word × 16			
data storage nemory	Random access buffer		6k words × 1			
nemory	E-mail	Attachment	6k words × 1			
	E-IIIali	Main text	960 words × 1			
Number of occupied I/O points		s	32 points (I/O assignment: Intelligent 32 points)			
Internal current consumption (5VDC)		(5VDC)	0.60A			
External dimensions			90 (H) × 28.5 (W) × 95 (D) [mm]			
Weight			0.18kg			

			Specific	cations	
	Item		LJ71E	71-100	
			100BASE-TX	10BASE-T	
	Data	Attachment	6k words × 1		
	size	Main text	960 wo	rds × 1	
	Data trans	sfer method	When sending: Send either a file as attachment or main text (select one). When receiving: Receive a file as attachment.		
	Subject		Us-ASCII format or IS	6O-2022-JP (Base64)	
	Attachme	nt format	MIME	format	
	MIME		Version	on 1.0	
Transmission	Data of attachment format		Can be selected from binary, ASCII, and CSV. File name: XXXX.bin (binary), XXXX.asc (ASCII), XXXX.csv (CSV) (CSV: Comma Separated Value)		
specifications	Division of attachment		Cannot be divided (Only one file can be sent/received.)*3		
sending/receiving data	When sending (encode)		Subject: Base64/7 bits Main text: 7 bits Attachment: Base64		
	When receiving (decode)		Subject: (Does not decode) Main text: (Cannot be received) Attached file: Base64/7 bits/8 bits/Quoted Printable*4		
	Encryptio	n	No	ne	
	Compress	sion	No	ne	
	Communi	cations with a mail	SMTP (sending server) Port number = 25, POP3 (receiving server) Port number = 110		
	Operation	n check mailer	Microsoft® Corporation Mic	crosoft Office Outlook 2003	

- *1 For the maximum segment length (a length between hubs), consult with the manufacturer of the switching hub used.
- *2 This applies when a repeater hub is used. For the number of levels that can be constructed when a switching hub is used, consult with the manufacturer of the switching hub used.
- *3 If divided files are received, only the first file is received and the remaining files are discarded.
- *4 If an e-mail is sent from a connected device to the programmable controller side, specify the encoding method (Base64/7 bits/8 bits/Quoted Printable) of the attachment.

3.3 Function List 3.3.1 Function lis

3.3 Function List

This section lists the E71 functions.

3.3.1 Function list

The following table lists the functions of the E71.

(1) Basic functions

The following table lists the basic E71 functions explained in this manual.

Function		Description	Reference
Connecting with MELS	SOFT products and a GOT	An E71 can be connected with MELSOFT products, such as a programming tool and MX Component, and a GOT.	Page 81, CHAPTER 8
MC protocol communications		CPU module data can be read/written from/to connected devices. Access to files can be also performed.	Page 84, CHAPTER 9
Communications usin	g SLMP	The connected device can read/write data from/to the buffer memory or device of an SLMP supporting device connected to the shared network with the E71. In addition, the connected device can read/write data from/to the device of the CPU module where an E71 is connected.	Page 88, CHAPTER 10
Data communications protocol	using the predefined	Data can be sent/received with protocols appropriate to each connected device. The connected device side protocol can be easily selected, or created/edited from the Predefined Protocol Library of GX Works2.	Page 94, CHAPTER 11
	Procedure exists No procedure	Any data is sent/received between a CPU module and connected devices using the fixed buffer of an E71.	Page 119, CHAPTER 12
Communications using a fixed buffer	Pairing open	Paring receiving/sending connections enables data communications with two connections by performing the open process for one port.	Page 138, Section 12.7
•	Broadcast communications	Broadcast communications are enabled with all E71-connected stations in the same Ethernet network that is connected to the E71 when "No Procedure" communications using a fixed buffer are performed using UDP/IP.	Page 140, Section 12.8
Communications usin	g a random access buffer	Data is read/written from multiple connected devices to the random access buffer of an E71.	Page 153, CHAPTER 13
Router relay function		Data communications are performed through a router and a gateway. This function is not the function where an E71 operates as a router.	Page 168, Section 14.1
Communications usin	g an auto-open UDP port	Communications are enabled without the open/close processes after an E71-connected station is started up.	Page 173, Section 14.2
Remote password		Unauthorized remote access to a CPU module is prevented.	Page 174, Section 14.3
Hub connection status monitor function		The current connection status and transmission speed of an E71 and a hub and the number of times that the E71 detected disconnection can be checked.	Page 184, Section 14.4
IP address in use detection function		If different stations in the same network use the same IP address, the address in use can be detected.	Page 185, Section 14.5
Alive check function		Whether a connected device is normally operating after a connection is established (open process) can be checked.	Page 187, Section 14.6

Function	Description	Reference
Module error collection function	An error that has occurred in an E71 can be stored in the CPU module as error history. The history data can be stored on a memory with the backup power feature; therefore, error details are held even if the CPU module is reset or the system is powered off.	Page 234, Section 16.3

(2) Special functions

The following special functions are also available. For the functions, refer to the following.

MELSEC-Q/L Ethernet Interface Module User's Manual (Application)

Function	Description
E-mail function	Data are sent/received using an e-mail. Data sent/received by a CPU module Data sent using the programmable controller CPU monitoring function (automatic notification function)
CC-Link IE Controller Network, CC-Link IE Field Network, MELSECNET/H, MELSECNET/10 relay communications	Data are communicated over multiple network systems where Ethernet and other networks exist together or network systems that relay multiple Ethernet networks.
Communications using data link instructions	Data of a CPU module in other stations can be read/written over Ethernet using data link instructions.
File transfer (FTP server) function	Data can be read/written in files from connected devices using an exclusive FTP command.

(3) Web function

This function allows data to be read/written from/to a remote CPU module over the Internet using a Web browser. For the function, refer to the following.

MELSEC-Q/L Ethernet Interface Module User's Manual (Web function)

3.3.2 Use with other functions

The following table lists the relationships between functions that can be used together.

 \bigcirc : Available, \times : Not available or this function does not correspond to the functions in the "Communication function" column.

	CC-Link IE Controller Network, CC-Link IE	Router	Alive		Communications			Communication method	
Communication function	Field Network, MELSECNET/H, MELSECNET/10 relay communications	relay function	check function	Pairing open	using an auto-open UDP port	Remote password	Broadcast communications	TCP/IP	UDP/IP
MC protocol communications	○*1	0	○*2	×	O*1	0	○ *1 *3	0	0
Communications using a fixed buffer	×	0	0	0	×	0	○ *3 *4	0	0
Communications using SLMP	×	0	0	×	0	0	○*3	0	0
Data communications using the predefined protocol	×	0	0	0	×	0	○*3	0	0
Communications using a random access buffer	×	0	0	×	×	0	×	0	0
E-mail function	×	×	×	×	×	×	×	0	×
Communications using data link instructions	0	0	×	×	0	×	0	×	0
File transfer (FTP server) function	×	0	×	×	×	0	×	0	×
Web function	0	0	×	×	×	0	×	0	×

^{*1} These functions cannot be used with an A-compatible 1E frame.

^{*2} The auto-open UDP port is excluded.

^{*3} These functions can be used only for UDP/IP communication.

^{*4} These functions cannot be used for communications using a fixed buffer in the "Procedure Exist" control method.

3.4 List of I/O Signals

The following table lists the I/O signals for an E71. The I/O signal assignment of when the start I/O number of an E71 is 0000 is listed below.

Device number	Signal name	Device number	Signal name		
X0	For fixed buffer communication of connection No.1 (ON: Sending normal completion or reception completion, OFF: -)	Y0	Connection No.1 (ON: At sending request or reception complete confirmation signal, OFF: -)		
X1	For fixed buffer communication of connection No.1 (ON: Detection of sending error or reception error, OFF: -)	Y1	Connection No.2 (ON: At sending request or reception complete confirmation signal, OFF: -)		
X2	For fixed buffer communication of connection No.2 (ON: Sending normal completion or reception completion, OFF: -)	Y2	Connection No.3 (ON: At sending request or reception complete confirmation signal, OFF: -)		
Х3	For fixed buffer communication of connection No.2 (ON: Detection of sending error or reception error, OFF: -)	Y3	Connection No.4 (ON: At sending request or reception complete confirmation signal, OFF: -)		
X4	For fixed buffer communication of connection No.3 (ON: Sending normal completion or reception completion, OFF: -)	Y4	Connection No.5 (ON: At sending request or reception complete confirmation signal, OFF: -)		
X5	For fixed buffer communication of connection No.3 (ON: Detection of sending error or reception error, OFF: -)	Y5	Connection No.6 (ON: At sending request or reception complete confirmation signal, OFF: -)		
X6	For fixed buffer communication of connection No.4 (ON: Sending normal completion or reception completion, OFF: -)	Y6	Connection No.7 (ON: At sending request or reception complete confirmation signal, OFF: -)		
X7	For fixed buffer communication of connection No.4 (ON: Detection of sending error or reception error, OFF: -)	Y7	Connection No.8 (ON: At sending request or reception complete confirmation signal, OFF: -)		
X8	For fixed buffer communication of connection No.5 (ON: Sending normal completion or reception completion, OFF: -)	Y8	Connection No.1 (ON: Open request, OFF: -)		
X9	For fixed buffer communication of connection No.5 (ON: Detection of sending error or reception error, OFF: -)	Y9	Connection No.2 (ON: Open request, OFF: -)		
XA	For fixed buffer communication of connection No.6 (ON: Sending normal completion or reception completion, OFF: -)	YA	Connection No.3 (ON: Open request, OFF: -)		
XB	For fixed buffer communication of connection No.6 (ON: Detection of sending error or reception error, OFF: -)	YB	Connection No.4 (ON: Open request, OFF: -)		
XC	For fixed buffer communication of connection No.7 (ON: Sending normal completion or reception completion, OFF: -)	YC	Connection No.5 (ON: Open request, OFF: -)		
XD	For fixed buffer communication of connection No.7 (ON: Detection of sending error or reception error, OFF: -)	YD	Connection No.6 (ON: Open request, OFF: -)		
XE	For fixed buffer communication of connection No.8 (ON: Sending normal completion or reception completion, OFF: -)	YE	Connection No.7 (ON: Open request, OFF: -)		
XF	For fixed buffer communication of connection No.8 (ON: Detection of sending error or reception error, OFF: -)	YF	Connection No.8 (ON: Open request, OFF: -)		
X10	Open completed for connection No.1 (ON: Open completion signal, OFF: -)	Y10	Use prohibited		
X11	Open completed for connection No.2 (ON: Open completion signal, OFF: -)	Y11	Use prohibited		
X12	Open completed for connection No.3 (ON: Open completion signal, OFF: -)	Y12	Use prohibited		
X13	Open completed for connection No.4 (ON: Open completion signal, OFF: -)	Y13	Use prohibited		
X14	Open completed for connection No.5 (ON: Open completion signal, OFF: -)	Y14	Use prohibited		
X15	Open completed for connection No.6 (ON: Open completion signal, OFF: -)	Y15	Use prohibited		
X16	Open completed for connection No.7 (ON: Open completion signal, OFF: -)	Y16	Use prohibited		
X17	Open completed for connection No.8 (ON: Open completion signal, OFF: -)	Y17	COM.ERR. LED Off request (ON: At off request, OFF: -)		
X18	Open abnormal detection signal (ON: At off request, OFF: -)	Y18	Use prohibited		

Device number	Signal name	Device number	Signal name
X19	Open abnormal detection signal (ON: Normal completion, OFF: -)	Y19	Initial request signal (ON: At request, OFF: -)
X1A	Open abnormal detection signal (ON: Abnormal end, OFF: -)	Y1A	Use prohibited
X1B	Use prohibited	Y1B	Use prohibited
X1C	COM.ERR. LED lit confirmation (ON: lit, OFF: off)	Y1C	Use prohibited
X1D	Predefined protocol ready (ON: Ready, OFF: -)	Y1D	Use prohibited
X1E	Use prohibited	Y1E	Use prohibited
X1F	Watchdog timer error detection (ON: Watchdog timer error, OFF: -)	Y1F	Use prohibited



Do not use any use prohibited signal as an I/O signal to the CPU module. Doing so may cause malfunction of the programmable controller system.

Remark

The I/O signals listed in this section are mainly applied when QnA series module programs are used. For the L series, the I/O signals for intelligent function modules are turned on and off with dedicated instructions. When QnA series module programs are used, it is recommended to replace the signals with the dedicated instructions described in the section that describes the corresponding functions.

3.5 Buffer Memory


This section describes the E71 buffer memory.

3.5.1 Configuration of the buffer memory

This section describes a buffer memory configuration.

(1) Buffer memory address configuration

A buffer memory area consists of 16 bits per address.



(2) Buffer memory area configuration

Buffer memory consists of user areas and system areas.

(a) User areas

A user area is an area where a user writes or reads data. A user area consists of a parameter area for the initial process and data communications, an area for data communications, and an area to store communication status and communication error data. Data communications may take long if user areas are used continually; therefore, use them only when needed.

(b) System areas

A system area is an area used by a system.



Do not write any data to the "system area". Doing so may cause malfunction of the programmable controller system.

3.5.2 List of buffer memory addresses

The following table lists the buffer memory addresses of an E71.

Address Decimal (Hexadecimal)	Application		Name	Initial value	Programming tool setting applicability
0 and 1 (0 _H and 1 _H)		Own station	E71 IP address	C00001FE _H	0
2 and 3 (2 _H and 3 _H)		System area		_	_
4 (4 _H)		• 00: Do not • 01: Use Conversion s Field Networ • 00: Autom • 01: IP add • 10: Table 6 • 11: Use-to FTP function • 00: Do not • 01: Use	function (b5, b4) use system setting for CC-Link IE Controller Network, CC-Link IE k, MELSECNET/H, MELSECNET/10 relay function (b7, b6) atic response system ress computation system exchange system gether system setting (b9, b8)	0100 _H	0
5 to 10 (5 _H to A _H)		System area		_	_
11 (B _H)	Initial process		TCP ULP timer value (Setting time = setting value × 500 ms)	3C _H (60)	0
12 (C _H)	parameter setting area		TCP zero window timer value (Setting time = setting value × 500 ms)	14 _H (20)	0
13 (D _H)			TCP resend timer value (Setting time = setting value × 500 ms)	14 _H (20)	0
14 (E _H)			TCP end timer value (Setting time = setting value × 500 ms)	28 _H (40)	0
15 (F _H)		Monitoring timer	IP assembly timer value (Setting time = setting value × 500 ms)	A _H (10)	0
16 (10 _H)			Response monitoring timer value (Setting time = setting value × 500 ms)	3C _H (60)	0
17 (11 _H)			Destination existence confirmation starting interval timer value (Setting time = setting value × 500 ms)	4B0 _H (1200)	0
18 (12 _H)			Destination existence confirmation interval timer value (Setting time = setting value × 500 ms)	14 _H (20)	0
19 (13 _H)			Destination existence confirmation resending time	3 _H (3)	0
20 (14 _H)		Auto-open U	DP port number	1388 _H	×
21 to 29 (15 _H to 1D _H)		System area		_	_

Address Decimal (Hexadecimal)	Application	Name	Initial value	Programming tool setting applicability
30 (1E _H)		TCP Maximum Segment Transmission setting area • 0 _H : Enable TCP Maximum Segment Size Option transmission • 8000 _H : Disable TCP Maximum Segment Size Option transmission Re-initialization makes the set value effective.	8000 _H	×
31 (1F _H)	Initial process parameter setting area (For reinitialization)	Communication condition setting (Ethernet Operation Setting) area Communication data code setting (b1) • 0: Binary Code • 1: ASCII Code TCP existence confirmation setting (b4) • 0: Use the Ping • 1: Use the KeepAlive Send frame setting (b5) • 0: Ethernet • 1: IEEE 802.3 Setting of write enable/disable at RUN time (b6) • 0: Disable • 1: Enable Initial timing setting (b8) • 0: Do not wait for OPEN (Communications impossible at STOP time) • 1: Always wait for OPEN (Communication possible at STOP time) Reinitialization specification (b15) • 0: Reinitialization process complete (reset by the system) • 1: Reinitialization process request (set by the user)	0_{H}	0

Address Decimal (Hexadecimal)	Application			Name	Initial value	Programming tool setting applicability		
32 (20 _H)		Connection usage setting area	are not perform 1: For receiving Destination existe 0: No confirm 1: Confirm Pairing open (b7) 0: Disable 1: Enable Communication of the communication of th	, or communications using a fixed buffer ned g ence confirmation (b1) method (protocol) (b8) munication procedure (b10, b9) exists ure protocol 5, b14) n or UDP/IP open	Он	0		
33 (21 _H)			Connection No.2 (The bit configuration is the same as Connection No.1.)					
34 (22 _H)	Communication parameter setting area		Connection No.3 (The bit configuration is the same as Connection No.1.)					
35 (23 _H)			Connection No.4 (The bit configuration is the same as Connection No.1.)					
36 (24 _H)			Connection No.5 (The bit configuration is the same as Connection No.1.)					
37 (25 _H)			Connection No.6 (The bit configuration is the same as Connection No.1.)					
38 (26 _H)			Connection No.7	Connection No.7 (The bit configuration is the same as Connection No.1.)				
39 (27 _H)			Connection No.8	(The bit configuration is the same as Conr	nection No.1.)			
40 (28 _H)				Own station port No.	0 _H	0		
41 to 42 (29 _H and 2A _H)			Connection	Destination IP address	0 _H	0		
43 (2B _H)		Communica	No.1	Destination Port No.	0 _H	0		
44 to 46 (2C _H to 2E _H)		tion address setting area		Destination MAC address	FFFFFFFFF	×		
47 to 53 (2F _H to 35 _H)			Connection No.2 (The bit configuration is the same as Connection No.1.)					
54 to 60 (36 _H to 3C _H)			Connection No.3	(The bit configuration is the same as Conr	nection No.1.)			

Address Decimal (Hexadecimal)	Application			Name	Initial value	Programming tool setting applicability		
61 to 67 (3D _H to 43 _H)			Connection No.4 (The bit configuration is the same as Connection No.1.)					
68 to 74 (44 _H to 4A _H)			Connection No.5 (The bit configuration is the same as Connection No.1.)					
75 to 81 (4B _H to 51 _H)	Communication	Communica tion address	Connection No.6 (The bit configuration is the same as Connection No.1.)					
82 to 88 (52 _H to 58 _H)	parameter setting area	setting area	Connection No.	7 (The bit configuration is the same as Conr	nection No.1.)			
89 to 95 (59 _H to 5F _H)			Connection No.	8 (The bit configuration is the same as Conr	nection No.1.)			
96 to 102 (60 _H to 66 _H)		System area			_	_		
103 and 104 (67 _H and 68 _H)		System area			_	_		
105 (69 _H)			Initial error code	9	0 _H	×		
106 and 107 (6A _H and 6B _H)			Own station IP address			×		
108 to 110 (6C _H to 6E _H)			Own station MAC address		0 _H	×		
111 to 115 (6F _H to 73 _H)		Area for the	System area		_	_		
116 (74 _H)		initial process	Auto-open UDP	port number	0 _H	×		
117 (75 _H)			System area		_	_		
118 (76 _H)			Station number (b0 to b7) Network number of the own station (b8 to b15)		0 _H	×		
119 (77 _H)	Communication		Own station group number		0 _H	×		
120 (78 _H)	status storage area			Own station port No.	0 _H	×		
121 and 122 (79 _H and 7A _H)				Destination IP address	0 _H	×		
123 (7B _H)				Destination Port No.	0 _H	×		
124 (7C _H)				Open error code	0 _H	×		
125 (7D _H)		Connection information area	Connection No.1	Fixed buffer sending error code	0 _H	×		
126 (7E _H)		a. oa		Connection end code	0 _H	×		
127 (7F _H)				Fixed buffer communication time (Maximum value)	0 _H	×		
128 (80 _H)				Fixed buffer communication time (Minimum value)	0 _H	×		
129 (81 _H)				Fixed buffer communication time (Current value)	0 _H	×		

Address Decimal (Hexadecimal)	Application		Name		Programming tool setting applicability			
130 to 139 (82 _H to 8B _H)			Connection No.2 (The bit configuration is the same as Connection No.1.)					
140 to 149 (8C _H to 95 _H)			Connection No.3 (The bit configuration is the same as Connection No.1.)					
150 to 159 (96 _H to 9F _H)			Connection No.4 (The bit configuration is the same as Conn	nection No.1.)				
160 to 169 (A0 _H to A9 _H)		Connection	Connection No.5 (The bit configuration is the same as Conn	nection No.1.)				
170 to 179 (AA _H to B3 _H)		area	Connection No.6 (The bit configuration is the same as Conn	nection No.1.)				
180 to 189 (B4 _H to BD _H)			Connection No.7 (The bit configuration is the same as Conn	nection No.1.)				
190 to 199 (BE _H to C7 _H)			Connection No.8 (The bit configuration is the same as Conn	nection No.1.)				
200 (C8 _H)	Communication status storage area	Area for	LED on/off status (Stores the on/off status of the LEDs on the front of the Ethernet module) INIT.LED (b0) 0: OFF 1: ON (initial process completed) OPEN LED (b1) 0: OFF 1: ON (connection open processing completed) ERR.LED (b3) 0: OFF 1: ON (hardware failure) COM.ERR.LED (b4) 0: OFF 1: ON (communication error) Bits other than those described above are reserved for system use.	O _H	×			
201 (C9 _H)		module status	Hub connection status area Communication mode (b9) • 0: Half duplex • 1: Full duplex Hub connection status (b10) • 0: Hub not connected/disconnected • 1: Hub connected Data transmission speed (b15, b14) • 00: Operating at 10BASE-T • 01: Operating at 100BASE-TX Bits other than those described above are reserved for system use.	0 _H	×			
202 (CA _H)			Switch status (operational mode setting) Communication data code setting • 0: Online • 1: Offline • 2: Self-loopback test • 3: Hardware test	0 _H	0			

Address						Programming
Decimal (Hexadecimal)	Application	Name			Initial value	tool setting applicability
203 (CB _H)	Communication status storage area	Module status area	Communication of 0: Communication of 0: Communication of 1: Parameters of 1: Parameters of 1: Use the Kees of Send frame setting of 1: Energy of 1: Enable of 1: Communication of 1: Always wait of 1: STOP time)	er setting (start up according to the setting (start up according to the confirmation setting (b4) g epAlive eng (b5)	O _H	•
204 (CC _H)			System area		_	_
205 (CD _H)			RECV instruction execution request		0 _H	×
206 (CE _H)		Area for	System area		-	_
207 (CF _H)		sending/rec eiving		ZNRD instruction	0 _H	×
208 (D0 _H)		instructions	Data link	System area	_	_
209 (D1 _H)			instruction execution result	ZNWR instruction	0 _H	×
210 to 223 (D2 _H to DF _H)				System area	_	_
224 to 226 (E0 _H to E2 _H)		System area			_	_
227 (E3 _H)	Error log area	Number of er	rors		0 _H	×
228 (E4 _H)		Error log write	e pointer		0 _H	×

Address Decimal (Hexadecimal)	Application			Name	Initial value	Programming tool setting applicability			
229 (E5 _H)				Error code/end code	0 _H	×			
230 (E6 _H)				Subheader	0 _H	×			
231 (E7 _H)				Command code	0 _H	×			
232 (E8 _H)			Error log block	Connection No.	0 _H	×			
233 (E9 _H)			1	Own station port No.	0 _H	×			
234 and 235 (EA _H and EB _H)				Destination IP address	0 _H	×			
236 (EC _H)				Destination Port No.	0 _H	×			
237 (ED _H)				System area	_	_			
238 to 246 (EE _H to F6 _H)			Error log block 2 (The bit configuration is the same as Error log block 1.)						
247 to 255 (F7 _H to FF _H)			Error log block 3 (The bit configuration is the same as Error log block 1.)						
256 to 264 (100 _H to 108 _H)			Error log block 4 (The bit configuration is the same as Error log block 1.)						
265 to 273 (109 _H to 111 _H)	Error log area	Error log block area	Error log block 5 (The bit configuration is the same as Error log block 1.)						
274 to 282 (112 _H to 11A _H)			Error log block 6 (The bit configuration is the same as Error log block 1.)						
283 to 291 (11B _H to 123 _H)			Error log block 7 (The bit configuration is the same as Error log block 1.)						
292 to 300 (124 _H to 12C _H)			Error log block 8 (The bit configuration is the same as Error log block 1.)						
301 to 309 (12D _H to 135 _H)			Error log block 9	(The bit configuration is the same as Error	log block 1.)				
310 to 318 (136 _H to 13E _H)			Error log block 10 (The bit configuration is the same as Error log block 1.)						
319 to 327 (13F _H to 147 _H)			Error log block 11 (The bit configuration is the same as Error log block 1.)						
328 to 336 (148 _H to 150 _H)			Error log block 12	2 (The bit configuration is the same as Erro	or log block 1.)				
337 to 345			Error log block 1:	3 (The bit configuration is the same as Erro	or log block 1.)				
(151 _H to 159 _H) 346 to 354 (15A _H to 162 _H)			Error log block 14 (The bit configuration is the same as Error log block 1.)						
355 to 363 (163 _H to 16B _H)		Error log block 15 (The bit configuration is the same as Error log block 1.)							
364 to 372 (16C _H to 174 _H)			Error log block 16	6 (The bit configuration is the same as Erro	or log block 1.)				
373 to 375 (175 _H to 177 _H)	System area				_	_			

Address						Programming
Decimal	Application			Name	Initial value	tool setting
(Hexadecimal)						applicability
376 and 377 (178 _H and 179 _H)				Received IP packet count	0 _H	×
378 and 379 (17A _H and 17B _H)			IP	Received IP packet count discarded due to sumcheck error	0 _H	×
380 and 381 (17C _H and 17D _H)			"	Sent IP packet total count	0 _H	×
382 to 407 (17E _H to 197 _H)				System area	1	_
408 and 409 (198 _H and 199 _H)				Received ICMP packet count	0 _H	×
410 and 411 (19A _H and 19B _H)				Received ICMP packet count discarded due to sum check error	0 _H	×
412 and 413 (19C _H and 19D _H)				Sent ICMP packet total count	0 _H	×
414 and 415 (19E _H and 19F _H)			ICMP	Echo request total count of received ICMP packets	0 _H	×
416 and 417 (1A0 _H and 1A1 _H)			tatus for ach	Echo reply total count of sent ICMP packets	0 _H	×
418 and 419 (1A2 _H and 1A3 _H)				Echo request total count of sent ICMP packets	0 _H	×
420 and 421 (1A4 _H and 1A5 _H)	Error log area	Status for each protocol		Echo reply total count of received ICMP packets	0 _H	×
422 to 439 (1A6 _H to 1B7 _H)		p. 0.000		System area	_	_
440 and 441 (1B8 _H and 1B9 _H)				Received TCP packet count	0 _H	×
442 and 443 (1BA _H and 1BB _H)			TCP	Received TCP packet count discarded due to sum check error	0 _H	×
444 and 445 (1BC _H and 1BD _H)			TOP	Sent TCP packet total count	0 _H	×
446 to 471 (1BE _H to 1D7 _H)				System area	1	_
472 and 473 (1D8 _H and 1D9 _H)				Received UDP packet count	0 _H	×
474 and 475 (1DA _H and 1DB _H)		LIDP	Received UDP packet count discarded due to sum check error	0 _H	×	
476 and 477 (1DC _H and 1DD _H)			UDP	Sent UDP packet total count	0 _H	×
478 to 481 (1DE _H to 1E1 _H)				System area	_	_
482 to 511 (1E2 _H to 1FF _H)			System area		_	_

Address Decimal (Hexadecimal)	Application		Name	Initial value	Programming tool setting applicability		
512 and 513 (200 _H and 201 _H)		Sub-net mas	k	0 _H	0		
514 and 515 (202 _H and 203 _H)		Default route	r IP address	0 _H	0		
516 (204 _H)		Number of re	gistered routers	0 _H	0		
517 and 518 (205 _H and 206 _H)		Router 1	Sub-net address	0 _H	0		
519 and 520 (207 _H and 208 _H)		Router	Router IP address	0 _H	0		
521 to 524 (209 _H to 20C _H)		Router 2 (The	e bit configuration is the same as Router 1.)				
525 to 528 (20D _H to 210 _H)	Router relay parameter setting area	Router 3 (The	e bit configuration is the same as Router 1.)				
529 to 532 (211 _H to 214 _H)		Router 4 (The	e bit configuration is the same as Router 1.)				
533 to 536 (215 _H to 218 _H)		Router 5 (The	e bit configuration is the same as Router 1.)				
537 to 540 (219 _H to 21C _H)		Router 6 (The	outer 6 (The bit configuration is the same as Router 1.)				
541 to 544 (21D _H to 220 _H)		Router 7 (The	outer 7 (The bit configuration is the same as Router 1.)				
545 to 548 (221 _H to 224 _H)		Router 8 (The	e bit configuration is the same as Router 1.)				
549 (225 _H)		System area		_	_		
550 to 551 (226 _H and 227 _H)		System area		_	_		
552 (228 _H)		Number of co	onversion table data	0 _H	0		
553 and 554 (229 _H to 22A _H)			Communication request destination/source stations network number and station number	0 _H	0		
555 and 556 (22B _H to 22C _H)		Conversion information No.1	External station Ethernet module IP address	0 _H	0		
557 and 558 (22D _H to 22E _H)	Station No.<-> IP information setting		System area	_	_		
559 to 564 (22F _H to 234 _H)	area	Conversion in	nformation No.2 (The bit configuration is the same as Convers	sion information No.1	.)		
to 034 to 036			to				
931 to 936 (3A3 _H to 3A8 _H)			nformation No.64 (The bit configuration is the same as Conve	rsion information No.	1.)		
937 and 938 (3A9 _H and 3AA _H)			pattern for CC-Link IE Controller Network, CC-Link IE Field LSECNET/H, and MELSECNET/10 routing	0 _H	0		
939 to 943 (3AB _H to 3AF _H)		System area		_	_		

Address					Programming	
Decimal (Hexadecimal)	Application		Name	Initial value	tool setting applicability	
944 to 949 (3B0 _H to 3B5 _H)		FTP login na	me	"LJ71E71"	0	
950 to 953 (3B6 _H to 3B9 _H)		Password		"LJ71E71"	0	
954 (3BA _H)	FTP setting area	Command in	put monitoring timer	708 _H	0	
955 (3BB _H)		Programmab	le controller CPU monitoring timer	A _H	0	
956 to 1663 (3BC _H to 67F _H)		System area		_	_	
1664 (680 _H)		Fixed buffer	Data length	0 _H	×	
1665 to 2687 (681 _H to A7F _H)		No.1	Fixed buffer data	0 _H	×	
2688 to 3711 (A80 _H to E7F _H)		Fixed buffer N	No.2 (The bit configuration is the same as Fixed buffer No.1.)			
3712 to 4735 (E80 _H to 127F _H)		Fixed buffer N	No.3 (The bit configuration is the same as Fixed buffer No.1.)			
4736 to 5759 (1280 _H to 167F _H)	Fixed buffer data area	Fixed buffer N	No.4 (The bit configuration is the same as Fixed buffer No.1.)	Fixed buffer No.1.)		
5760 to 6783 (1680 _H to 1A7F _H)		Fixed buffer N	No.5 (The bit configuration is the same as Fixed buffer No.1.)	·		
6784 to 7807 (1A80 _H to 1E7F _H)		Fixed buffer N	No.6 (The bit configuration is the same as Fixed buffer No.1.)			
7808 to 8831 (1E80 _H to 227F _H)		Fixed buffer N	No.7 (The bit configuration is the same as Fixed buffer No.1.)			
8832 to 9855 (2280 _H to 267F _H)		Fixed buffer N	No.8 (The bit configuration is the same as Fixed buffer No.1.)			
9856 to 16383 (2680 _H to 3FFF _H)	Shared area for random access	Shared area	for random access buffers and e-mail buffers	0 _H	×	
16384 to 18431 (4000 _H to 47FF _H)	buffers and e-mail buffers	System area		_	_	
18432 to 20479 (4800 _H to 4FFF _H)	Send/receive area for predefined protocol support function	Send/receive	area for predefined protocol support function	0 _H	0	

Address Decimal (Hexadecimal)	Application		Name	Initial value	Programming tool setting applicability	
20480 (5000 _H)			Open completion signal • 0: Open incomplete • 1: Open completed Connection No.1 (b0) Connection No.2 (b1) to Connection No.16 (b15)	0 _H	×	
20481 (5001 _H)		Connection status	System area	_	_	
20482 (5002 _H)	Connection status	information area	Open request signal O: No open request Connection No.1 (b0) Connection No.2 (b1) to Connection No.16 (b15)	0 _H	×	
20483 and 20484 (5003 _H and 5004 _H)	storage area		System area	_	_	
20485 (5005 _H)		Fixed buffer information area	Fixed buffer reception status signal O: Data not received I: Data being received Connection No.1 (b0) Connection No.2 (b1) to Connection No.16 (b15)	0 _H	×	
20486 (5006 _H)		Remote password status storage area	Remote password status • 0: Unlock status/no remote password setting • 1: Lock status Connection No.1 (b0) Connection No.2 (b1) to Connection No.16 (b15)	0 _H	×	
20487 (5007 _H)		Remote password status storage area	Remote password status 0: Unlock status/no remote password setting 1: Lock status Auto-open UDP port (b0) MELSOFT application transmission port (UDP) (b1) MELSOFT application transmission port (TCP) (b2) FTP transmission port (b3)	0 _H	×	
20488 (5008 _H)	System port information area	System port use prohibited designation area	System port use prohibited designation • 0: Use allowed • 1: Use prohibited • Auto-open UDP port (b0) • MELSOFT application transmission port (UDP) (b1) • MELSOFT application transmission port (TCP) (b2)	0 _H	×	
20489 to 20591 (5009 _H to 506F _H)		3.00	System area	_	_	

Address Decimal (Hexadecimal)	Application			Name	Initial value	Programming tool setting applicability
20592 (5070 _H)			count designati	ord mismatch notification accumulated ion (For user open port) ation Notification accumulated count	1 _H	×
20593 (5071 _H)			count designati application tran transmission po • 0: No design	•	2 _H	×
20594 (5072 _H)				Accumulated count of unlock process normal completion	0 _H	×
20595 (5073 _H)				Accumulated count of unlock process abnormal end	0 _H	×
20596 (5074 _H)			Connection No.1	Accumulated count of lock process normal completion	0 _H	×
20597 (5075 _H)				Accumulated count of lock process abnormal end	0 _H	×
20598 (5076 _H)	Monitoring area	Remote password function		Accumulated count of lock process based on close	0 _H	×
20599 to 20603 (5077 _H to 507B _H)		monitoring area	Connection No	.2 (The bit configuration is the same as Conr	nection No.1.)	
20604 to 20608 (507C _H to 5080 _H)			Connection No	.3 (The bit configuration is the same as Conr	nection No.1.)	
20609 to 20613 (5081 _H to 5085 _H)			Connection No	.4 (The bit configuration is the same as Conr	nection No.1.)	
20614 to 20618 (5086 _H to 508A _H)			Connection No	.5 (The bit configuration is the same as Conr	nection No.1.)	
20619 to 20623 (508B _H to 508F _H)			Connection No	.6 (The bit configuration is the same as Conr	nection No.1.)	
20624 to 20628 (5090 _H to 5094 _H)			Connection No	.7 (The bit configuration is the same as Conr	nection No.1.)	
20629 to 20633 (5095 _H to 5099 _H)			Connection No	.8 (The bit configuration is the same as Conr	nection No.1.)	
20634 to 20638 (509A _H to 509E _H)			Connection No	.9 (The bit configuration is the same as Conr	nection No.1.)	
20639 to 20643 (509F _H to 50A3 _H)			Connection No	.10 (The bit configuration is the same as Cor	nnection No.1.)	

Address Decimal (Hexadecimal)	Application		Name	Initial value	Programming tool setting applicability		
20644 to 20648 (50A4 _H to 50A8 _H)			Connection No.11 (The bit configuration is the same as Connection No.1.)				
20649 to 20653 (50A9 _H to 50AD _H)			Connection No.12 (The bit configuration is the same as Cor	nnection No.1.)			
20654 to 20658 (50AE _H to 50B2 _H)			Connection No.13 (The bit configuration is the same as Cor	nnection No.1.)			
20659 to 20663 (50B3 _H to 50B7 _H)			Connection No.14 (The bit configuration is the same as Cor	nnection No.1.)			
20664 to 20668 (50B8 _H to 50BC _H)	Monitoring groo	Remote password function	Connection No.15 (The bit configuration is the same as Cor	nnection No.1.)			
20669 to 20673 (50BD _H to 50C1 _H)	Monitoring area	monitoring area	Connection No.16 (The bit configuration is the same as Cor	nnection No.1.)			
20674 to 20678 (50C2 _H to 50C6 _H)			Auto-open UDP port (The bit configuration is the same as C	connection No.1.)			
20679 to 20683 (50C7 _H to 50CB _H)			MELSOFT application transmission port (UDP) (The bit con No.1.)	figuration is the sam	e as Connection		
20684 to 20688 (50CC _H to 50D0 _H)			MELSOFT application transmission port (TCP) (The bit configuration is the same as Connection No.1.)				
20689 to 20693 (50D1 _H to 50D5 _H)			FTP transmission port (The bit configuration is the same as Connection No.1.)				
20694 to 20736 (50D6 _H to 5100 _H)		System area		_	_		
20737 (5101 _H)		Error log poin	nter	0 _H	×		
20738 (5102 _H)	Log counter (HTTP response code 100 to 199)	0 _H	×		
20739 (5103 _H)		Log counter (HTTP response code 200 to 299)	0 _H	×		
20740 (5104 _H)		Log counter (HTTP response code 300 to 399)	0 _H	×		
20741 (5105 _H)		Log counter (HTTP response code 400 to 499)	0 _H	×		
20742 (5106 _H)	HTTP status storage area	Log counter (HTTP response code 500 to 599)	0 _H	×		
20743 (5107 _H)		System area		_	_		
20744 (5108 _H)			HTTP response code	0 _H	×		
20745 and 20746 (5109 _H and 510A _H)		Error log block 1	Destination IP address	0 _H	×		
20747 to 20750 (510B _H to 510E _H)			Error time	0 _H	×		
20751 to 20757 (510F _H to 5115 _H)		Error log bloo	ck 2 (The bit configuration is the same as Error log block 1.)	•	•		
20758 to 20764 (5116 _H to 511C _H)		Error log bloc	ck 3 (The bit configuration is the same as Error log block 1.)				

Address Decimal (Hexadecimal)	Application	Name	Initial value	Programming tool setting applicability
20765 to 20771 (511D _H to 5123 _H)		Error log block 4 (The bit configuration is the same as Error log block 1.)		
20772 to 20778 (5124 _H to 512A _H)		Error log block 5 (The bit configuration is the same as Error log block 1.)		
20779 to 20785 (512B _H to 5131 _H)		Error log block 6 (The bit configuration is the same as Error log block 1.)		
20786 to 20792 (5132 _H to 5138 _H)		Error log block 7 (The bit configuration is the same as Error log block 1.)		
20793 to 20799 (5139 _H to 513F _H)		Error log block 8 (The bit configuration is the same as Error log block 1.)		
20800 to 20806 (5140 _H to 5146 _H)		Error log block 9 (The bit configuration is the same as Error log block 1.)		
20807 to 20813 (5147 _H to 514D _H)	HTTP status storage area	Error log block 10 (The bit configuration is the same as Error log block 1.)		
20814 to 20820 (514E _H to 5154 _H)		Error log block 11 (The bit configuration is the same as Error log block 1.)		
20821 to 20827 (5155 _H to 515B _H)		Error log block 12 (The bit configuration is the same as Error log block 1.)		
20828 to 20834 (515C _H to 5162 _H)		Error log block 13 (The bit configuration is the same as Error log block 1.)		
20835 to 20841 (5163 _H to 5169 _H)		Error log block 14 (The bit configuration is the same as Error log block 1.)		
20842 to 20848 (516A _H to 5170 _H)		Error log block 15 (The bit configuration is the same as Error log block 1.)		
20849 to 20855 (5171 _H to 5177 _H)		Error log block 16 (The bit configuration is the same as Error log block 1.)		
20856 to 20994 (5178 _H to 5202 _H)	System area		_	_
20995 (5203 _H)	Disconnection detection storage area	Disconnection detection count	0 _H	×
20996 to 21055 (5204 _H to 523F _H)	System area		_	_
21056 (5240 _H)*1	Receive buffer status storage area	Receive buffer full detection signal 0: Receive buffer not full 1: Receive buffer full	0 _H	×
21057 to 21119 (5241 _H to 527F _H)	System area	tem area		_
21120 (5280 _H)		Same IP address detection flag • 0: Unique IP addresses • 1: Same IP address for multiple stations	0 _H	×
21121 to 21123 (5281 _H to 5283 _H)	IP address status storage area	The MAC address of the station that has been already connected to the network (The address is stored in the station with the same IP address.)	FFFFFFFFFF	×
21124 to 21126 (5284 _H to 5286 _H)		The MAC address of the station with the IP address used for another station (The address is stored in the station that has been already connected to the network.)	FFFFFFFFF	×
21127 to 21279 (5287 _H to 531F _H)	System area		_	_

Address						Programming
Decimal	Application			Name	Initial value	tool setting
(Hexadecimal)						applicability
21280 to 21283 (5320 _H to 5323 _H)		System area			_	_
21284 (5324 _H)				Protocol No.	0 _H	×
21285 (5325 _H)		Protocol setti	ng data error	Setting type	0 _H	×
21286 (5326 _H)	Protocol setting	information		Packet No.	0 _H	×
21287 (5327 _H)	data check area			Element No.	0 _H	×
21288 (5328 _H)		Number of re	gistered protocols		0 _H	×
21289 to 21295 (5329 _H to 532F _H)		System area			_	_
21296 to 21311 (5330 _H to 533F _H)		Protocol registration			0 _H	×
21312 to 21695 (5340 _H to 54BF _H)	System area				_	_
21696 (54C0 _H)			Protocol execution status		0 _H	×
21697 (54C1 _H)			System area		_	_
21698 to 21713 (54C2 _H to 54D1 _H)		Connection No.1	Received data ve	erification result (receive packet No.1 to	0 _H	×
21714 (54D2 _H)			Number of protoc	col executions	0 _H	×
21715 (54D3 _H)			Protocol cancella	ation specification	0 _H	0
21716 to 21735 (54D4 _H to 54E7 _H)	Predefined protocol support function	Connection N	lo.2 (The bit config	uration is the same as Connection No.1.)		
21736 to 21755 (54E8 _H to 54FB _H)	execution status check area	Connection N	lo.3 (The bit config	uration is the same as Connection No.1.)		
21756 to 21775 (54FC _H to 550F _H)		Connection N	Connection No.4 (The bit configuration is the same as Connection No.1.)			
21776 to 21795 (5510 _H to 5523 _H)		Connection No.5 (The bit configuration is the same as Connection No.1.)				
21796 to 21815 (5524 _H to 5537 _H)		Connection N	lo.6 (The bit config	uration is the same as Connection No.1.)		
21816 to 21835 (5538 _H to 554B _H)		Connection N	lo.7 (The bit config	uration is the same as Connection No.1.)		
21836 to 21855 (554C _H to 555F _H)		Connection N	lo.8 (The bit config	uration is the same as Connection No.1.)		

Address						Programming		
Decimal (Hovadocimal)	Application			Name	Initial value	tool setting applicability		
(Hexadecimal) 21856 to 21875						аррисарицу		
(5560 _H to 5573 _H)		Connection N	No.9 (The bit conf	iguration is the same as Connection No.1.)				
21876 to 21895 (5574 _H to 5587 _H)		Connection N	No.10 (The bit cor	nfiguration is the same as Connection No.1.)				
21896 to 21915 (5588 _H to 559B _H)		Connection N	No.11 (The bit con	nfiguration is the same as Connection No.1.)				
21916 to 21935 (559C _H to 55AF _H)	Predefined protocol support function	Connection N	No.12 (The bit cor	nfiguration is the same as Connection No.1.)				
21936 to 21955 (55B0 _H to 55C3 _H)	execution status check area	Connection N	No.13 (The bit cor	nfiguration is the same as Connection No.1.)				
21956 to 21975 (55C4 _H to 55D7 _H)		Connection N	No.14 (The bit cor	nfiguration is the same as Connection No.1.)				
21976 to 21995 (55D8 _H to 55EB _H)		Connection N	No.15 (The bit cor	nfiguration is the same as Connection No.1.)				
21996 to 22015 (55EC _H to 55FF _H)		Connection N	No.16 (The bit cor	nfiguration is the same as Connection No.1.)				
22016 to 22559 (5600 _H to 581F _H)	System area				_	_		
22560 (5820 _H)				Own station port No.	0 _H	×		
22561 and 22562 (5821 _H to 5822 _H)				Destination IP address	0 _H	×		
22563 (5823 _H)				Destination Port No.	0 _H	×		
22564 (5824 _H)			Connectio No.9		Open error code	0 _H	×	
22565 (5825 _H)						Connection No.9	Fixed buffer sending error code	0 _H
22566 (5826 _H)				Connection end code	0 _H	×		
22567 (5827 _H)				Fixed buffer communication time (Maximum value)	0 _H	×		
22568 (5828 _H)	Communication	Connection	Connection	Connection		Fixed buffer communication time (Minimum value)	0 _H	×
22569 (5829 _H)	status storage area	information area		Fixed buffer communication time (Current value)	0 _H	×		
22570 to 22579 (582A _H to 5833 _H)			Connection No	.10 (The bit configuration is the same as Cor	nnection No.9.)	<u>I</u>		
22580 to 22589 (5834 _H to 583D _H)			Connection No	.11 (The bit configuration is the same as Con	nection No.9.)			
22590 to 22599 (583E _H to 5847 _H)			Connection No.12 (The bit configuration is the same as Connection No.9.)					
22600 to 22609 (5848 _H to 5851 _H)			Connection No	.13 (The bit configuration is the same as Cor	nnection No.9.)			
22610 to 22619 (5852 _H to 585B _H)			Connection No	.14 (The bit configuration is the same as Cor	nnection No.9.)			
22620 to 22629 (585C _H to 5865 _H)			Connection No	.15 (The bit configuration is the same as Cor	nnection No.9.)			
22630 to 22639 (5866 _H to 586F _H)			Connection No	.16 (The bit configuration is the same as Cor	nnection No.9.)			

Address Decimal (Hexadecimal)	Application		Name			Programming tool setting applicability
22640 (5870 _H)			Number of mails	remaining on the server	0 _H	×
22641 (5871 _H)			Dedicated instruc	ction normal completion count	0 _H	×
22642 (5872 _H)			Dedicated instruc	ction abnormal end count	0 _H	×
22643 (5873 _H)			Normal receiving	count	0 _H	×
22644 (5874 _H)			Attached file rece	eiving count	0 _H	×
22645 (5875 _H)			Server inquiry count		0 _H	×
22646 (5876 _H)	E-mail status		Server communication error count		0 _H	×
22647 (5877 _H)	storage area	Receive	Error log write count		0 _H	×
22648 (5878 _H)			Receiving error le	og write pointer	0 _H	×
22649 (5879 _H)				Error code	0 _H	×
22650 (587A _H)				Command code	0 _H	×
22651 to 22658 (587B _H to 5882 _H)			Error log block	From	0 _H	×
22659 to 22662 (5883 _H to 5886 _H)				Date	0 _H	×
22663 to 22692 (5887 _H to 58A4 _H)				Subject	0 _H	×

Address		Program			Programming			
Decimal (Hexadecimal)	Application		Name	Initial value	tool setting applicability			
22693 to 22736 (58A5 _H to 58D0 _H)			Error log block 2 (The bit configuration is the same as Error	log block 1.)				
22737 to 22780 (58D1 _H to 58FC _H)	_		Error log block 3 (The bit configuration is the same as Error log block 1.)					
22781 to 22824 (58FD _H to 5928 _H)			Error log block 4 (The bit configuration is the same as Error	log block 1.)				
22825 to 22868 (5929 _H to 5954 _H)			Error log block 5 (The bit configuration is the same as Error	log block 1.)				
22869 to 22912 (5955 _H to 5980 _H)			Error log block 6 (The bit configuration is the same as Error	log block 1.)				
22913 to 22956 (5981 _H to 59AC _H)			Error log block 7 (The bit configuration is the same as Error	log block 1.)				
22957 to 23000 (59AD _H to 59D8 _H)			Error log block 8 (The bit configuration is the same as Error	log block 1.)				
23001 to 23044 (59D9 _H to 5A04 _H)		Receive	Error log block 9 (The bit configuration is the same as Error log block 1.)					
23045 to 23088 (5A05 _H to 5A30 _H)	E-mail status storage area		Error log block 10 (The bit configuration is the same as Error log block 1.)					
23089 to 23132 (5A31 _H to 5A5C _H)			Error log block 11 (The bit configuration is the same as Error log block 1.)					
23133 to 23176 (5A5D _H to 5A88 _H)			Error log block 12 (The bit configuration is the same as Error log block 1.)					
23177 to 23220 (5A89 _H to 5AB4 _H)			Error log block 13 (The bit configuration is the same as Error log block 1.)					
23221 to 23264 (5AB5 _H to 5AE0 _H)			Error log block 14 (The bit configuration is the same as Error log block 1.)					
23265 to 23308 (5AE1 _H to 5B0C _H)			Error log block 15 (The bit configuration is the same as Error log block 1.)					
23309 to 23352 (5B0D _H to 5B38 _H)			Error log block 16 (The bit configuration is the same as Erro	ne bit configuration is the same as Error log block 1.)				
23353 (5B39 _H)			Dedicated instruction normal completion count	0 _H	×			
23354 (5B3A _H)			Dedicated instruction abnormal end count	0 _H	×			
23355 (5B3B _H)			Number of mails normally completed	0 _H	×			
23356 (5B3C _H)		Send	Attached file sending count	0 _H	×			
23357 (5B3D _H)			Sending to the server count	0 _H	×			
23358 (5B3E _H)			Number of mails abnormally completed	0 _H	×			
23359 (5B3F _H)			Error log write count	0 _H	×			
23360 (5B40 _H)			Sending error log write pointer	0 _H	×			

Address Decimal (Hexadecimal)	Application			Name	Initial value	Programming tool setting applicability		
23361 (5B41 _H)				Error code	0 _H	×		
23362 (5B42 _H)				Command code	0 _H	×		
23363 to 23370 (5B43 _H to 5B4A _H)			Error log block 1	То	0 _H	×		
23371 to 23374 (5B4B _H to 5B4E _H)				Date	0 _H	×		
23375 to 23404 (5B4F _H to 5B6C _H)				Subject	0 _H	×		
23405 to 23448 (5B6D _H to 5B98 _H)		Send	Error log block 2	(The bit configuration is the same as Error	log block 1.)			
23449 to 23492 (5B99 _H to 5BC4 _H)	E-mail status storage area	Seria	Error log block 3	(The bit configuration is the same as Error	log block 1.)			
23493 to 23536 (5BC5 _H to 5BF0 _H)			Error log block 4 (The bit configuration is the same as Error log block 1.)					
23537 to 23580 (5BF1 _H to 5C1C _H)			Error log block 5 (The bit configuration is the same as Error log block 1.)					
23581 to 23624 (5C1D _H to 5C48 _H)			Error log block 6 (The bit configuration is the same as Error log block 1.)					
23625 to 23668 (5C49 _H to 5C74 _H)			Error log block 7 (The bit configuration is the same as Error log block 1.)					
23669 to 23712 (5C75 _H to 5CA0 _H)			Error log block 8	log block 1.)				
23713 to 24575 (5CA1 _H to 5FFF _H)		System area	System area		_	_		
24576 (6000 _H)		Fixed buffer	Data length		0 _H	×		
24577 to 25599 (6001 _H to 63FF _H)		No.9	Fixed buffer data		0 _H	×		
25600 to 26623 (6400 _H to 67FF _H)		Fixed buffer N	lo.10 (The bit conf	iguration is the same as Fixed buffer No.9.)	1			
26624 to 27647 (6800 _H to 6BFF _H)		Fixed buffer N	No.11 (The bit confi	iguration is the same as Fixed buffer No.9.)				
27648 to 28671 (6C00 _H to 6FFF _H)	Fixed buffer data area	Fixed buffer No.12 (The bit configuration is the same as Fixed buffer No.9.)						
28672 to 29695 (7000 _H to 73FF _H)		Fixed buffer No.13 (The bit configuration is the same as Fixed buffer No.9.)						
29696 to 30719 (7400 _H to 77FF _H)		Fixed buffer N	No.14 (The bit conf	iguration is the same as Fixed buffer No.9.)				
30720 to 31743 (7800 _H to 7BFF _H)		Fixed buffer N	No.15 (The bit conf	iguration is the same as Fixed buffer No.9.)				
31744 to 32767 (7C00 _H to 7FFF _H)		Fixed buffer N	No.16 (The bit conf	0.16 (The bit configuration is the same as Fixed buffer No.9.)				

^{*1} Availability depends on the version of the E71. ([Page 300, Appendix 3)

CHAPTER 4 PROCEDURES BEFORE OPERATION

This chapter describes how to connect an E71 to Ethernet. For how to communicate with connected devices after the E71 is connected, refer to the communication procedure. (Fig. Page 63, CHAPTER 7)


Checkbox	System consideration Design the system configuration of the E71.		Page 27, CHAPTER 3, Page 56, CHAPTER 5
	Installation Connect the E71.		Page 25, CHAPTER 2, Page 60, Section 6.1
	Wiring Connect an Ethernet cable to the E71.		Page 57, Section 5.2, Page 61, Section 6.2
	Setting parameters Set the following parameters, which are required to start up the E71, from the programming tool. • Basic setting • Ethernet operation setting		Page 65, Section 7.1.2, Page 66, Section 7.1.3
	Restarting the CPU module Reflect the parameter settings by turning off and on the CPU module or resetting the CPU module.	F	MELSEC-L CPU Module User's Manual (Hardware Design, Maintenance and Inspection)
	Network diagnostics Check that the cables are connected properly or that communications are performed properly with the set parameters. (PING test, loopback test)		Page 312, Appendix 5
Continued	to COMMUNICATION PROCEDURE (FF Page 63, CHAPTER 7)		

Memo

CHAPTER 5 SYSTEM CONFIGURATION


5.1 Overall System Configuration

The following is a system configuration example of when using an E71.



5.2 Network Components

This section describes the devices used for Ethernet.





An E71 determines whether to use 100BASE-TX or 10BASE-T and the full-duplex or half-duplex transmission mode according to the hub. For connection to a hub without the automatic negotiation function, set the half-duplex mode on the hub side.

(1) 100BASE-TX connection

To configure a system for 100BASE-TX connection, use devices that meet the IEEE 802.3 100 BASE-TX standards.

Configur	ation device	Description
Shielded twisted pair	Straight cable	A Category 5 or 5e cross cable is usable.
cable (STP)*2	Cross cable	A Category 5 or 5e cross cable is usable.
Connector	RJ45 connector	_
Hub	100Mbps hub	Up to two levels of cascade connection can be configured.*1

- *1 This applies when a repeater hub is used. For the number of levels that can be constructed when a switching hub is used, consult with the manufacturer of the switching hub used.
- *2 Data can be communicated with an E71 (between LJ71E71-100 modules). In addition, an E71 can be directly connected to a GOT.



During high-speed communications (100Mbps) using 100BASE-TX connection, a communication error may occur due to high-frequency noise from devices other than a programmable controller in a given installation environment. The following lists countermeasures to be taken on the E71 side to avoid high-frequency noise influence.

- Wiring connection
 - Do not bundle the cable with the main circuit or power cable or do not place it near those lines.
 - Put the cable in a duct.
- Communication method
 - Use TCP/IP for data communications with connected devices.
 - · Increase the number of retries of communications if needed.
- 10Mbps communications
 - Use a 10Mbps hub for the E71 and set the data transmission speed to 10Mbps.
 - Change the transmission speed of the E71 to 10Mbps using the UINI instruction. (FP Page 226, Section 15.13)



Consult a network specialist for required devices.

(2) 10BASE-T connection

To configure a system for 10BASE-T connection, use devices that meet the IEEE 802.3 10BASE-T standards.

Configurat	tion device	Description
Unshielded twisted pair cable (UTP) or shielded	Straight cable	A Category 3, 4, or 5 straight cable or cross cable is usable.
twisted pair cable (STP)*2	Cross cable	A Category 3, 4, or 3 straight cable or closs cable is usable.
Connector	RJ45 connector	_
Hub	10Mbps hub	Up to four levels of cascade connection can be configured.*1

This applies when a repeater hub is used. For the number of levels that can be constructed when a switching hub is used, consult with the manufacturer of the switching hub used.

*2	can be communicated with an E71 (between LJ71E71-100 modules). In addition, an E71 can be direct GOT.	ctly connected
Ren)	
Co	a network specialist for required devices.	
• • •	•••••••	• • • • • •

5.3 Applicable Systems

5.3 Applicable Systems

This section describes MELSEC-L series systems that include an E71.

(1) Applicable CPU modules and the number of connectable modules

An E71 can be connected to an LCPU with an serial number (first five digits) of 14112 or later. For the number of connectable modules, refer to the following.

MELSEC-L CPU Module User's Manual (Hardware Design, Maintenance and Inspection)

(2) Applicable software

GX Works2 is required for setting and diagnosing an E71. GX Developer cannot be used.

Software	Version
GX Works2	1.95Z or later

CHAPTER 6 INSTALLATION AND WIRING

This chapter describes installation and wiring of the E71.

6.1 Installation

This section describes installation of the E71.

(1) Installation method

For the module installation environment and position, refer to the following.
MELSEC-L CPU Module User's Manual (Hardware Design, Maintenance and Inspection)

(2) Handling precautions

Do not drop or apply strong shock to the E71 case since it is made from resin.


6.2 Wiring

This section describes Ethernet cable wiring and wiring precautions. For a network configuration and cables and hubs used, refer to "SYSTEM CONFIGURATION". (Fig. Page 56, CHAPTER 5)

(1) Ethernet cable connection


The following is how to connect and disconnect an Ethernet cable.

(a) Connecting the cable



- 1. Power off the E71 and the connected device.
- 2. Push the Ethernet cable connector into the E71 until it clicks. Pay attention to the connector's direction.

(b) Disconnecting the cable



- 3. Power on the E71 and the connected device.
- 1. Power off the system.
- 2. Press the latch down and unplug the Ethernet cable.

(2) Precautions

This section describes wiring precautions.

(a) Handling

Place the Ethernet cable in a duct or clamp them. If not, dangling cable may swing or inadvertently be pulled, resulting in damage to the module or cables or malfunction due to poor contact.

Do not touch the core of the cable-side or module-side connector, and protect it from dirt or dust. If oil from your hand, dirt or dust is attached to the core, it can increase transmission loss, arising a problem in data link. Check the following:

- · Is any Ethernet cable disconnected?
- · Is any Ethernet cable shorted?
- · Are the connectors securely connected?

(b) Broken cable latch

Do not use Ethernet cables with broken latches. Doing so may cause the cable to unplug or malfunction.

(c) Connecting and disconnecting the Ethernet cable

Hold the connector part when connecting and disconnecting the Ethernet cable. Pulling a cable connected to the module may damage the module or cable or result in malfunction due to poor contact.

(d) Maximum station-to-station distance (maximum cable length)

The maximum station-to-station distance is 100m. However, the distance may be shorter depending on the operating environment of the cable. For details, contact your cable manufacturer.

(e) Bend radius

The bend radius of the Ethernet cable is limited. For details, see the specifications of the Ethernet cable to be used.

CHAPTER 7 COMMUNICATION PROCEDURE

This chapter describes the procedure for communicating with connected devices after the E71 is connected to Ethernet. For the procedure for connecting the E71 to Ethernet, refer to "PROCEDURES BEFORE OPERATION".


Continued from PROCEDURES BEFORE OPERATION

(Fig. Page 54, CHAPTER 4)



Parameter settings

Set the parameters (excluding the basic setting and Ethernet operation setting) if necessary.





Starting the CPU module

Reflect the parameter settings by turning off and on the CPU module or resetting the CPU module.





Initial process

The initial process of the E71 is automatically performed.



Open process

The open process is to establish a connection with a connected device.



Page 71, Section 7.2, Page 78, Section 7.3



Data communications using each function

Close process

The close process is to disconnect (cancel) the connection with the connected device established by the open process.



Page 71, Section 7.2, Page 78, Section 7.3

7.1 Setting Parameters Required for Communications

This section describes how to set parameters to communicate between the E71 and connected devices.

7.1.1 Parameter list


The following table lists parameters set through a programming tool.

Item			Description	Reference	
		Network Type	Configure settings to use the E71 as a network module.		
		Start I/O No.			
	Basic setting	Network No.		Page 65, Section 7.1.2	
	basic setting	Group No.		Tage 65, Section 7.1.2	
		Station No.			
		Mode			
	Operation Setting		Configure the settings, such as an IP address, to connect the E71 to Ethernet.	Page 66, Section 7.1.3	
	Initial Setting		Set a data communication timer value.	Page 301, Appendix 4.1	
Network Parameter	Open Setting		Configure connection settings.	Page 68, Section 7.1.4, Parameter setting of each function	
	Router Relay Parameter		Configure settings to communicate with connected devices on Ethernet via a router and a gateway.		
	Station No. <-> IP Information		Configure settings (e.g. network number and station number) to communicate with other network modules.	MELSEC-Q/L Ethernet Interface Module User's Manual (Application)	
	FTP Parameters		Configure the settings of the file transfer (FTP) function.		
	E-mail Setting		Configure the settings of the e-mail function and the automatic notification function.		
	Interrupt Settings		Set the control number (SI) on the E71 side to request an interrupt to the CPU module.	Page 130, Section 12.5.1	
	Routing Parameters		Set the communication path to communicate with a station having a different network number.	MELSEC-Q/L Ethernet Interface Module User's Manual (Application)	
	Valid Module During Other Station Access		Select a relay module when an access request with no network number specified is issued from another station.	-	
Predefined Protocol Support Function		nction	The connected device side protocol can be easily selected, or created/edited from the Predefined Protocol Library of GX Works2.	Page 94, CHAPTER 11	
Remote Password			Select the connection protected by a remote password.	Page 174, Section 14.3	

7.1.2 Basic setting

Set items, such as a network number and station number.

Project window ⇔ [Parameter] ⇔ [Network Parameter] ⇔ [Ethernet/CC IE Field] ⇔ Select "Ethernet" under "Network Type".




Item	Description	Setting range
Network Type	Select "Ethernet".	_
Start I/O No.	Set the start I/O number of the E71 in units of 16 points.	Within the number of I/O points of the CPU module
Network No.	Set the network number of the E71.	1 to 239
Group No.	Set the group number of the E71.	0 to 32
Station No.	Set the station number of the E71.	1 to 64
Mode	Select the operation mode of the E71.	Online Offline Self-Loopback Test H/W Test

7.1.3 Ethernet Operation Setting

Configure the settings, such as an IP address, to connect the E71 to Ethernet.

Project window ⇔ [Parameter] ⇔ [Network Parameter] ⇔ [Ethernet/CC IE Field] ⇔ Select "Ethernet" under "Network Type". ⇔ Operation Setting button



Item		Description	Setting range	
Communication Data Code		Select the communication data code for the connected device.	Binary Code ASCII Code	
Initial Timing		Refer to (1) in this section.	Do not wait for OPEN (Communications impossible at STOP time) Always wait for OPEN (Communication possible at STOP time)	
IP Address Setting	Input Format	Select the IP address input format.	• DEC • HEX	
	IP Address	Set the IP address of the own station. Make sure that the E71 on the own station and the connected device to be communicated with have the same class and subnet address. Consult with the network administrator for the IP address setting.	• DEC: 0.0.0.1 to 255.255.255.254 • HEX 00.00.00.01 to FF.FF.FF.FE	
Send Frame Setting		Select the frame of the Ethernet header for the data link layer to be sent by the E71. An E71 receives data from the connected device both with the Ethernet frame and the IEEE802.3 frame.	• Ethernet (V2.0) • IEEE802.3*1	
Enable Online Change		Select whether to enable connected devices to write data in MC protocol communications while the CPU module is in RUN.	Selected: Enable Not selected: Disable	
TCP Existence Confirmation Setting		Select an alive check method in TCP/IP communications.	Use the KeepAlive Use the Ping	

^{*1} The IEEE802.3 frame format can be used only when the connected device is compatible with the frame. Generally, using the Ethernet frame is recommended.

(1) Initial Timing

This setting configures the open timing of the connection where "TCP" (Passive open) or "UDP" has been selected under "Open System" in the open setting. (Fig. Page 68, Section 7.1.4)

(a) Do not wait for OPEN (Communications impossible at STOP time)

Connections are opened or closed using a program. Communications cannot be performed while the switch on the CPU module is set to STOP.

(b) Always wait for OPEN (Communication possible at STOP time)

Connections always wait for the open status according to the "Open System" parameter. (This eliminates the need to open/close connections using a program.*1) Communications can be performed while the switch on the CPU module is set to STOP.


*1 If the program of the CPU module on the own station closes a connection, the station does not enter the OPEN request wait status after the connection is disconnected.



When remotely controlling the CPU module from a connected device, select "Always wait for OPEN (Communication possible at STOP time)". If "Do not wait for OPEN (Communications impossible at STOP time)" is selected, the communication line is closed during remote STOP. After the line is closed, the line cannot be reopened on the CPU module side, and remote RUN cannot be performed from the connected device.

7.1.4 Open Setting

Configure settings to open connections for data communications with connected devices.



Item	Description	Setting range	
IP Address/Port No. Input Format	Select the input format for the IP address and port number.	• DEC • HEX	
Protocol	Select the communication protocol for the connected device.	• TCP	
PTOLOCOI	(Fig. Page 71, Section 7.2, Page 78, Section 7.3)	• UDP	
Open System	Set this item when "TCP" is selected under "Protocol". (Fig. 2.2, Page 74, Section 7.2.3, Page 76, Section 7.2.4)	 Active Unpassive Fullpassive MELSOFT Connection*1 	
Fixed Buffer	For communications using a fixed buffer, select whether to use the buffer for sending or for receiving in a connection to the connected device. When not performing communications using a fixed buffer, select "Send". (Fig. Page 119, CHAPTER 12)	Send Receive Predefined protocol	
Fixed Buffer Communication	Select a communication method for communications using a fixed buffer. (Fig. 2) Page 119, CHAPTER 12)	Procedure Exist No Procedure	
Pairing Open	Configure the pairing open setting for communications using a fixed buffer. ([] Page 138, Section 12.7)	Disable Enable	
Existence Confirmation	Select whether to use the alive check function. (Fig. Page 187, Section 14.6)	No Confirm Confirm	
Host Station Port No.	Set the E71 connection port numbers.	• DEC: 1025 to 4999, 5003 to 65534*2 • HEX: 401 _H to 1387 _H , 138B _H to FFFE _H *2	

Item	Description	Setting range
Destination IP Address	Set the IP address of the connected device.	• DEC: 0.0.0.0 to 255.255.255.255 • HEX: 00.00.00.00 to FF.FF.FF.FF
Destination Port No.	Set port numbers for connections of connected devices.	• DEC: 1 to 65535*3 • HEX: 1 _H to FFFF _H *3

^{*1} An E71 is always waiting for an open request from a connected device (communications can be performed during STOP), regardless of the initial timing setting in the Ethernet operation setting. (Page 66, Section 7.1.3)

^{*2} Do not enter 5000 (1388 $_{\rm H}$) to 5002 (138A $_{\rm H}$). (Page 299, Appendix 2)

 $^{^{*}3}$ The range of 1 (1_H) to 1024 (400_H) is available only in the E71 with the serial number (first five digits) of "15042" or later.



• Note the following points when setting port numbers.

○: Can be set, ×: Cannot be set

Connection status	Description	Communication protocol	
		TCP/IP	UDP/IP
Connected device E71 Connected device Connected device	When connecting multiple connected devices, set multiple own station port numbers.	0	0
Connected device E71 Connected device O Connected device	When connecting multiple connected devices, set a single own station port number. (However, connections need to be opened by the number of connections.) This setting cannot be configured when the own station is Unpassive.	0	×
E71 Connected device	When connecting multiple ports on a connected device, set multiple port numbers of the E71.	0	0
E71 Connected device	When connecting multiple ports on a connected device, set a single port number of the E71. (However, connections need to be opened by the number of connections.) This setting cannot be configured when the own station is Unpassive.	0	×
E71 Connected device	When connecting the same port on a connected device, set multiple port numbers of the E71. (However, connections need to be opened by the number of connections.)	0	0
E71 Connected device	Multiple ports can be set for the same port on a connected device and on the E71 only when paring open has been set.	0	0

 Consult with the network administrator for setting the port numbers of the E71 and the connected device and the IP address of the connected device.

7.2 TCP/IP Communications


This section describes TCP/IP communications.

7.2.1 Establishing a connection

TCP/IP communications require establishing connections between communication devices. When the server-side device is in standby status after performing a Passive open process, a connection is established after the client-side device issues an open request (Active open process) to the server and a response is received.


In TCP/IP communications, the system establishes a connection and checks whether each data has arrived at the recipient normally, thereby ensuring data reliability. Compared to UDP/IP communications, however, TCP/IP places a greater load on the line.

When the E71 is in Passive open status



7.2.2 Communication process

This section describes the process from establishing a connection to terminating communications.






- The corresponding bit of Open completion signal (address: 5000_H) automatically turns off and the communication line is closed in the following situations:
 - A timeout has occurred in the alive check function. (Fig. Page 187, Section 14.6)
 - · An E71 has received a close request and the ABORT (RST) instruction from a connected device.
 - An E71 has received Alive open request from a connected device again with open completed in TCP.
 After an E71 sends an ACK to a connected device, the E71 closes the connection when receiving the RST command from the connected device. If the E71 with a different IP address or port number receives Active open request from the connected device again, the E71 only sends the RST command. (It does not close the connection.)
 - · A timeout has occurred upon transmission in TCP.
- After the connected device sends a close request to the E71, wait for 500ms or more before performing an open process again.

7.2.3 Active open procedure

Active open is a connection method that performs an active open process on a connected device in Passive open wait status. The procedure that the E71 performs an Active open process is as follows. For the OPEN/CLOSE instructions, refer to "DEDICATED INSTRUCTIONS". (Fig. Page 189, CHAPTER 15)

Open/close processes for the connection number 1



- After parameter communications, check that the initial process of the E71 is normally completed. (Initial normal completion signal (X19): ON)
- Start the open process using the OPEN instruction. (Open request signal (address: 5002_H (b0)): ON)
- The E71 performs the open process. (The E71 sends an open request (SYN) to the connected device.)
- When the open process is normally completed, data communications are enabled.*1
- 5 Start a close process using the CLOSE instruction. (Open request signal: OFF)
- The E71 performs the close process. (The E71 sends a close request (FIN) to the connected device.)
- When the close process is normally completed, data communications terminate.*2

- *1 If the E71 sends an SYN and the connected device returns a RST, Open abnormal detection signal (X18) turns on immediately and the open process terminates. (Open abnormal end)
- *2 If an ACK and a FIN are not returned within the time specified by the TCP end timer value, the E71 forcibly closes the connection (sends a RST). (Close abnormal end)

7.2.4 Passive open procedure


The E71 has the following two connection methods for Passive open.

Unpassive	Performs a passive open process on connections for all devices connected to the network regardless of the IP address and port number of the destination device.	
Fullpassive	Performs a passive open process on connections for the connected device specified by the	
	IP address and port number.	

Under the Passive open method, the open/close processes are performed using the procedures described below, according to the Ethernet operation setting.

(1) When "Always wait for OPEN (Communication possible at STOP time)" is selected for the Ethernet operation setting

As the E71 is set to always wait for open, a connection is established when an Active open is requested from the connected device. This eliminates the need for open/close processing programs on the E71 side.



- After parameter communications, check that the initial process of the E71 is normally completed. (Initial normal completion signal (X19): ON)
 - After the initial process is normally completed, the connection enters open enable status and the E71 waits for an open request from the connected device.
- The E71 starts the open process upon receiving the open request (SYN) from the connected device. When the open process is normally completed, Open completion signal (address: 5000_H (b0)) turns on and data communications are enabled.
- The E71 starts the close process upon receiving the close request (FIN) from the connected device. When the close process is completed, Open completion signal (address: 5000H (b0)) turns off and data communications are disabled.
- After the internal process of the E71 is completed, the connection returns to the OPEN request wait status.
 - *1 An open request (SYN) received after the normal completion of an initial process and before the E71 is in the OPEN request wait status will cause an error, and the E71 sends a connection forced close (RST).




When the open/close processes are performed from the E71 side using a dedicated instruction, even if "Always wait for OPEN" has been selected for the Ethernet operation setting, the connection will not return to the open acceptance enable status after the close process is completed.

(2) When "Do not wait for OPEN (Communications impossible at STOP time)" is selected for the Ethernet operation setting

Executing the OPEN/CLOSE instructions is required on the E71 to make the E71 enter open/close wait status before receiving an open/close request from the connected device. When the open process is normally completed, data sending and receiving are enabled. For the OPEN/CLOSE instructions, refer to "DEDICATED INSTRUCTIONS". (Fig. Page 189, CHAPTER 15)

Open/close processes for the connection number 1



- After parameter communications, check that the initial process of the E71 is normally completed. (Initial normal completion signal (X19): ON)
- Start the open process using the OPEN instruction. (Open request signal (address: 5002_H (b0)): ON)
- The E71 starts the open process upon receiving the open request (SYN) from the connected device. When the open process is normally completed, Open completion signal (address: 5000_H (b0)) turns on and data communications are enabled.
- The E71 starts the close process upon receiving the close request (FIN) from the connected device. When the close process is completed, Open completion signal (address: 5000H (b0)) turns off and data communications are disabled.
- Start the close process using the CLOSE instruction. (Open request signal: OFF)
 - *1 An open request (SYN) received after the normal completion of an initial process and before the E71 is in the OPEN request wait status will cause an error, and the E71 sends a connection forced close (RST).




- Change connection settings before executing the OPEN instruction.
- Once an open process is performed, an open request cannot be canceled before the open process is completed.
 Perform a close process (Execute the CLOSE instruction) after the open process is completed.

7.3 UDP/IP Communications

This section describes UDP/IP communications. In UDP/IP communications, the system does not establish a connection and does not check whether each data has arrived at the destination normally, thereby reducing the load on the line. However, UDP/IP communications do not guarantee data reliability as the TCP/IP communications do.

7.3.1 Communication process

Unlike TCP/IP communications, UDP/IP communications do not require connections to be established with connected devices.



Point P

- If a timeout has occurred in the alive check function, the corresponding bit of Open completion signal (address: 5000_H)
 automatically turns off and the communication line is closed.
- After the connected device sends a close request to the E71, wait for 500ms or more before performing an open process again.

7.3.2 Open procedure

The open/close processes are performed by the procedures described below, according to the Ethernet operation setting.

(1) When "Always wait for OPEN (Communication possible at STOP time)" is selected for the Ethernet operation setting

After the E71-connected station is started up, the connection in UDP/IP communications automatically opens and data sending/receiving are enabled. Creating open/close processing programs is not required.




When open/close processes are performed from the E71 side using a dedicated instruction with "Always wait for OPEN (Communication possible at STOP time)" set in the Ethernet operation setting, all open/close processes with the subsequent connected devices must be performed in a program.

(2) When "Do not wait for OPEN (Communications impossible at STOP time)" is selected for the Ethernet operation setting

Executing the OPEN/CLOSE instructions is required on the E71 to make the E71 enter open/close wait status open/close wait status before receiving an open/close request from the connected device. When the open process is normally completed, data sending and receiving are enabled. For the OPEN/CLOSE instructions, refer to "DEDICATED INSTRUCTIONS".

(F Page 189, CHAPTER 15)

Ex Open/close processes for the connection number 1



- After parameter communications, check that the initial process of the E71 is normally completed. (Initial normal completion signal (X19): ON)
- Start the open process using the OPEN instruction. (Open request signal (address: 5002_H (b0)): ON)
- The E71 performs the open process. (Internal process only)
- Data communications are enabled when the open process is normally completed.
- Start the close process using the CLOSE instruction. (Open request signal: OFF)
- 6 The E71 performs the close process. (Internal process only)
- When the close process is normally completed, data communications terminate.

CHAPTER 8 CONNECTING MELSOFT PRODUCTS AND A GOT


This chapter describes the connection of the E71 with MELSOFT products (such as a programming tool and MX Component) and the GOT.

8.1 Applications

This section describes applications according to a connection type.

(1) Programming and monitoring over Ethernet

In Ethernet, a programming tool can create programming of a programmable controller and monitor a programmable controller (MELSOFT connection), and the GOT can monitor and test a programmable controller. Remote operations making full use of the Ethernet capability, long-distance connectivity and high-speed communications, are achieved.



(2) Connecting multiple products

Multiple MELSOFT products and GOTs can be connected using MELSOFT application communication ports.



The connection used in the connection with MELSOFT products is only for data communications with the MELSOFT products and cannot be used for data communications with connected devices other than MELSOFT products.

(a) Connection using the TCP/IP communications

The E71 can connect to up to 17 MELSOFT products using one dedicated system connection and 16 user connections. GOTs cannot be connected using the TCP/IP communications. (Use the UDP/IP communications.)


(b) Connection using the UDP/IP communications


The E71 can connect a MELSOFT product and a GOT using one dedicated system connection.


8.2 Data Communication Procedure

This section describes the data communication procedure in the MELSOFT connection.

Ex Connecting the E71 and a personal computer (programming tool)







- 1. Write the parameter settings (Page 68, Section 7.1.4) in the CPU module. To connect multiple products in the TCP/IP communications, set the connection for the second product or more in the open setting. In the following cases, the open setting is not required.
 - \cdot Only one product is connected in the TCP/IP communications.
 - \cdot The network is running in the UDP/IP communications.
- 2. Set the connection target in the programming tool.
 - Connection destination window ⇒ [Connection1]


Select "Ethernet Board" under "PC side I/F" and double-click the item. The window shown to left appears.

On the window, enter the network number and station number of the personal computer, not of the E71.

Determine the network number and station number of the personal computer as follows:

The network number must be the same as that of the E71.

The station number must be different from that of the E71 on the same network.



- 4. Select "Ethernet Module" under "PLC side I/F" and double-click the item. The window shown to left appears. Set the station number and the IP address according to the network parameters.
- Set "Other Station Setting" and "Network Communication Route" when required.
- 6. A Passive open process is performed on all the MELSOFT products connected to the network. (The E71 will wait for an Active open request to itself.)

CHAPTER 9 MC PROTOCOL COMMUNICATIONS

Using MC protocol communications, connected devices that can send and receive data in accordance with the MC protocol can access a CPU module. Because an E71 processes and sends/receives data based on commands from connected devices, no programs for data communications are required on the programmable controller side. For MC protocol communications, refer to the following.

MELSEC Communication Protocol Reference Manual

9.1 Applications

Applications of MC protocol communications are as follows.

(1) Data read/write

Data can be read/written from/to a CPU module device and intelligent function module buffer memory. This allows a connected device to monitor the CPU module operation, perform data analysis, and manage production control.

(2) File read/ write

Files such as a program and parameter stored in a CPU module can be read/written. This allows a connected device to manage CPU module files and switch execution programs.

(3) Remote control of a CPU module

The remote operation allows a connected device to remotely operate a CPU module.

(4) Turning off the COM.ERR. LED

The COM.ERR. LED on an E71 can be turned off from a connected device.

(5) Remote password lock/unlock

A remote password can be locked/unlocked from a connected device.


(6) Access to a programmable controller in other stations over other networks

In a system containing CC-Link IE Controller Network, CC-Link IE Field Network, MELSECNET/H, MELSECNET/10, and Ethernet, access to a programmable controller in other stations can be performed over each network from a connected device.

9.2 Communication Structure

9.2 Communication Structure

When a connected device sends a message to an E71 in the MC protocol message format, the E71 performs the process according to the message. During communications, a CPU module including the E71 operates as a server, and the connected device (a personal computer or other terminals) operates as a client. Based on the command message received from the client, the server (the E71) automatically sends an appropriate response message.



The frames that can be used with an E71 are as follows.

- 4E frame
- · QnA-compatible 3E frame
- · A-compatible 1E frame

9.3 Data Communication Procedure

The following is a data communication procedure for MC protocol communications.

- 1. Set the parameters. (Fig. Page 87, Section 9.4)
- 2. Perform the open process and establish a connection between the E71 and the connected device. (Fig. Page 71, Section 7.2, Page 78, Section 7.3)
- 3. Once the connection is established, the connected device sends an MC protocol message.
- 4. The connection is closed after the communications are completed.




In the cases described below, an E71 performs a remote password check when the connected device accesses the programmable controller. If communications cannot be performed, unlock the remote password. (Fig. Page 175, Section 14.3.2)

- When a remote password has been set in the CPU module
- When the connection for data communications with the connected device is to be subjected to the remote password check

9.4 Parameter Setting

Set the following parameters for MC protocol communications.

- Basic setting (FP Page 65, Section 7.1.2)
- Ethernet operation setting (F Page 66, Section 7.1.3)
- Open setting (Page 68, Section 7.1.4)



Item	Description	Setting range		
Fixed Buffer	Select the communication method for communications using a fixed buffer. For	ations using a fixed buffer. For Procedure Exist		
Communication	MC protocol communications, select "Procedure Exist".	Procedure Exist		

CHAPTER 10 SLMP COMMUNICATIONS

SLMP is a protocol that enables connected devices to access SLMP supporting devices over Ethernet.

SLMP communications are available among devices that can receive/send messages in the SLMP control procedure.

This function is available only in the E71 with the serial number (first five digits) of "15042" or later.

For SLMP communications, refer to the following.

SLMP Reference Manual

10.1 Applications

Applications of SLMP communications are as follows.

(1) Data read/write

Data can be read/written from/to a device of the CPU module where an E71 is connected and intelligent function module buffer memory. This allows a connected device to monitor the operation of the CPU module where an E71 is connected, perform data analysis, and manage production control.

(2) Remote control of a CPU module

The remote operation allows a connected device to remotely operate a CPU module where an E71 is connected.


(3) Turning off the COM.ERR. LED

The COM.ERR. LED on an E71 can be turned off from a connected device.

10.2 Communication Structure

10.2 Communication Structure

When a connected device sends a message to an E71 in the SLMP message format, the E71 performs the process according to the message. During communications, a CPU module including the E71 operates as a server, and the connected device (a personal computer or other terminals) operates as a client. Based on the request message received from the client, the server (the E71) automatically sends an appropriate response message.



10.3 Data Communication Procedure

The following is a data communication procedure for SLMP communications.

- 1. Set the parameters. (Page 91, Section 10.4)
- 2. Perform the open process and establish a connection between the E71 and the connected device. (Fig. Page 71, Section 7.2, Page 78, Section 7.3)
- 3. Once the connection is established, the connected device sends an SLMP message.
- 4. The connection is closed after the communications are completed.



In the cases described below, an E71 performs a remote password check when the connected device accesses the programmable controller. If communications cannot be performed, unlock the remote password. (Fig. Page 175, Section 14.3.2)


- · When a remote password has been set in the CPU module
- When the connection for data communications with the connected device is to be subjected to the remote password check

10.4 Parameter Setting

10.4 Parameter Setting

Set the following parameters for SLMP communications.

- Basic setting (Page 65, Section 7.1.2)
- Ethernet operation setting (F Page 66, Section 7.1.3)
- Open setting (Page 68, Section 7.1.4)



Item	Description	Setting range
Fixed Buffer	Select the communication method for communications using a fixed buffer. For	Procedure Exist
Communication	SLMP communications, select "Procedure Exist".	Procedure Exist

10.5 Available command list

The following table lists the commands that can be executed from a connected device to the E71.

The \square part in the Subcommand column varies depending on the specified device.

For details on each command, refer to the following.

SLMP Reference Manual

Item		0	Cubaammand	Description	
Туре	Operation	Command	Subcommand	Description	
		0401	00□1	Reads values in 1-point units from bit devices (consecutive device numbers).	
	Read		00□0	 Reads values in 16-point units from bit devices (consecutive device numbers). Reads values in 1-word units from word devices (consecutive device numbers). 	
		1401	00□1	Writes values to bit devices (consecutive device numbers) in 1-point units.	
	Write		00□0	Writes values to bit devices (consecutive device numbers) in 16-point units. Writes values to word devices (consecutive device numbers) in 1-word units.	
	Read Random	0403	00□0	Specifies a device number to read the device value. Discrete device numbers can be used. Reads bit devices in 16- or 32-point units. Reads word devices in 1- or 2-word units.	
Device			00□1	Specifies a device number in 1-point units to write a value to a bit device. Discrete device numbers can be used.	
	Write Random	1402	00□0	 Specifies a device number in 16-point units to write a value to a bit device. Discrete device numbers can be used. Specifies a device number in 1- or 2-word units to write a value to a word device. Discrete device numbers can be used. 	
	Entry Monitor Device	0801	00□0	Registers a device to be read by Execute Monitor (command: 0802).	
	Execute Monitor	0802	0000	Reads the value of the device registered by Entry Monitor Device (command: 0801).	
	Read Block	0406	00□0	Specifies n points (1 point: 16 bits) of word or bit devices as one block, and reads multiple blocks of data. Discrete device numbers can be used.	
	Write Block	1406	00□0	Specifies n points (1 point: 16 bits) of word or bit devices as one block, and writes multiple blocks of data. Discrete device numbers can be used.	
	Read	0613	0000	Reads buffer memory data of the E71.	
Memory	Write	1613	0000	Writes data to the buffer memory of the E71.	
Extend Unit	Read	0601	0000	Reads buffer memory data of the intelligent function module.	
Exteria Offic	Write	1601	0000	Writes data to the buffer memory of the intelligent function module.	
	Remote Run	1001	0000	Executes remote RUN to the CPU module where an E71 is connected.	
	Remote Stop	1002	0000	Executes remote STOP to the CPU module where an E71 is connected.	
Remote	Remote Pause	1003	0000	Executes remote PAUSE to the CPU module where an E71 is connected.	
Control	Remote Latch Clear	1005	0000	Executes remote latch clear to the CPU module where an E71 is connected.	
	Remote Reset	1006	0000	Executes remote RESET to the CPU module where an E71 is connected.	
	Read Type Name	0101	0000	Reads the model name and code of the CPU module where an E71 is connected.	
Remote	Lock	1631	0000	Specifies the remote password to disable the communication with other devices. (The locked state is activated from the unlocked state.)	
Password	Unlock	1630	0000	Specifies the remote password to enable communication with other devices. (The unlocked state is activated from the locked state.)	

Item		Command	Subcommand	Decembration:	
Type	Operation	Command	Subcommand	Description	
	Read Directory/File	1810	0000	Reads file list information from the CPU module where an E71 is connected.	
	Search Directory/File	1811	0000	Reads the file number of the specified file from the CPU module where an E71 is connected.	
	New File	1820	0000	Reserves storage area for the specified file of the CPU module where an E71 is connected.	
	Delete File	1822	0000	Deletes a file in the CPU module where an E71 is connected.	
	Copy File	1824	0000	Copies the specified file in the CPU module where an E71 is connected.	
File	Change File State	1825	0000	Changes the attributes of the file in the CPU module where an E71 is connected.	
	Change File Date	1826	0000	Changes the creation date of the file in the CPU module where an E71 is connected.	
	Open File	1827	0000	Locks a file so that the data of the file is not changed by other devices in the CPU module where an E71 is connected.	
	Read File	1828	0000	Reads the data of a file from the CPU module where an E71 is connected.	
	Write File	1829	0000	Writes the data to a file in the CPU module where an E71 is connected.	
	Close File	182A	0000	Cancels the file lock by the open process.	
Self Test		0619	0000	Tests whether the communication with the E71 is normally executed or not.	
Clear Error		1617	0000	Turns off the COM.ERR. LED on the E71.	

CHAPTER 11 DATA COMMUNICATIONS USING THE PREDEFINED PROTOCOL


Data can be transferred between a connected device and the CPU module with a protocol appropriate to the connected device (such as a measuring instrument or a bar code reader).

Device or buffer memory data can be taken into communication packets, and thereby this protocol communications are suitable for data that may change in each communication.

The protocol setting required to communicate with the connected device can be configured in GX Works2.

Protocols can be selected from the Predefined Protocol Library or can be created and edited.

This function is available only in the E71 with the serial number (first five digits) of "15042" or later.



For the protocol setting method, refer to the following.

GX Works2 Version 1 Operating Manual (Intelligent Function Module)

Point P

- The followings are the maximum numbers of protocols and packets that can be registered.
 - Protocols: Up to 128
 - Packets: Up to 256
 - · Packet data area size: Up to 12288 bytes

If once the number of packets reaches the upper limit, protocols cannot be added even though the number of protocols has not reached the upper limit.


In addition, if once the packet data area size reaches the upper limit, protocols and packets cannot be added even though the numbers of protocols and packets have not reached the upper limit.

For details, refer to the following.


- GX Works2 Version 1 Operating Manual (Intelligent Function Module)
- From Connection No.1 to 16 are available.
- The Communication Data Code becomes Binary Code regardless of the setting.

11.1 Data Communication Procedure


By using the predefined protocol support function, data can be communicated with the connected device in the following procedure.




- Display the "Predefined Protocol Support Function" window.
 - [Tool] ⇔ [Predefined Protocol Support Function]⇒ [Ethernet Module...]



2. Create a new file.





Select "Predefined Protocol Library" or "Add New" in the "Add Protocol" window.


When "Predefined Protocol Library" is selected, select the protocol from Predefined Protocol Library registered in GX Works2.



If "User Protocol Library" is selected in the "Add Protocol" window, protocols saved by user can be read. For details on the User Protocol Library, refer to the following.

GX Works2 Version 1 Operating Manual (Intelligent Function Module)

11.1 Data Communication Procedure





4. Set the items required for the data communications.


- Set communication parameters in the "Protocol Detailed Setting" window.
 - "Protocol Detailed Setting" window ⇔ Select a protocol ⇔ [Edit] ⇔ [Protocol Detailed Setting...]



• Set the configuration of packets to be sent and received in the "Packet Setting" window.







5. Write the protocol setting data to the flash ROM.

© [Online] ⇒ [Write to PLC...]

Select a target module and write the protocol setting data to the flash ROM.*1

*1 When the initial process is not completed, the protocol setting data cannot be written to the flash ROM. Before writing the data, set the network parameters and check that the initial process is completed.

(The initial process completion can be checked using Initial normal completion signal (X19).)



- The following data cannot be read out because they are not written to the E71. However, when the protocols are selected from the Predefined Protocol Library, the followings can be displayed.
 - Manufacturer
 - · Packet Name
 - Protocol Detailed Setting Type, Version, Explanation
 - · Packet Setting Element Name
- Module Selection using the Predefined Protocol Support Function is available only when "Not Specification" is set in the Transfer Setup of GX Works2.

When other station is specified, the E71 specified in the Transfer Setup of GX Works2 becomes the target module.

6. Execute the protocol by using a dedicated instruction.

Execute the protocol written to the flash ROM by using the dedicated instruction (ECPRTCL instruction).



- Protocols can be executed only when the target connection is in the following status:
 - · When Open completion signal is on
 - · When "Predefined protocol" is set to Fixed Buffer Communication in the open setting


If the protocol is executed to the connection where the above conditions are not satisfied, the ECPRTCL instruction ends abnormally.

11.2 Communication Type of Protocols


11.2 Communication Type of Protocols

Receive and send packets from/to the connected device for the process execution are registered in a protocol. Packet elements set using the predefined protocol support function correspond to the data part of the send/receive packets. The following shows an example of packet configuration. For details on the packet elements, refer to Page 336, Appendix 8.3.

(1) TCP/IP



(2) UDP/IP



Communications with the connected device using the predefined protocol function are performed with the following procedure (communication types).

For the operations of each communication type, refer to Page 329, Appendix 8.1.

Communication type name	Description	
Send Only	Sends a send packet once.	
Receive Only	Receives a packet if it matches any of up to 16 defined receive packets.	
Send&Receive	Sends a send packet, then receives a packet if it matches any of up to 16 defined receive packets.	

11.3 Packet Elements


A packet consists of packet elements.

Up to 32 elements can be placed in a packet, and the maximum data length is 2046 bytes per packet.

The following shows the details of the packet elements.

For examples of packet element data, refer to Page 336, Appendix 8.3.

(1) Static Data



This element is used when a specific code or character string such as a command exists in a packet.

- When sending: The specified code and character string are sent.
- · When receiving: Receive data are verified.


Multiple Static Data elements can be placed anywhere in the data part.

The following table lists the items.

Item	Item Description	
Element Name	Set name of the element.	_
Code Type Select a data type of the setting value. ASCII String/ASCII Control Code/HEX		_
Setting Value	Set data within 1 to 50 bytes. Code type and setting range are as follows: • ASCII String: 20 _H to 7F _H • ASCII Control Code: Control code of 00 _H to 1F _H and 7F _H • HEX: Hexadecimal data of 00 _H to FF _H	ASCII String: "ABC" ASCII Control Code: STX HEX: FFFF

11.3 Packet Elements

(2) Length



This element is used when an element indicating the data length is included in a packet.

- When sending: The data length of the specified range is calculated and the result is added to a send packet.
- When receiving: The data (setting value) corresponds to the Length in the receive data is verified as the data length of the specified range.

Length elements can be placed anywhere in the data part.

The following table lists the items.

Item			Remark	
Element Nar	me	Set name of the element.	_	
Code Type		Select a format of the data le	ength.	_
Data Length		Select the data length on the The range is 1 to 4.	line.	_
Data Flow		Forward Direction (Upper Byte→Lower Byte)	When sending: The calculated Length is sent from the upper byte. When receiving: The data is received from the upper byte.	
		Reverse Direction (Lower Byte→Upper Byte)	When sending: The calculated Length is sent from the lower byte. When receiving: The data is received from the lower byte.	Not settable when Data Length is 1 byte
		Byte Swap (by Word)*1	When sending: The calculated Length is sent swapping the upper byte and lower byte by word. When receiving: The data is received swapping the upper byte and lower byte by word.	
Star Calculating		Select the start element num The range is 1 to 32.	_	
Range	End	Select the end element number The range is 1 to 32.	_	


^{*1} Available only when the Data Length is 4 bytes.

Point P

- Multiple Length elements can be placed in a packet.
- When there is no element other than a Length element, an element error occurs.
 (To use a Length element, one or more element(s) other than Length is/are required.)
- When the number of digits of calculation result is greater than that specified in "Data Length", digits greater than the specified digit are omitted (ignored).
- Ex. When the Data Length is 2 bytes and the calculation result is 123 bytes, the data length is considered as 23.
- When a Non-conversion Variable (Variable length) or Non-verified Reception (Variable number of characters) is placed behind a Length and is not included in the Length calculating range, place Static Data immediate after the Nonconversion Variable or Non-verified Reception.
- When "Code Type" is "ASCII Hexadecimal", a corresponding packet is regarded as a mismatch packet if a string except
 for "0" to "9", "A" to "F", and "a" to "f" is received.
- When sending data converted to ASCII characters, use "0" to "9" or "A" to "F".
- When multiple Length elements are placed, the calculating range cannot be set as follows:
 - · A Length calculating range overlaps the others.
 - The calculating range of a Length is greater than that of the Length placed before.
- Length element cannot be placed at the end of the packet elements.

11.3 Packet Elements

(3) Non-conversion Variable



This element is used to send data in the device memory of a CPU module or buffer memory as a part of a send packet, or to store a part of a receive packet to the device memory of a CPU module device or buffer memory. The following table lists the items.

Item	Description			
Element Name	Set name of the element.			
	Fixed Length	Sends and receives the data whose length is fixed.		
Fixed Length/Variable Length	Variable Length	When sending: The data length at the time of the protocol execution is specified and the data is sent. When receiving: The data of which the length is variable is received.		
Data Length/Maximum Data Length	Set the length of data to be sent and received. (For the variable length data, set the maximum data length that can be specified to the data length storag area.) The range is 1 to 2046.			
Heit of Obered Pete	Lower Byte + Upper Byte	When sending: Each one word (2 bytes) data in the data storage area is sent in the order of the lower byte to the upper byte. When receiving: The receive data is stored to the data storage area in the order of the lower byte to the upper byte.		
Unit of Stored Data	Lower Bytes Only	When sending: Each lower byte data in the data storage area is sent. The E71 ignores data in the upper byte. When receiving: The receive data is stored to each lower byte in the data storage area. The E71 stores 00 _H in the upper byte.		
Byte Swap Disable/Enable		When sending: When "Enable" is selected, data in the upper byte and lower byte are swapped by word (2 bytes) and sent. When "Unit of Stored Data" is "Lower Byte + Upper Byte" and "Data Length" is an odd number of bytes, the upper byte is sent at transmission of the last byte. When "Unit of Stored Data" is "Lower Bytes Only" and "Data Length" is an odd number of bytes, data without any byte swap is sent at transmission of the last byte. When receiving: When "Enable" is selected, data in the upper byte and lower byte are swapped by word (2 bytes) and sent. When "Unit of Stored Data" is "Lower Byte + Upper Byte" and "Data Length" is an odd number of bytes, the last byte is stored to the upper byte. When "Unit of Stored Data" is "Lower Bytes Only" and "Data Length" is an odd number of bytes, the last byte is stored without any byte swap.		

Item	Description
	Specify a start device to store variable value.
	Available devices are as follows:
	• Internal user*1*2
	Input relay (X)
	Output relay (Y)
	Internal relay (M)
Data Storage Area	Latch relay (L)
Specification	Link relay (B)
	Data register (D)
	Link register (W)
	• File register* ²
	File register (R, ZR)
	Buffer memory
	G device (G) (Send/receive area for predefined protocol support function (address: 4800 _H to 4FFF _H))

^{*1} Do not set local devices.


The following describes the configuration of the data storage area.

(a) When "Fixed Length/Variable Length" is "Fixed Length"

An area starting from the device number which is specified in the "Element Setting" window is considered as the data storage area.

The data storage area to be occupied varies depending on the setting of "Unit of Stored Data".

- When "Lower Byte + Upper Byte" is selected, the same size as the data length is occupied.
 (However, when the data length of a send packet is an odd number, the upper byte (lower byte for "Byte Swap") of the last device is not sent. When the data length of a receive packet is an odd number, the last data is stored with one byte of 00_H.)
- When "Lower Bytes Only" is selected, twice the size of the data length is occupied.



^{*2} Set within the device range specified in the "Device" window of PLC Parameter.


11.3 Packet Elements

(b) When "Fixed Length/Variable Length" is "Variable Length"

An area starting from the device number which is specified in the "Element Setting" window +1 is considered as the data storage area.

The data storage area to be occupied varies depending on the setting of "Unit of Stored Data".

- When "Lower Byte + Upper Byte" is selected, the same size as the data length + one word (length for the
 data length storage area) are occupied. (However, when the data length of a send packet is an odd
 number, the upper byte (lower byte for "Byte Swap") of the last device is not sent. When the data length of
 a receive packet is an odd number, the last data is stored with one byte of 00_H.)
- When "Lower Bytes Only" is selected, twice size of the data length + one word (length for the data length storage area) are occupied.




*: The unit of the data length is fixed to byte.

Point P

- Multiple Non-conversion Variable elements can be placed in a packet.
- When "Fixed Length/Variable Length" is "Variable Length" and the configuration is set as follows, an error occurs:
 - An element other than Static Data is placed behind a Non-conversion Variable element when Non-conversion
 Variable is out of the Length calculating range or when there is no Length element (except for when Nonconversion Variable is placed at the end of the packet elements).
 - Multiple Non-conversion Variable elements are placed in the Length calculating range, while a Length element is not placed.
 - A Non-conversion Variable element is placed before a Length element in the Length calculating range.

(4) Non-verified Reception



This element is used when receive data include unnecessary data.

The E71 skips characters as many as the specified number if a receive packet includes a Non-verified Reception. The following table lists the items.

Item		Remark		
Element Name	Set name of the element.	_		
Data Longth	0 (Variable number of characters)	Set this item when the number of characters not to be verified varies in each communication.	_	
Data Length	1 to 2046 (Specified number of characters)	Set the number of characters not to be verified.	-	



- Multiple Non-verified Reception elements can be placed in a packet.
- When "Data Length" is set to 0 and the configuration is set as follows, an error occurs:
 - An element other than Static Data is placed behind a Non-verified Reception element when Non-verified Reception is out of the Length calculating range or when there is no Length element (except for when Non-verified Reception is placed at the end of the packet elements).
 - Multiple Non-verified Reception elements are placed in the Length calculating range, while a Length element is not placed.
 - A Non-verified Reception element is placed before a Length element in the Length calculating range.

11.4 Execution Condition of Predefined Protocol Communication

11.4 Execution Condition of Predefined Protocol Communication

Communications using the predefined protocol can be executed when Predefined protocol ready (X1D) is on. This section describes the operations of Predefined protocol ready (X1D).

(1) When the power supply is on or reset

The E71 checks the written protocol setting data when the power supply is on or reset.

If the protocol setting data is set correctly, the E71 turns on Predefined protocol ready (X1D) then the protocols can be executed.


Predefined protocol ready (X1D) is used as an interlock signal when the protocols are executed.

If an error has occurred in the protocol setting data, Predefined protocol ready (X1D) stays off and the error details are stored to the protocol setting data check area (address: 5320_H to $533F_H$).


If no protocol setting data has been set, the E71 does not check the data and Predefined protocol ready (X1D) stays off.

The information about whether protocol setting data has been registered can be checked in Number of registered protocols (address: 5328_H) and Protocol registration (address: 5330_H to 533F_H).

(a) If the protocol setting data is set correctly



(b) If an error has occurred in the protocol setting data




(2) When the protocol setting data is written


When the protocol setting data writing from GX Works2 is completed, Predefined protocol ready (X1D) turns off. After the completion, the E71 checks the protocol setting data. If the protocol setting data is set correctly, the E71 turns on Predefined protocol ready (X1D).

If an error has occurred in the protocol setting data, Predefined protocol ready (X1D) stays off and the error details are stored to the protocol setting data check area (address: 5320_H to $533F_H$).

(a) If the protocol setting data is set correctly



(b) If an error has occurred in the protocol setting data



(3) When the UINI instruction is being executed

The E71 does not check the protocol setting data when the UINI instruction is being executed. Predefined protocol ready (X1D) keeps its status even when the instruction is executed.

(4) The operations of X1D and COM.ERR.LED

If an error has occurred in the protocol setting data when the power supply is on or reset, or at the data check after the data writing, Protocol setting data error (error code: C402_H) occurs.


Predefined protocol ready (X1D) turns off and the COM.ERR.LED turns on at this time.

11.5 Example of Predefined Protocol Communications

This section describes an example of communications using the predefined protocol under the following system configuration.

11.5.1 System configuration example

(1) System configuration



11.5 Example of Predefined Protocol Communications 11.5.2 Parameter Setting


11.5.2 Parameter Setting

(1) Sending side (LCPU-1 side)

The following is an example of the parameter settings of the sending side (LCPU-1 side).


(a) Basic setting

The following is an example of the basic setting.




(b) Ethernet operation setting

The following is an example of the Ethernet operation setting.



(c) Open setting

The following is an example of the open setting.




(d) Protocol setting data

The value in D100 to D109 of the destination station can be read by using SLMP (Device Read) command in the Predefined Protocol Library.


The followings are setting examples of the protocol setting data using the Predefined Protocol Support Function.

[Protocol Setting]




[Packet Setting]


· Send Packet (Request)



· Receive Packet (Normal response)



· Receive Packet (Error response)




(2) Receiving side (LCPU-2 side)


The following is an example of the parameter settings of the receiving side (LCPU-2 side).

(a) Basic setting


The following is an example of the basic setting.



(b) Ethernet operation setting



(c) Open setting



11.5 Example of Predefined Protocol Communications 11.5.3 Program example

11.5.3 Program example

The following is a program example that specifies Connection No.1 and executes a protocol by using the ECPRTCL instruction.

(1) Sample program

(a) Sending side (LCPU-1 side)

```
<<Open process program>>
         SM400
                                                                                                      U0\
                                                                                             -[MOV
                                                                                                      G20480
                                                                                                                 K4M0
                                                                                                      U0\
                                                                                             √мо∨
                                                                                                      G20482
                                                                                                                 K4M20
         M1000
                                                                                                      -[PLS
                                                                                                                 M1001
         M1001
                    X19
                                       M20
                                       1/
                                                                                             MOVP
                                                                                                       Н0
                                                                                                                 D100
                                                                          ZP.OPEN U0
                                                                                             K1
                                                                                                      D100
                                                                                                                 M100
          M100
                   M101
                                                                                                       SET
                                                                                                                 M150
                   M101
                                                                                                      SET
                                                                                                                 M151
```

```
<< Program for predefined protocol communications>>
                                                                                                       PLS
                                                                                                                 M3001
           M3001
                                                                                                       -FINC
                                                                                                                 D0
                                                                                             -[моv
                                                                                                       Н0
                                                                                                                 D1
                                                                                             -[моv
                                                                                                       H0FF
                                                                                                                 D2
                                                                                             -[моv
                                                                                                       H10
                                                                                                                 D4
           M3001
            \dashv
                                                                                             -[DMOV
                                                                                                       K100
                                                                                             -[моv
                                                                                                       H0A8
                                                                                                                 D7
                                                                                             -[моv
                                                                                                       K10
                                                                                                                 D8
```

```
M3001
                                                                       _[моv
                                                                                K1
                                                                                         D202
                                       -[GP.ECPRTCL
                                                                       K1
                                                                                D200
                                                                                         M200
M200
        M201
                                                                                SET
                                                                                         M250
        M201
                                                                                _[SET
                                                                       -[MOVP
                                                                              D201
                                                                                         D300
```

```
<<Close process program>>
                                                                                                  -[PLF
                                                                                                             M360
           м360
— | —
                    M150
                                                                                                   -[PLS
                                                                                                             M361
           -[PLS
                                                                                                             M6001
           M6001
                     мо
—| |-
                                                              _[ZP.CLOSE
                                                                                U0
                                                                                                  D400
                                                                                                             M400
           M361
                    M410
                                                                                                  _[SET
                                                                                                             M410
           M400
                    M401
                                                                                                   _[SET
                     -1/-
                                                                                                             M402
                    M401
                                                                                                  -[SET
                                                                                                             M403
                                                                                                   -[RST
                                                                                                             M410
```

CHAPTER 12 COMMUNICATIONS USING A FIXED BUFFER

This chapter describes communications using a fixed buffer.

12.1 Applications

In communications using a fixed buffer, a programmable controller can actively send data; therefore, data can be sent from the programmable controller to the host system when an error occurs in machine equipment or some other conditions are satisfied. A maximum of 1K word of data can be sent or received between programmable controllers or between a programmable controller and the host system.

12.1.1 Differences between the "Procedure Exist" and "No Procedure" control methods

There are two control methods for communications using a fixed buffer; "Procedure Exist" control method and "No Procedure" control method. This section describes the differences between the "Procedure Exist" and "No Procedure" control methods.

Item	Difference		
item	Procedure Exist	No Procedure	
Message format	Data is sent/received in a fixed data format.	Data is sent/received in the message format of the connected device.	
A response to data receiving	A response to data receiving is sent.	A response to data receiving is not sent.	
Data code	Communications can be performed using a binary code or ASCII code.	Communications are performed using only a binary code.	
Data length specified using a dedicated instruction	Specified by the number of words.	Specified by the number of bytes.	
Amount of application data per communication	Maximum of 1017 words	Maximum of 2046 bytes	



A connection with a connected device is dedicated for "No Procedure" communications using a fixed buffer. MC protocol communications and "Procedure Exist" communications using a fixed buffer and random access buffer cannot be performed at the same time as "No Procedure" communications using a fixed buffer.

12.2 Communication Structure

This section describes the structure of communications using a fixed buffer.


(1) Data flow

In communications using a fixed buffer, data is sent/received using dedicated instructions.

- · Sending data: BUFSND instruction
- Receiving data: BUFRCV instruction or BUFRCVS instruction

When the "Procedure Exist" control method is used, the CPU module and the connected device communicate on a 1:1 basis. The CPU module sends/receives data to/from the connected device while handshaking with the connected device.

When the "No Procedure" control method is used, the CPU module sends/receives data to/from the connected device in a non-procedural manner.




(2) Connected devices where data communications can be performed

Data communications can be performed with the following connected devices.

- · Devices in Ethernet where an E71 is connected
- · Devices connected with the router relay function

When using each fixed buffer (numbers 1 to 16) as shown in the figure below, set the destination devices and usage conditions (e.g. for sending/receiving and "Procedure Exist"/"No Procedure") in the open setting to fix a connected device to each buffer.



Note the following points when changing connected devices.

- During TCP/IP communications, a connected device can be changed only when the connection with the connected device is not established (when Open completion signal is off).
- During UDP/IP communications, a connected device can be changed regardless of the status of connection with the connected device.

Point P

- When changing connected devices, do not use the pairing open or alive check function.
- When "No Procedure" is selected for a connection, the connection is dedicated to "No Procedure" communications using a fixed buffer after the open process is completed. When "Procedure Exist" is selected for a connection, the following data communications can be performed after the open process is completed.
 - MC protocol communications
 - Communications using a fixed buffer using the "Procedure Exist" control method
 - · Communications using a random access buffer

(3) Processes during data sending/receiving

(a) When data is sent

When a CPU module executes the BUFSND instruction, the E71 sends data of the applicable fixed buffer number n to the connected device that is specified in Communication address setting area (addresses: 28_{H} to $5F_{H}$) corresponding to the fixed buffer number n.

(b) When data is received

An E71 processes the data that is received from the connected device set in the communication address setting area corresponding to the fixed buffer number n.*1 In addition, when an E71 stores the received data in the corresponding fixed buffer in the receive process, it updates the IP address and destination port number of the connected device in Connection information area (addresses: 78_H to C7_H and 5820_H to 586F_H) corresponding to the fixed buffer number n. If data is received from a connected device not set in the connection information area of the buffer memory, an E71 ignores the received data.

*1 With the TCP/IP Unpassive open, data is sent to or received from a connected device stored in the connection information area of the buffer memory.




When received data is stored in the corresponding fixed buffer in the receive process of broadcast communications, an E71 updates the destination IP address and port number in Connection information area (address: 78_H to $C7_H$ and 5820_H to $586F_H$) corresponding to the fixed buffer number n.

12.3 Data Sending Procedure

This section describes how an E71 sends data to the connected device.

(1) Procedure exists

The following is the data send process performed in the fixed buffer number 1 area for the connection number 1.



- 1 Confirm the normal completion of the initial process. (Initial normal completion signal (X19): ON)
- Establish a connection between the E71 and the connected device and confirm the normal completion of the open process of the connection number 1.
- 3 Execute the BUFSND instruction. (The data is sent.)
- The send data in the fixed buffer number 1 is sent to the connected device by the send data length.
- When the connected device receives the data from the E71, the connected device sends a response to the E71.
- When the E71 receives the response from the connected device, the E71 stops sending data. If a response is not sent within the response monitoring timer value, a data send error occurs.*1


 After the data send process abnormally ends, execute the BUFSND instruction again to repeat the send process.
 - *1 Refer to the section describing the initial setting when adjusting the monitoring timer value. (Fig. Page 301, Appendix 4.1)

Point P

- The items configured in the open setting become enabled when Open completion signal of an E71 is started up.
- Do not send data (command) before data communications are completed (or a response is received) in response to the previous data (command).
- When an E71 communicates data with multiple connected devices, data can be sent sequentially; however, switching the connected devices before sending/receiving data is recommended to prevent communication problems. When a connection opened using the UDP/IP protocol is used, change the setting values in the communication address setting area before sending or receiving data to switch the connected devices.

(2) No procedure

The following is the data send process performed in the fixed buffer number 1 area for the connection number 1.



- Confirm the normal completion of the initial process. (Initial normal completion signal (X19): ON)
- Establish a connection between the E71 and the connected device and confirm the normal completion of the open process of the connection number 1.
- Secute the BUFSND instruction. (The data is sent.)
- The send data in the fixed buffer number 1 is sent to the connected device by the send data length.
- The E71 stops sending data. After the data send process abnormally ends, execute the BUFSND instruction again to repeat the send process.



During UDP/IP communications, when the internal process of an E71 is normally completed, the data send process ends even if the communication line between a CPU module and the connected device is not connected due to cable disconnection or other causes. It is recommended to set an original communication procedure to send/receive data.

12.4 Data Receiving Procedure

This section describes how an E71 receives data from the connected device. The following methods for receiving data are offered:


- Data receiving using the main program (BUFRCV instruction)
- · Data receiving using an interrupt program (BUFRCVS instruction)

12.4.1 Data receiving using the main program (BUFRCV instruction)

A receive process in the main program is performed using the BUFRCV instruction.

(1) Procedure exists

The following is the data receive process performed in the fixed buffer number 1 area for the connection number 1.




- Confirm the normal completion of the initial process. (Initial normal completion signal (X19): ON)
- Establish a connection between the E71 and the connected device and confirm the normal completion of the open process of the connection number 1.
- Receive data from the destination.
 - Fixed buffer reception status signal (address: 5005_H (b0)): ON
- Execute the BUFRCV instruction to read the receive data length and receive data from the fixed buffer number 1.
 - Fixed buffer reception status signal (address: 5005_H (b0)): OFF
- When the receive data length and the receive data are completely read out, a response is sent to the destination.
- 6 End the receive process. If the data receive process is abnormally ended, execute the BUFRCV instruction again to repeat the receive process.



- The items configured in the open setting become enabled when Open completion signal of an E71 is started up.
- When the buffer memory area that stores Fixed buffer reception status signal is turned off and on, execute the BUFRCV instruction.
- When abnormal data is received, Fixed buffer reception status signal does not turn on. In addition, data is not stored in the fixed buffer number 1 area.

(2) No procedure

The following is the receive process performed in the fixed buffer number 1 area for the connection number 1.



- Confirm the normal completion of the initial process. (Initial normal completion signal (X19): ON)
- Establish a connection between the E71 and the connected device and confirm the normal completion of the open process of the connection number 1.
- Receive data from the connected device.
 - Fixed buffer reception status signal (address: 5005_H (b0)): ON
- Execute the BUFRCV instruction to read the receive data length and receive data from the fixed buffer number 1.
 - Fixed buffer reception status signal (address: 5005_H (b0)): OFF
- 5 End the receive process. If the data receive process is abnormally ended, execute the BUFRCV instruction again to repeat the receive process.

Point P

- The items configured in the open setting become enabled when Open completion signal of an E71 is started up.
- When the buffer memory area that stores Fixed buffer reception status signal is turned off and on, execute the BUFRCV instruction.
- When abnormal data is received, Fixed buffer reception status signal does not turn on. In addition, data is not stored in the fixed buffer number 1 area.

12.4.2 Data receiving using an interrupt program (BUFRCVS instruction)


A receive process in an interrupt program is performed using the BUFRCVS instruction. An interrupt program is started up when data is received from a connected device, and receive data for a CPU module can be read.

The following settings are required to use an interrupt program: (FP Page 130, Section 12.5.1)

- · Interrupt pointer setting
- · Interrupt settings

(1) Procedure exists


The following is the receive process performed in the fixed buffer number 2 area for the connection number 2.



- Confirm the normal completion of the initial process. (Initial normal completion signal (X19): ON)
- Establish a connection between the E71 and the connected device and confirm the normal completion of the open process of the connection number 2.
- Receive data from the destination.
 - Fixed buffer reception status signal (address: 5005_H (b1)): ON
 - Request the CPU module to start up the interrupt program.
- The interrupt program starts up. Execute the BUFRCVS instruction to read the receive data length and receive data from the fixed buffer number 2.
- When the receive data length and the receive data are completely read out, a response is sent to the destination.*1
- 6 End the interrupt program to restart the main program.
 - *1 If the data receive process is abnormally ended, the E71 does not return a response.

(2) No procedure

The following is the receive process performed in the fixed buffer number 2 area for the connection number 2.




- Confirm the normal completion of the initial process. (Initial normal completion signal (X19): ON)
- Establish a connection between the E71 and the connected device and confirm the normal completion of the open process of the connection number 1.
- Receive data from the destination.
 - Request the CPU module to start up the interrupt program.
- The interrupt program starts up. Execute the BUFRCVS instruction to read the receive data length and receive data from the fixed buffer number 1.
- **5** End the interrupt program to restart the main program.

12.5 Parameter Setting

Set the following parameters to perform communications using a fixed buffer.


- Basic setting (FP Page 65, Section 7.1.2)
- Ethernet operation setting (F Page 66, Section 7.1.3)
- Open setting (Page 68, Section 7.1.4)



Item	Description	Setting range
Fixed Buffer	Select whether to use the fixed buffer for connection with the connected device for sending or receiving.	• Send • Receive
Fixed Buffer Communication	Select the communication method for communications using a fixed buffer.	Procedure Exist No Procedure
Pairing Open	Select whether to disable or enable the pairing open for communications using a fixed buffer. (Page 138, Section 12.7)	Disable Enable
Existence Confirmation	Select whether or not to use the alive check function. (Fig. Page 187, Section 14.6) Select "No Confirm" to send data by broadcast communications during "No Procedure" communications using a fixed buffer.	No Confirm Confirm

12.5.1 Parameter setting when using an interrupt program


Configure the parameter setting on a programming tool to start up an interrupt program.



(1) Interrupt pointer setting

The following is a setting example.

Project window ⇔ [Parameter] ⇔ [PLC Parameter] ⇔ [PLC System] ⇔ Interrupt Pointer Setting button




	Item	Description	Setting range
PLC Side	Interrupt Pointer Start No.	Set the start number of the interrupt pointer used in a program.	50 to 255
	Interrupt Pointer Count	Set the number of interrupt pointers used in a program.	1 to 16
	Start I/O No.	Set the start I/O number of an E71.	0000 _H to 0FE0 _H
Intelligent Module Side	Start SI No.	Among maximum 16 interrupt (SI) numbers (control numbers on the Ethernet module side) to be set in the interrupt program, set the smallest numbers 0 to 15.	0 to 15

(2) Interrupt settings

The following is a setting example.

Project window ⇔ [Parameter] ⇔ [Network Parameter] ⇔ [Ethernet/CC IE Field] ⇔ Select "Ethernet" under "Network Type". ⇔ Interrupt Settings button



Item	Description	Setting range
Input Format	The input format of each data is decimal number only.	_
Device Code	Select a device code. Select "Fixed Buffer" in this setting.	Fixed Buffer
Channel No./Connection No.	Set the connection number of the fixed buffer to trigger the interrupt program.	1 to 16
Interrupt (SI) No.	Set the interrupt control number for the E71 for when an interrupt request is issued from the E71 to the CPU module.*1	0 to 15

^{*1} Do not set the same interrupt (SI) numbers as those to be set for an interrupt of other communications using a fixed buffer or the RECV instruction.



Interrupt (SI) numbers can be assigned by the user to receive up to 16 communications using a fixed buffer and communications using the RECV instruction in an interrupt program. The user must manage the interrupt (SI) numbers assigned for receiving data.

12.6 Data Format

Communication data consists of a header and application data.

12.6.1 Header

The header for TCP/IP or UDP/IP is used. Because an E71 automatically adds and deletes a header, the user setting is not required.

(1) Detailed header sizes

(a) TCP/IP

Ethernet	IP	TCP
(14 bytes)	(20 bytes)	(20 bytes)

(b) UDP/IP

Ethernet	IP	UDP
(14 bytes)	(20 bytes)	(8 bytes)

12.6.2 Application data

This section describes the application data configuration.


(1) Procedure exists

In the application data for communications with the "Procedure Exist" control method, the following data code is expressed in a binary code or an ASCII code. To switch between a binary code and an ASCII code, use the Ethernet operation setting.




(a) Format

· Communications using a binary code




· Communications using an ASCII code



(b) Subheader

Because an E71 automatically adds and deletes a header, the user setting is not required.



(c) Data length setting

The following are the data sizes of a text (command).


- Communications using a binary code: Maximum of 1017 words
- Communications using an ASCII code: Maximum of 508 words

(d) Text (command)

The following is the format of a command/response.


· Communications using a binary code

Command format



· Communications using an ASCII code

Command format



(e) End codes

An error code is stored in the end code added to a response. For the error codes, refer to the error code list. (Fig. Page 259, Section 16.7.1) End codes are stored in the complete status area (in the control data) of the BUFSND and BUFRCV instructions, as well as the communication status storage area of the buffer memory.



If an error code related to MC protocol communications or communications using a random access buffer is stored during communications using a fixed buffer, it may be caused by the following.

Cause	Action
The data length value specified in the application data of the message sent from a connected device to the E71 is different from the actual text data size.	Specify the actual text data size for the data length in the application data. (Refer to "Remark" in this page.)
The subheader of the message sent from a connected device to the E71 is incorrect.	Correct the subheader specified in the application data.




Depending on the restrictions of the buffers of the own station and destination station, data may be divided for communications. Data received separately is restored (reassembled) by the E71 for communications. The received data is restored (reassembled) based on the data length in the communication data. The E71 performs the following processes if data in the communication data is incorrect.

- If the data length specified immediately after the subheader is smaller than the amount of text data received

 A) The data immediately after the subheader is smaller than the amount of text data received.

 The data immediately after the subheader is smaller than the amount of text data received.
 - 1) The data immediately after the text data equivalent to the data length specified immediately after the subheader is regarded as the next message.
 - 2) Because the header of each message is a subheader, an E71 processes data according to the code in the subheader.
 - 3) If the subheader contains a code that is not recognized by an E71, the E71 sends a response notifying about an abnormal end to the connected device.



In the figure above, the E71 returns a response containing a code obtained by changing the most significant bit of the code processed as a subheader to 1.

For example, if the subheader of a command is 65_H, the subheader of the response is E5_H.

- If the data length specified immediately after the subheader is larger than the amount of text data received
 - 1) The E71 waits for the remaining data.
 - 2) When the remaining data is received within the response monitoring timer value, the E71 processes data according to the code in the subheader.
 - If the remaining data could not be received within the response monitoring timer value, the E71 performs the following processes.
 - Sends the ABORT (RST) instruction to the connected device and closes the line.
 - Notifies the CPU module that an open error has occurred by turning on Open abnormal detection signal (X18)
 - Stores the error code in the open error code storage area. (The error code is not stored in the error log storage area.)

(2) No procedure

In the application data for communications in the "No Procedure" control method, the following data code is expressed in a binary code. Communications are performed using a binary code regardless of the communication data code setting.

Text (command)

Maximum of 2046 bytes




In communications in the "No Procedure" control method, a subheader or data length setting is not added unlike the "Procedure Exist" control method; therefore, all data are handled as a valid text. In addition, the E71 turns on Fixed buffer reception status signal after storing the size of the received message (packet) in the data length storage area. It is recommended to set a checking method. For example, include data length and a data type code in the application data of a message so that the number of bytes and data type of the application data can be identified on the receiving side.

12.7 Pairing Open

Pairing open is an opening method that connects the own station with the connected device using only one port by pairing the receive and send connections for communications using a fixed buffer.

12.7.1 Applications

Enabling the pairing open allows data communications to be performed with two connections by performing the open process for one port. MC protocol communications and communications using a random access buffer can be also performed using paring-opened connections.






- Connected devices where communications can be performed using the pairing open method are those in Ethernet where an E71 is connected and those connected using the router relay function.
- The open/close processes in the receive connection where the pairing open has been enabled automatically perform the open/close processes in the next connection (send connection).

12.7.2 Parameter setting

The following is the pairing open setting.



Item	Description	Setting range
Pairing Open	Set "Pairing Open" of the receive connection to "Enable". The next connection is	_
	automatically set as a send connection.*1	_

*1 When "Enable" has been set in "Pairing Open" for a send connection, the following window appears.



When the ______ button is selected, the applicable connection becomes a receive connection, and the next connection is automatically set as a send connection. (When "Enable" has already been set in "Pairing Open", the setting is overwritten.)

Point P

Because the fixed buffer of the connection with the connected device (for receiving) and the fixed buffer of the next connection (for sending) are paired, set connection numbers 1 to 7 and 9 to 15 as receive connections. (Connection numbers 8 and 16 cannot be set.)

12.8 Broadcast Communications

Broadcast communications mean that the same data is sent to all E71-connected stations in the same Ethernet network and to the connected devices without specifying destinations. Broadcast communications can be performed when the following conditions are met.

- · When UDP/IP protocol is used
- When "No Procedure" communications using a fixed buffer or data communications using the predefined protocol are performed

Point P

- When connected devices in the same Ethernet network do not need to receive communication messages by broadcast communications, a discarding process is required.
- The user needs to determine the port numbers dedicated for data sending/receiving for broadcast communications.
- Sending/receiving procedures to perform the broadcast communications in communications using the predefined
 protocol are same as that in communications using a fixed buffer except for setting "Predefined protocol" under "Fixed
 Buffer Communication" of the open setting.

12.8.1 Sending/receiving procedures

(1) Sending procedure


To send data by broadcast communications, set the IP addresses of the connected devices where the E71 sends data to FFFFFFFH_H and perform the open process. The E71 sets all the host address bits to 1 and sends data over the Ethernet network.

(2) Receiving procedure

To receive data as data for broadcast communications, set the IP addresses of the connected devices that send data to the E71 to FFFFFFFH_H and the port numbers to FFFF_H and perform the open process.

Remark

The following is the outline of the internal process of an E71 when data is received in the "No Procedure" control method or by broadcast communications. (The values specified in the buffer memory addresses 0_H , 1_H and 28_H to $5F_H$ are used for the IP addresses and port numbers of the E71 in the own station as well as those of connected devices.)




*1 When all the bits of the area expressing the host address of the IP address of the receive data request destination are 1, proceed to "YES".

12.8.2 Parameter setting

The following is the parameter setting for broadcast communications.

(1) When sending data


The following is the parameter setting for data sending.



Item	Description	Setting range
Protocol	Select "UDP".	_
Fixed Buffer	Select "Send".	_
Fixed Buffer Communication	Select "No Procedure".	_
Existence Confirmation	Select "No Confirm".	_
Destination IP Address	Set FFFFFFF _H .	_

(2) When receiving data

The following is the parameter setting for data receiving.



Item	Description	Setting range
Protocol	Select "UDP".	_
Fixed Buffer	Select "Receive".	_
Fixed Buffer Communication	Select "No Procedure".	_
Existence Confirmation	Select "No Confirm".	_
Destination IP Address	Set FFFFFFF _H .	_
Destination Port No.	Set FFFF _H .	_

12.8.3 Precautions

This section describes the precautions for broadcast communications.

(1) Port number

To perform broadcast communications, the user needs to determine the port numbers dedicated for data sending/receiving for broadcast communications and specify these port numbers.

(2) Size of send/receive data per sending/receiving

A maximum of 2046 bytes of data in the application data can be processed per sending/receiving. To send data with a size exceeding 2047 bytes, divide the data into smaller chunks at the send source.



An E71 temporarily stores a subsequent receive data in its internal buffer for the operating system until the current receive process is completed. If data with a size exceeding the capacity of the internal buffer (approximately 40KB) is received by broadcast communications, the data is discarded. In communications using a fixed buffer in the "Procedure Exist" control method, the E71 sends a command message to the connected device, waits for a response message, then sends the next command message. Therefore, the user need not take account of the above-mentioned internal buffer for the operating system.


12.9 Example of Communications Using a Fixed Buffer12.9.1 System configuration

12.9 Example of Communications Using a Fixed Buffer

This section describes an example of communications using a fixed buffer in the "Procedure Exist" control method between an E71 and the connected device.

12.9.1 System configuration

The following system configuration is used for explanation purpose.



12.9.2 Parameter setting


This section describes a parameter setting example.

(1) Sending side (LCPU-1 side)

The following is an example of the parameter settings of the sending side (LCPU-1 side).


(a) Basic setting

The following is an example of the basic setting.




(b) Ethernet operation setting

The following is an example of the Ethernet operation setting.



(c) Open setting

The following is an example of the open setting.




(2) Receiving side (LCPU-2 side)

The following is an example of the parameter settings of the receiving side (LCPU-2 side).


(a) Basic setting

The following is an example of the basic setting.




(b) Ethernet operation setting

The following is an example of the Ethernet operation setting.



(c) Open setting

The following is an example of the open setting.



12.9 Example of Communications Using a Fixed Buffer 12.9.3 Program

12.9.3 Program

(1) Sample program procedures

This section describes the procedures for a sample program.

(a) Sending side (LCPU-1 side)

The following describes how communications are processed on the sending side (LCPU-1 side).

- 1. Set each parameter on a programming tool and write the set parameters to the CPU module. Then reset the CPU module and check that the initial process is completed.
- 2. Perform the open process (Active open) of the connection number 1.
- 3. Perform communications using a fixed buffer from the CPU module using the BUFSND instruction.
- 4. After the data is sent, perform the close process of the connection number 1.

(b) Receiving side (LCPU-2 side)

The following describes how communications are processed on the receiving side (LCPU-2 side).


- 1. Set each parameter on a programming tool and write the set parameters to the CPU module. Then reset the CPU module and check that the initial process is completed. When the initial process is normally completed, the connection number 1 waits for an Active open request from the connected device.
- 2. Perform communications using a fixed buffer from the connected device.
- 3. Use the BUFRCV instruction to read the data that have been received by the corresponding fixed buffer data area of the E71 into the CPU module.

(2) Sample program

(a) Program on the sending side (LCPU-1 side)

The following is a program on the sending side (LCPU-1 side).

```
<<Open process program>>
SM400
                                                                                           U0\
                                                                                  -[моv
  +
                                                                                           G20480
                                                                                                      K4M0
                                                                                           U0\
                                                                                  -[MOV
                                                                                           G20482
                                                                                                      K4M20
           M20
                                                                                           -[INCP
                                                                                                      D20
 M1000
                                                                                           -[PLS
                                                                                                      M1001
 M1001
           X19
                             M20
                     Μ0
                                                                                  MOVP
                                                                                            H0
                                                                                                      D100
                                                                ZP.OPEN U0
                                                                                   K1
                                                                                           D100
                                                                                                      M100
 M100
          M101
                                                                                           SET
                                                                                                      M110
          M101
                                                                                           -[SET
                                                                                                      M111
```



```
<<Close processing program>>
                                                                                                 -[PLF
                                                                                                            M160
   M160
             M150
                                                                                                 -[PLS
                                                                                                            M161
   M6000
                                                                                                  -[PLS
                                                                                                            M6001
    \dashv \vdash
   M6001
              M0
    +
                                                           -[ZP.CLOSE
                                                                              U0
                                                                                        K1
                                                                                                  D200
                                                                                                            M200
   M161
             M210
                                                                                                  -[SET
    +
                                                                                                            M210
   M200
             M201
                                                                                                 _[SET
    \dashv
                                                                                                            M202
             M201
              +
                                                                                                  -[SET
                                                                                                            M203
                                                                                                  -[RST
                                                                                                            M210
```

(b) Receiving side (LCPU-2 side)

The following is a program on the receiving side (LCPU-2 side).

```
<<Fixed buffer No.1 receive program>>
   SM400
                                                                                             U0\
                                                                                     √MOV
                                                                                              G20480
                                                                                                        K4M0
                                                                                             U0\
                                                                                              G20482
                                                                                                        K4M20
                                                                                             U0\
                                                                                     Гмоч
                                                                                              G20485
                                                                                                        K4M40
   M5000
                                         M500
     4+
                                                                                              PLS
                                                                                                        M5001
   M5001
                                                ZP.BUFRCV
                                                                                     D5000
                                                                                              D500
                                                                                                        M500
                                                                  U0
                                                                            K1
             M501
    M500
                                                                                     Process upon completion
             M501
                                                                                    Process upon abnormal end
```

Point P


- Secure sufficient device areas according to the maximum length of data sent from the send source to prevent the device areas used for other purposes from being overwritten by the receive data.
- To receive data at shorter intervals than the scan time of the CPU module, add the normally closed contact for the completion device (M500) of the BUFRCV instruction to the execution conditions of the BUFRCV instruction as shown in the above program. When there is no normally closed contact for the completion device (M500), the receive direction (M5001) of the BUFRCV instruction is not turned off and on and the BUFRCV instruction may not be executed.

CHAPTER 13 COMMUNICATIONS USING A RANDOM ACCESS BUFFER

This section describes communications using a random access buffer.

13.1 Applications

In communications using a random access buffer, data can be freely read from and written to any connected device (not including an E71). A random access buffer is used as a common buffer area for all the connected devices in the Ethernet network.



Point P


Data communications (sending/receiving) by e-mail using a CPU module cannot be used together with communications using a random access buffer. Only one of the functions can be used at one time. (The e-mail sending function using the E71 programmable controller CPU monitoring function can be used together with communications using a random access buffer.)

13.2 Communication Structure

This section describes the structure of communications using a random access buffer.

(1) Data flow

The data flow in communications using a random access buffer is as follows. The FROM/TO instructions or intelligent function module devices are used to access a random access buffer from a CPU module.



Point P

- Communications can be performed only with connected devices where communications using a fixed buffer in the "Procedure Exist" control method are set using the connection with Open completion signal of an E71 on.
- Communications are performed asynchronously with the program. If synchronization is required, use communications
 using a fixed buffer.


(2) Connected devices where data communications can be performed

Data communications can be performed with the following connected devices:

- · Devices in Ethernet where an E71 is connected
- · Devices connected using the router relay function

13.2.1 How data is read from a connected device


The following figure shows how an E71 sends data in response to a read request sent from a connected device.



- Write data in the random access buffer of the E71 using the TO instruction.
- 2 Asynchronously with the process 1 above, the connected device sends a read request to the E71. (The E71 side: command receiving)
- 3 Upon receiving the read request from the connected device, the E71 sends the data written in the random access buffer to the connected device that sent the read request. (The E71 side: response sending)

13.2.2 How a connected device writes data

The following figure shows how a connected device writes data to the E71 random access buffer.




- The connected device writes data to the random access buffer of the E71. (The E71 side: command receiving)
- 2 The E71 processes the write request from the connected device and returns the writing result to the connected device that sent the write request. (The E71 side: response sending)
- 3 Asynchronously with the processes 1 and 2 above, the data written in the random access buffer is read using the FROM instruction.

13.3 Parameter Setting

Set the following parameters to perform communications using a random access buffer.

- Basic setting (Page 65, Section 7.1.2)
- Ethernet operation setting (F Page 66, Section 7.1.3)
- Open setting (Page 68, Section 7.1.4)



Item	Description	Setting range
Fixed Buffer	Select the communication method for communications using a fixed buffer. Select	Procedure Exist
Communication	"Procedure Exist" for communications using a random access buffer.	Frocedure Exist

13.4 Data Format

Communication data consists of a header and application data.

13.4.1 Header

The header for TCP/IP or UDP/IP is used. Because an E71 automatically adds and deletes a header, the user setting is not required.

(1) Detailed header sizes

(a) TCP/IP

Ethernet	IP	TCP
(14 bytes)	(20 bytes)	(20 bytes)

(b) UDP/IP

Ethernet	IP	UDP
(14 bytes)	(20 bytes)	(8 bytes)


13.4.2 Application data

In the application data for communications with the "Procedure Exist" control method, the following data code is expressed in a binary code or an ASCII code. To switch between a binary code and an ASCII code, use the Ethernet operation setting.




(1) Format

· Communications using a binary code




· Communications using an ASCII code



(2) Subheader

Because an E71 automatically adds and deletes a header, the user setting is not required.





(a) When reading


Communications using a binary code


Communications using an ASCII code












(3) Start address

Use a logical address to set the start address of a random access buffer that reads/writes data.

(F Page 166, Section 13.6)


(a) Communications using a binary code

Specify the start address using a binary value.



(b) Communications using an ASCII code

Specify the start address using an ASCII code value expressed in hexadecimal.




(4) Data length setting

Set the number of words of the read/written data in the random access buffer range.


(a) Communications using a binary code

Specify the number of words using a binary value. (Maximum of 1017 words)



(b) Communications using an ASCII code


Specify the number of words using an ASCII code value expressed in hexadecimal. (Maximum of 508 words)




(5) Text

Text is a data written to and read from a random access buffer.


(a) Communications using a binary code



(b) Communications using an ASCII code







(6) End code

An error code is stored in the end code added to a response. For the error codes, refer to the error code list. (Fig. Page 259, Section 16.7.1) End codes are stored in the communication status storage area of the buffer memory.


13.4.3 Examples of command and response formats

This section describes examples of command and response formats.

(1) Writing data to a random access buffer upon a write request from a connected device

(a) Communications using a binary code

· Command format (from the connected device to the E71)




• Response format (from the E71 to the connected device)

Subheader	End code
Е2н	00н

(b) Communications using an ASCII code

• Command format (from the connected device to the E71)




• Response format (from the E71 to the connected device)

Subhe	eader	End	code
45н	32н	30н	30н


(2) Reading data from a random access buffer upon a read request from a connected device

(a) Communications using a binary code

• Command format (from the connected device to the E71)



• Response format (from the E71 to the connected device)




(b) Communications using an ASCII code

• Command format (from the connected device to the E71)

	Subhe	eader		9	Start a	ddress		Data length			1
	,			(H)	-	-	(L)	(H)	-	-	(L)
36н	31н	30н	30н	00н	00н	31н	34н	00н	00н	00н	41н

• Command format (from the connected device to the E71)



13.5 Precautions when Creating Programs

This section describes the precautions when creating programs for communications using a random access buffer.

(1) Completion of the initial and open processes

The initial process and the connection open process need to be completed.

(2) Send request from a CPU module

A CPU module cannot issue send requests. In addition, reception completion in a CPU module is not confirmed. When it is necessary to synchronize data sending/receiving between the CPU module and the connected device, use communications using a fixed buffer.

(3) Random access buffer address


The address specified by the connected device and the address specified using the FROM/TO instructions are different. For details, refer to the physical and logical addresses of a random access buffer. (Fig. Page 166, Section 13.6)

13.6 Physical and Logical Addresses of a Random Access Buffer

This section describes the start address of the E71 random access buffer (without battery backup), which is specified in commands.


Note that when designating the start address of a random access buffer, the address specified by a connected device is different from that specified using the FROM/TO instructions.

- · Physical address: Address specified with the FROM/TO instructions of a program
- · Logical address: Address specified by a connected device as the start address in the command



13.7 Example of Communications Using a Random Access Buffer

The following figure shows an example of a write operation from a connected device.



- The receive completion flag is provided at the end of the received data.
- 2 The receive completion flag is monitored.
- When the receive completion flag turns on, the data is transmitted from the random access buffer to the CPU module.

CHAPTER 14 OTHER FUNCTIONS

This chapter describes basic functions of the E71 other than those described in the preceding chapters.

14.1 Router Relay Function

This section describes the router relay function.


14.1.1 Applications

This function allows the E71 to communicate with connected devices on other Ethernet networks via a router and gateway. This function does not allow the E71 to operate as a router. One default router and up to eight routers can be set.

14.1.2 Parameter settings

Configure the settings in the following window.

Project window ⇔ [Parameter] ⇔ [Network Parameter] ⇔ [Ethernet/CC IE Field] ⇔ Select "Ethernet" under "Network Type". ⇔ Router Relay Parameter button



Item		Description	Setting range
Router Relay	Function	Select whether to use the router relay function.	Not Used/Use
Subnet Mask Pattern		Refer to (1) in this section.	C0000000 _H to FFFFFFC _H
Default Router IP Address		Refer to (2) in this section.	A value other than 00000000 _H and FFFFFFFF _H
Input Format		Select the input format of router information.	DEC/HEX
Router	Sub-net Address	Refer to (3) (a) in this section.	A value other than 00000000 _H and FFFFFFFF _H
Information	Router IP Address	Refer to (3) (b) in this section.	A value other than 00000000 _H and FFFFFFFF _H

(1) Subnet mask pattern


Set the subnet mask. (Consult with the network administrator for the setting.) When not using the subnet mask, set any of the following values according to the class.

Class	Mask value
Class A	FF000000 _H
Class B	FFFF0000 _H
Class C	FFFFF00 _H

(a) Setting example

The following shows a Class B setting example.





Point P

- All devices on the same subnetwork must have the common subnet mask.
- When not managed by the subnetwork, the connected devices need not have subnet masks. (Set the network address of the corresponding class.)

(2) Default router IP address

Set the IP address of the router (default router) when the E71 communicates with the connected devices on other Ethernet networks via a router other than the one specified in the router information. Set the value that satisfies the following conditions.

- · Condition 1: The IP address class is any of A, B, and C.
- · Condition 2: The subnet address of the default router is the same as that of the E71 on the own station.
- · Condition 3: The host address bits are not all "0" or all "1".




If the corresponding subnet address does not exist in the router information when the connection is opened or data communications are performed, communications are performed via the default router.

(3) Router information


(a) Subnet address

Set the network address^{*1} or subnet address^{*2} of the connected device when the E71 communicates with the connected devices on other Ethernet networks via a router other than the default router. Set the value that satisfies the following conditions.


- · Condition 1: The IP address class is any of A, B, and C.
- · Condition 2: The host address bits are all "0".
- *1 If the class (network address) of the E71 on the own station differs from that of the connected device, set the network address of the connected device.
- *2 If the class (network address) of the E71 on the own station is the same as that of the connected device, set the subnet address of the connected device.




[EX] When the network addresses differ between the E71 on the own station and the connected device



When the classes differ between the E71 on the own station and the connected device



When the network address of the E71 on the own station is the same as that of the connected device



(b) Router IP address

Set the IP addresses of the routers when the E71 communicates with the connected devices on other Ethernet networks via a router other than the default router. Set the value that satisfies the following conditions.

- Condition 1: The IP address class is any of A, B, and C.
- Condition 2: The subnet address of the router is the same as that of the E71 on the own station.
- Condition 3: The host address bits are not all "0" or all "1".

Point P

- When the E71 communicates with the connected devices via a router in Passive open status, communications can be performed without using the router relay function.
- The router relay function is not needed in a system that uses the Proxy router.

14.2 Communications Using an Auto-open UDP Port14.2.1 Application

14.2 Communications Using an Auto-open UDP Port

This section describes communications using the auto-open UDP port.

14.2.1 Application

The auto-open UDP port is a UDP/IP port that automatically opens and closes at the following timing. Using this port makes the E71 ready for communications upon completion of an initial process, thus enabling communications without using any programs regardless of the open status of connection numbers 1 to 16.

(1) Open and close timing

The port automatically opens according to the registered parameter settings upon completion of the initial process of the E71. In addition, it automatically closes when the E71-connected station is powered off or reset.

Point P

- The E71 enables communications using an auto-open UDP port after the initial process is normally completed, and the E71 on the own station waits for communication requests to itself (auto open).
- The E71 accepts requests from anywhere as long as they are addressed to the E71 itself.
- When a communication request is accepted from the connected device, the corresponding port number is occupied until the process is completed. Even if the next communication request is accepted during this time, the communication process will be waited.
- To change the auto-open UDP port number, a reinitialization process is required. (Fig. Page 305, Appendix 4.2)

14.3 Remote Password

The CPU module can be protected by a remote password.



A remote password is to prevent unauthorized access (e.g. Corruption of programs and data) from connected devices. However, this function does not guarantee prevention of all unauthorized access. To have the programmable controller system fully secured against unauthorized access from the connected devices, take additional measures. Mitsubishi Electric Corporation does not hold any responsibility for any system problems caused by unauthorized access.

The following are examples of measures against unauthorized access.

- · Install a firewall.
- Install a personal computer as a relay station and control the relay of communication data using an application program.
- Install the connected device that can control access rights (Please consult with your network service provider or networking equipment manufacturer.) as a relay station.

14.3.1 Application

This function allows or prohibits access from connected devices to the CPU module through the following modules. This prevents remote unauthorized access to the CPU module.

- F71
- · Built-in Ethernet port LCPU
- C24

14.3.2 Remote password setting processes (unlock and lock processes)

This section describes the processes that enable/disable access from the connected devices to the programmable controller.

(1) Access permission process (unlock process)

To access the specified CPU module, the connected device performs a remote password unlock process for the remote password-protected E71 on the station in direct connection (own station). The following are unlock process methods.

- · Dedicated command of the MC protocol (remote password (unlock): 1630)
- · When the file transfer (FTP server) function is in use: Dedicated FTP command (password-unlock)
- · Programming tool: Input of the remote password in the window
- When the Web function is in use: Input of a remote password in the window displayed on the Web browser

When the unlock process is not performed, the remote password-set E71 that has accepted a communication request checks an entered remote password and disables access to the specified station.

All data received prior to the unlock process is treated as an error.

(2) Access process

Access to the specified station is enabled when the remote password unlock process is completed normally. Specify the station to be accessed and access the station.

(3) Access prohibition process (lock process)

To terminate the access to the specified station, the connected device performs the remote password lock process to disable subsequent access. The following are lock process methods.

- Dedicated command of the MC protocol (remote password (lock): 1631)
- · When the file transfer (FTP server) function is in use: Dedicated FTP command (password-lock)
- · Programming tool: Automatically executes the lock process.
- · When the Web function is in use: Automatically performs a lock process when the Web browser is closed.

14.3.3 Remote password check procedure

This section describes the procedure of the remote password check performed by the E71.

(1) Communications in which an entered remote password is checked


When the following parameters have been set for the E71 on the LCPU station, the E71 checks a remote password for communication requests listed below.

- · When a remote password has been set in the CPU module
- When the connection where the E71 communicates with a connected device has been set as the target for the remote password check

The E71 checks an entered remote password for a communication request addressed to the own station/another station received from a connected device.

The E71 performs a send process upon the following send requests without checking an entered remote password.

- · Send request from the CPU module on the own station (such as communications using a fixed buffer)
- Communication request from the connected device (including the programming tool connected to the CPU module on the own station) to send data to another station upon request from the CPU module



*1 A communication request from the connected device cannot be accepted because a remote password check has been set. If the remote password check has not been set, the communication request is accepted, and the E71 can communicate with the connected devices.


(2) Selecting a connection for which the remote password check is performed

A connection for which an entered remote password is checked can be selected using a parameter. (Fig. Page 183, Section 14.3.6)

(3) Stations that can be accessed when the remote password check is performed

When the CPU module is protected with a remote password, the stations accessible by the connected device and the LCPU stations that can perform the remote password unlock/lock processes are limited to those in the same network. The following shows an example of accessible stations.

When a remote password has been set in the LCPU on the station 1-1, and the remote password check has been set in 1) on the station 1-1




The station A is the only connected device that can perform an unlock/lock process for 1) of the station 1-1.

- •: Stations that can be accessed from the connected device after the remote password unlock process
- O: Stations that can be accessed from the connected device without performing the remote password unlock process

Connected	Target programmable controller station (request destination)								
device ^{*1} (request source)	Station 1-1 Station 1-2 Station 2-1 Station 2-2 Station 3-1 Station LCPU LCPU LCPU LCPU LCPU								
Station A	•	0	•	•	•	•			
Station B	0	0	0	0	0	0			
Station C	0	0	0	0	0	0			
Station D	0	0	0	0	0	0			

^{*1} The station A can access the stations marked with ● after the remote password unlock process is completed for 1) of the station 1-1. It can access the stations marked with ○ when the communication lines are open. Stations B, C, and D can access the stations marked with ○ when the communication lines are open.

When a remote password and the remote password check have been set in multiple LCPU stations



The unlock/lock process can be performed for the following connected devices.

- .1) of the station 1-1: By the station A only
- .1) of the station 2-2: By the station C only
- .1) of the station 3-2: By the station D only
 - •: Stations that can be accessed from the connected device after the remote password unlock process
 - O: Stations that can be accessed from the connected device without performing the remote password unlock process
 - \times : Stations that cannot be accessed from the connected device

Composted devices*1	Target programmable controller station (request destination)							
Connected device*1 (request source)	Station 1-1	Station 1-2	Station 2-1	Station 2-2	Station 3-1	Station 3-2		
(request source)	LCPU	LCPU	LCPU	LCPU	LCPU	LCPU		
Station A	•	0	•	×	×	×		
Station B	0	0	0	×	×	×		
Station C	0	0	0	•	•	×		
Station D	0	0	0	0	0	•		

The station A can access the stations marked with ● after the remote password unlock process is completed for 1) of the station 1-1, and can access the stations marked with ○ when the communication lines are open. The station B can access the stations marked with ○ when the communication lines are open. The station C can access the stations marked with ● after the remote password unlock process is completed for 1) of the station 2-2, and can access the stations marked with ○ when the communication lines are open. The station D can access the stations marked with ● after the remote password unlock process is completed for 1) of the station 3-2, and can access the stations marked with ○ when the communication lines are open.



To disable access from the connected devices to other stations through CC-Link IE Controller Network, CC-Link IE Field Network, MELSECNET/H, and MELSECNET/10 relay communication functions, select "MELSOFT Application Transmission port (UDP/IP), Dedicated Instruction, CC-Link IE, NET10(H) Relay Transmission Port" in the remote password setting of the relay station or a station to be accessed.

14.3.4 Differences in functions according to the remote password check status (enabled/disabled)

The following table lists the behavior of the functions according to the remote password check status (enabled/disabled).

Function		Remote password check setting				
FL	inction	Disabled	Enabled			
Connection with MELSOFT products and a GOT		After an initial process is completed, communications are enabled by establishing a connection in the programming tool.	After the remote password is entered, communications are enabled. The remote password lock process is automatically performed when the project is closed.			
MC protocol communications	User open port	After an open process is completed, communications are enabled.	After an open process is completed, communications are enabled from the time that the unlock command is received until the lock command is received.			
	Auto-open UDP port	After an initial process is completed, communications are enabled.	After an initial process is completed, communications are enabled from the time that the unlock command is received until the lock command is received.			
Communications	User open port	After an open process is completed, communications are enabled.	Use MC protocol to communicate with the CPU module where a remote password is			
using SLMP	Auto-open UDP port	After an initial process is completed, communications are enabled.	set because SLMP does not have unlock and lock commands.			
Communications using	ng the predefined protocol	After an open process is completed, communications are enabled.	After an open process is completed, communications are enabled.*1			
Communications using the predefined protocol support function		After an initial process is completed, communications are enabled by establishing a connection in GX Works2.	After the remote password is entered, communications are enabled. The remote password lock process is automatically performed when the protocol setting data are closed.			
Communications using a fixed buffer	Procedure exists		After an open process is completed, communications are enabled from the time that the unlock command is received until the lock command is received.			
	No procedure	After an open process is completed, communications are enabled.	After an open process is completed, communications are enabled.*1			
Communications usir	ng a random access buffer		After an open process is completed, communications are enabled from the time that the unlock command is received until the lock command is received.			
E-mail function		After an initial process is completed, data sending and receiving are enabled.*2	After an initial process is completed, data sending and receiving are enabled.*2			
Web function		After an initial process is completed,	After the remote password is entered, communications are enabled. The remote password lock process is automatically performed when the Web browser is closed.			
CC-Link IE Controller Network, MELSECNI MELSECNET/10 rela		communications are enabled.	After an initial process is completed, communications are enabled.*3			
Communications usir	ng data link instructions					

Function	Remote password check setting				
Function	Disabled	Enabled			
File transfer (FTP server) function	Within Ethernet, communications are enabled with the connected device that has completed an open process.	After an open process is completed, communications are enabled from the time that the unlock command is received until the lock command is received.			

- A dedicated connection is used for "No Procedure" communications using a fixed buffer or communications using the predefined protocol. Do not set the remote password for the connection with the connected device.
- *2 Remote password check is not performed against the e-mail function.
- *3 If a remote password has been set to the CPU module on the relay station or station to be accessed where the E71 is connected, access to another station may not be performed.

14.3.5 Precautions

The precautions for using the remote password function of the E71 are provided below.

(1) Timing of activating a remote password

To enable the remote password setting, power off or reset the CPU module. After a remote password has been set, restart the CPU module.

(2) Target connections

Set a remote password check only for the connections used for data communications with the connected devices that can perform unlock and lock processes.

In communications using a fixed buffer, do not set the remote password check for the connections through which the connected device receives data sent from the CPU module.

(3) Connections where "No Procedure" communications using a fixed buffer are performed

Do not set a remote password check for connections where "No Procedure" communications using a fixed buffer are performed. The remote password check is not performed for such connections.

(4) Access to the programmable controller on another station

When the connected device accesses the programmable controller on another station through the E71, it may fail to access the remote-password-protected CPU modules on the relay station or the station to be accessed.

(5) For UDP/IP communications

(a) Connected device for data communications

Do not perform data communications with unspecified connected device. Set the destination device.

(b) Alive check function

Use the alive check function of the E71.*1 Also, when terminating data communications, perform the remote password lock process. If the process is not performed, data communications from other devices are enabled until a timeout occurs by the alive check function of the E71. For this reason, when setting a connection with the connected device using a programming tool, set the parameters as follows.

- When configuring the initial setting, set the start interval timer value and the interval timer value for the alive check function as small as possible.
- When configuring the open setting, select "Confirm" under "Existence Confirmation".
- *1 The alive check is automatically performed when the connection for data communications through the auto-open UDP port is set as the target for the remote password check.

(6) Communications from the programming tool in the Ethernet connection

For communications from a programming tool in the Ethernet connection, using TCP/IP communications is recommended.

(7) When the unlock process or lock process fails

If the remote password unlock/lock process fails, check the remote password of the CPU module then perform the unlock/lock process again.

(a) E71 operation in case of a process failure

If the number of process failures exceeds the notification accumulated count^{*1} set in the buffer memory area, the E71 performs the following operations.

- · The E71 turns on the COM.ERR. LED.
- The E71 stores C200_H in the error code and end code storage area in the buffer memory area, Error log storage area (address: 227 (E3_H) to 372 (174_H)).
- *1 This is the number of times stored in Remote password mismatch notification accumulated count designation (address: 20592 (5070_H) and 20593 (5071_H)) by the CPU module (using an instruction such as the TO instruction) when the E71 starts up.

In the above case, identify the connection where the unlock/lock process has failed using the following buffer memory areas.

- Accumulated count of unlock process abnormal end (address of Connection No.1: 20595 (5073_H)
- Accumulated count of lock process abnormal end (address of Connection No.1: 20597 (5075_H)

(b) Corrective action against a process failure

Take the following actions if required.

- · Close the connection with the connected device.
- Write "0" in the buffer memory areas, Accumulated count of unlock process abnormal end (address: 20595 (5073_H) and Accumulated count of lock process abnormal end (address: 20597 (5075_H)). If this action is not taken, the process (a) above will be performed each time a process failure occurs exceeding the notification accumulated count.
- If the number of unlock/lock process failures for the connection to the connected device is greater than the
 above accumulated notification count, the possible cause is unauthorized access from the connected
 device. Disable the connection using the buffer memory area, System port use prohibited designation area
 (address: 20488 (5008_H)). (After this, the unlock process cannot be performed for the connection until
 "Use allowed" is set.)
- Inform the system manager that the number of unlock/lock process failures is greater than the accumulated notification count, and take corrective actions.





- For the method to turn off the COM.ERR. LED, refer to the method using the Ethernet diagnostics. (Fig. Page 293, Section 16.10)
- The accumulated counts of unlock/lock process abnormal end for Connection Nos.1 to 16 stored in the buffer memory can be cleared.
 - Accumulated count of unlock process abnormal end (address of Connection No.1: 20595 (5073_H))
 - Accumulated count of lock process abnormal end (address of Connection No.1: 20597 (5075_H))

14.3.6 Parameter settings

The remote password setting of the E71 is described.

Project window ⇔ [Parameter] ⇔ [Remote Password]





		Item	Description	Setting range
	Password Setting		Enter a password set for the CPU module.	_
Remote Password Setting		Model Name	Select the module model that checks an entered remote password against the remote password set for the CPU module.	LJ71E71-100
	Password Active Module Setting	Start XY	Set the start address of the module that checks an entered remote password.	0000 _H to 0FE0 _H
		Condition	Opens the "Remote Password Detail Setting" window.	_
	User Connection No.*1*3	Connection 1 to Connection 16		
		Auto Open UDP Port		
		FTP Transmission Port (TCP/IP)		
Remote Password Detail Setting	System Connection*2	MELSOFT Application Transmission Port (TCP/IP)	Specify a connection where an entered remote password is checked.	_
	Gystem Connection	MELSOFT Application Transmission Port (UDP/IP), Dedicated Instruction, CC-Link IE, NET/10(H) Relay Transmission Port		
		HTTP Port, HTTP Protocol		

- *1 The user connection is used to perform MC protocol communications and fixed buffer communications.
- *2 The system connection is used in the system to perform FTP communications and MELSOFT communications (TCP/IP, UDP/IP).
- *3 When "MELSOFT Connection" has been selected in the open setting, select the MELSOFT application communication port in "System Connection".

MELSOFT connection is performed to the MELSOFT application communication port of the system connection, not of the user connection. If the MELSOFT application communication port is not selected in "System Connection", a window for a password does not appear.



When determining a remote password, take care of the following.

- · Avoid a simple character string (e.g. Character string consisting of alphanumeric characters only).
- Combine alphanumeric characters and special characters (e.g. "?", "!", "&", and "%").
- Avoid using a character string that represents the user's name or the date of birth.

14.4 Hub Connection Status Monitor Function

The current connection status and transmission speed of an E71 and a hub and the number of times that the E71 detected disconnection can be checked using the following buffer memory areas. For details on buffer memory areas, refer to the list of buffer memory addresses. (FF Page 35, Section 3.5.2)

Buffer memory area	Description
Hub connection status area (address: 201 (C9 _H))	Stores the current connection status and transmission speed of an E71 and a hub.
Disconnection detection count (address: 20995 (5203 _H))	Stores the number of times that the E71 detected disconnection after an initial process. Disconnection is detected in any of the following cases. • Disconnection between the E71 and a hub • Cable removal from the hub side connector • Hub power-off • Cable removal from the E71 side connector




If an error has occurred 65536 times or more, the count stops at 65535 (FFFF $_H$). Write "0" to this area using a program to clear the stored value.

14.5 IP Address in Use Detection Function

If different stations in the same network use the same IP address, the address in use can be detected. This prevents a network from stopping due to incorrect IP address.

When the connected device with the same IP address does not support the IP address in use detection function, the error is not detected.



(1) Checking the IP address already in use

The following two methods are available:

- · Checking buffer memory areas
- · Checking using the Ethernet diagnostics

(a) Checking buffer memory areas

Both the station already connected to the network and the station with the same IP address (station connected to the network later), and the MAC addresses of the stations with the same IP address can be checked. The destination IP address can be checked only in the station with the same IP address (station connected to the network later).

	Buffer memory area	Buffer memory address	Description
Destination IP addre	ss (stored in the station with the same IP address	234 (EA _H)	The third and fourth octets of the IP address
connected to the net	work later.)	235 (EB _H)	The first and second octets of the IP address
	The MAC address of the station that has been	21121 (5281 _H)	The fifth and sixth octets of the MAC address
	already connected to the network (stored in the station with the same IP address connected to	21122 (5282 _H)	The third and fourth octets of the MAC address
IP address status	the network later).	21123 (5283 _H)	The first and second octets of the MAC address
storage area	The MAC address of the station with the same IP	21124 (5284 _H)	The fifth and sixth octets of the MAC address
	address connected to the network later (stored in the station that has been already connected to	21125 (5285 _H)	The third and fourth octets of the MAC address
	the network).	21126 (5286 _H)	The first and second octets of the MAC address




When the MAC address of the station that has been already connected to the network is 00.26.92.89.2E.89, the IP address already in use is 10.97.24.01, and the MAC address of the station connected to the network later is 00.26.92.DE.26.90, the value stored in each buffer memory area is as follows.

- 234 (EA $_{\rm H}$): 1801 $_{\rm H}$ (the third and fourth octets of the IP address)
- 235 (EB_H): 0A61_H (the first and second octets of the IP address)
- 21121 (5281_H): 2E89_H (the fifth and sixth octets of the MAC address)
- 21122 (5282_H): 9289_H (the third and fourth octets of the MAC address)
- 21123 (5283_H): 0026_H (the first and second octets of the MAC address)
- 21124 (5284_H): 2690_H (the fifth and sixth octets of the MAC address)
- 21125 (5285_H): 92DE_H (the third and fourth octets of the MAC address)
- 21126 (5286_H): 0026_H (the first and second octets of the MAC address)

(b) Checking using the Ethernet diagnostics

An error code $(C00F_H)$ is displayed in the "Ethernet Diagnostics" window, and the IP address used in multiple stations is displayed in the "Destination IP Address" column. The destination IP address can be checked only in the station with the same IP address (station connected to the network later).

[Diagnostics]
 □ [Ethernet Diagnostics...]



14.6 Alive Check Function

14.6 Alive Check Function

When the E71 has not communicated with the connected device for a certain period of time while the connection is open, this function checks whether the connected device is alive by sending an alive check message to the connected device and waiting for the response.

(1) Parameter setting

To enable the alive check function, select "Confirm" under "Existence Confirmation" in the open setting. (Fig. Page 68, Section 7.1.4) In TCP/IP communications, the following methods can be selected in the Ethernet operation setting. (Fig. Page 66, Section 7.1.3)

(2) Alive check method

The following alive check methods are available.

(a) Check using the PING command

This method is used for a connection opened using TCP/IP or UDP/IP. The E71 performs an alive check by sending the PING command (ICMP echo request/response function) to the connected device with which communications have not been performed for a certain period of time and waiting to see whether the response is received.*1

*1 The E71 automatically sends an echo response packet when it receives a PING echo request. (It sends a response to the received PING command even if the connection used in the data communications with the connected device is closed.)

(b) Check using the KeepAlive function

This method is used for a connection opened using TCP/IP. The E71 performs an alive check by sending a KeepAlive ACK message to the connected device with which communications have not been performed for a certain period of time and waiting to see whether the response is received.*1


*1 The connection may be disconnected if the connected device does not support the TCP KeepAlive function (response to a KeepAlive ACK message).

(3) If a response message cannot be received from the connected device

If a response message cannot be received from the connected device (or if an error has been detected) using the alive check function, the following processes are performed.

- The corresponding connection will be forcibly closed. (The line is disconnected.) Open the connection using a user program again.
- Open completion signal is turned off, and the error code (C035_H) is stored in the open error code storage
 area.

Assuming that the values^{*1} are set so that the number of retries may be three, the E71 performs an alive check at the timing shown in the figure below (an example of alive check using the PING command).



*1 The values of the number of retries and timers can be changed in the initial setting. (Fig. 2011) Page 301, Appendix 4.1)

CHAPTER 15 DEDICATED INSTRUCTIONS

Dedicated instructions facilitate programming for using intelligent function modules. This chapter describes dedicated instructions that can be used in the E71.

15.1 List of Dedicated Instructions

(1) Dedicated instructions for using basic functions

The following table lists dedicated instructions for using the functions explained in this manual.

Instruction	Description	Reference
OPEN	Establishes (opens) a connection with the connected device to perform data communications.	Page 192, Section 15.5
CLOSE	Disconnects (closes) a connection with the connected device performing data communications.	Page 196, Section 15.6
ECPRTCL	Executes the protocols registered in the flash ROM of the E71 using the Predefined Protocol Support Function of GX Works2.	Page 199, Section 15.7
BUFSND	Sends data to the connected device through communications using a fixed buffer.	Page 209, Section 15.8
BUFRCV	Reads data received from the connected device through communications using a fixed buffer. (used in the main program)	Page 213, Section 15.9
BUFRCVS	Reads data received from the connected device through communications using a fixed buffer. (used in an interrupt program)	Page 217, Section 15.10
ERRCLR	Turns off LEDs of the E71 or clears error information stored in the buffer memory.	Page 219, Section 15.11
ERRRD	Reads error information stored in the buffer memory of the E71.	Page 223, Section 15.12
UINI	Re-initializes the E71.	Page 226, Section 15.13

(2) Dedicated instructions for using special functions

The following table lists dedicated instructions for using special functions. For details on the dedicated instructions, refer to the following.

MELSEC-Q/L Ethernet Interface Module User's Manual (Application)

Function	Instruction	Description					
E mail function	MRECV	Reads the received e-mails.					
E-mail function	MSEND	Sends e-mails.					
	READ	Reads word device data from other stations.					
	RECV	Reads data received from other stations. (Used in the main program.)					
	RECVS	Reads data received from other stations. (Used in an interrupt program.)					
	REQ	Performs remote RUN/STOP to CPU modules on other stations.					
0	REQ	Reads/writes the clock data of other stations.					
Communications using data link instructions	SEND	Sends data to other stations.					
data iiiik iiisti dottorio	SREAD	Reads word device data from other stations. (with a completion device)					
	SWRITE	Writes word device data to other stations. (with a completion device)					
	WRITE	Writes word device data to other stations.					
	ZNRD	Reads word device data from other stations (ACPU).					
	ZNWR	Writes word device data to other stations (ACPU).					

15.2 Parameter Settings for Using Dedicated Instructions

When using dedicated instructions, set the parameters of each function.

15.2.1 When using data link instructions

When using data link instructions, set the following parameters.

- Station No. <-> IP information setting
- · Routing parameters setting

For details on the settings, refer to the following.

MELSEC-Q/L Ethernet Interface Module User's Manual (Application)

15.3 Precautions for Dedicated Instructions

15.3 Precautions for Dedicated Instructions

This section describes precautions for using dedicated instructions.

(1) When changing data specified by dedicated instructions

Do not change any data (e.g. control data) until execution of the dedicated instruction is completed.

(2) When the dedicated instruction is not completed

Check that "Online" has been set under "Mode" in the network parameter window. Dedicated instructions cannot be executed during offline.

(3) Securing service process time

When accessing a programmable controller on another station using a data link instruction during the Ethernet diagnostics, execution of the instruction may be delayed. Take the following measures to execute the data link instruction after the Ethernet diagnostics.

- · Execute the COM instruction.
- Reserve time for a communication process for 2 to 3 ms. Use a programming tool for the setting.
 - Project window \Leftrightarrow [Parameter] \Leftrightarrow [PLC Parameter] \Leftrightarrow "Service Processing Setting" under the "PLC System" tab

(4) Specifying the first argument of a dedicated instruction (Un)

The first argument of a dedicated instruction (Un) can be also specified with double quotation marks (" ").

15.4 Organization of the Dedicated Instruction Sections

For the organization of the dedicated instruction sections, refer to Page 13.

15.5 ZP.OPEN

This instruction establishes (opens) a connection with the connected device to perform data communications.



	Available device									
Setting data*1	Internal (system		File register	Link direct device J□\□		Intelligent function module	Index register	Cons	stant	Others
	Bit	Word	register	Bit	Word	device U□\G□	Zn	K, H	\$	
(S1)	_	0	0			_		0		_
(S2)	_	0	0			_		_		_
(D1)	0	0	0			_		_		_

^{*1} The file registers set for each local device and program cannot be used.

(1) Setting data

Setting data	Description	Set by	Data type		
Un/"Un"	Start I/O number of the E71 (00 to FE _H : The first two digits		BIN 16-bit/character		
OII/ OII	of the three-digit I/O number)	User	string		
(S1)	Connection number (1 to 16)		BIN 16-bit		
(S2)	Start number of the device that stores control data	User, system	Device name		
	The start number of the bit device in the own station that				
(D1)	turns on for one scan upon completion of the instruction.	System	Bit		
	(D1)+1 also turns on if the instruction ends abnormally.				

(2) Control data

Device	Item	Setting data	Setting range	Set by
(S2)+0	Execution type/completion type	To open a connection, specify whether to use the parameter settings of a programming tool or to use the settings stored in the following control data starting from (S2)+2. • 0000 _H : Use the parameter settings of the programming tool. • 8000 _H : Use the settings of control data starting from (S2)+2 to (S2)+9.	0000 _H , 8000 _H	User
(S2)+1	Completion status	Stores the status at completion. • 0000 _H : Normal completion • Values other than 0000 _H : Abnormal end (error code)	_	System
(S2)+2	Usage setting area	Specify the application of a connection. • Usage of fixed buffer (b0) 0: For sending or fixed buffer communications are not performed 1: For receiving • Destination existence confirmation (b1) 0: No confirm 1: Confirm • Pairing open (b7) 0: Disable 1: Enable • Communication method (protocol) (b8) 0: TCP/IP 1: UDP/IP • Fixed buffer communication procedure (b10, b9) 00: Procedure exists 01: No procedure 10: Predefined protocol • Open system (b15, b14) 00: Active open or UDP/IP 10: Unpassive open 11: Fullpassive open	As described in the left	User
(S2)+3	Own station port No.	Specify the port number of the own station.	401 _H to 1387 _H , 138B _H to FFFE _H	User
(S2)+4 (S2)+5	Destination IP address	Specify the IP address of the connected device.	1 _H to FFFFFFF _H (FFFFFFFF _H : broadcast)	User
(S2)+6	Destination port No.	Specify the port number of the connected device.	1 _H to FFFF _H *1(FFFF _H : broadcast)	User
(S2)+7 (S2)+8 (S2)+9	Destination MAC address	Specify the MAC address of the connected device.	n 000000000000 _H FFFFFFFFFF _H	User


 $^{^{*}1}$ The range of 1_{H} to 400_{H} is available only in the E71 with the serial number (first five digits) of "15042" or later.

(3) Functions

- This instruction performs the open process for a connection specified by (S1) for the module specified by Un. The setting value used for the open process is selected by (S2)+0.
- Completion of the OPEN instruction can be checked with Completion device (D1)+0 and (D1)+1.

Item	Description				
Completion device (D1)+0:	Turns on at the END process of the scan where the OPEN instruction is completed and turns off at the next END process.				
Completion device (D1)+1:	Turns on and off depending on the completion status of the OPEN instruction. Normal completion: Stays off and does not change. Abnormal end: Turns on at the END process of the scan where the OPEN instruction is completed and turns off at the next END process.				

[Operation while the OPEN instruction is being executed]



• The ZP.OPEN instruction is executed on the rising edge (OFF \rightarrow ON) of the open command.




Do not perform an open or close process using I/O signals and the dedicated instruction together for the same connection. Doing so will result in malfunction.

(4) Errors

If a dedicated instruction ends with an error, Completion device (D1)+1 turns on, and the error code is stored in Completion status (S2)+1.

(5) Program example

The following shows a sample program that performs an Active open process on the connection number 1 for TCP/IP communications (when the I/O signals of the E71 are X/Y00 to X/Y1F).



- *1 Necessary when the open setting of the programming tool is used. (In this case, the program marked with *2 is unnecessary.)
- *2 Necessary when the open setting of the program is used. (In this case, the program marked with *1 is unnecessary.)

15.6 ZP.CLOSE

This instruction disconnects (closes) a connection with the connected device performing data communications.



		Available device								
Setting data ^{*1}	Internal device (system, user)		File register	Link direct device J□\□		Intelligent function module	Index register	Constant		Others
	Bit	Word	register	Bit	Word	device U□\G□	Zn	K, H	\$	
(S1)	_	0	0			_		0	_	_
(S2)	_	0	0			_		_	_	_
(D1)	0	0	0			_		_	_	_

^{*1} The file registers set for each local device and program cannot be used.

(1) Setting data

Setting data	Description	Set by	Data type
Un/"Un"	Start I/O number of the E71 (00 to FE _H : The first two digits		BIN 16-bit/character
OII/ OII	of the three-digit I/O number)	string	
(S1)	Connection number (1 to 16)	BIN 16-bit	
(S2)	Start number of the device that stores control data		Device name
(D1)	The start number of the bit device in the own station that turns on for one scan upon completion of the instruction. (D1)+1 also turns on if the instruction ends abnormally.	System	Bit

(2) Control data


Device	Item	Setting data	Setting range	Set by
(S2)+0	System area	_	_	_
(S2)+1	Completion status	Stores the status at completion. • 0000 _H : Normal completion • Values other than 0000 _H : Abnormal end (error code)	_	System

(3) Functions

- This instruction performs the close process for a connection specified by (S1) for the module specified by Un (connection closed).
- · Completion of the CLOSE instruction can be checked with Completion device (D1)+0 and (D1)+1.

Item	Description
Completion device (D1)+0:	Turns on at the END process of the scan where the CLOSE instruction is completed and turns off at the next END process.
Completion device (D1)+1:	Turns on and off depending on the completion status of the CLOSE instruction. Normal completion: Stays off and does not change. Abnormal end: Turns on at the END process of the scan where the CLOSE instruction is completed and turns off at the next END process.

[Operation while the CLOSE instruction is being executed]



• The ZP.CLOSE instruction is executed on the rising edge (OFF \rightarrow ON) of the close command.



Do not perform a open/close process using I/O signals and using the dedicated instruction together for the same connection. Doing so will result in malfunction.

(4) Errors

If a dedicated instruction ends with an error, Completion device (D1)+1 turns on, and the error code is stored in Completion status (S2)+1.

(5) Program example

The following shows a sample program that closes the connection number 1 (when the I/O signals of the E71 are X/Y00 to X/Y1F).

```
М0
                                                             -[PLF
                                                                       M160
M160
           M110
                                                             -[PLS
                                                                       M161
M6000
                                                             -[PLS
                                                                      M6001
M6001
            М0
                              ZP.CLOSE
                                              U0
                                                     K1
                                                             D200
                                                                      M200
M161
           M210
                                                             - SET
                                                                      M210
M200
           M201
                                                             -[SET
                                                                       M202
            #
           M201
                                                             - SET
                                                                      M203
                                                             -[RST
                                                                       M210
                                                             -[RST
                                                                       M110
```

15.7 GP.ECPRTCL

15.7 GP.ECPRTCL

This instruction executes the protocols registered in the flash ROM of the E71 using the predefined protocol support function of GX Works2.



					Availa	able device				
Setting data ^{*1}	(System, user)		File register	J□\□		Intelligent Index function module register		Constant		Others
	Bit	Word	register	Bit	Word	device U□\G□	Zn	K,H	\$	
n1	0	0	0		•	_		0	_	_
n2	0	0	0			_		0	_	_
(S)	0	0	0			_		_	_	_
(D)	0	0	0		•	_		_	_	_

^{*1} The file registers set for each local device and program cannot be used.

(1) Setting data

Setting data	Description	Set by	Data type
Un	Start I/O number of the E71 (00 to FE _H : The first two digits		BIN 16-bit
Oll	of the three-digit I/O number)		BIN 10-BIL
n1	Connection number (1 to 16)	User	BIN 16-bit
	Gorineea on Hamber (1 to 10)	300.	Device name
n2	Number of consecutive protocol executions (1 to 8)		BIN 16-bit
	Trainber of consecutive protocor executions (1 to c)		Device name
(S)	Start number of the device that stores control data	User/system	Device name
	The start number of the bit device in the own station that		
(D)	turns on for one scan upon completion of the instruction.	System	Bit
	(D)+1 also turns on if the instruction ends abnormally.		

(2) Control data

Device	Item	Setting data	Setting range	Set by
(S)+0	Execution count result	Stores the number of protocols which are executed by using the ECPRTCL instruction. Protocols with errors are included in the count. When settings of the setting data or control data contain an error, "0" is stored.	0, 1 to 8	System
(S)+1	Completion status	Stores the status at completion. When multiple protocols are executed, the status of the protocol executed at last is stored. 0000 _H : Normal completion Values other than 0000 _H (error code): Abnormal end	_	System
(S)+2	Execution protocol number specification 1	Set the first protocol number to be executed.	1 to 128	User
(S)+3	Execution protocol number specification 2	Set the second protocol number to be executed.	0, 1 to 128	User
(S)+4	Execution protocol number specification 3	Set the third protocol number to be executed.	0, 1 to 128	User
(S)+5	Execution protocol number specification 4	Set the fourth protocol number to be executed.	0, 1 to 128	User
(S)+6	Execution protocol number specification 5	Set the fifth protocol number to be executed.	0, 1 to 128	User
(S)+7	Execution protocol number specification 6	Set the sixth protocol number to be executed.	0, 1 to 128	User
(S)+8	Execution protocol number specification 7	Set the seventh protocol number to be executed.	0, 1 to 128	User
(S)+9	Execution protocol number specification 8	Set the eighth protocol number to be executed.	0, 1 to 128	User
(S)+10	Matched receive packet No.1	When the communication type of the first protocol executed includes receiving, the matched receive packet number is stored. When the communication type is "Send Only", "0" is stored. If an error occurs to the first protocol executed, "0" is stored.	0, 1 to 16	System
(S)+11	Matched receive packet No.2	When the communication type of the second protocol executed includes receiving, the matched receive packet number is stored. When the communication type is "Send Only", "0" is stored. If an error occurs to the second protocol executed, "0" is stored. When the number of protocols which are executed is less than 2, "0" is stored.	0, 1 to 16	System

Device	Item	Setting data	Setting range	Set by
(S)+12	Matched receive packet No.3	When the communication type of the third protocol executed includes receiving, the matched receive packet number is stored. When the communication type is "Send Only", "0" is stored. If an error occurs to the third protocol executed, "0" is stored. When the number of protocols which are executed is less than 3, "0" is stored.	0, 1 to 16	System
(S)+13	Matched receive packet No.4	When the communication type of the fourth protocol executed includes receiving, the matched receive packet number is stored. When the communication type is "Send Only", "0" is stored. If an error occurs to the fourth protocol executed, "0" is stored. When the number of protocols which are executed is less than 4, "0" is stored.	0, 1 to 16	System
(S)+14	Matched receive packet No.5	When the communication type of the fifth protocol executed includes receiving, the matched receive packet number is stored. When the communication type is "Send Only", "0" is stored. If an error occurs to the fifth protocol executed, "0" is stored. When the number of protocols which are executed is less than 5, "0" is stored.	0, 1 to 16	System
(S)+15	Matched receive packet No.6	When the communication type of the sixth protocol executed includes receiving, the matched receive packet number is stored. When the communication type is "Send Only", "0" is stored. If an error occurs to the sixth protocol executed, "0" is stored. When the number of protocols which are executed is less than 6, "0" is stored.	0, 1 to 16	System
(S)+16	Matched receive packet No.7	When the communication type of the seventh protocol executed includes receiving, the matched receive packet number is stored. When the communication type is "Send Only", "0" is stored. If an error occurs to the seventh protocol executed, "0" is stored. When the number of protocols which are executed is less than 7, "0" is stored.	0, 1 to 16	System
(S)+17	Matched receive packet No.8	When the communication type of the eighth protocol executed includes receiving, the matched receive packet number is stored. When the communication type is "Send Only", "0" is stored. If an error occurs to the eighth protocol executed, "0" is stored. When the number of protocols which are executed is less than 8, "0" is stored.	0, 1 to 16	System

(3) Functions

- The module specified by Un executes the protocol setting data written to the flash ROM.
 The protocol is executed according to the control data of the device specified by (S) and the following devices.
 - The connection specified by n1 is used.
- Protocols are executed consecutively for the number of times specified by n2 (up to eight protocols) by one instruction.
- When two or more ECPRTCL instructions are executed simultaneously for the same connection, the following instruction will be ignored until the first instruction is completed.
- The number of protocols is stored in (S)+0.
- Protocol execution status can be checked in the predefined protocol support function execution status check area (address: 54C0_H to 55FF_H).
- The communication type of the protocol executed and fixed buffer setting of the connection No. specified by n1 must be matched.
 - The following table lists the combination of the communication type and the connection No. that can be specified by n1.

Communication type	Connection No. that can be specified by n1		
When the communication type of all protocols executed (up to eight protocols) is "Send Only"	 A connection where "Send" is selected in the open setting (no paring open setting) A connection where paring open is set*1*2 		
When the communication type of all protocols executed (up to eight protocols) is "Receive Only"	 A connection where "Receive" is selected in the open setting (no paring open setting) A connection where paring open is set*1*2 		
When the communication type of any protocol executed (up to eight protocols) is "Send&Receive"	A connection where paring approximately as the state of t		
When the communication types of protocols executed (up to eight protocols) are "Send Only" and "Receive Only"	A connection where paring open is set*1*3		

^{*1} To specify a connection where paring open is set, either of pairing-opened connections can be specified.


^{*2} When a pairing-opened connection is specified, an extra connection is used.

^{*3} When the protocols executed include the communication type of "Send&Receive" or "Send Only" and "Receive Only", pairing open setting is required.

· Completion of the ECPRTCL instruction can be checked with Completion device (D) and (D1)+1.

Item	Description
Completion device (D1)+0	Turns on at the END process of the scan where the ECPRTCL instruction is completed and turns off at the next END process.
Completion device (D1)+1	Turns on and off depending on the completion status of the ECPRTCL instruction. Normal completion: Stays off and does not change. Abnormal end: Turns on at the END process of the scan where the ECPRTCL instruction is completed and turns off at the next END process.

[Operation while the ECPRTCL instruction is being executed]



*2: Protocols are consecutively executed by the number of protocols specified in n2 of the setting data in the order specified with the control data (up to eight protocols) with one ECPRTCL instruction.





- When multiple protocols are executed and an error has occurred in one protocol, the following protocols are not executed and the dedicated instruction ends abnormally.
- For the connection where the ECPRTCL instruction can be executed, "Predefined protocol" is set in Fixed Buffer Communication. Thus, the following communications are not available.
 - MC protocol communications
 - Communications using a fixed buffer (procedure exists)
 - Communications using a fixed buffer (no procedure)
 - Communications using a random access buffer
- File transfer (FTP server) function, e-mail function, Web function, or MELSOFT connection, which uses a dedicated connection, can be executed while the ECPRTCL instruction is being executed.
- When protocols which include Non-conversion Variable are executed and the data length of the variable for one packet exceeds 1920 bytes, the value of the CPU module device may not be acquired at one scan.
 Do not change the value of the CPU module device specified in Non-conversion Variable until the ECPRTCL instruction
 - Do not change the value of the CPU module device specified in Non-conversion Variable until the ECPRICL instruction is completed.
 - Buffer memory is not affected by the sequence scan of the CPU module. Assigning them in a variable enables more high-speed process than assigning the CPU module device.
- If the protocol setting data is written while the ECPRTCL instruction is being executed, protocol execution is canceled upon the writing completion. Protocol setting data writing during the ECPRTCL instruction execution (error code: C430_H) occurs and the ECPRTCL instruction ends abnormally.
- When the open setting for the specified connection and the communication type of the protocol executed does not match,
 Connection number setting error (error code: C407_H) occurs and the ECPRTCL instruction ends abnormally.
- When the waiting time is set to "0" (wait infinitely) in the Protocol Detailed Setting, the dedicated instruction is not completed until the data specified in the protocol setting is received.

(4) Errors

Completion device (D)+1 turns on and the error code is stored in Completion status (S)+1 in the following cases.

- · When the setting value of the control data is abnormal
- · When an error is detected in the protocol setting data registered in GX Works2
- When an error has occurred in protocols (the following protocols will not be executed.)
- When a value other than "Predefined protocol" is set in Fixed Buffer Communication for connection No. specified by n1

(5) Program example

For the program example, refer to Page 110, Section 11.5.


(6) Canceling protocol execution

A protocol can be canceled during its execution.

This function is used to terminate the protocol execution forcibly when a communication error occurs with the connected device.

(a) Execution method for cancel request

Set the cancel request to Protocol cancellation specification (address: 54D3_H (Connection No.1)).



15.7 GP.ECPRTCL

(b) Operations after execution of cancel request

[Operations of the ECPRTCL instruction]

- The ECPRTCL instruction ends abnormally and Protocol cancel request error (error code: C404_H) is stored in Completion status (S)+1.
- When cancel request is executed to the nth protocol while multiple protocols are being executed
 consecutively, the E71 terminates the nth protocol forcibly and the following protocols are not executed.
 The following table lists the control data that are stored when protocols are canceled.

Device	Item	Stored value
(S)+0	Execution count result	The number of protocols executed including canceled protocols (When cancel request is executed to the second protocol, 2 is stored.)
(S)+1	Completion status	Protocol cancel request error (error code: C404 _H)
(S+10) to (S+17)	Matched receive packet No.1 to 8	Matched receive packet number of the executed protocol

[Operations of the E71]

• If the cancel request is executed when any protocol is not being executed, the E71 completes the cancel without any process.

Point P

- If any data is received from the connected device after the protocol whose communication type includes receiving is canceled, the data will be discarded.
- The E71 checks whether any cancel request exists at periodic processing. For this reason, it may take some time to
 process the cancellation after the cancel request is executed.
- When Protocol cancellation specification (address: 54D3H (Connection No.1)) is "1: Cancellation request", the next ECPRTCL instruction cannot be executed.


(c) Timing chart

The E71 performs the following process according to the timing of cancel request.


Protocol execution status (address: 54C0 _H)	E71 operations at cancel request
0: Unexecuted	No process
1: Waiting for transmission	The E71 cancels the sending and terminates the dedicated instruction forcibly.
2: Sending	The E71 terminates the dedicated instruction forcibly at sending completion.
3: Waiting for data reception	The E71 cancels the receiving and terminates the dedicated instruction forcibly.
4: Receiving	The E71 terminates the dedicated instruction forcibly at receiving completion.
5: Completed	The E71 terminates the dedicated instruction when protocols are executed consecutively.

The followings describe the operations of protocol cancellation according to the timing.


 When the cancel request is performed before sending (when "1" (Waiting for transmission) is set in Protocol execution status (address: 54C0_H))




 When the cancel request is performed before sending completion (when "2" (Sending) is set in Protocol execution status (address: 54C0_H) and the sending has not been completed)




 When the cancel request is performed at sending completion (when "2" (Sending) is set in Protocol execution status (address: 54C0_H) and the sending has been completed)



 When the cancel request is performed before receiving (when "3" (Waiting for data reception) is set in Protocol execution status (address: 54C0_H))



 When the cancel request is performed during receiving (when "4" (Receiving) is set in Protocol execution status (address: 54C0_H))



15.8 ZP.BUFSND

15.8 ZP.BUFSND

This instruction sends data to the connected device through communications using a fixed buffer.



		Available device									
Setting data ^{*1}	Internal (system		File	Link direct device J□\□		Intelligent function module	Index register	Cons	stant	Others	
	Bit	Word	register	Bit	Word	device U□\G□	Zn	K, H	\$		
(S1)	_	0	0			_		0	_	_	
(S2)	_	0	0		_		_	_	_		
(S3)	l	0	0		_		_	_	_		
(D1)	0	0	0		•	_	_	_	_	_	

The file registers set for each local device and program cannot be used.

(1) Setting data

Setting data	Description	Set by	Data type	
Un/"Un"	Start I/O number of the E71 (00 to FE _H : The first two digits		BIN 16-bit/character	
OII/ OII	of the three-digit I/O number)	User	string	
(S1)	Connection number (1 to 16)		BIN 16-bit	
(S2)	Start number of the device that stores control data	System	Device name	
(S3)	Start number of the device that stores send data	User	Device name	
	The start number of the bit device in the own station that			
(D1)	turns on for one scan upon completion of the instruction.	System	Bit	
	(D1)+1 also turns on if the instruction ends abnormally.			

(2) Control data


Device	Item	Setting data	Setting range	Set by
(S2)+0	System area	_	_	_
(S2)+1	Completion status	Stores the status at completion. • 0000 _H : Normal completion • Values other than 0000 _H : Abnormal end (error code)	_	System

(3) Send data

Device	Item		Setting range	Set by	
		Specify send data	_	_	
(\$3)+0	Send data length	length. (Depending on the procedure of fixed buffer communications, the data length is the number of words or the number of bytes.)	Procedure exists (communications using a binary code): Number of words	1 to 1017 User	
			Procedure exists (communications using an ASCII code): Number of words		User
			No procedure (communications using a binary code): Number of bytes	1 to 2046	
(S3)+1 to (S3)+n	Send data	Specify the send data.		_	User

(4) Functions


• This instruction sends the data specified by (S3) to the connected device of the connection specified by (S1) for the module specified by Un.



• Completion of the BUFSND instruction can be checked with Completion device (D1)+0 and (D1)+1.

Item	Description			
Completion device (D1)+0:	Turns on at the END process of the scan where the BUFSND instruction is completed and turns off at the next END process.			
Completion device (D1)+1:	Turns on and off depending on the completion status of the BUFSND instruction. Normal completion: Stays off and does not change. Abnormal end: Turns on at the END process of the scan where the BUFSND instruction is completed and turns off at the next END process.			

[Operation while the BUFSND instruction is being executed]



- The ZP.BUFSND instruction is executed on the rising edge (OFF \rightarrow ON) of the sending command.



Do not perform a send process using I/O signals and using the dedicated instruction together for the same connection. Doing so will result in malfunction.

(5) Errors

If a dedicated instruction ends with an error, Completion device (D1)+1 turns on, and the error code is stored in Completion status (S2)+1.

(6) Program example

The following shows a sample program that sends data stored on the fixed buffer of the connection number 1 (when the I/O signals of the E71 are X/Y00 to X/Y1F).

```
M3000
                                                                     -[PLS
                                                                                 M3001
M3001
                                                          - MOV
                                                                     К3
                                                                                 D300
                                                          -[MOV
                                                                     K1000
                                                                                 D301
                                                          -[MOV
                                                                     K2000
                                                                                 D302
                                                          Гмоч
                                                                     K9999
                                                                                 D303
                             ZP.BUFSND
                                                          D3000
                                                                     D300
                                            U0
                                                                                  M300
                                                   Κ1
M300
           M301
                                                               Process upon completion
           M301
                                                              Process upon abnormal end
```

15.9 ZP.BUFRCV

15.9 ZP.BUFRCV

This instruction reads data received from the connected device through communications using a fixed buffer (used in the main program).



	Available device									
Setting data ^{*1}	Internal (system		File	Link direct device J□\□			Index register	Cons	stant	Others
	Bit	Word	register	Bit	Word	device U□\G□	Zn	K, H	\$	
(S1)	_	0	0			_		0	_	_
(S2)	_	0	0		_		_	_	_	
(D1)		0	0	_		_	_			
(D2)	0	0	0			_		_	_	_

^{*1} The file registers set for each local device and program cannot be used.

(1) Setting data

Setting data	Description	Set by	Data type	
Un/"Un"	Start I/O number of the E71 (00 to FE _H : The first two digits		BIN 16-bit/character	
On/ On	of the three-digit I/O number)	string		
(S1)	Connection number (1 to 16)	BIN 16-bit		
(S2)	Start number of the device that stores control data		Device name	
(D1)	Start number of the device that stores receive data		Device name	
(D2)	The start number of the bit device in the own station that	System		
	turns on for one scan upon completion of the instruction.		Bit	
	(D2)+1 also turns on if the instruction ends abnormally.			

(2) Control data


Device	Item	Setting data	Setting range	Set by
(S2)+0	System area	_	_	_
(S2)+1	Completion status	Stores the status at completion. • 0000 _H : Normal completion • Values other than 0000 _H : Abnormal end (error code)	_	System

(3) Receive data

Device	Item		Setting range	Set by	
	of the data the fixed the fixed the area. (Dep Receive data length buffer communic data length number or	Stores the data length of the data read from the fixed buffer data area. (Depending on the procedure of fixed buffer	Procedure exists (communications using a binary code): Number of words	1 to 1017	
(D1)+0			Procedure exists (communications using an ASCII code): Number of words	1 to 508	System
		communications, the data length is the number of words or the number of bytes.)	No procedure (communications using a binary code): Number of bytes	1 to 2046	
(D1)+1 to (D1)+n	Receive data	Stores the data read from the smallest address.	_	System	

(4) Functions


• This instruction reads the receive data (for fixed buffer communications) of the connection specified by (S1) for the module specified by Un.



• Completion of the BUFRCV instruction can be checked with Completion device (D2)+0 and (D2)+1.

Item	Description
Completion device (D2)+0:	Turns on at the END process of the scan where the BUFRCV instruction is completed and turns off at the next END process.
Completion device (D2)+1:	Turns on and off depending on the completion status of the BUFRCV instruction. Normal completion: Stays off and does not change. Abnormal end: Turns on at the END process of the scan where the BUFRCV instruction is completed and turns off at the next END process.

[Operation while the BUFRCV instruction is being executed]



The ZP.BUFRCV instruction is executed on the rising edge (OFF → ON) of the read command (bit for a connection with the connected device set in Fixed buffer reception status signal (address: 5005_H)).



- Do not perform a receive process using I/O signals and using the dedicated instruction together for the same connection.
 Doing so will result in malfunction.
- When receive data is read from the same connection, the BUFRCVS instruction (for an interrupt program) cannot be used together.

(5) Errors

If a dedicated instruction ends with an error, Completion device (D2)+1 turns on, and the error code is stored in Completion status (S2)+1.

(6) Program example

The following shows a sample program that reads the receive data from the fixed buffer of connection number 1 (when the I/O signals of the E71 are X/Y00 to X/Y1F).

```
SM400
                                                                                           U0\
                                                                                                      K4M0
                                                                                  -[MOV
                                                                                           G20480
                                                                                           U0\
                                                                                  -[MOV
                                                                                           G20482
                                                                                                      K4M20
                                                                                           U0\
                                                                                  Гмоч
                                                                                           G20485
                                                                                                      K4M40
M5000
          X19
                   M0
                             M40
                                     M500
                                                                                           PLS
                                                                                                      M5001
M5001
                                                                                  D5000
\dashv \vdash
                                            ZP.BUFRCV
                                                                U0
                                                                                           D500
                                                                                                      M500
                                                                         K1
M500
         M501
 +
                                                                                 Process upon completion
         M501
                                                                               Process upon abnormal end
```

15.10 Z.BUFRCVS

15.10 z.BUFRCVS

This instruction reads data received from the connected device through communications using a fixed buffer (used in an interrupt program).



Setting data ^{*1}		Available device									
	Internal device (system, user)		File register			Intelligent function module	Index register	Constant		Others	
	Bit	Word	register	Bit	Word	device U□\G□	Zn	K, H	\$		
(S1)	_	0	0			_		0	_	_	
(D1)	_	0	0			_		_	_	_	

The file registers set for each local device and program cannot be used.

(1) Setting data


Setting data	Description	Set by	Data type
Un/"Un"	Start I/O number of the E71 (00 to FE _H : The first two digits		BIN 16-bit/character
	of the three-digit I/O number)	User	string
(S1)	Connection number (1 to 16)		BIN 16-bit
(D1)	Start number of the device that stores receive data	System	Device name

(2) Receive data


Device	Item		Setting data			
	(D1)+0 Receive data length buf cordata nur	Stores the data length of the data read from the fixed buffer data	Procedure exists (communications using a binary code): Number of words	1 to 1017		
(D1)+0		area. (Depending on the procedure of fixed buffer communications, the data length is the	Procedure exists (communications using an ASCII code): Number of words No procedure (communications using a	umber of words 1 to 508 Sys		
		number of words or the number of bytes.)	binary code): Number of bytes			
(D1)+1 to (D1)+n	Receive data	Stores the data read fro the smallest address.	_	System		

(3) Functions

• This instruction reads the receive data (for fixed buffer communications) of the connection specified by (S1) for the module specified by Un.



[Operation while the BUFRCVS instruction is being executed]



 The Z.BUFRCVS instruction is executed in an interrupt program, and the process is completed within one scan.

Point P


- To read receive data using an interrupt program, configure both the interrupt settings and interrupt pointer setting parameters of the programming tool. (Page 130, Section 12.5.1)
- When receive data is read from the same connection, the BUFRCV instruction (for the main program) cannot be used together.

(4) Errors

If a dedicated instruction ends with an error, Diagnostic errors (SM0) turns on, and the error code is stored in SD0.

(5) Program example

The following shows a sample program that reads the receive data from the fixed buffer of connection number 2 (when the I/O signals of the E71 are X/Y00 to X/Y1F).



15.11 ZP.ERRCLR

15.11 ZP.ERRCLR

This instruction turns off LEDs of the E71 or clears error information stored in the buffer memory.



		Available device										
Setting data ^{*1}	Internal device (system, user)		File Link direct device		Intelligent function module	Index register	Constant		Others			
	Bit	Word	register	Bit	Word	device U□\G□	Zn	K, H	\$			
(S1)	_	0	0			_		_	_	_		
(D1)	0	0	0			_		_	_	-		

^{*1} The file registers set for each local device and program cannot be used.

(1) Setting data

Setting data	Description	Set by	Data type	
Un/"Un"	Start I/O number of the E71 (00 to FE _H : The first two digits	User	BIN 16-bit/character	
	of the three-digit I/O number)	333.	string	
(S1)	Start number of the device that stores control data	User, system	Device name	
	The start number of the bit device in the own station that			
(D1)	turns on for one scan upon completion of the instruction.	System	Bit	
	(D1)+1 also turns on if the instruction ends abnormally.			

(2) Control data

Device	Item	Setting data	Setting range	Set by
(S1)+0	System area	_	_	_
(S1)+1	Completion status	Stores the status at completion. • 0000 _H : Normal completion • Values other than 0000 _H : Abnormal end (error code)	_	System
(S1)+2	Clear target specification	Specify error information to be cleared. • 0000 _H : Initial error code • 0001 _H to 0010 _H : Open error code for a connection with the connected device • 0100 _H : Error log block area • 0101 _H : Communication status - status for each protocol • 0102 _H : Communication status - e-mail receiving status • 0103 _H : Communication status - e-mail sending status • FFFF _H : Clears all of the above	As listed in the left	User
(S1)+3	Clear function specification	Specify the function to be cleared. • 0000 _H : COM.ERR LED off, error code clear • FFFF _H : Error log clear	0000 _H , FFFF _H	User
(S1)+4 to (S1)+7	System area	_	_	_

(3) Functions


• This instruction turns off the COM.ERR. LED and clears error information listed below for the module specified by Un.

	Item	Target specification (S1)+2	Function specification (S1)+3	Error information to be cleared (buffer memory)
Initial error		0000 _H C		 Initial error code (address: 69_H) COM.ERR. LED off
Open error		0001 _H to 0010 _H	0000 _H	Open error code for a connection with the connected device (address: 7C _H , 86 _H)
Error log		0100 _H	FFFF _H	Error log (address: E3 _H to 174 _H)
	Status for each protocol	0101 _H	FFFF _H	Clears communication status. (address: 178 _H to 1FF _H)
Communication status	E-mail receiving status	0102 _H	FFFF _H	E-mail receiving (address: 5871 _H to 5B38 _H)
	E-mail sending status	0103 _H	FFFF _H	E-mail sending (address: 5B39 _H to 5CA0 _H)
All		FFFF _H	FFFF _H	Clears all of the above.

• Completion of the ERRCLR instruction can be checked with Completion device (D1)+0 and (D1)+1.

Item	Description
Completion device (D1)+0:	Turns on at the END process of the scan where the ERRCLR instruction is completed and turns off at the next END process.
Completion device (D1)+1:	Turns on and off depending on the completion status of the ERRCLR instruction. Normal completion: Stays off and does not change. Abnormal end: Turns on at the END process of the scan where the ERRCLR instruction is completed and turns off at the next END process.

[Operation while the ERRCLR instruction is being executed]




- The ZP.ERRCLR instruction is executed on the rising edge (OFF \rightarrow ON) of the clear command.

(4) Errors

If a dedicated instruction ends with an error, Completion device (D1)+1 turns on, and the error code is stored in Completion status (S1)+1.

(5) Program example

The following shows a sample program that clears the open error code of the connection number 1 (when the I/O signals of the E71 are X/Y00 to X/Y1F).



15.12 ZP.ERRRD

15.12 ZP.ERRRD

This instruction reads error information stored in the buffer memory of the E71.



		Available device										
Setting data ^{*1}	Internal device (system, user)		File Link direct device		Intelligent function module	Index register	Constant		Others			
	Bit	Word	register	Bit	Word	device U□\G□	Zn	K, H	\$			
(S1)	_	0	0			_		_	_	_		
(D1)	0	0	0			_		_	_	l		

^{*1} The file registers set for each local device and program cannot be used.

(1) Setting data

Setting data	Description	Set by	Data type
Un/"Un"	art I/O number of the E71 (00 to FE _H : The first two digits User		BIN 16-bit/character
	of the three-digit I/O number)	3001	string
(S1)	Start number of the device that stores control data	User, system	Device name
(D1)	The start number of the bit device in the own station that turns on for one scan upon completion of the instruction. (D1)+1 also turns on if the instruction ends abnormally.	System	Bit

(2) Control data

Device	Item	Setting data	Setting range	Set by
(S1)+0	System area	_	_	_
(S1)+1	Completion status	Stores the status at completion. • 0000 _H : Normal completion • Values other than 0000 _H : Abnormal end (error code)	_	System
(S1)+2	Read information specification	Specify error information to be read. • 0000 _H : Initial error code • 0001 _H to 0010 _H : Open error code for a connection with the connected device	0000 _H , 0001 _H to 0010 _H	User
(S1)+3	Read target information specification	Specify whether to read the latest error information. • 0000 _H : Reads the latest error information.	0000 _H	User
(S1)+4	Error information	Stores the error information that has been read. • 0000 _H : No error • Values other than 0000 _H (error code): Abnormal end	1	System
(S1)+5 to (S1)+7	System area	_	_	_

(3) Functions


• This instruction reads the error information of the module specified for Un.

Item	Target specification (S1)+2	Function specification (S1)+3	Error information to be read (buffer memory)
Initial error	0000 _H	0000 _H	Initial error code (address: 69 _H)
Open error	0001 _H to 0010 _H	0000 _H	Open error code for a connection with the connected device (address: 7C _H , 86 _H)

• Completion of the ERRRD instruction can be checked with Completion device (D1)+0 and (D1)+1.

Item Description	
Completion device (D1)+0: Turns on at the END process of the scan where the ERRRD instruction is completurns off at the next END process.	
Completion device (D1)+1:	Turns on and off depending on the completion status of the ERRRD instruction. Normal completion: Stays off and does not change. Abnormal end: Turns on at the END process of the scan where the ERRRD instruction is completed and turns off at the next END process.

[Operation while the ERRRD instruction is being executed]




- The ZP.ERRRD instruction is executed on the rising edge (OFF \rightarrow ON) of the read command.

(4) Errors

If a dedicated instruction ends with an error, Completion device (D1)+1 turns on, and the error code is stored in Completion status (S1)+1.

(5) Program example

The following shows a sample program that reads the open error code of the connection number 1 (when the I/O signals of the E71 are X/Y00 to X/Y1F).



15.13 ZP.UINI

This instruction changes the setting, such as the Ethernet operation setting, and re-initializes the E71.



	Available device									
Setting data ^{*1}	Internal (system		File	Link direct device J□\□		Intelligent function module	Index register	Constant		Others
	Bit	Word	register	Bit	Word	device U□\G□	Zn	K, H	\$	
(S1)	_	0	0			_		_	_	_
(D1)	0	0	0			_				

^{*1} The file registers set for each local device and program cannot be used.

(1) Setting data

Setting data	Description	Set by	Data type
Un/"Un"	Start I/O number of the E71 (00 to FE _H : The first two digits	User	BIN 16-bit/character
OII/ OII	of the three-digit I/O number)	Osei	string
(S1)	Start number of the device that stores control data User, system Device name		Device name
The start number of the bit device in the own station that			
(D1)	turns on for one scan upon completion of the instruction. System Bit		Bit
	(D1)+1 also turns on if the instruction ends abnormally.		

(2) Control data

Device	Item	Setting data	Setting range	Set by
(S1)+0	System area	_	_	_
(S1)+1	Completion status	Stores the status at completion. • 0000 _H : Normal completion • Values other than 0000 _H : Abnormal end (error code)		System
(S1)+2	Specification of changed item	Specify 0000 _H to update the address information on the connected devices retained by the E71. Specify the target for setting change among the own station IP address, Ethernet operation setting, transmission speed, and communication mode. Do not specify the transmission speed and communication mode together with the own station IP address and Ethernet operation setting. If doing so, only the specification of the own station IP address and Ethernet operation setting is updated. • Specification of own station IP address change (b0): Specify whether to change the own station IP address. (Set the address in (S1)+3 and (S1)+4.) 0: Do not change 1: Change • Specification of the Ethernet operation setting change (b1): Specify whether to change the Ethernet operation setting. (Set the parameters in (S1)+5.) 0: Do not change 1: Change • Specification of transmission speed and communication mode changes (b12 to b15): Specify the transmission speed and the communicate mode. 0: Do not change 1: Auto negotiation 2: 100Mbps/full-duplex 3: 100Mbps/half-duplex 4: 10Mbps/half-duplex 5: 10Mbps/half-duplex	0000 _H to 5000 _H	User
(S1)+3 (S1)+4	Own station IP address	Specify the IP address of the own station.	00000001 _H to FFFFFFE _H	User
(S1)+5	Ethernet operation setting	Specify the Ethernet operation setting. Communication data code setting (b1) Binary Code Setting (b2) TCP existence confirmation setting (b4) Use the Ping Send frame setting (b5) Ethernet Send frame setting (b5) Ethernet Setting of write enable/disable at RUN time (b6) Disable Send Frame Setting (b8) Disable Setting of write enable/disable at RUN time (b6)	As listed in the left	User
	1	- 1	1	


*1 The E71 enables data exchange to be resumed by clearing the address information of the connected device retained in the E71 and performing a reinitialization process. (Initial normal completion signal (X19) turns on.)

(3) Functions

- This instruction re-initializes the module specified by Un.
- Completion of the UINI instruction can be checked with Completion device (D1)+0 and (D1)+1.

Item	Description	
Completion device (D1)+0:	Turns on at the END process of the scan where the UINI instruction is completed and turns off at the next END process.	
Completion device (D1)+1:	Turns on and off depending on the completion status of the UINI instruction. Normal completion: Stays off and does not change. Abnormal end: Turns on at the END process of the scan where the UINI instruction is completed and turns off at the next END process.	

[Operation while the UINI instruction is being executed]



The ZP.UINI instruction is executed on the rising edge (OFF → ON) of the reinitialization command.



To re-initialize the E71, note the following.

- Terminate all data communications with connected devices, check that all connections are closed, then reinitialize the E71.
- Do not perform a reinitialization process using both direct writing to the buffer memory and the UINI instruction.
 Also, do not request another reinitialization process while reinitialization is being performed.
- When the IP address of the E71 has been changed, reset that of the connected device as well. (If the connected device retains the MAC address of the destination device, the communications may not be continued after the IP address of the E71 has been changed.)

15.13 ZP.UINI

(4) Errors

If a dedicated instruction ends with an error, Completion device (D1)+1 turns on, and the error code is stored in Completion status (S1)+1.

(5) Program example

The following pages show sample programs that change the following setting items using the UINI instruction.

- · Ethernet operation setting
- · Transmission speed and communication mode




The following are sample programs for communications using connection numbers 1 and 2. When using other connections, specify the corresponding signals and bits for each connection.

The UINI instruction is also used in the program for a reinitialization process. When performing a reinitialization process using the UINI instruction, refer to the program for a reinitialization process. (Page 305, Appendix 4.2)


(a) Changing the Ethernet operation setting

The following page provides a sample program that changes the Ethernet operation setting (enables writing during RUN) (when the I/O signals of the E71 are X/Y00 to X/Y1F).



(b) Changing the transmission speed and communication mode

The following page provides a sample program that changes the Ethernet operation setting (enables writing during RUN) (when the I/O signals of the E71 are X/Y00 to X/Y1F).



CHAPTER 16 TROUBLESHOOTING

This chapter describes how to identify causes of problems that occur when an E71 is used and take corrective action.

16.1 Before Troubleshooting


Check that the POWER LED of the power supply module and the MODE LED of the CPU module are on. If either or both are off, troubleshoot the CPU module.

User's Manual (hardware design, maintenance and inspection) for the CPU module used

16.2 Troubleshooting Procedure


How to identify the cause of a problem and take corrective action is explained below. Use a programming tool to identify the cause and take corrective action.

(1) Procedure




 Connect the CPU module to a programming tool, and open the "System Monitor" window.

C [Diagnostics] ⇒ [System Monitor]



When an error in the E71 is reported, select the E71 and click the Detailed Information button.

When an error in a module other than the E71 is reported, refer to the manual for that module.





3. The "Module's Detailed Information" window is displayed. Clicking the Update Error History button displays the error details and corrective action.

- **4.** If the error details cannot be obtained in the step above, perform the troubleshooting below.
 - · Checking the LEDs (FP Page 235, Section 16.4)
 - $\cdot \ \mathsf{Troubleshooting} \ \mathsf{by} \ \mathsf{symptom}$
 - (Page 238, Section 16.6)
 - · Ethernet Diagnostics (FP Page 290, Section 16.8)

16.3 Checking with the Module Error Collection Function

With the module error collection function, the errors that have occurred in the E71 are saved into the CPU module. This allows error details to be held even if the power is turned off or the CPU module is reset. Check the E71's errors collected by the CPU module on the "Error History" window.





16.4 Checking the LEDs

The following describes how to troubleshoot the problem by checking the LEDs.



The on/off status of the INIT. LED, OPEN LED, ERR. LED, and COM.ERR. LED can be also checked with a programming tool and in buffer memory.

- With a programming tool: "H/W Information" window (Page 291, Section 16.9)
- In buffer memory: Area for module status (address: C8_H) (Page 35, Section 3.5.2)

16.4.1 If the RUN LED turns off

The following table lists the items to be checked and the actions to be taken if the RUN LED turns off after the E71 is powered on.

Check item	Action
Is it a watchdog timer error?	Reset the CPU module and check that the RUN LED turns on. If the RUN LED still does not turn on, the E71 may be faulty. Please consult your local Mitsubishi representative.
Is the E71 connected properly?	Power off the E71, and connect the module properly.
Is the power capacity of the power supply module sufficient?	Check if the power supply module has enough power capacity.

If the action above does not solve the problem, perform the following tests on the E71 to check for hardware error.

- Hardware test (Page 323, Appendix 6.2)
- Self-loopback test (FP Page 322, Appendix 6.1)

16.4.2 If the ERR. LED or COM.ERR. LED turns on

Connect the CPU module connected to the E71 with the ERR. LED or COM.ERR. LED on to a programming tool to identify the cause. (Fig. Page 232, Section 16.2, Page 290, Section 16.8)

If the action above does not solve the problem, perform the following tests on the E71 to check for hardware error.

- Hardware test (Page 323, Appendix 6.2)
- Self-loopback test (FP Page 322, Appendix 6.1)

The COM.ERR. LED does not turn off even after the error cause is removed. To turn it off, refer to "How to Turn Off the COM.ERR. LED". ([Page 293, Section 16.10)

16.4.3 If the SD/RD LED does not flash when data is sent

The following table lists the items to be checked and the actions to be taken if the SD LED does not flash when data is sent.

Check item	Action
Is the ERR. LED or COM.ERR. LED on?	Remove the cause that turned on the ERR. LED or COM.ERR. LED.
Are the cables properly connected?	Check the cable connection. In addition, perform a line test to check if there is a problem with the cable connection and the Ethernet line. ([] Page 312, Appendix 5)
Are the parameter settings correct?	Correct the IP addresses of the own station and the communication destination, router setting, and subnet mask setting.
Is the program correct?	Correct the send program of the connected device.

- Hardware test (FF Page 323, Appendix 6.2)
- Self-loopback test (F Page 322, Appendix 6.1)

16.5 Checking with a Display Unit

With the buffer memory monitor/test of a display unit, a value in the buffer memory can be checked without a programming tool, and a problem can be troubleshot.

For how to monitor buffer memory with a display unit, refer to the following.

MELSEC-L CPU Module User's Manual (Function Explanation, Program Fundamentals)

16.6 Troubleshooting by Symptom

The following describes how to troubleshoot for each phenomenon. When an error occurs in the E71, identify the cause with the programming tool. (Fig. Page 232, Section 16.2)

16.6.1 Communications cannot be performed with the connected device.

The following table lists how to troubleshoot the problem when the E71 cannot communicate with the connected device.

Check item	Action
Is the RUN LED of the E71 on?	Reset the CPU module. If resetting the CPU module does not turn on the RUN LED on the E71, the hardware of the E71 may be faulty. Replace the E71 and restart all the connected devices that were performing communications with the own station.*1
Does the connected device conform to the Ethernet standard?	Replace the device with one conforming to the Ethernet standard. ([] Page 56, CHAPTER 5)
Is the cable securely connected?	Securely lock the cable. Check the wiring. (FF Page 61, Section 6.2)
Is the network parameter mode set to "Online"?	Set the network parameter mode to "Online". ([] Page 65, Section 7.1.2)
Does the communication data code (ASCII or binary) setting match with that of the connected device?	If the data code settings do not match, data cannot be sent or received because the connected device cannot normally decode commands.*2 Set the same data code as that of the connected device in "Communication Data Code" of the Ethernet operation setting. (Fig. Page 66, Section 7.1.3)
Has the initial process been completed normally? (Is Initial normal completion signal (X19) on?)	 If Initial normal completion signal (X19) is off, perform the initial process. (Page 301, Appendix 4) If the initial setting of the programming tool is same as that of the initial process program, delete the initial process program.
Was a device on the line (such as an E71, connected device, hub, and router) replaced by the one with the same IP address?	Restart all the devices on the line.*1

- *1 Devices on an Ethernet network contain the IP to Mac address mapping, called an "ARP cache". If a device on a line is replaced by another device with the same IP address, the MAC address contained in the "ARP cache" and the MAC address of the replaced device do not match; therefore, communications may not be performed normally. The "ARP cache" is updated when the device is reset or after a certain period of time. The time varies depending on the devices.
- *2 If the communication data code setting is different between the E71 and the connected device, error codes that are not found in the error code list may be returned to the connected device. When receiving data with different data codes, the E71 cannot decode commands normally. The E71 returns an error response according to the communication data code setting.
 - (Fig. Page 136, Section 12.6.2 (1) (e), Remark)
- *3 If the LG and FG terminals of the power supply module on the E71-connected station are not connected, the communication line may be closed (disconnected) due to noise; therefore, communications with the connected device may not be performed.

If the action above does not solve the problem, check for an error in each communication process and take corrective action.

(F) Page 240, Section 16.6.4 to Page 248, Section 16.6.13)

16.6.2 The E71 frequently fails to receive a message sent from the connected device.

The following table lists how to troubleshoot the problem when the E71 frequently fails to receive a message sent from the connected device.

Check item	Action
Has the error code ${\rm C0C7_H}$ been stored in Error code/end code (address: ${\rm E5_H}$) in the error log block?	There may be a heavy load on the Ethernet line due to data sending and receiving between connected devices. Taking action such as separating networks or decreasing the number of data sending reduces the load on the Ethernet line. Consult the network administrator and reduce the load on the Ethernet line.
Has 1 _H been stored in Receive buffer full detection signal (address: 5240 _H)?*1	 Taking action such as separating networks or decreasing the number of data sending reduces the load on the Ethernet line. When communications using a fixed buffer is used, check whether the BUFRCV instruction is executed. (Fig. Page 124, Section 12.4.1) To receive data at shorter intervals than the scan time of the CPU module using a fixed buffer, add the normally closed contact for the completion device of the BUFRCV instruction to the execution conditions of the BUFRCV instruction. (Fig. Page 152, Section 12.9.3 (2) (b))
Has the number in Received TCP packet count (address: 1B8 _H and 1B9 _H) increased?	If the packets cannot be received even though the number of received TCP packets has increased, set the value of TCP Maximum Segment Transmission setting area (address: 1E _H) to 8000 _H . Then perform the initial process again. (Fig. Page 301, Appendix 4)

^{*1} Availability depends on the version of the E71. (FP Page 300, Appendix 3)

If the action above does not solve the problem, perform the following tests on the E71 to check for hardware error.

- Hardware test (Page 323, Appendix 6.2)
- Self-loopback test (FP Page 322, Appendix 6.1)

16.6.3 A dedicated instruction is not completed.

The following table lists how to troubleshoot the problem when a dedicated instruction is not completed.

Check item	Action
	Set the network parameter mode to "Online".
Is the network parameter mode set to "Online"?	Page 65, Section 7.1.2) (If a dedicated instruction is executed in the
	"Offline" mode, no error occurs but the instruction is not completed.)

- Hardware test (Page 323, Appendix 6.2)
- Self-loopback test (FF Page 322, Appendix 6.1)

16.6.4 MC protocol communications cannot be performed.

The following table lists how to troubleshoot the problem when the E71 cannot perform MC protocol communications.

Check item	Action		
Has the connection with the connected device been opened? (Check the corresponding bit of 5000 _H in the buffer memory.)*1	Open the connection with the connected device. Check if the open/close process for I/O signals and the OPEN/CLOSE instructions are not used together for the same connection. If so, correct the program.		
Did the connected device send a command?	Send a command to the E71.		
Was a response returned to the device that had sent the command?	 Check if the correct IP address was specified in the command. If not, correct the IP address and send the command again. Check if the communication protocol (TCP/IP or UDP/IP) matches with that of the connected device. If not, correct it. 		
Does the communication protocol (TCP/IP or UDP/IP) match with that of the connected device?	Use the same communication protocol (TCP/IP or UDP/IP) as that of the connected device.		
Does the communication data code (ASCII or binary) setting match with that of the connected device?	If the data code settings do not match, data cannot be sent or received because the connected device cannot normally decode commands. *2Use the same setting of "Communication Data Code" in the Ethernet operation setting as that of the connected device. (Fig. Page 66, Section 7.1.3)		
Is the end code of the response 0?	Check the end and error codes to correct the error.		
Is the correct command format used for the command type, device, address, and others?	Correct the command format.		
Is the write operation during RUN enabled?	Check the checkbox next to "Enable Online Change" in the Ethernet operation setting.		
Has an open or initial error occurred in the error log area?	Check and correct the error.		

- *1 If the connection of only the connected device is closed due to cable disconnection, personal computer restart, or other reasons, reopen the connection using the same port used before the error occurred. The E71 does not close a connection if it receives an Active open request again from the connected device with a different IP address or a port number.
- *2 If the communication data code setting is different between the E71 and the connected device, error codes that are not found in the error code list may be returned to the connected device. When receiving data with different data codes, the E71 cannot decode commands normally. The E71 returns an error response according to the communication data code setting.

(F Page 136, Section 12.6.2 (1) (e), Remarks)

- Hardware test (Page 323, Appendix 6.2)
- Self-loopback test (Page 322, Appendix 6.1)

16.6.5 Communications using SLMP cannot be performed.

If communications cannot be performed with a connected device using SLMP, refer to the troubleshooting in the following and take corrective action.

SLMP Reference Manual

16.6.6 Communications using the predefined protocol cannot be performed.

The following table lists how to troubleshoot the problem when the E71 cannot perform communications using the predefined protocol.

Check item	Action	
Has the connection with the connected device been opened? (Check the corresponding bit of 5000 _H in the buffer memory.)	 Open the connection with the connected device. Check if the open/close processes for I/O signals and the OPEN/CLOSE instructions are not used together for the same connection. If so, correct the program. Read Open error code (address: 124 (7C_H)) in the communication status storage area. Then check the error details and correct the error 	
Is the IP address setting of the connected device correct?	Check and correct the IP address of the connected device.	
Does the Protocol in the open setting match with that of the connected device (TCP/IP or UDP/IP)?	Check and correct the settings if they are unmatched.	
Is "Predefined protocol" set to Fixed Buffer Communication in the open setting?	 Set "Predefined protocol" to Fixed Buffer Communication in the open setting. Configure the setting so that the fixed buffer setting (Send or Receive) in the open setting matches the communication type of the protocol (Send Only, Receive Only, or Send&Receive)*1. 	
Is Predefined protocol ready (X1D) on?	Write the protocol setting data to the E71.	
Was the ECPRTCL instruction executed?	Correct the execution conditions of the ECPRTCL instruction.	
Was the ECPRTCL instruction completed normally?	Check the error code in the ECPRTCL instruction completion status are and correct the error.	
Is the execution protocol number set to the control data of the ECPRTCL instruction?	Set the execution protocol number to the control data of the ECPRTCL instruction.	
Is the communication status of the connected device normal?	Correct the error in the connected device.	
Has an open or initial error occurred in the error log area?	Check and correct the error.	

^{*1} For details on the settings, refer to Page 202, Section 15.7 (3).

- Hardware test (Page 323, Appendix 6.2)
- Self-loopback test (Page 322, Appendix 6.1)

16.6.7 The protocol setting data cannot be read or written.

The following table lists how to troubleshoot the problem when the protocol setting data cannot be read or written. Check that GX Works2 and the CPU module are connectable on the Transfer Setup of GX Works2 before troubleshooting the problem.

(1) To read the protocol setting data

Check item	Action
Are the values in Protocol setting data error information (address: 5324 _H to 5327 _H) and Number of registered protocols (address: 5328 _H) set to 0?	Write the protocol setting data to the E71 because they have not been written.

(2) To write the protocol setting data

Check item	Action	
Did the ERR.LED turn on after writing the protocol setting	Check the values in Protocol setting data error information (address: 5324 _H	
data?	to 5327 _H) and correct the error.	



When an error is detected in the edited protocol, check that the conditions for element placement are satisfied in the Packet Setting.

Especially the following conditions must be satisfied.

- When a Non-conversion Variable (Variable length) or Non-verified Reception (Variable number of characters) is placed behind a Length and is not included in the Length calculating range, place Static Data immediate after the Non-conversion Variable or Non-verified Reception.
- When multiple Length elements are set in one packet, configure the setting so that each Length calculating range does not overlap the others.

16.6.8 Data cannot be sent with communications using a fixed buffer.

The following table lists how to troubleshoot the problem when an E71 cannot send data with communications using a fixed buffer.

Check item	Action	
Has the connection with the connected device been opened? (Check the corresponding bit of 5000 _H in the buffer memory.)	Open the connection with the connected device. Check if the open/close processes for I/O signals and the OPEN/CLOS instructions are not used together for the same connection. If so, corrette program. Read Open error code (address: 124 (7C _H)) in the communication states.	
Is the IP address setting of the connected device correct?	storage area. Then check the error details and correct the error. Check and correct the IP address of the connected device.	
Does the communication protocol (TCP/IP or UDP/IP) match with that of the connected device?	Use the same communication protocol (TCP/IP or UDP/IP) as that of the connected device.	
Was the BUFSND instruction executed?	Correct the execution conditions of the BUFSND instruction. Check if the send/receive process for I/O signals and the BUFSND/BUFRCV instructions are used together for the same connection. If so, correct the program.	
Was the BUFSND instruction completed normally?	Check the error code in the BUFSND instruction completion status area and correct the error.	
Has the data length of the send data been set in the control data?	Write the data length.	
Is the communication status of the connected device normal?	Correct the error in the connected device.	
Has an open or initial error occurred in the error log area?	Check and correct the error.	

- Hardware test (Page 323, Appendix 6.2)
- Self-loopback test (FF Page 322, Appendix 6.1)

16.6.9 Data cannot be received with communications using a fixed buffer.

The following table lists how to troubleshoot the problem when an E71 cannot receive data with communications using a fixed buffer.

Check item	Action	
Does the receive data length match with the amount of data actually received?	If the amount of the actually received data is smaller than the receive data length, receive the remaining data. If it is larger than the receive data length, receive the excess data as the next request message or discard it.	
Has the connection with the connected device been opened? (Check the corresponding bit of 5000 _H in the buffer memory.)	 Open the connection with the connected device. Check if the open/close processes for I/O signals and the OPEN/CLOSE instructions are not used together for the same connection. If so, correct the program. Read Open error code (address: 124 (7C_H)) in the communication status storage area. Then check the error details and correct the error. 	
Is the IP address setting of the connected device correct?	Check and correct the IP address of the connected device.	
Does the communication protocol (TCP/IP or UDP/IP) match with that of the connected device?	Use the same communication protocol (TCP/IP or UDP/IP) as that of the connected device.	
Is the receive status signal of the corresponding fixed buffer on? (Check the corresponding bit of 5005 _H in the buffer memory.)	Data was not sent from the connected device. Check the connected device on the sending side and correct the error.	
Was the BUFRCV instruction executed?	 Correct the execution conditions of the BUFRCV instruction. Check if the send/receive processes for I/O signals and the BUFSND/BUFRCV instructions are not used together for the same connection. If so, correct the program. 	
Was the BUFRCV instruction completed normally?	Check the error code in the BUFSND instruction completion status area and correct the error.	
Was the BUFRCVS instruction executed?	Correct the interrupt setting of the programming tool. Check if the send/receive processes for I/O signals and the BUFSND/BUFRCV instructions are not used for the same connection. I so, correct the program.	
Is the control data of the BUFRCVS instruction correct?	Correct the control data.	
Has an open or initial error occurred in the error log area?	Check and correct the error.	

- Hardware test (FP Page 323, Appendix 6.2)
- Self-loopback test (Page 322, Appendix 6.1)

16.6.10 Communications using a random access buffer cannot be performed.

The following table lists how to troubleshoot the problem when an E71 cannot perform communications using a random access buffer.

Check item	Action	
Has the connection with the connected device been opened? (Check the corresponding bit of 5000 _H in the buffer memory.)	Open the connection with the connected device. Check if the open/close process for I/O signals and the OPEN/CLOSE instructions are used together for the same connection. If so, correct the program.	
Did the connected device send a command?	Send a command to the E71.	
Was a response returned to the device that had sent the command?	 Check if the correct IP address was specified in the command. If not, correct the IP address and send the command again. Check if the communication protocol (TCP/IP or UDP/IP) matches wit that of the connected device. If not, correct it. 	
Is the end code of the response 0?	Check the end and error codes to correct the error.	
Is the correct buffer memory address specified for the command?	Correct the buffer memory address and send the command again.	
Has data been set in the specified address of the random access buffer?	Write the data.	
Has the write data been set in the connected device?	Set the data.	
Has an open or initial error occurred in the error log area?	Check and correct the error.	

- Hardware test (Page 323, Appendix 6.2)
- Self-loopback test (FP Page 322, Appendix 6.1)

16.6.11 An e-mail cannot be sent.

The following table lists how to troubleshoot the problem when an E71 cannot send an e-mail.

(1) When sending an e-mail with a program

Check item	Action	
Was the MSEND instruction executed?	Correct the execution conditions of the MSEND instruction.	
Was the MSEND instruction completed normally?	Check the error code in the MSEND instruction completion status area at the e-mail sending error log to correct the error.	
Is the error response received from the mail server using the MRECV instruction?	Check with the system administrator that the following settings are correct: • DNS setting • E-mail setting	

If the action above does not solve the problem, check the following.

- Is the e-mail parameter setting of the E71 correct?
- · Is the mail server system down?
- · Is there any error in the communication path?

(2) When sending an e-mail with the programmable controller CPU monitoring function

Check item	Action	
Are the monitoring conditions satisfied?	Check the notification setting with the programming tool.	
Was the first sending performed using the programmable controller CPU monitoring function?	Check if there is any device outside the range of the device settings among the condition devices and correct the condition device.	
Were the second and subsequent sendings performed using the programmable controller CPU monitoring function?	Correct the following so that the monitoring condition disable time becomes longer than the value set in "PLC Inquiry Interval". • PLC Inquiry Interval • Condition Device Correct the following so that the sending time of the SMTP server and the E71 becomes shorter than the value set in "PLC Inquiry Interval". • Reduce the load on the SMTP server. • When the SMTP server and the E71 are connected via routers or other devices, connect the E71 to the same main line as the SMTP server.	

If the action above does not solve the problem, check the following.

- Is the e-mail parameter setting of the E71 correct?
- · Is the mail server system down?
- · Is there any error in the communication path?

16.6.12 An e-mail cannot be received.

The following table lists how to troubleshoot the problem when an E71 cannot receive an e-mail.

Check item	Action	
Was the MRECV instruction executed?	Correct the execution conditions of the MSEND instruction.	
Was the MRECV instruction completed normally?	Check the error code in the MRECV instruction completion status area and correct the error.	
Does the receive data exist in the device?	Shorten the inquiry interval. Check if there is any error in the communication path. Check the number of e-mails remaining on the mail server.	
Is the receive data value incorrect? (Are the characters in the subject garbled?)	Check and correct the e-mail parameter settings. Check if the mail server system is down. Check if there is any error in the communication path.	
Is a device other than the E71 sending the data?	 If EUC or SHIFT-JIS is used, perform the following: Send an e-mail from a personal computer to the own station. Check the header information of the received e-mail sent by the own station. For Outlook Express, select "Properties" → "Details". In the header information, check that the setting is "Content-Type:text-plain:charset=iso-2022jp". If it is "charset=EUC-jp" or "charset=SHIFT-JIS", correct it. 	
Is the E71 sending the data?	Because the E71 does not decode received data, it cannot receive an e mail normally. Try to send an e-mail from a device other than the E71.	
Did the sending device send the e-mail in the ASCII code or convert the ASCII code further into the ASCII code?	Check the following. • Convert the e-mail attachment into the binary code and send it. • Check if the sent data (e-mail attachment) is not in the ASCII code.	

16.6.13 Communications using data link instructions cannot be performed.

The following table lists how to troubleshoot the problem when an E71 cannot perform communications using data link instructions.

Check item	Action	
Is the communication status of the connected device normal?	Correct the error of the connected device.	
Is the number of resends set upon every instruction execution?	Modify the program to set the number of resends upon every instruction execution.	
Does an error occur even after the arrival monitoring time is increased?	Check and correct the arrival monitoring time.	
Does an error occur even after the setting value in "TCP Resend Timer" in the initial setting is increased?	Check and correct the setting value in "TCP Resend Timer".	
Are the routing parameter settings correct?	Check the routing parameters and correct the error.	
Is the Station No. <->IP information setting configured?	Set the "Station No.<->IP Information" setting in the network parameter window. (MELSEC-Q/L Ethernet Interface Module User's Manual (Application))	
	(Application))	

- Hardware test (FF Page 323, Appendix 6.2)
- Self-loopback test (F Page 322, Appendix 6.1)

16.7 Error Code List

This section describes the error codes (abnormal codes) of the errors that may occur in each process for performing communications between the E71 and a connected device as well as errors caused by process requests issued from the CPU module of the own station, the error details, and the actions to be taken. The following table lists the types of errors that may occur.

Error type	Description	Buffer memory area that stores the error code
Errors occurring in the initial process	Setting value error Initial process error	Page 250, Section 16.7 (1)
Errors occurring in the open process	Setting value error Open process error	Page 250, Section 16.7 (2)
Errors occurring in communications using a fixed buffer (sending) with the connected device	Specified data error Sending error	Page 250, Section 16.7 (3), Page 250, Section 16.7 (4)
Errors occurring in communications using a fixed buffer with the connected device	Specified data error Communication error (excluding errors occurring in communications using a fixed buffer (sending) with the connected device)	Page 250, Section 16.7 (4)
Errors returned to the connected device when communicating with it	Errors returned in communications using a fixed buffer (end code) Errors returned in communications using a random access buffer (end code)	_
	Errors returned in communications using the MC protocol	End code or error code for each command
Errors occurring while communicating with the destination (including the causes in the "Description" column), and whose error codes are stored in the error log area	Specified data error Errors where the source cannot be found Errors that have occurred in MC protocol communications Errors that have occurred in communications using a random access buffer	Page 251, Section 16.7 (5)
Errors occurring in data communications using the predefined protocol	Setting data error Receiving error	Page 252, Section 16.7 (6) Page 254, Section 16.7 (7)
Errors (response commands) occurring in communications with the destination using the file transfer (FTP server) function	Specified data error Communication error	MELSEC-L CPU Module User's Manual (Built-In Ethernet Function)
Errors occurring in communications using the Web function	Communication error	Page 255, Section 16.7 (8)
Errors occurring when an e-mail is received	Setting data error Receiving error	Page 256, Section 16.7 (9) (a)
Errors occurring when an e-mail is sent	Setting data error Sending error	Page 258, Section 16.7 (9) (b)
Errors occurring in communications using data link instructions from the CPU module of the own station	Specified data error Communication error	Not stored (stored in the complete status area of the instructions)
Errors occurring in communications using the dedicated instructions from the CPU module of the own station	Specified data error Communication data error	Not stored (stored in the complete status area of the instructions)

(1) Initial error code (address: 69_H)

The error codes generated when the initial process is executed are stored. Error codes are stored in binary when Initial abnormal completion signal (X1A) is on. The error codes are cleared when Initial normal completion signal (X19) turns on, but can be also cleared by the following processes:

- · Resetting or powering off the CPU module
- · Writing 0 to the initial error code storage area using a program

(2) Open error code (address: 7C_H to C1_H, 5824_H to 5869_H)

The result of the open process for connection with the connected device is stored in binary.

- · 0: Normal completion
- Values other than 0: Abnormal end (Open abnormal detection signal (X18): ON)

The error codes are cleared by the following operations:

- · Reopening the connection that caused an open error
- · Powering off and on or resetting the CPU module

(3) Fixed buffer sending error code (address: 7D_H to C2_H, 5825_H to 586A_H)

The error codes generated when an error has occurred in data sending to the destination during communications using a fixed buffer in the connection with the connected device are stored. A sending error code is cleared when the next data sending is completed normally.

(4) Connection end code (address: 7E_H to C3_H, 5826_H to 586B_H)

The codes returned in the responses from the destination during communications using a fixed buffer in the connection with the connected device are stored in binary. Process the end codes in the responses according to the destination.

(5) Error log area (address: E0_H to 1FF_H)

The following table lists the details of the error log area. The buffer memory addresses of the error log block are those of the error log block 1. For the addresses of the error log block 2 and later, refer to the list of buffer memory addresses. (Fig. Page 35, Section 3.5.2)

	r memory name	Address	Description					
Number of	f errors	E3 _H	The number of errors registered in the error log block area is stored. When the number of errors reaches 65536, the count stops at FFFF _H (65535).*1					
Error log write pointer E4 _H			The number of the error log block where the latest error log is registered is stored. • 0: No error (no registration of error log) • 1 or more: The number of the error log block where the latest error log is registered. If the pointer value is 16, it means that the latest error log is registered in the error log block 16 area. When the number of errors reaches 17, the error log is then registered in the error log block 1 area again.*2					
Error code/end E5 _H code			An error code indicating error details is stored. The subheader code of the error message is stored in bits 0 to 7 of the corresponding area. (Bits 8 to 15 store 0.) For errors below the TCP/IP or UDP/IP level, 0 is stored.					
Error log block	Command code	E7 _H	The command code of the error message or the values of the lower bytes of the request type and subrequest type of the data link instructions are stored. b15					
	Connection No.	E8 _H	The number of the error connection is stored in bits 0 to 7 of the corresponding area. (Bits 8 to 15 store 0.) For errors below the TCP/IP or UDP/IP level, 0 is stored.					
	Own station port No.	E9 _H	The port number of the error own station is stored. For errors below the TCP/IP or UDP/IP level, 0 is stored.					
	Destination IP address	EA _H and EB _H	The IP address of the error connected device is stored. 0 is stored in the following cases: • For errors below the IP level • When an error response was sent through the CPU module					
	Destination Port No.	ECH	The IP address of the error connected device is stored. For errors below the TCP/IP or UDP/IP level, 0 is stored.					
Status for each protocol 178 _H to 1FF _H			The number of occurrences of the corresponding status of each protocol is stored. When the count value by the E71 exceeds two words, the count stops at FFFFFFF _H (4294967295).					

- *1 The error information is continued to be stored into the following areas even if the count of the errors is stopped:
 - · Error log write pointer storage area
 - Error log block
- *2 An error log block area consists of 16 error log blocks that have the same data order.




Values stored in the buffer memory are cleared when an E71-connected station is powered on or reset. (They are not cleared during the initial process.) Although this area does not normally need to be read, read it when necessary for maintenance or other purposes.

(6) Protocol setting data check area (address: $5320_{\rm H}$ to $533F_{\rm H}$)

The following table lists the details of the protocol setting data check area.

Buffer memory name		Address	Description		
	Protocol No.	5324 _H	When an error is detected in the protocol setting data, the protocol No. where an error has been detected is stored. The protocols are checked from the lowest protocol No. and the first protocol No. where an error has been detected is stored. • 0: No errors • 1 to 128: Protocol No. • 65535: Unidentified *1		
Protocol	Setting type	5325 _H	When an error is detected in the Packet Setting or Element Setting, 0 is stored. When an error is detected in the Protocol Detailed Setting, 1 is stored. (Valid when the Protocol No. value is 1 to 128) • 0: Packet setting or element setting • 1: Protocol detailed setting • 65535: Unidentified*1		
setting data error information	Packet No.	5326 _H	When an error is detected in the protocol setting data, the packet No. where an error has been detected is stored. The send packet is checked first, then receive packet (expected packet) is checked from the lowest packet No. and the first packet No. where an error has been detected is stored. (Valid when the Setting type value is 0) • 0: Send packet • 1 to 16: Receive packet • 65535: Unidentified*1		
	Element No. 5327 _H		When an error is detected in the protocol setting data, the element No. where an error has been detected is stored. The elements are checked from the lowest element No. and the first element No. where an error has been detected is stored. (Valid when the Setting type value is 0) 1 to 32: Element No. 65535: Unidentified*1		
Number of registered protocols		5328 _H	Number of registered protocols in the protocol setting data is stored. When the check results include any error, 0 is stored. • 0: No registration • 1 to 128: Number of registrations		



- *1 When the setting value gets Unidentified (65535), the following causes are possible:
 - · When settings undetectable with the E71 used are written
 - \cdot When the protocol setting data is broken (hardware failure)

(7) Predefined protocol support function execution status check area (address: $54C0_H$ to $55FF_H$)

The following table lists the details of the predefined protocol support function execution status check area. The buffer memory addresses are those of Connection No.1. For the addresses of the Connection No.2 and later, refer to the list of buffer memory addresses. (FFP Page 35, Section 3.5.2)

Buffer memory name Address		Description			
Protocol execution status	54C0 _H	The status of protocols being executed in Connection No.1 is stored. • 0: Unexecuted • 1: Waiting for transmission • 2: Sending • 3: Waiting for data reception • 4: Receiving • 5: Completed			
Received data verification result (receive packet No.1)	54C2 _H	Verification result of receive packet No.1 is stored. (Fig. Page 254, Section 16.7 (7) (a)) • b0 to b7: Element No. where the verification result did not match • b8 to b15: The cause of mismatch (verification result code)			
Received data verification result (receive packet No.2 to 16) 54C3 _H to 54D1 _H		The bit configuration is the same as receive packet No.1.			
Number of protocol executions	54D2 _H	The number of protocol executions in Connection No.1 is stored. • 0: No protocol execution • 1 to 65535: Number of executions (When the number exceeds 65535, the value remains 65535.)			
Protocol cancellation specification	54D3 _H	Cancels the protocol executed in Connection No.1. • 0: No cancellation specification • 1: Cancellation request (set by user) • 2: Cancel completed (set by the system)			

(a) Received data verification result

The following information is stored in Received data verification result.

• Element No. where the verification result did not match (b0 to b7)

Stored value	Description			
0	Verification matched			
1 to 32	Element No. where the verification result did not match			
FF _H	Verification not performed			

• The cause of mismatch (verification result code) (b8 to b15)

Stored value	Description	Cause
00 _H	Normal	-
01 _H	Insufficient receive data	The total packet size of receive data is smaller than that set in protocol data.
10 _H	Data not matched	The receive data do not match the value set in protocol data.
11 _H	ASCII-binary conversion error	When "ASCII Hexadecimal" is set in Code Type, data not in ASCII code are received.
12 _H	Data length error	The received Length value exceeded 2046 bytes.
30 _H	Data length size error	The Length value received from the connected device does not match the actual length.
FF _H	Verification not performed	-

(8) HTTP status storage area (address: $5101_{\rm H}$ to $5177_{\rm H}$)

The following table lists the HTTP status storage areas. The buffer memory addresses of the error log block are those of the error log block 1. For the addresses of the error log block 2 and later, refer to the list of buffer memory addresses. (Fig. Page 35, Section 3.5.2)

	Buffer memory name Address				Description				
Error log pointer 51		5101 _H	• 0: • 1 d If the 16 at log b	The number of the error log block where the latest error log is registered is stored. • 0: No error (no registration of error log) • 1 or more: The number of the error log block where the latest error log is registered. If the pointer value is 16, it means that the latest error log is registered in the error log block 16 area. When the number of errors reaches 17, the error log is then registered in the error log block 1 area again.*1					tered. or log block in the error
Log counter 5102 _H to 5106 _H				number ser is s	•	ise code	was r	eturned from the E71 to the	Web
	HTTP response code	5108 _H	The	The HTTP response code in case of an error is stored.					
	Destination IP address	5109 _H to 510A _H	The	The IP address of the server in case of an error is stored.					
			The	time wh	en the error occurred is st	ored in t	he BC	D code.	
Error log				b15	to	b8	b7	to	b0
block					Month (01н to 12н)		Year (00н to 99н): Last two digits of th	ne year
				b15	to	b8	b7	to	b0
	Error time	510B _H to 510E _H			Hour (00н to 23н)			Day (01н to 31н)	
				b15	to	b8	b7	to	b0
					Second (00н to 59н)			Minute (00н to 59н)	
				b15	to	b8	b7	to	b0
				Year (0	00н to 99н): First two digits of	the year		Day of the week (0 to 6)	

^{*1} An error log block area consists of 16 error log blocks that have the same data order.

(9) E-mail status storage area (address: 5870_H to 5FFF_H)

When the stored count exceeds $FFFF_H$, the count starts from 0_H again. The following table lists the details of the e-mail status storage area. The buffer memory addresses of the error log block are those of the error log block 1. For the addresses of the error log block 2 and later, refer to the list of buffer memory addresses.

(F Page 35, Section 3.5.2)

(a) Receive area

Buffer memory name	Address	Description
Number of mails remaining on the server	5870 _H	The number of remaining e-mails returned when the E71 inquired the receive mail server is stored. • 0: No received mail in the server • 1 to 15: The number of mails remaining in the server • 16: The number of mails in the server is 16 or more.
Dedicated instruction normal completion count	5871 _H	The cumulative number of normal completions of the dedicated instruction (MRECV) is stored. O: The MRECV instruction has not been executed or no executions have resulted in normal completion. I or more: The cumulative number of normal completions of the MRECV instruction
Dedicated instruction abnormal completion count	5872 _H	The cumulative number of abnormal ends of the dedicated instruction (MRECV) is stored. • 0: The MRECV instruction has not been executed or no executions have resulted in abnormal end. • 1 or more: The cumulative number of abnormal ends of the MRECV instruction
Normal receiving count	5873 _H	The cumulative number of received e-mails forwarded by the E71 to the mail buffer data area is stored. • 0: No mail has been transferred. • 1 or more: The number of normal mail transfer completions
Attached file receiving count	5874 _H	The cumulative number of e-mails with an attachment received by the E71 is stored. • 0: No e-mail with an attachment has been received. • 1 or more: The number of normal reception of e-mails with an attachment
Server inquiry count	5875 _H	The cumulative number of inquiries to the receive mail server according to the parameter setting is stored. • 0: No inquiry has been made to the server. • 1 or more: The cumulative number of inquiries to the server
Server communication error count	5876 _H	The cumulative number of communication errors returned in response to inquiries to the receive mail server is stored. • 0: No communication error between servers or no inquiry • 1 or more: The cumulative number of communication errors
Error log write count	5877 _H	The cumulative number of registrations in the receiving error log block area is stored. • 0: No error or no inquiry to the server • 1 or more: The cumulative number of writes to the error log block area
Receiving error log write pointer	5878 _H	The number of the error log block where the latest receiving error log is registered is stored. • 0: No error (no registration of error log) • 1 or more: The number of the error log block where the latest error log is registered. If the pointer value is 16, it means that the latest error log is registered in the receiving error log block 16 area. When the number of errors reaches 17, the error log is then registered in the error log block 1 area again.*1

Buffer memory name		Address	Description						
	Error code	5879 _H	An error co	de indicating the error de	tails is s	tored.			
	Command code	587A _H	The system	The system command code of the error message is stored.					
	From	587B _H	The first eight words of the sender's e-mail address of the error e-mail in the communications with the mail server are stored in the ASCII code. (Example) If the sender's e-mail address is "use@from.add.sample.co.jp", "use@from.add.sam" is stored in the ASCII code.						
Error log block	Date	5883 _H			Year (00н to 99н): Last two digits of the year b8 b7 to b0 Day (01н to 31н) b8 b7 to b0 Minute (00н to 59н) b8 b7 to b0			b0 e year b0 b0 b0	
	Subject	5887 _H	The first 30 words of the e-mail subject are stored. A subject is not stored succe it contains characters other than alphanumeric and ASCII code characters.					essfully if	

^{*1} A receiving error log block area consists of 16 error log blocks that have the same data order.

(b) Send area

Buffer me	emory name	Address	Description				
Dedicated instru		5B39 _H	The cumulative number of normal completions of the dedicated instruction (MSEND) is stored. O: The MSEND instruction has not been executed or no executions have resulted in normal completion. 1 or more: The cumulative number of normal completions of the MSEND instruction				
Dedicated instruction countries		5B3A _H	The cumulative number of abnormal ends of the dedicated instruction (MSEND) is stored. • 0: The MSEND instruction has not been executed or no executions have resulted in abnormal end. • 1 or more: The cumulative number of abnormal ends of the MSEND instruction				
Number of mails completed	s normally	5B3B _H	The cumulative number of sent e-mails forwarded by the E71 to the send mail server is stored. • 0: No mail has been sent. • 1 or more: The number of normal completions of mail sending				
Attached file se	nding count	5B3C _H	The cumulative number of e-mails with an attachment sent by the E71 is stored. • 0: No e-mail with an attachment has been sent. • 1 or more: The number of normal sending of e-mails with an attachment				
Sending to the server count		5B3D _H	The cumulative number of e-mails sent by the E71 to the send mail server is stored. • 0: No e-mail has been sent to the server. • 1 or more: The cumulative number of sending e-mails to the server				
Number of mails abnormally completed		5B3E _H	The cumulative number of communication errors returned in response to send requests to the send mail server is stored. • 0: No communication error between servers or no e-mail sent • 1 or more: The cumulative number of communication errors				
Error log write o	count	5B3F _H	The cumulative number of registrations in the send error log block area is store • 0: No error or no inquiry to the server • 1 or more: The cumulative number of writes to the error log block area				
Sending error log write pointer		5B40 _H	The number of the error log block where the latest send error log is registered is stored. • 0: No error (no registration of sending error log) • 1 or more: The number of the error log block where the latest sending error log is registered. If the pointer value is 8, it means that the latest error log is registered in the receiving error log block 8 area. When the number of receiving errors reaches nine, the error log is then registered in the error log block 1 area again.*1				
	Error code	5B41 _H	An error code indicating the error details is stored.				
	Command code	5B42 _H	The system command code of the error message is stored.				
Error log block	То	5B43 _H	The first eight words of the receiver's e-mail address of the error e-mail in the communications with the mail server are stored in the ASCII code. (Example) If the sender's e-mail address is "use@from.add.sample.co.jp", "use@from.add.sam" is stored in the ASCII code.				
	Date	5B4B _H	The date and time when the e-mail was sent are stored in the BCD code (similar to 5883 _H of (a)).				
	Subject	5B4F _H	The first 15 words of the e-mail subject are stored. A subject is not stored successfully if it contains characters other than alphanumeric and ASCII code characters.				

^{*1} A sending error log block area consists of 16 error log blocks that have the same data order.

16.7.1 End codes returned to a connected device during data communications

The following table lists the error codes stored in the end code appended to a response during data communications.

O: Stored in the end code appended to a response

			Data communication type			
Error code	Error description	Action	MC protocol communications	Communications using a fixed buffer	Communications using a random access buffer	
00 _H	Normal completion	When each communication is normally completed, the error code 00 _H is stored.	0	0	0	
02 _H	The device range destination of devices to be read/written from/to is incorrect.	Check and correct the specified start device and the number of points.	0			
50 _H	Codes for the command/response type of a subheader are not within the specifications. MC protocol communications: 00 _H to 3C _H Communications using a fixed buffer: 60 _H Communications using a random access buffer: 61 _H , 62 _H In communications using a fixed buffer, if the data length setting is smaller than the actual data amount, the remaining data is processed as the second data. In this case, a subheader undefined command type error may occur.	Check and correct the command/response type set for the connected device. (Because the E71 automatically adds the command/response type, the user setting is not required.) Check and correct the data length.	0	0	0	
51 _H	In communications using a random access buffer, the start address specified by a connected device has been set outside the range from 0 to 6143.	Check and correct the specified start address.			0	
52 _H	 In communications using a random access buffer, the start address and the number of data words (depending on the setting when reading data) specified by a connected device exceeds the range from 0 to 6143. Data by the number of words specified (text) cannot be sent in one frame. (The data length value or the amount of the text sent/received are not in the allowable range.) 	Check and correct the start address and the number of data words. Correct the number of read/write points.		Ο	0	


			Data communication type			
Error code	Error description	Action	MC protocol communications	Communications using a fixed buffer	Communications using a random access buffer	
54 _H	When "ASCII Code" has been selected in the communication data code setting in the Ethernet operation setting, ASCII code data which cannot be converted into binary code data has been sent from the connected device.	Check and correct the data sent from the connected device.	0	0	0	
55 _H	When "Enable Online Change" was disabled (or not selected) in the Ethernet operation setting, the connected device requested a data write while the CPU module was running. While the CPU module was running, the connected device requested for writing a parameter, program, or microcomputer program.	Enable (select) "Enable Online Change" in the Ethernet operation setting and write data. (However, a parameter, program, or microcomputer program cannot be written while the CPU module is running.) Set the switch on the CPU module to STOP and write the data.	0			
56 _H	The connected device specified a wrong device.	Correct the device specification.	0			

			Da	ta communication t	ype
Error code	Error description	Action	MC protocol communications	Communications using a fixed buffer	Communications using a random access buffer
	The number of points for a command specified by a connected device exceeds the maximum number of processing points (number of processes that can be executed per communication) for each process. Addresses from the start address (start device number and start step number) to the specified number of points exceed the largest addresses (device number and step number) for each process.	Correct the specified points or the start address (device number and step number).	0		
57 _H	 The byte length of a command is not within the range defined by the specifications. When data is written, the set number of write data points is different from the specified number of points. 	Check the data length of the command and set the data again.	0		
	A monitor request was issued even though monitoring data is not registered.	Register the monitoring data.	0		
	For data read/write in a microcomputer program, an address after the last address that can be set in the parameter setting has been specified.	Data cannot be read from/written to an area with an address after the last address. Correct the specified address.	0		
	In the block number specification of the extension file register, a block number exceeding the range of the corresponding memory cassette size has been specified.	Correct the block number.	0		
	 The start address (start device number and start step number) of a command specified by a connected device has been set outside the range that can be specified. For data read/write in a microcomputer program or file register, values exceeding the CPU module parameter setting range has been specified. 	Correct the value to the one within the range that can be specified for each process.	0		
58 _H	A block number specified for an extension file register does not exist.	Correct the block number.	0		
	A file register cannot be specified.	Correct the device specification.	0		
	 A word device has been specified for the command for bit devices. The start number of bit devices has been specified using a value other than a multiple of 16 in the command for word devices. 	Correct the command or specified device.	0		

			Data communication type		
Error code	Error description	Action	MC protocol communications	Communications using a fixed buffer	Communications using a random access buffer
59 _H	An extension file register cannot be specified.	Correct the device specification.	0		
5B _H	The CPU module and the E71 cannot communicate. The CPU module cannot process a request from a connected device.	Check the error code appended to the end code and correct the error.	0		
60 _H	The communication time between the CPU module and the E71 exceeded the CPU monitoring timer value.	Increase the CPU monitoring timer value.	0		
63 _H	In communications using a fixed buffer, the remote password of the port for the destination E71 is in the lock status.	 After unlocking the remote password using the MC protocol, perform communications using a fixed buffer. Exclude ports used for communications using a fixed buffer from the targets of the remote password check. 		0	0
A0 _H to FFFF _H	The error details and how to troubleshoot (FF Page 264, Section 16.7.3)	the problem are the same a	as those for the error	code stored in the b	uffer memory.

16.7.2 Abnormal codes returned during communications using an Acompatible 1E frame

The following table lists the error codes stored in the abnormal code appended to a response in the A-compatible 1E frame in MC protocol communications. (An abnormal code is appended only when an end code is $5B_{H}$.)



Error code	Error	Error description	Action
10 _H	PC number error	The PC number specified with a command is not FF of the own station or not the station number set with the MELSECNET link parameters.	Change the PC number to FF _H of the own station or not the station number set using the link parameter to perform communications again.
11 _H	Mode error	After the E71 receives a request from the connected device normally, communications cannot be normally performed between the E71 and the CPU module due to some causes such as noise.	Perform communications again. If the error occurs again, check for noise and other causes and/or replace the E71.
12 _H	Intelligent function module designation error	The specified intelligent function module number has not been assigned to an intelligent function module that has the buffer memory and where communications can be performed. (For example, the specified module is an I/O module or empty.)	Change the specified data contents in the control procedure or change the connecting position of the intelligent function module. Then perform communications again.
18 _H	Remote error	The remote RUN/STOP cannot be executed. (The remote STOP/PAUSE has been already executed from another module.)	Check if the remote STOP/PAUSE has been already executed from another module. Then cancel the operation to perform communications again.
1F _H	Device error	Invalid device specification	Correct the specified device. Do not access a device which does not exist.
20 _H	Link error	The CPU module of the request destination has been disconnected from the data link.	Check if the CPU module of the station number set for the PC number has been disconnected. Then remove the cause of the disconnection to perform communications again.
21 _H	Intelligent function module bus error	Memory access to the intelligent function module cannot be performed due to the following causes: The control bus to the intelligent function module is faulty. The intelligent function module is in failure.	There is a hardware problem with the CPU module, intelligent function module, or the E71. Please consult your local Mitsubishi representative.

16.7.3 Error codes stored in the buffer memory

The following table lists the error codes stored in each buffer memory area when an error occurs. For the buffer memory areas where these error codes are stored, refer to the descriptions of the corresponding buffer memory area. (Fig. Page 35, Section 3.5.2)

Error code	Error description	Action
00 _H		
02 _H		
0050 _H		
0051 _H		
0052 _H	1	
0054 _H		ne same as those for the end code returned to the connected
0055 _H	device in data communications. (FP Page 259, Section 1	10.7.1)
0056 _H		
0057 _H		
0058 _H		
0059 _H		
005B _H	The CPU module and the Ethernet module cannot communicate. The programmable controller CPU cannot process the request from the connected device.	Check the error code appended to the end code and correct the error.
0060 _H	The communication time between the CPU module and the Ethernet module exceeded the CPU monitoring timer value.	Increase the CPU monitoring timer value.
0063 _H	In communications using a fixed buffer, the remote password of the port for the destination Ethernet module is in the lock status.	 After unlocking the remote password using the MC protocol, perform communications using a fixed buffer. Exclude ports used for communications using a fixed buffer from the targets of the remote password check.
00A0 _H	This request cannot be specified in connection with the connected device.	Correct the request details. Correct the open setting.
00A1 _H	Contents of the request cannot be analyzed because the text length or request data length is too short.	Check and correct the text length or request data length of the Qn header. Then send data to the Ethernet module again.
00A2 _H	This request cannot be processed.	Correct the request details and command.
3E8 _H to 4FFF _H	(Errors detected by a programmable controller CPU)	Refer to the troubleshooting section of the user's manual (hardware design, maintenance and inspection) for the CPU module used, and take corrective action.
7000 _H to 7FFF _H	(Errors detected by a module such as a serial communication module)	Refer to a manual such as a serial communication module user's manual, and take corrective action.
B000 _H to BFFF _H	(Errors detected by a CC-Link module)	Refer to the CC-Link System Master/Local Module User's Manual, and take corrective action.
C001 _H	 The IP address setting value of the E71 for the initial process is incorrect. The setting value of the subnet mask field for the router relay function is incorrect. 	Correct the IP address. Set the class to A/B/C. Correct the subnet mask.
C002 _H	Some of the various timer setting values for the initial process are outside the allowable range.	Check and correct each timer setting value for the initial process.
C003 _H	The setting value of the auto-open UDP port number for the initial process is outside the allowable range.	Check and correct the auto-open UDP port number.

Error code	Error description	Action
C004 _H	The setting value of the subnet mask field is incorrect.	Correct the subnet mask and perform the initial process again.
C005 _H	 The setting value of the default router IP address for the router relay function is incorrect. The network address (network address after the subnet mask) of the default router IP address is different from that of the IP address of the Ethernet module in the own station. 	Correct the default router IP address and perform the initial process again. Set the same network address as that of the IP address of the Ethernet module in the own station.
C006 _H	The setting value of the subnet address for the router relay function is incorrect.	Correct the subnet address and perform the initial process again.
C007 _H	 The setting value of the router IP address for the router relay function is incorrect. The network address (network address after the subnet mask) of the router IP address is different from that of the IP address of the Ethernet module in the own station. 	 Correct the router IP address and perform the initial process again. Change the IP address of the Ethernet module in the own station to the same address as the network address.
C00E _H	The send/receive process has been executed while the IP address in use detection function is being executed.	Do not execute the send/receive process while executing the IP address in use detection function.
		Set different IP addresses.
C00F _H	One IP address is used for two or more modules.	The MAC addresses of the Ethernet modules in the stations with the same IP address can be checked in IP address status storage area (5281 _H to 5286 _H).
C010 _H	The setting value of the Ethernet module port number for the open process is incorrect.	Correct the port number.
C011 _H	The setting value of the port number of the connected device for the open process is incorrect.	Correct the port number.
C012 _H	The port number set is used in a connection already opened in TCP/IP.	Correct the port numbers of the Ethernet module and the connected device.
C013 _H	The port number used in a connection already opened is set for the open process in UDP/IP.	Correct the port number of the Ethernet module.
C014 _H	The initial process or open process of the Ethernet module is not completed.	Perform the initial process or open process.
C015 _H	The setting value of the IP address of the connected device for the open process is incorrect.	Correct the IP address. Set the class to A/B/C.
C016 _H	The open process of the connection (or the next connection) specified for pairing open has been already completed.	 Check that none of the connections targeted for pairing open has been opened. Correct the combination of modules set for pairing open.
C017 _H	A connection could not be established in the open process of the TCP connection.	Check the operation of the connected device. Check the open process of the connected device. Correct the open setting of the communication parameters. Correct the port number of the Ethernet module, the IP address and port number of the connected device, and the open setting. Check if the cable is disconnected.
C018 _H	The setting value of the IP address of the connected device is incorrect.	Correct the IP address.
C020 _H	The data length exceeds the allowable range.	Correct the data length. When the amount of data to be sent exceeds the limit, divide the data into smaller chunks to send it.
C021 _H	An abnormal end response was received for communications using a fixed buffer.	Read the response end code from the connection end code or error log area and perform the required action.

Error code	Error description	Action
C022 _H	 A response could not be received within the response monitoring timer value. The connection with the connected device was closed while waiting for a response. 	Check the operation of the connected device. Correct the response monitoring timer value. Check the open status of the connection with the connected device.
C023 _H	The connection with the connected device has not been opened. The connection with the connected device has been closed.	Open the connection with the connected device.
C024 _H	When "Predefined protocol" is set in "Fixed Buffer Communication" setting, communications using a fixed buffer or a random access buffer are executed. When "Procedure Exist" or "No Procedure" is set in "Fixed Buffer Communication" setting, a predefined protocol is executed.	Correct the connection number of BUFSND/BUFRCV/BUFRCVS/ECPRTCL instructions. Correct the "Fixed Buffer Communication" setting (Procedure Exist/No Procedure/Predefined protocol) of the corresponding connection.
C025 _H	There is an error in the usage setting area when starting the open process by the OPEN instruction or input/output signals.	When starting the open by using the OPEN instruction, correct the usage setting area of the control data. When starting the open by input/output signals, correct the connection usage setting area of the buffer memory.
C026 _H	An error has occurred when reading/writing/verifying the predefined protocol setting data.	 Check that connection cable with the engineering tool is not disconnected and read/write/verify the predefined protocol setting data again. Do not write data simultaneously when writing protocol setting data from multiple engineering tools.
C030 _H	A sending error has occurred.	 Because there may be congestion of packets on the line, send data after a certain period of time. Check if the cable is disconnected. Perform the self-diagnostics test to check for an error in the Ethernet module.
C031 _H	A sending error has occurred.	 Because there may be congestion of packets on the line, send data after a certain period of time. Check if the cable is disconnected. Perform the self-diagnostics test to check for an error in the Ethernet module.
C032 _H	A TCP ULP timeout error has occurred in the TCP/IP communication. (The connected device does not send an ACK response.)	 Check the operation of the connected device. Correct the TCP ULP timeout value and perform the initial process again. Because there may be congestion of packets on the line, send data after a certain period of time. Check if the cable is disconnected.
C033 _H	There is no connected device with the IP address that has been set.	 Correct the IP address of the connected device and the Ethernet address. Use the default value (FFFFFFFFFFFFH) if the connected device has the ARP function. If it does not have the function, set the MAC address. Check the operation of the connected device. Because there may be congestion of packets on the line, send data after a certain period of time. Check if the cable is disconnected.
C034 _H	On the ARP table, there is no connected device with the IP address that has been set.	Decrease the number of communication destinations.
C035 _H	The existence of the connected device could not be checked within the response monitoring timer value.	Check the operation of the connected device. Correct the settings of the alive check. Check if the cable is disconnected.

Error code	Error description	Action
		Check if the cable is disconnected.
C036 _H	Because a cable is not connected or disconnected, the send process cannot be executed.	Perform the loopback test to check for an error in the line.Perform the self-diagnostics test to check for an error in
		the Ethernet module.
	Not all the data could be received within the response	
	monitoring timer value.	Correct the data length of the communication data.
C040 _H	Sufficient data for the data length could not be received. The second sec	Because there may be congestion of packets on the line,
	The remaining part of the message divided at the TCP/IP level could not be received within the response	correct the settings of the initial process.
	monitoring timer value.	Send the same data from the connected device again.
	-	Correct the checksum value sent from the connected
	There is an error in the checksum of the receive data when	device and send the correct value.
C041 _H	TCP is used.	Check the situation of the line, such as noise, the distance
		between the line and power cable, and the grounding of
		each device.
		Correct the checksum value sent from the connected
C043	There is an error in the checksum of the receive data when	device and send the correct value.
C042 _H	UDP is used.	Check the situation of the line, such as noise, the distance between the line and power cable, and the grounding of
		each device.
		Correct the checksum value sent from the connected
		device and send the correct value.
C043 _H	The checksum in the header of the IP packet received is	Check the situation of the line, such as noise, the distance
	incorrect.	between the line and power cable, and the grounding of
		each device.
C044 _H	An error pocket of ICMD was received	Check the operation of the connected device.
C044H	An error packet of ICMP was received.	Check if the cable is disconnected.
C045 _H	An error packet of ICMP was received.	Check the operation of the connected device.
0043H	All error packet of ICMP was received.	Check if the cable is disconnected.
C046 _H	An error packet of ICMP was received.	Check the operation of the connected device.
	7 iii orror publicit or rollini ii waa roooriyaa.	Check if the cable is disconnected.
C047 _H	An error packet of ICMP was received.	Check the operation of the connected device.
		Check if the cable is disconnected.
C048 _H	An error packet of ICMP was received.	Check the operation of the connected device.
		Check if the cable is disconnected.
		Check the operation of the connected device. Page 1991 the connected device.
		Because there may be congestion of packets on the line, send data after a certain period of time.
C049 _H	An error packet of ICMP was received.	Check if the cable is disconnected.
		If an alive check timeout occurs, correct the IP assembly
		timer value of the connected device.
		Check the operation of the connected device.
		Because there may be congestion of packets on the line,
C04A _H	An error packet of ICMP was received. (An IP assembly	send data after a certain period of time.
- ¥ 'H	timeout error has occurred in the connected device.)	Check if the cable is disconnected.
		If an alive check timeout occurs, correct the IP assembly
		timer value of the connected device.
C04B _H		Check the operation of the connected device. Page 1997 The connection of page 1997 the line.
	An IP assembly timeout error has occurred. (The remaining part of the divided data could not be received	Because there may be congestion of packets on the line,
		send data after a certain period of time. • Check if the cable is disconnected.
	and a timeout has occurred.)	Correct the IP assembly timer value and perform the initial
		process again.
	Because there is no space in the internal buffer, such as	Send the same data again and check the receipt of a
C04C _H	the IP header buffer, data cannot be sent.	response.

Error code	Error description	Action
C04D _H	In communications using an auto-open UDP port or communications using a fixed buffer in the "No Procedure" control method, there is an error in the data length specified in the application data of the message received by the Ethernet module. Not all the receive data can be stored.	Correct the data length. Correct the text size so that the text data size is within the receive buffer memory size.
С050 _Н	When "ASCII Code" has been selected in the communication data code setting in the Ethernet operation setting, ASCII code data which cannot be converted into binary code data has been sent from the connected device.	Select "Binary Code" in the Ethernet operation setting. Then restart the Ethernet module to perform communications again. Check and correct the data sent from the connected device and send it again.
C051 _H	The number of read/write points is outside the allowable range.	Correct the number of read/write points and send the data to the Ethernet module again.
C052 _H	The number of read/write points is outside the allowable range.	Correct the number of read/write points and send the data to the Ethernet module again.
C053 _H	The number of read/write points is outside the allowable range.	Correct the number of read/write points and send the data to the Ethernet module again.
C054 _H	The number of read/write points is outside the allowable range.	Correct the number of read/write points and send the data to the Ethernet module again.
C055 _H	The number of file data read/write points is outside the allowable range.	Correct the number of read/write points (or the number of bytes) and send the data to the Ethernet module again.
C056 _H	The read/write request exceeds the largest address. The address is 0.	Correct the start address or the number of read/write points and send the data to the Ethernet module again. (Make sure that the request does not exceed the largest address.)
C057 _H	The request data length does not match with the number of data in the character (a part of text).	Check and correct the text or requested data length of the Qn header. Then send the data to the Ethernet module again.
C058 _H	The request data length after the ASCII/binary conversion does not match with the number of data in the character (a part of text).	Check and correct the text or requested data length of the Qn header. Then send the data to the Ethernet module again.
C059 _H	Incorrect designation of the command and subcommand	Correct the request details.
C05A _H	The Ethernet module cannot read/write data from/to the specified device.	Check the device for read/write.
C05B _H	The Ethernet module cannot read/write data from/to the specified device.	Check the device for read/write.
C05C _H	Incorrect request (For example, a request for data read/write in bit units has been issued to a word device.)	Correct the request details and send it to the Ethernet module again. (For example, change the subcommand.)
C05D _H	The monitor registration is not performed.	Register the monitoring data and perform monitoring.
C05E _H	The communication time between the Ethernet module and the programmable controller CPU exceeded the CPU monitoring timer value.	 Increase the CPU monitoring timer value. Check that the programmable controller CPU is operating normally. Correct the network number or PC number. If the destination is a station with a different network number, correct the routing parameter setting. If the destination is a station with a different network number, check if the network number is not in use.
C05F _H	This request cannot be executed to the target programmable controller.	Correct the network number or PC number. Correct the read/write request details.
C060 _H	Incorrect request (For example, incorrect data was specified for bit devices.)	Correct the request details and send it to the Ethernet module again. (For example, correct the data.)

Error code	Error description	Action
C061 _H	The request data length does not match with the number of data in the character (a part of text).	Check and correct the text or requested data length of the Qn header. Then send the data to the Ethernet module again.
C062 _H	When writing was prohibited while the CPU was running, data has been written to the remote I/O station using the MC protocol (with a QnA-compatible 3E frame or 4E frame).	To write data to the remote I/O station using the MC protocol (with a QnA-compatible 3E frame or 4E frame), select "Enable Write at RUN time" in the Ethernet operation setting.
C070 _H	The device memory cannot be extended for the target station.	Read/write data without the device memory set for extension. Device memory can be extended only in an Ethernet module-connected station and a Q/QnACPU via CC-Link IE Controller Network, MELSECNET/H, or MELSECNET/10.
C071 _H	The number of device points for data read/write set for modules other than a Q/QnACPU is too large.	Correct the number of device points for data read/write and send the data to the Ethernet module again.
C072 _H	Incorrect request (For example, a request for data read/write in bit units has been issued to a word device.)	Check whether the data can be requested to the target programmable controller CPU. Correct the request details and send it to the Ethernet module again. (For example, change the subcommand.)
C073 _H	The Ethernet module cannot issue this request to the target programmable controller CPU. (For example, the number of double word access points cannot be specified for modules other than a Q/QnACPU.)	Correct the request details.
C074 _H	This request cannot be executed to the target programmable controller CPU.	Correct the network number or PC number. Correct the read/write request details.
C080 _H	The destination IP address could not be obtained during CC-Link IE Controller Network, CC-Link IE Field Network, MELSECNET/H, MELSECNET/10 relay communications or communications using data link instructions.	Set the Station No. <-> IP information in the Ethernet module. Change the conversion method for the CC-Link IE Controller Network, CC-Link IE Field Network, MELSECNET/H, and MELSECNET/10 relay communication parameters.
C081 _H	The termination process for the Ethernet module is in process, and whether communications using data link instructions have reached cannot be checked.	Finish all the communications to perform the termination process of the Ethernet module.
C082 _H	The communication process was abnormally ended in the following communications. • Communications with a programming tool (UDP/IP) • CC-Link IE Controller Network, CC-Link IE Field Network, MELSECNET/H, MELSECNET/10 relay communications	Check if the relay station/connected station is operating normally. (If the communication is alive, no action for this error is required.) Check if there is an error with the cable connection between the own station and the connected station. If the line is heavily loaded, reduce the load. Increase the number of resends for the data link instructions. Increase the time reserved for the communication process in the service processing setting in "PLC System" under "PLC Parameter".
C083 _H	The communication process was abnormally ended in communications using data link instructions.	 Check if the relay station/connected station is operating normally. (If the communication is alive, no action for this error is required.) Check if there is an error with the cable connection between the own station and the connected station. If the line is heavily loaded, reduce the load. Increase the time reserved for the communication process in the service processing setting in "PLC System" under "PLC Parameter".

Error code	Error description	Action
C084 _H	The communication process was abnormally ended in communications using data link instructions.	Check if the own station/relay station/connected station is running normally. Check if there is a problem with the cable connection between the own station and the connected station. Increase the TCP resend timer value. Increase the time reserved for the communication process in the service processing setting in "PLC System" under "PLC Parameter".
C085 _H	The own station's channel specified by another station in communications using data link instructions is currently in use.	Execute the request from another station again.
C086 _H	A message exceeding the receive message size was received.	Correct the send message size of the request source.
C087 _H	There is an error in the IP address set in the Station No. <-> IP information setting for CC-Link IE Controller Network, CC-Link IE Field Network, MELSECNET/H, MELSECNET/10 relay communications.	In the Station No.<->IP information setting, set the IP addresses for the CC-Link IE Controller Network, CC-Link IE Field Network, MELSECNET/H, and MELSECNET/10 relay communication target devices.
C0B2 _H	There is no insufficient space in the receive buffer of the relay station PC number for MELSOFT connection or data link instructions, or the communication request destination station. (Receive buffer full error)	 Increase the request interval. Decrease the number of request nodes. Wait for a response to the previous request before sending the next request. Correct the timeout value.
C0B3 _H	A request that cannot be processed was issued from the programmable controller CPU.	Correct the request details. Correct the network number or PC number.
C0B5 _H	Data that cannot be processed by the programmable controller CPU or Ethernet module was specified.	Correct the request details. Cancel the current request.
C0B6 _H	The channel number is outside the allowable range.	Specify the channel number from 1 to 8.
C0B7 _H	A channel number currently in use was specified.	Change the channel number. Perform communications again after the current communications are completed.
C0B8 _H	 The network number or PC number is outside the allowable range. A response from the programmable controller CPU is faulty. 	Correct the network number or PC number. Check the programmable controller CPU operation.
C0B9 _H	The open process of the TCP connection has not been completed.	 Perform the open process. Check the operation of the connected device. After sending a close request (FIN) from the connected device to the E71, perform the open process again and wait for 500ms or more.
C0BA _H	Because the close process is in process using the CLOSE instruction, a send request cannot be accepted.	Perform the open process and send the request.
C0BB _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C0BC _H	The specified communication line is closed.	Open the communication line. Correct the target connection number.

Error code	Error description	Action
C0BD _H	Requests have been accepted successively and cannot be sent.	Check if requests have been sent successively without waiting for a response.
C0BE _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C0BF _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C0C0 _H	The open process of the UDP connection has not been completed.	Perform the open process.Check the operation of the connected device.
C0C1 _H	The transmission interval of UDP is too short.	Check if a send request is being repeatedly issued. Increase the send interval.
C0C2 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C0C3 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C0C4 _H	The UINI instruction has been executed during communications.	Execute the UINI instruction after closing all connections.

Error code	Error description	Action
C0C5 _H	A send request was issued to the connected device with the class/network address different from those of the own station when the router relay function is not used. The setting of the router relay parameter is incorrect.	 Enable the router relay function and perform the initial process. Set the correct data in the router relay parameter. Correct the IP address of the connected device and perform the open process. Check if the network address is correct. After changing the network address, perform the initial process again.
C0C6 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C0C7 _H	An Ethernet module system error has occurred.	Take action such as separating networks or decreasing the number of data sending to reduce the load on the Ethernet line. Consult the network administrator and reduce the load on the Ethernet line. Perform the self-diagnostics test to check for an error in the Ethernet module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C0C8 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C0C9 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.

Error code	Error description	Action	
C0CA _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.	
C0CB _H	Another send request was issued before the send process has not been completed.	Wait for completion of transmission before sending the next send request.	
C0CC _H	System error (The OS detected an error.)	• Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.	
C0CF _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.	
C0D0 _H	Incorrect data length was specified.	Correct the specified data length.	
C0D1 _H	The number of resends is incorrect.	Correct the number of resends.	
C0D2 _H	The arrival monitoring time is incorrect. The number of relay stations in CC-Link IE Controller Network, CC-Link IE Field Network, MELSECNET/H, and MELSECNET/10 exceeded the allowable range.	Correct the arrival monitoring time. Check the specified value for the communication destination. Correct the settings in the Station No. <-> IP information for the stations between the own station and the communication destination.	
C0D4 _H	The number of relay stations in CC-Link IE Controller Network, CC-Link IE Field Network, MELSECNET/H, and MELSECNET/10 exceeded the allowable range.	Check the specified value for the communication destination. Correct the settings in the Station No. <-> IP information for the stations between the own station and the communication destination.	
C0D5 _H	The number of retries is incorrect.	Correct the number of retries.	
C0D6 _H	The network number or station number is incorrect.	Correct the settings for the communication destination. Correct the specified value for the communication destination.	

Error code	Error description	Action
C0D7 _H	Data were sent without the initial process completed.	Set the parameters with the programming tool and write them to the CPU module. Then perform communications with the connected device. Wait for normal completion of the initial process before performing communications with the connected device.
C0D8 _H	The number of blocks exceeded the range.	Correct the specified value for the number of blocks.
C0D9 _H	The subcommand value is incorrect.	Correct the specified value for the subcommand.
C0DA _H	A response to the PING test could not be received within the time of the communication time check.	Correct the IP address and host name of the Ethernet module where the PING test is executed. Enable the Ethernet module where the PING test is executed to perform communications. (Complete the initial process.)
C0DB _H	The IP address and host name of the Ethernet module for	Correct the IP address and host name of the Ethernet
OODDH	the PING test are incorrect.	module to perform the PING test.
C0DC _H	System error (The OS detected an error.)	 Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C0DD _H	System error (The OS detected an error.)	 Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C0DE _H	Data could not be received within the specified arrival monitoring time.	 Correct the specified arrival monitoring time. Correct the specified channel number. Check the status of the send source station and relay station.
C0DF _H	System error (The OS detected an error.)	 Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.

Error code	Error description	Action
C0E0 _H	An error was detected in the programmable controller CPU.	Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.
C0E1 _H	An error was detected in the programmable controller CPU.	Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.
C0E2 _H	An error was detected in the programmable controller CPU.	Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.
C0E3 _H	An error was detected in the programmable controller CPU.	Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.
C0E4 _H	An error was detected in the programmable controller CPU.	Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.
C0E5 _H	An error was detected in the programmable controller CPU.	Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.

Error code	Error description	Action
C0E6 _H	An error was detected in the programmable controller CPU.	 Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.
C0E7 _H	An error was detected in the programmable controller CPU.	 Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.
C0E8 _H	An error was detected in the programmable controller CPU.	Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.
C0E9 _H	An error was detected in the programmable controller CPU.	Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.
C0EA _H	An error was detected in the programmable controller CPU.	 Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.
C0EB _H	An error was detected in the programmable controller CPU.	 Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.

Error code	Error description	Action
C0EC _H	An error was detected in the programmable controller CPU.	Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.
C0ED _H	An error was detected in the programmable controller CPU.	 Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.
C0EE _H	An error was detected in the programmable controller CPU.	Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.
C0EF _H	An error was detected in the programmable controller CPU.	Check that the programmable controller CPU and each intelligent function module are properly connected. Check that the programmable controller CPU is not in the reset status. Check if an error exists in the programmable controller CPU. If an error exists, take the action required to correct it. Replace the power supply module, programmable controller CPU, or intelligent function module.
C0F0 _H	An Ethernet module RAM error was detected in the hardware test (H/W test).	Perform the hardware test again. If an error occurs again, the Ethernet module may have a hardware error. Please consult your local Mitsubishi representative.
C0F1 _H	An Ethernet module ROM error was detected in the hardware test (H/W test).	 Perform the hardware test again. If an error occurs again, the Ethernet module may have a hardware error. Please consult your local Mitsubishi representative.
C0F3 _H	A system error (major error) was detected in the CPU module.	Remove the error cause of the CPU module in the own station.
C0F4 _H	System error (The OS detected an error.)	• Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.

Error code	Error description	Action
C0F5 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C0F6 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C0F7 _H	An error has occurred in the self-loopback test.	Because there may be congestion of packets on the line, send data from the connected device after a certain period of time. Check if the cable is disconnected. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C0F8 _H	System error (The OS detected an error.)	Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C100 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C101 _H	A response could not be received from the DNS client.	Check the address of the DNS server. Check if communications with the DNS server can be performed using the PING command. Check if the IP addresses of the own station and the DNS server belong to the same class. (If they belong to different classes, check the router setting.)

Error code	Error description	Action
C102 _H	A response from the SMTP layer could not be received.	Check if the SMTP server name has been registered in the DNS. Delete the SMTP server name and change the setting to the IP address setting. Then check the operation. Check if communications with the SMTP server can be performed using the PING command.
C103 _H	System error (The OS detected an error.)	• Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C104 _H	System error (The OS detected an error.)	• Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C105 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C106 _H	System error (The OS detected an error.)	Pollow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.

Error code	Error description	Action
C110 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C111 _H	A response could not be received from the DNS client.	Check the cables and hubs. Check if communications with the DNS server can be performed using the PING command.
C112 _H	A response from the POP3 layer could not be received.	 Check if the POP3 server name has been registered in the DNS. Delete the POP3 server name and change the setting to the IP address setting. Then check the operation. Check if communications with the POP3 server can be performed using the PING command.
C113 _H	An e-mail without an attachment was received. (This error occurs when an attachment is not read normally.)	 Specify the attachment on the sending side. Check the program on the sending side. If data sending using the MSEND instruction previously failed with the sending source of the mail server, check the destination of the MSEND instruction. Check if the e-mail specifications, such as the encoding/decoding style and file format, on the sending side are the same as those for the Ethernet module. Receive an e-mail with an unknown destination and unknown destination server from the SMTP server.
C114 _H	An e-mail that was received has an attachment with an invalid name.	 Check if the file extension of the attachment is "bin" or "asc" on the sending side. Check that the e-mail is not compressed or encrypted. Check the destination of the MSEND instruction. Receive an e-mail with an unknown destination and unknown destination server from the SMTP server.
C115 _H	System error (The OS detected an error.)	• Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.

Error code	Error description	Action
C116 _H	System error (The OS detected an error.)	Pollow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C117 _H	System error (The OS detected an error.)	• Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C118 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C119 _H	There is no received mail.	 Read Mail information storage area (address: 2682_H) of the buffer memory and read received e-mails remaining on the server.
C11A _H	The received mail failed to be converted.	Check that the e-mail is not compressed or encrypted. Check if the e-mail specifications, such as the encoding/decoding style and file format, on the sending side are the same as those for the Ethernet module. Check if the sending side has not divided the file.
C11B _H	An e-mail was sent and an error mail was received from the mail server of the destination.	 Receive an e-mail with an unknown destination and unknown destination server from the SMTP server. (The received mail is stored in the mail buffer.) Check if the portion before "@" is correct in the mail address setting in the parameter settings. Check if the portion before "@" has been registered on the destination mail server.
C11D _H	The attachment size exceeded the allowable size.	 Check if the attachment size is 6K words or less. Check that the sending side has not divided the attachment.
C120 _H	The SMTP server could not be opened.	Check that the port number of the SMTP server is 25. Check if communications with the SMTP server can be performed using the PING command.
C121 _H	Communications cannot be performed with the SMTP server. (Error response)	Check if the SMTP server is busy.

Error code	Error description	Action
C122 _H	Communications cannot be performed with the SMTP server. (Abort)	Check if the SMTP server is busy.
C123 _H	Communications cannot be performed with the SMTP server. (Reset response)	Check if the SMTP server is busy.
C124 _H	A response from the SMTP server timed out.	Check for an error in the SMTP server. Check if the network is heavily loaded.
C125 _H	Forcefully disconnected from the SMTP server	Check for an error in the SMTP server. Check if the network is heavily loaded.
C126 _H	The SMTP server could not be closed.	Check for an error in the SMTP server. Check if the network is heavily loaded.
C127 _H	Closing the SMTP server gave an error response.	Check for an error in the SMTP server. Check if the network is heavily loaded.
C130 _H	The communication channel is closed because the service is not available.	Check the status of the SMTP server.
C131 _H	The SMTP server is in process, and an error response was received.	Check that a user name not registered in the server has not been specified. Send the e-mail again after a certain period of time.
C132 _H	The SMTP server is in process, and an error response was received. (Local error)	Check the status of the SMTP server.
C133 _H	The SMTP server is in process, and an error response was received. (Insufficient memory area)	Check the status of the SMTP server.
C134 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C135 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C136 _H	System error (The OS detected an error.)	• Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.

Error code	Error description	Action
C137 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C138 _H	The SMTP server is in process, and an error response was received. (Mailbox not found)	Check if the mail address of the Ethernet module has been correctly set.
C139 _H	System error (The OS detected an error.)	 Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C13A _H	The SMTP server is in process, and an error response was	Check the status of the SMTP server.
C13B _H	received. (Exceeded the allocation of the memory area) The SMTP server is in process, and an error response was received. (Illegal mailbox name)	Check if the mail address of the Ethernet module has been correctly set.
C13C _H	System error (The OS detected an error.)	Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C140 _H	The POP3 server could not be opened.	Check that the port number of the POP3 server is 110. (The port number of the Ethernet module is fixed to 110.) Check if communications with the POP3 server can be performed using the PING command.
C141 _H	Communications cannot be performed with the POP3 server. (Error response)	Check if the POP3 server is busy.
C142 _H	Communications cannot be performed with the POP3 server. (Abort)	Check if the POP3 server is busy.
C143 _H	Communications cannot be performed with the POP3 server. (Reset response)	Check if the POP3 server is busy.
C144 _H	A response from the POP3 server could not be received.	Check for an error in the POP3 server. Check if the network is heavily loaded.
C145 _H	Forcefully disconnected from the POP3 server	Check for an error in the POP3 server.
C146 _H	The POP3 server could not be closed.	Check for an error in the POP3 server. Check if the network is heavily loaded.

Error code	Error description	Action
C147 _H	Closing the POP3 server gave an error response.	Check for an error in the POP3 server.
C150 _H	POP3 server verification error	Check the status of the POP3 server.
C151 _H	The Ethernet module's mail address (e-mail setting parameter) is different from the account name in the mailbox on the server side.	Check the account name of the mailbox on the server side and correct the account of the mailbox set in the Ethernet module.
C152 _H	The Ethernet module's password (e-mail setting parameter) is different from the password on the server side.	Check the password on the server side and correct the password of the Ethernet module.
C153 _H	An error has occurred in acquisition of the received mail list. (The list of the mail that arrived at the POP3 server failed to be acquired.)	Reset the server inquiry time to the default value and restart the CPU module of the own station.
C154 _H	An error has occurred upon receiving a mail. (An e-mail cannot be read from the POP3 server.)	Check that the e-mail is not compressed or encrypted. Check if the e-mail specifications, such as the encoding/decoding style and file format, on the sending side are the same as those for the Ethernet module.
C160 _H	A response was received from the DNS server after timeout.	Check if the network is heavily loaded. Check the status of the DNS server.
C161 _H	A response from the DNS server could not be received.	Check the status of the DNS server. Check if the network is heavily loaded. Check the status of the DNS server.
C162 _H	System error (The OS detected an error.)	 Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C163 _H	System error (The OS detected an error.)	 Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.
C171 _H	An error was returned from the DNS server.	Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.
C172 _H	An error was returned from the DNS server.	 Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.

Error code	Error description	Action
C173 _H	An error was returned from the DNS server.	Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.
C174 _H	An error was returned from the DNS server.	Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.
C175 _H	An error was returned from the DNS server.	Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.
C176 _H	An error was returned from the DNS server.	 Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.
C177 _H	An error was returned from the DNS server.	Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.
C178 _H	An error was returned from the DNS server.	Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.
C179 _H	An error was returned from the DNS server.	Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.
C17A _H	An error was returned from the DNS server.	 Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.
C17B _H	An error was returned from the DNS server.	Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.

Error code	Error description	Action
C17C _H	An error was returned from the DNS server.	 Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.
C17D _H	An error was returned from the DNS server.	 Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.
C17E _H	An error was returned from the DNS server.	 Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.
C17F _H	An error was returned from the DNS server.	Check if the IP address of the DNS server is correct. Check if the mail server names (SMTP server names and POP server names) are correct. Check with the network administrator if the DNS function of the server specified in the DNS setting is properly operating.
C180 _H	The device specified in "Condition Device" in "News Setting" is outside the range set in the [Device] tab of the PLC parameter window.	Correct the device settings in the PLC parameter window and specify the condition devices within the range of the device settings.
C1A0 _H	An illegal request was made.	Try again. If the same error occurs, the Ethernet module may have a hardware error. Please consult your local Mitsubishi representative.
C1A2 _H	A response to the request could not be received.	Check and correct the response waiting time.
C1A4 _H	A request or subrequest is incorrect.	Correct the request and subrequest.
C1A5 _H	The specified target station or clear target is incorrect.	Correct the specified target station or clear target.
C1A6 _H	The specified connection number is incorrect.	 Specify the connection number within the range of 1 to 16. Do not select the connection number 8 or 16 when using the pairing open method.
C1A7 _H	The specified network number is incorrect.	Correct the specified network number.
C1A8 _H	The specified station number is incorrect.	Correct the specified station number.
C1A9 _H	The specified device number is incorrect.	Correct the specified device number.
C1AA _H	The specified device name is incorrect.	Correct the specified device name.
C1AC _H	The specified number of resends is incorrect.	Correct the number of resends.
C1AD _H	The specified data length is incorrect.	Correct the specified data length.
C1AE _H	The send/receive data length and header length are incorrect.	Correct the specified send/receive data length and header length to values within the allowable ranges. The send/receive data length needs to be equal to or longer than the header length.
C1AF _H	The specified port number is incorrect.	Correct the specified port number.
C1B0 _H	The open process of the specified connection has been already completed.	Perform the close process before the open process.
C1B1 _H	The open process of the specified connection has not been completed.	Perform the open process.

Error code	Error description	Action	
C1B2 _H	The OPEN or CLOSE instruction is being executed in the specified connection.	Try again after the OPEN or CLOSE instruction is completed.	
C1B3 _H	Another send or receive instruction is being executed in the specified channel.	Change the channel number. Try again after the send or receive instruction is completed.	
C1B4 _H	The specified arrival monitoring time is incorrect.	Set the arrival monitoring time to a value within the allowable range.	
C1B5 _H	Data could not be received within the specified arrival monitoring time.	Correct the specified arrival monitoring time.	
C1B6 _H	The specified send mail address number is incorrect.	Correct the specified send mail address number. Correct the send mail address setting in the parameter setting.	
C1B7 _H	A reading operation was executed while no receiving e-mail was stored in the mail buffer data area.	If there is an mail received in the mail information, execute the MRECV instruction.	
C1B8 _H	The RECV instruction was executed for the channel that had not received data.	Correct the execution condition of the RECV instruction. Correct the channel number.	
C1B9 _H	The OPEN instruction cannot be executed for the specified connection.	Correct the connection number.	
C1BA _H	The dedicated instruction was executed with the initialization not completed.	Execute the dedicated instruction after the initial process is completed.	
C1BB _H	The target station CPU type is incorrect.	Correct the specified target station CPU type.	
C200 _H	The remote password is incorrect.	Correct the remote password, and unlock/lock the remote password again.	
C201 _H	The remote password status of the port used for communications is in the lock status.	After unlocking the remote password, perform communications.	
C202 _H	When another station was accessed, the remote password could not be unlocked.	When accessing another station, do not set the remote password on the relay station or access station or do not execute the remote password check on them.	
C203 _H	System error (The OS detected an error.)	Follow the procedure below. Check if the Ethernet module, the power supply module, and the CPU module are properly connected. Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. Check if the power capacity is sufficient. Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consequences.	
C204 _H	The device is different from the one requesting the remote password unlock.	Request the lock process of the remote password from the connected device that requested the unlock process of the remote password.	
C205 _H	When another station was accessed, the remote password could not be unlocked.	When accessing another station, do not set the remote password on the relay station or access station or do not execute the remote password check on them.	

Error code	Error description	Action	
C206 _H	System error (The OS detected an error.)	• Follow the procedure below. (1) Check if the Ethernet module, the power supply module, and the CPU module are properly connected. (2) Check if the operating environment of the Ethernet module conforms to the general specifications of the CPU module. (3) Check if the power capacity is sufficient. (4) Check if the hardware is normal according to the manual for each module. If the actions above do not solve the problem, please consult your local Mitsubishi representative.	
C207 _H	The file name has too many characters.	Name the file with 255 characters or less.	
C300 _H	A response could not be received within the response monitoring timer value.	Check the operation of the connected device. Correct the response monitoring timer value.	
C400 _H	Protocol not-ready error	Check that Predefined protocol ready (X1D) has turned on before executing the ECPRTCL instruction. Execute the ECPRTCL instruction after rewriting the protocol setting data to the Ethernet module. If an error still occurs even after rewriting, replace the module.	
C401 _H	Protocol unregistered error	 Correct the specified protocol number and execute the protocol again. Register the corresponding protocol to the specified protocol number. 	
C402 _H	Protocol setting data error	Correct the protocol setting data and register it again.	
C403 _H	Simultaneous dedicated instructions execution error	 Do not execute dedicated instructions which do not support simultaneous execution. Correct the specified connection number and execute the dedicated instruction again. 	
C404 _H	Protocol cancel request error	Check the canceled protocol in the control data of the ECPRTCL instruction (execution count result) and eliminate the cause of the cancellation.	
C405 _H	Protocol number setting error	Correct the specified protocol number and execute the protocol again.	
C406 _H	Continuous protocol execution count setting error	Correct the number of protocols to be executed continuously and execute the protocol again.	
C407 _H	Connection number setting error	 Correct the specified connection number and execute the protocol again. Correct the connection setting of the specified connection number and execute the protocol again. 	
C410 _H	Receive wait timeout error	 Check if the cable is disconnected. Correct the connection setting of the specified connection number and execute the protocol again. Check that there is no error in the connected device. Check that the sending from the connected device is not interrupted. Check that there is no data lost due to a receive error. Check that there is no error in the data (packet) sent by the connected device. 	
C411 _H	Packet size error	 Check the data sent by the connected device. To send data that exceeds 2046 bytes from the connected device, divide the data into several parts and send them separately. 	

Error code	Error description	Action	
C417 _H	Data length setting error, data quantity setting error	Check the maximum allowable data length and specify the maximum length or less in the data length storage area. Check the maximum allowable data quantity, and specify the maximum quantity or less in the data quantity storage area.	
C420 _H	Flash ROM write error	Write the data again. If an error still occurs even after rewriting, replace the module.	
C421 _H	Flash ROM write count over limit error	Replace the module because the number of writes exceeded the limit.	
C430 _H	Protocol setting data writing during the ECPRTCL instruction execution	If the ECPRTCL instruction is under execution, cancel the instruction and write the protocol setting data.	
C431 _H	Connection close during the ECPRTCL instruction execution	Check the operation of the connected device. Check the connection open status with the connected device. Open the connection with the connected device again and execute the instruction.	
D000 _H to	(Errors detected by CC-Link IE Field Network)	Refer to the manual for each module.	
E000 _H to	(Errors detected by CC-Link IE Controller Network)	Refer to the manual for each module.	
F000 _H to	(Errors detected by the MELSECNET/H and MELSECNET/10 network system)	Refer to the MELSECNET/H or MELSECNET/10 network system reference manual, and take corrective action.	


Remark

The error codes listed in the table include those returned to the connected device. Each buffer memory may also store the error numbers of the response messages returned from the connected device. If an error code other than those listed is stored, check the manual for the connected device and the response message from the connected device.

16.8 Ethernet Diagnostics

Items such as the module status, parameter settings, communication status, and error history of an E71 can be checked. Perform the diagnostics in the "Ethernet Diagnostics" window of the programming tool.

[Diagnostics]
 □ [Ethernet Diagnostics...]



Item	Description			
Target Module Setting (Module No.)	Specify the E71 to be monitored. The number of other network modules is not included.			
Parameter Status	Module information (such as the IP address and basic settings) is displayed.			
Error History	The number of errors and their details (such as the error code and information about the connection where the error has occurred) is displayed.			
Status of Each Connection	The status of each connection (such as error codes and the open setting) is displayed.			
Status of Each Protocol	Information such as the total number of data sending/receiving times for each protocol is displayed.			
LED Status	The operation mode and the LED status of the E71 are displayed.			
Received E-mail Information	Received mail information and the error log are displayed.			
Send E-mail Information	Sent mail information and the error log are displayed.			
PING Test button	The "PING Test" window is displayed.			
Loop Test button	The "Loopback Test" window is displayed.			
COM.ERR Off button	The COM.ERR. LED is turned off. (Fig. 293, Section 16.10)			




For each window and detailed explanations, refer to the following.

Operating manual for the programming tool used


16.9 Checking the Status of the E71 with the System Monitor

Open the system monitor window of a programming tool to check the LED status, connection status, and operating status of the E71.

- 1. Open the "System Monitor" window.
- 2. Select the module to diagnose in the "Main Block" field in the upper left of the window. Then click the HAW Information | button.



3. The "H/W Information" is displayed.




Item		Description			
Display Form	at	Switches the input format of "H/W LED Information" and "H/W SW Information".			
	INIT.				
	OPEN	Indicates the statuses of the LEDs on the E71.			
H/W LED	ERR.	0000: Off 0001: On			
Information	COM. ERR.	3001.011			
mormation	BUF1 to BUF16	Indicates the connection statuses of the connection numbers 1 to 16. 0000: Open not completed 0001: Open completed			
	NET NO.	Indicates the network No. of the E71.			
	GRP NO.	Indicates the group No. of the E71.			
	ST NO.	Indicates the station number of the E71.			
	MODE	Indicates the mode of the E71. 0000: Online 0001: Offline 0002: Self-loopback test 0003: H/W test			
H/W SW Information	CONFIG	Indicates the operating status of the E71, which has been set with a programming tool. b15 b9 b8 b7 b6 b5 b4 b3 b2 b1 b0 -			

16.10 How to Turn Off the COM.ERR. LED

The COM.ERR. LED turns on when an error occurs during communications with the connected device. The COM.ERR. LED does not turn off even after the error cause is removed. Turn it off using the following methods.

(1) Using an I/O signal

Turn off the COM.ERR. LED by turning on COM.ERR. LED OFF request (Y17). An off request continues to be issued while COM.ERR. LED OFF request (Y17) is on. However, this method does not clear the error information in the error log area in the buffer memory.



(2) Using a dedicated instruction

Turn off the COM.ERR. LED using the ERRCLR instruction. (Fig. 219, Section 15.11) This method can also clear the error information (initial error code, open error code) or the error log.

(3) In the "Ethernet Diagnostics" window

Turn off the COM.ERR. LED by clicking the commercial button in the "Ethernet Diagnostics" window. However, this method does not clear the error information in the error log area in the buffer memory. For the window, refer to "Ethernet Diagnostics".

(F Page 290, Section 16.8)

(4) Using the MC protocol

Turn off the COM.ERR. LED using the dedicated command for the MC protocol (LED off, Error code initialization: 1617). For details, refer to the following.

MELSEC Communication Protocol Reference Manual

APPENDICES

Appendix 1 Processing Time

Calculate the minimum processing time for each function using the expressions below. Note that the processing time may become longer depending on the load factor on the network (how congested the line is), the window size of each connected device, the number of connections, and system configuration. Use the values obtained from the expressions as a guideline for the processing time when communications are performed in only one connection.

(1) Minimum processing time of communications using a fixed buffer (communications between the E71s)

(a) Procedure exists

Tfs = St + Ke + $(Kdf \times Df)$ + Sr

Tfs	The time from the start of sending to the completion of sending (unit: ms)
St	Sending station scan time
Ke, Kdf	Constant (Refer to the table below.)
Df	Number of send data words
Sr	Receiving station scan time

	LJ71E71-100				
ltem	TCP/IP com	munications	UDP/IP communications		
	Ke	Kdf	Ke	Kdf	
Communications using a binary code	7.3	0.0033	6.2	0.0040	
Communications using an ASCII code	7.3	0.0082	6.2	0.0081	

(b) No procedures

Tfs = St + Ke + (Kdf \times Df)

Tfs	The time from the start of sending to the completion of sending (unit: ms)	
St	Sending station scan time	
Ke, Kdf	Constant (Refer to the table below.)	
Df	Number of send data bytes	

	LJ71E71-100				
Item	TCP/IP com	munications	UDP/IP communications		
	Ke	Kdf	Ke	Kdf	
Communications using a binary code	5.4	0.0010	3.8	0.0009	

[Calculation example]

The time between the E71 sending 1017-word data of a binary code and it completing the sending when the E71 communicates with another E71 in TCP/IP with the "Procedure Exist" method (unit: ms)

Assume that the scan time on the sending side is 10ms, and the scan time on the receiving side is 8ms.

• $28.6561 \text{ (ms)} = 10 + 7.3 + (0.0033 \times 1017) + 8$

(2) Minimum processing time of communications using a random access buffer

Trs = Kr + (Kdr × Df) + ACK processing time of a connected device (added only for TCP/IP communications)

Trs	The time between the E71 receiving request data from a personal computer and it completing the process (unit: ms)
Kr, Kdr	Constant (Refer to the table below.)
Df	Number of request data words
ACK processing time of the	The time between a random access buffer reading/writing completed and the
connected device	connected device returning ACK

Item			LJ71E71-100			
		TCP/IP con	TCP/IP communications		UDP/IP communications	
		Kr	Kdr	Kr	Kdr	
Reading	Communications using a binary code	2.0	0.0010	1.4	0.0012	
Reading	Communications using an ASCII code	2.0	0.0032	1.4	0.0033	
Writing	Communications using a binary code	2.0	0.0016	1.4	0.0018	
vviiting	Communications using an ASCII code	2.0	0.0056	1.4	0.0048	

[Calculation example 1]

The time between the E71 receiving request data from a personal computer and it completing reading when the E71 communicates with the personal computer in TCP/IP and reads 508-word data of a binary code from a random access buffer (unit: ms)

2.508 + ACK processing time of the connected device (ms) ≒ 2.0 + (0.0010 × 508) + ACK processing time
of the connected device

[Calculation example 2]

The time between the E71 receiving request data from a personal computer and it completing writing when the E71 communicates with the personal computer in TCP/IP and writes 508-word data of a binary code to a random access buffer (unit: ms)

2.8128 + ACK processing time of the connected device (ms) ≒ 2.0 + (0.0016 × 508) + ACK processing time
of the connected device


(3) Minimum processing time of MC protocol communications (batch reading and batch writing)

Tfs = Ke + (Kdt \times Df) + Scr \times number of scans required for the process + ACK processing time of the connected device

	The time between the E71 receiving request data from a personal computer and it completing	
Tfs	the process	
	(unit: ms)*1	
Ke, Kdt	Constant (Refer to the table below.)	
Df	Number of request data words + number of response data words (Application data part)	
	CPU module processing time	
Scr	Own station access: E71-connected station scan time	
	Another station access over MELSECNET/10: Transmission delay time + E71-connected	
	station scan time	

Item			LJ71E71-100			
		TCP/IP con	TCP/IP communications		UDP/IP communications	
		Ke	Kdt	Ke	Kdt	
Batch reading	Communications using a binary code	3.3	0.0022	2.6	0.0018	
	Communications using an ASCII code	3.3	0.0046	2.7	0.0046	
Batch writing	Communications using a binary code	3.3	0.0024	2.6	0.0033	
	Communications using an ASCII code	3.3	0.0073	2.7	0.0070	

^{*1} The time from when the E71 receives the request data from the personal computer until it completes the process is shown below.



[Calculation example 1]

The time between the E71 receiving request data from a personal computer and it completing reading when the E71 communicates with the personal computer in TCP/IP and reads 100-point data of an ASCII code from the data register (D) in the own station (unit: ms)

Assume that the scan time of the E71-connected station is 10ms, the command data length is 21 words, and the response data length is 211 words.

14.37 + ACK processing time of the connected device (ms)

 = 3.3 + (0.0046 × (21 + 211)) + 10 × 1 + ACK processing time of the connected device

[Calculation example 2]

The time between the E71 receiving request data from a personal computer and it completing writing when the E71 communicates with the personal computer in TCP/IP and writes 100-point data of an ASCII code to the data register (D) in the own station (unit: ms)

Assume that the scan time of the E71-connected station is 10ms, the command data length is 221 words, the response data length is 11 words, and writing during RUN is enabled.

14.99 (ms) + ACK processing time of the connected device
 ≒ 3.3 + (0.0073 × (221 + 11)) + 10 × 1 + ACK processing time of the connected device

(4) Processing time of the dedicated instructions

The following table lists approximate operation processing time of each dedicated instruction. The operation processing time differs depending on the system configuration and the scan time on the sending/receiving stations.

	Number of access points		Processing time (unit: ms) LCPU		Instruction execution condition
Instruction name					
	Condition 1)	Condition 2)	For 1)	For 2)	
BUFRCV			0.80	1.16	
BUFRCVS	1 word	1 word words		0.61	TCP/IP communications, binary code communications, and fixed buffer communications (procedure exists)
BUFSND		Words	7.44	10.80	bullet communications (procedure exists)
CLOSE	1 p	ort	2	.36	A UDP/IP transmission port is closed.
ERRCLR	All error informa	ation is cleared.	1	.06	_
ERRRD	An initial error	code is read.	1	.04	_
OPEN	1 p	ort	2	.12	A UDP/IP transmission port is open.
RECVS		960 words	0.23	0.62	
RECVS		480 words		0.42	
READ		960 words	7.00	12.50	
READ	READ	480 words	7.20	9.84	
SREAD	960 words 7.28 12.60	12.60			
SKEAD		480 words	1.20	9.92	Communications between E71-connected stations
RECV		960 words	2.00	Communications between E71-connected stations	
RECV	1 word	480 words	1.30	1.86	
SEND		960 words	4.64	8.32	
SLIND		480 words		6.32	
WRITE		960 words	7.28	13.00	
WINITE		480 words		9.84	
SWRITE		960 words	7.36	13.00	
OWNTE		480 words	7.36	10.20	
ZNRD		230 words	7.12	7.84	
ZNWR		230 Words	7.04	8.48	
UINI	_	_	11	1.20	Time between the UINI instruction accepted and reinitialization completed (X19 turning on)
ECPRTCL	*1			_	

^{*1} The processing time of the ECPRTCL instruction differs depending on a connected device or a protocol.

Appendix 2 Port Numbers Used for the E71

Appendix 2 Port Numbers Used for the E71

The following table lists port numbers reserved for an E71 system.

Port number	Application
1388 _H (5000)	Auto-open UDP port (Default value)*1
1389 _H (5001) MELSOFT application transmission port (UDP)	
138A _H (5002)	MELSOFT application transmission port (TCP)

^{*1} The port number can be changed.

The port number can be changed by overwriting the buffer memory address, Automatic open UDP port number (address: 20 (14_H)).

Appendix 3 New and Improved Functions

The following table lists the new and improved functions in the E71 and supported versions of modules and programming tool.

[How to see the table]

· Numbers in quotation marks in the table represent the first five digits of the serial number of each module.

 \bigcirc : Available (No version restriction), \times : Not available

Function	Version of E71	Version of CPU module	Version of GX Works2	Reference
Communications using SLMP	Function version A or later of "15042"	0 0		Page 88, CHAPTER 10
Data communications using the predefined protocol	Function version A or later of "15042"	0	Version 1.492N or later	Page 94, CHAPTER 11
Setting range extension of the communication destination port number (Port number 1 (1 _H) to 1024 (400 _H) can be set.)	Function version A or later of "15042"	0	Version 1.492N or later	Page 63, CHAPTER 7
Receive buffer full detection signal (address: 21056 (5240 _H))	Function version A or later of "17032"	0	0	Page 35, Section 3.5.2

Appendix 4 Initial Process

The initial process is for enabling data communications with connected devices by setting the minimum number of parameters for the E71.

In the MELSEC-L series, the initial process is performed automatically.

(1) Checking the initial process result

The results of the initial process can be checked using the LEDs and I/O signals.

Initial process	INIT.LED	Initial normal completion signal (X19)	Initial abnormal completion signal (X1A)
Upon normal completion	ON	ON	OFF
Upon abnormal end	OFF	OFF	ON


If the initial process is not normally completed, correct the set values of parameters listed in Chapter 7 and those in the initial process setting parameter described in this chapter. After correcting the parameters, write them to the CPU module again, power off and on the CPU module or reset the CPU module.

Appendix 4.1 Setting the initial process

Configure the setting in the initial setting window. Each setting time is calculated by "setting value × 500ms".

Project window ⇔ [Parameter] ⇔ [Network Parameter] ⇔ [Ethernet/CC IE Field] ⇔ Select

"Ethernet" under "Network Type". ⇔ Initial Setting button



	Item	Description	Setting range
	TCP ULP Timer	Set Time to Live during packet sending in TCP/IP.	2 to 32767
Timer Setting	TCP Zero Window Timer	Set the receive buffer value on the recipient. If the receive buffer on the recipient has no free space (window size = 0), data sending is waited until the recipient has free receive buffer space. At this time, the sender sends packets for checking the sending window to the recipient according to the TCP zero window timer value to check the receiving status.	
	TCP Resend Timer	Set the time to resend ACK if it is not returned when a connection is opened or data is sent in TCP/IP. This timer is also used for Time to Live for the ARP function. (ARP is resent by the time of "TCP resend timer value/2" if no response to an ARP request is returned.) This timer is also used as the minimum set time for arrival monitoring time for data link instructions.	2 to 32767
	TCP End Timer	When closing the TCP/IP connection by the own station, set the monitoring time for waiting for a FIN from the connected device after the own station sends a FIN and an ACK is returned from the connected device. If a FIN is not received from the connected device within the time specified by the TCP end timer value, a RST is sent to the connected device and the connection is forcibly closed.	2 to 32767
	IP Assembly Timer	The communication data may be divided at the IP level before being sent due to the buffer limitation of the sending station or the receiving station. Set the waiting time for the divided data in such a case.	1 to 32766
	Response Monitoring Timer	Set the following waiting time. • Time for waiting a response after a command is sent • For receiving divided messages, time until the last message is received after the first message is received	2 to 32767
	Dest. Confirmation Start Interval	Set the time until starting the alive check after communications with the connected device of the connection that has been opened where the alive check target exists is lost.	1 to 32767
	Dest. Confirmation Interval	For the connection that is opened where the alive check target exists, set the interval to perform the alive check again when a response from the connected device as the alive check target is not received.	1 to 32767
	Dest. Confirmation Resend	For the connection that has been opened where the alive check target exists, set the number of times that the alive check is performed again when a response from the connected device as the alive check target is not received.	1 to 32767
	Input Format	Select an input format.	DEC/HEX
5110	IP Address of DNS Server1		
DNS Sotting*1	IP Address of DNS Server2	Sat the ID address of each DNS server	_
Setting ^{*1}	IP Address of DNS Server3	Set the IP address of each DNS server.	
	IP Address of DNS Server4		

^{*1} The DNS setting is configured for using the e-mail function. For details, refer to the following.

MELSEC-Q/L Ethernet Interface Module User's Manual (Application)

(1) Precautions for settings

· Specify the setting value of each timer on the E71 side so that the following formula is met.

$$\left(\begin{array}{c} \text{Response} \\ \text{monitoring} \\ \text{timer value} \end{array} \right) \geq \left(\begin{array}{c} \text{TCP ULP} \\ \text{timer value} \end{array} \right) \geq \left(\begin{array}{c} \text{TCP end} \\ \text{timer value} \end{array} \right) \geq \left(\begin{array}{c} \text{TCP} \\ \text{resend} \\ \text{timer value} \end{array} \right) > \left(\begin{array}{c} \text{IP} \\ \text{assembly} \\ \text{timer value} \end{array} \right)$$

$$\left(\begin{array}{c} \text{TCP} \\ \text{resend} \\ \text{timer value} \end{array} \right) = \left(\begin{array}{c} \text{TCP zero window} \\ \text{timer value} \end{array} \right)$$

When connecting Mitsubishi products to the line, configure the same settings for both modules.

Specify the setting value of each timer on the connected device side so that the following formula is met. The
frequency of a communication error, such as a transmission timeout, may be higher if the timer values do not
meet the formula.


*1 "n" is the number of TCP segment transmission and is calculated by the following formula.

- The number of TCP segment transmission when communications are performed on the same line
 The Maximum Segment Size is 1460 bytes on the same line (without a router) and the number of TCP
 Segment transmission is as follows.
 - n = 1 when the size of the message sent by the E71 is 1460 bytes or less
 - n = 2 when the size of the message sent by the E71 is greater than 1460 bytes
 - The number of TCP segment transmission when communications are performed on a different line. The Maximum Segment Size is at least 536 bytes on another line (via a dialup router or other communication device) and the number of TCP Segment transmission is as follows.
 - n = 1 when the size of the message sent by the E71 is 536 bytes or less
 - n = 2 when the size of the message sent by the E71 is greater than 536 bytes and no more than 1072 bytes
 - n = 3 when the size of the message sent by the E71 is greater than 1072 bytes and no more than 1608 bytes

 When a communication failure occurs due to a problem such as noise, change the value so that the number of retries may increase. The number of retries is obtained using the following formula. (When using the default values, 3 = (60 ÷ 20))

Number of retries = TCP ULP timer value ÷ TCP resend timer value

When the number of retries is three and data sending fails, a data sending error occurs at the timing shown in the figure below (in communications using the fixed buffer).



A: TCP resend timer value (The time at which data are sent when ACK is not returned after data transmission)

• When not performing the above retry process (set 0 times), configure the setting so that the following formula is met.

$$\left(\begin{array}{c} \mathsf{TCP} \ \mathsf{ULP} \\ \mathsf{timer} \ \mathsf{value} \end{array} \right) \ = \ \left(\begin{array}{c} \mathsf{TCP} \ \mathsf{end} \\ \mathsf{timer} \ \mathsf{value} \end{array} \right) \ = \ \left(\begin{array}{c} \mathsf{TCP} \ \mathsf{resend} \\ \mathsf{timer} \ \mathsf{value} \end{array} \right)$$

(Set the same value for the timer values.)

Appendix 4.2 Reinitialization process

The reinitialization process sets the E71 to the status after startup without restarting the programmable controller (or resetting the CPU module). Perform the reinitialization process using a program.

(1) The purpose of a reinitialization process

The purpose of a reinitialization process is described.

(a) To update address information of a connected device held by the E71

To prevent other devices from illegally accessing the programmable controller using the IP address of the connected device with which communications are normally performed, the E71 holds the IP address of the connected device and the corresponding MAC address.*1 If a module or the board of the connected device is replaced due to a failure, the address information of the connected device held by the E71 must be cleared by the reinitialization process.

*1 A MAC address is unique to a device. No devices share the same MAC address.

(b) To change the IP address of the E71 on the own station

When a system is changed, by only changing the own station IP address set by the programming tool, communications with the connected device can be resumed.

(c) To change the Ethernet operation setting

By changing the communication conditions in the Ethernet operation setting set using the programming tool, communications with the connected device can be resumed.


(d) To change the transmission speed and communication mode

By changing the transmission speed and communication mode, communications with the connected device can be resumed.

(2) Program for the reinitialization process

Perform the reinitialization process using a program. The following shows the process timing and sample programs.

(a) Process timing



- Check the normal completion of the initial process. (Initial normal completion signal (X19): ON)
- Terminate all data communications with the connected devices and perform a close process on all connections.
- 3 Execute the UINI instruction. Specify the parameters (such as the IP address of the own station and Ethernet operation setting) using the control data of the dedicated instruction and initialize the E71.
- When the E71 reinitialization request is completed, Initial normal completion signal (X19) turns off.
- When the reinitialization processes are all completed, Reinitialization specification (address: 1F_H (b15) turns "0" and Initial normal completion signal (X19) turns on. If the reinitialization process fails, an error code is stored in the initial error code storage area.

(b) Sample program

The following two methods are available:

- · Using the dedicated instruction (UINI instruction)
- · Writing directly to the buffer memory



Do not use the method using the dedicated instruction (UINI instruction) and the method by writing directly to the buffer memory together.

(c) Using the dedicated instruction (UINI instruction)


The following shows an example where the reinitialization process is performed using the UINI instruction and the OPEN instruction is executed after the process is completed. (When the I/O signals of the E71 are X/Y00 to X/Y1F)


```
SM400
                                                                            U0\
                                                                   √MOV
                                                                             G20480
                                                                                       K4M0
                                                                            U0\
                                                                             G20482
                                                                                       K4M20
M6500
                                                                             SET
                                                                                       M2500
 ╢
M2500
          X19
                    M0
                              M1
                                                                   - MOV
                                                                             K2
                                                                                       D252
                                                                            U0\
                                                                   - MOV
                                                                                       D255
                                                                             G203
                                                                             SET
                                                                                       D255.6
                                                          ZP.UINI
                                                                    U0
                                                                             D250
                                                                                       M250
                                                                             RST
                                                                                       M2500
                                                                             RST
                                                                                       M3001
M250
          M251
                                                                       Process upon completion
                                                                                       M3000
          M251
                                                                     Process upon abnormal end
```

```
M3000 U0\G31.F
                         U0\
G105
                                   H0
                                                                         Process upon completion
                                                                               -[RST
                                                                                         M3000
                                                                               _[SET
                                                                                         M3001
                         U0\
                         G105
                                   H0
                                                                        Process upon abnormal end
M1000
         M3001
                   X19
                             M0
                                      M20
                                                                      MOVP
                                                                               Н0
                                                                                         D100
                                                     ZP.OPEN U0
                                                                      K1
                                                                               D100
                                                                                         M100
M100
         M101
          #
                                                                         Process upon completion
                                                                         Communications enabled
         M101
                                                                       Process upon abnormal end
```

(d) Writing directly to the buffer memory

The following shows an example where the stored values in the TCP Maximum Segment Transmission setting area and Communication condition setting (Ethernet Operation Setting) area is changed (when the I/O signals of the E71 are X/Y00 to X/Y1F). Create a program with a contact (such as a flag for user) indicating the status of the open completion signal storage area.





Remark

This is a sample program for communications using connection numbers 1 and 2. When using another connection number, specify the corresponding signals and bits.

(3) Precautions

(a) Buffer memory area settings

The following parameters operate according to the settings of the corresponding buffer memory areas configured when a reinitialization process is performed. Therefore, do not change the settings of the buffer memory areas.

- · Timer setting of the initial setting
- · Open setting
- · Router relay parameter setting
- Station number <-> IP information setting
- · FTP parameters setting

(b) Reinitialization process request

Do not request another reinitialization process while a reinitialization process is in progress.

Appendix 5 Line Status Check

The E71 line status, parameter settings, and progress of the initial process can be checked. The following two methods can be used to check the line status.


- · PING test
- · Loopback test

Appendix 5.1 PING test

This section describes the PING test.

(1) Performing a test with direct connection to the E71

This test is to check the existence of an E71 that has completed the initial process on the same Ethernet network using the programming tool or to check the existence of a connected device, such as a personal computer, having a specified IP address.




(a) Applications


The line status between the programming tool (personal computer) and the E71 can be checked.


(b) Operating procedure

Use the following procedure.



1. Click the PING Test button in the "Ethernet Diagnostics" window.






2. Configure the settings and click the Execute button.



3. Click the Yes button.

4. The test results are displayed.




(c) Action for abnormal end

If the test fails, check the following and perform the test again.

- · Whether the E71 is properly connected
- · Connection to the Ethernet network
- · Parameter settings written in the CPU module
- Operating status of the CPU module (whether or not an error has occurred)
- · IP addresses set in the programming tool and the PING test target station
- · Whether the connected device has been reset after the E71 was replaced

(2) Performing a test with direct connection to the CPU module

This test is to check the existence of an E71*1*2, that has completed the initial process on the same Ethernet network where a station connected to the programming tool exists or to check the existence of a connected device, such as a personal computer, having a specified IP address, by directly connecting the programming tool and the CPU module.




- *1 This also applies to Q/QnA/A series modules. However, for an AJ71E71, AJ71E71-B2, and AJ71E71-B5, software versions S and later are required.
- *2 The PING test cannot be executed on the own station.

(a) Applications

By specifying the execution station and the target station, the PING test can be executed from a remote device.


(b) Operating procedure

Use the following procedure.




1. Click the PING Test button in the "Ethernet Diagnostics" window.


C [Diagnostics] ⇔ [Ethernet Diagnostics] ⇔
"Target Module Setting" under "Module No."



2. Configure the settings and click the button.



3. Click the Yes button.



4. The test results are displayed.

(c) Action for abnormal end

If the test fails, take the same action as that for the method using direct connection to the E71. (Fig. Page 312, Appendix 5.1 (1))

(3) Performing a test with the PING command

The PING test can be also executed using the PING command. The following shows an example of checking whether the initial process has been completed by issuing a PING command to the E71 of the own station from a connected device in the same Ethernet network.

[Specification method] ping IP Address
When the IP address of an E71 is 192.168.3.40
(Window upon normal completion)

C:\Ding 192.168.3.40

Pinging 192.168.3.40 with 32 bytes of data:

Request timed out.

Request timed out.

Request timed out.


Request timed out.

Pring tabletics for 192.168.3.48:

Packets: Sent = 4, Received = 8, Lost = 4 (198% loss),

C:\D_

(Window upon abnormal end)



(a) Action for abnormal end

If the test fails, check the following and perform the test again.


- · Whether the E71 is properly connected
- · Connection to the Ethernet network
- · Parameter settings written in the CPU module
- Operating status of the CPU module (whether or not an error has occurred)
- · IP address of the destination E71 specified using the PING command

Appendix 5.2 Loopback test

This section describes the loopback test.

(1) Performing a test using a programming tool

This test is to check whether the initial process for each module has been completed. The test is executed on the network of stations connected to the programming tool, and loopback test messages are sent sequentially to each E71*1 on the network and in the station number range specified for the loopback test request designation.



^{*1} Because the QJ71E71-100 of function version A and QnA/A series modules do not have a function for responding to this request, the test results cannot be checked.

(a) Applications


The test can be executed only by specifying the network number for the test and target station number range.




For the E71-connected station subjected to the loopback test, do not specify the MELSOFT application transmission port (UDP/IP) as a valid port for the password check. The loopback test cannot be executed.


(b) Operating procedure

Use the following procedure.



1. Click the Loop Test button in the "Ethernet Diagnostics" window.





2. Configure the settings and click the button to display the test results.



If the same IP address or station number is assigned to multiple stations, only the results of the station that responds first are displayed.

(c) Action for abnormal end

If the loopback test fails, "No response" or an error code is displayed.

Displayed test result	Status of the target E71	Cause	Action	
IP address	Initial processing normal completion status (INIT. LED turns on.)	Normal completion	_	
	No error	The initial process for the target E71 has not been completed normally.	Correct the following parameter settings. Basic setting Ethernet operation setting Initial setting	
		There is an error, such as cable disconnection and line disconnection, in the line connection to the target E71.	Check the cable.	
		The IP address of the target E71 is incorrect. (The class or subnet address differs from that of the E71.)	Correct the set values of the Ethernet operation settings.	
No response		The same IP address has been set to multiple target E71 modules.		
		The same network number or station number has been set to multiple target E71 modules.	Perform the PING test on the "No response" module. When the test is completed normally, correct the set values in the basic settings.	
	No error/Error exists	The Ethernet line is heavily loaded (including a case where an error equivalent to the error codes C030 _H and C031 _H is occurring).	When the Ethernet line is not heavily loaded, perform the test again.	
	Error exists	The routing parameter is not set (an error equivalent to the error code C080 _H is occurring).	Correct the set value of the routing parameter.	
	No error	The MELSOFT application transmission port (UDP/IP) for the target E71 is locked with the remote password.	Disable the remote password setting and write the parameter to the CPU module.	
Error code		The target E71 is a function version A module.	Check the module name and function version.	
	No error/Error exists	The Ethernet line is heavily loaded (including a case where an error equivalent to the error codes C030 _H and C031 _H is occurring).	When the Ethernet line is not heavily loaded, perform the test again.	


Point P

For an E71 where the loopback test failed, check the error and take corrective action. Then restart the E71-connected station. Restarting the E71 executes the initial process. To check whether the initial process has been completed in the E71, perform the PING test. The PING test can be also performed on the "Loopback Test" window.

(2) Performing a test using the MC protocol

The loopback test can be also executed using MC protocol communications. Note, however, that only the E71 in the own station can be used. The test cannot be executed on E71 modules in other stations over the network. For details, refer to the following.

MELSEC Communication Protocol Reference Manual



(a) Execution method

Execute the test using the MC protocol dedicated command (Loopback test: 0619).



When the user port on the E71 side is used to perform MC protocol communications, the line connection process is necessary. Execute the open process for the connection used for the E71 side.

Appendix 6 Self-Diagnostic Tests


This section describes the self-diagnostic tests to check data communications and hardware of an E71.

Appendix 6.1 Self-loopback test

Hardware including the E71 communication circuit is checked. Send the test message destined to the own station of the E71 to the line. Then check whether the same message can be received over the network.

(1) Operating procedure

Use the following procedure.



- 1. Connect the E71 to the line. *1
- 2. Set the switch on the CPU module to "STOP".
- Select "Self-Loopback Test" under "Mode" and write the parameter to the CPU module.
 - Project window ⇔ [Parameter] ⇔ [Network Parameter] ⇔ [Ethernet/CC IE Field] ⇔ Select "Ethernet" under "Network Type".

- 4. Resetting the CPU module starts the test. Test time is approximately five seconds. The RUN and OPEN LEDs turn on during the test.
- Check the LED of the E71 after five seconds. When the test is running normally, the RUN LED turns on. If the test fails, the RUN and ERR. LEDs turn on.
- *1 When the line is not connected, the self-loopback test is not performed and ends normally.

If an error is detected in the self-loopback test, the following causes are possible. The error information is stored in Error log area (address: E5_H) in the buffer memory.

- E71 hardware error
- · Ethernet line error




There is no hardware-related problem even when the self-loopback test is executed while the destination is online. Because a packet collision occurs when there are many packets on the line, the test may fail or may not be completed in five seconds. In this case, execute the test after stopping data communications between other devices.

Appendix 6.2 Hardware test (H/W Test)

The RAM and ROM of an E71 are checked.

(1) Operating procedure

Use the following procedure.



- 1. Set the switch on the CPU module to "STOP".
- 2. Select "H/W Test" under "Mode" and write the parameter to the CPU module.
 - Project window ⇔ [Parameter] ⇔ [Network

 Parameter] ⇔ [Ethernet/CC IE Field] ⇔ Select

 "Ethernet" under "Network Type".

- Resetting the CPU module starts the test. Test time is approximately five seconds. The RUN and OPEN LEDs turn on during the test.
- **4.** Check the LED of the E71 after five seconds. When the test is running normally, the RUN LED turns on. If the test fails, the RUN and ERR. LEDs turn on.

If an error is detected in the hardware test (H/W test), the following cause is possible. The error information is stored in Error log area (address: E5_H) in the buffer memory.

• E71 RAM/ROM error



If the test fails, perform it again. If it fails again, there may be a hardware problem with the E71. Please consult your local Mitsubishi representative.

Appendix 7 Differences from Ethernet Modules of Other Series

This section describes the differences between an E71 and Ethernet modules of other series.

Appendix 7.1 Differences from a built-in Ethernet port LCPU

For comparison of the specifications and functions between an LJ71E71-100 and a Built-in Ethernet port LCPU, refer to the following.

MELSEC-L CPU Module User's Manual (Built-In Ethernet Function)

Appendix 7.2 Differences from Q series modules

The functions of LJ71E71-100 are the same as those of QJ71E71-100, except for those listed below. A program of QJ71E71-100 can be also used.

○: Supported, ×: Not supported

Item	LJ71E71-100	QJ71E71-100
AUTO MDI/MDI-X compatibility (automatic detection of a straight cable and a cross cable)	0	×
File password 32	0	×
Redundant system supporting function	×	0

Appendix 7.3 Differences from QnA/A series modules

This section provides the functional comparison between an E71 and QnA/A series modules and precautions for using the same program. The QnA/A series modules are the following products.

Series	Model name	Product name
	AJ71E71	AJ71E71, A1SJ71E71-B2, A1SJ71E71-B5
A series	AJ71E71-S3	AJ71E71-S3, A1SJ71E71-B2-S3, A1SJ71E71-B5-S3
AJ71E71N		AJ71E71N3-T, AJ71E71N-B5, AJ71E71N-B2, AJ71E71N-T, AJ71E71N-B5T, A1SJ71E71N3-T, A1SJ71E71N-B5, A1SJ71E71N-B2, A1SJ71E71N-T, A1SJ71E71-B5T
QnA series	QE71(N)	AJ71QE71, AJ71QE71-B5, A1SJ71QE71-B2, A1SJ71QE71-B5, AJ71QE71N3-T, AJ71QE71N-B5, AJ71QE71N-B2, AJ71QE71N-T, AJ71QE71N-B5T, A1SJ71QE71N3-T, A1SJ71QE71N-B5, A1SJ71QE71N-B2, A1SJ71QE71N-T, A1SJ71QE71N-B5T

(1) Functional comparison

The following table lists the functional comparison.

 \bigcirc : Supported, \times : Not supported

				QE71(N)		E71
	Function		AJ71E71-S3, AJ71E71N	9706 or earlier	9706B or later	
1.27.1	Initial process with the program	0	0	0	0	0
Initial process	Initial process with parameter settings	×	×	×	0	0
*1	Open process with the program	0	0	0	0	0
Open process*1	Open process with parameter settings	×	×	×	×	0
Communications using a	Procedure Exist	0	0	0	0	○*2
fixed buffer	No Procedure	×	0	0	0	○*2
Communications using a	random access buffer	0	0	0	0	0
MC protocol communication	ons	0	0	0	○*3	○*3
Communications using da	ta link instructions	×	×	×	○*4	0
Interrupt process (upon	BUFRCVS instruction	×	×	×	×	0
data receiving)	RECVS instruction	×	×	×	×	0
E-mail function	Send/receive with the program	×	×	×	×	0
E-mail function	Send with the auto notification function	×	×	×	×	0
File transfer (FTP server)	function	×	×	×	0	0
Web function		×	×	×	×	0
Broadcast communication	s	×	0	0	0	0
Communications with the	switch on the CPU module set to STOP	×	0	×	0	0
Selection of the communication	cation data code (ASCII/binary)	0	0	0	0	0
	work, CC-Link IE Field Network, CNET/10 relay communications	×	×	×	○*4	0
Router relay function		×	0	0	0	0
Connected device alive	Ping	×	0	0	0	0
check	KeepAlive	×	×	×	×	0
Pairing open		×	0	0	0	0
Unit of each timer setting	500ms	×*5	0	○ (Fixed)	○ (Fixed)	○ (Fixed)
value for data communications	2s	○ (Fixed)	0	×	×	×
Connection to	TCP/IP	×	×	×	×	0
MELSOFT products	UDP/IP	×	0	0	0	0
Installation of EEPROM		×	×	0	0	×*6
TCP Maximum Segment	Size Option transmission	×	○*7	×	○*7	○*8
Hub connection status monitor function		×	×	×	×	0
IP address in use detection function		×	×	×	×	0
Communications using SLMP		×	×	×	×	○*9
Data communications using	ng the predefined protocol	×	×	×	×	○*9
Module error collection fu	nction	×	×	×	×	0

- *1 For the E71, the number of connections for the open process from the CPU module has increased to 16 connections.
- *2 Compatible with the I/O signal and QE71(N) buffer memory
- *3 Data of up to 960 words can be read from/written to an E71, and up to 480 words in a QE71(N).
- *4 Availability depends on the CPU module and programming tool version.
- *5 This applies to a module with the software version of Q or earlier.
- *6 No EEPROM is installed. Items registered in the EEPROM of a QE71(N) are set using the parameter settings of the programming tool.
- *7 This applies to a module with the software version of E or later.
- *8 If the E71 cannot communicate data when combined with a certain connected device, the setting can be changed in the buffer memory (address: 30(1E_H)). (Fig. Page 35, Section 3.5.2)

 After changing the setting, execute the reinitialization process.
- *9 Availability depends on the E71 and a programming tool version (FF Page 300, Appendix 3).



The response performance of the E71 to connected devices is faster than that of the A/QnA series modules. When the E71 is used, the compatibility with the A/QnA series modules cannot be precisely maintained. If there is a problem due to the performance of the connected device, create a timing similar to that of the existing system using the CPU module constant scan setting.

(2) Precautions for using the same program

The QnA/A series modules used for data communications between a CPU module and the connected device on the Ethernet network can be replaced by an E71. This section describes precautions for using the same program used in QnA/A series modules.

(a) AJ71E71(-S3) and AJ71E71N

· Program of connected devices

The following communication function programs of connected devices for an AJ71E71(-S3) and AJ71E71N can be used for communications with an E71. However, because the response speed of the AJ71E71(-S3) and AJ71E71N is different from that of the E71, the program may not be used as is. Before using the same program, check the operation.

Function	Connected device → E71	E71→ connected device	AJ71E71(-S3), AJ71E71N→E71	E71→AJ71E71(-S3), AJ71E71N
Communications using a fixed buffer ("Procedure Exist")	0	0	0	0
Communications using a random access buffer	0	_	_	_
Data read/write in the CPU module*1	0	_	_	_

- \bigcirc : Communications allowed by using the program for an AJ71E71(-S3) and AJ71E71N on the connected device side, -: Not allowed to use
 - *1 Only A-compatible 1E frame commands can be used for data communications. To perform data communications using a command other than the A-compatible 1E frame commands, create a new program.
 - Program for an AJ71E71(-S3) and AJ71E71N in the own station
 Because the assignment of the buffer memory areas for an E71 is different from that for an AJ71E71(-S3) and AJ71E71N, a program for the AJ71E71(-S3) and AJ71E71N cannot be used for an E71. Create a new program by referring to chapters that explain each function.
 - Program using an I/O signal
 Programs cannot be used together with parameter settings on the programming tool.

(b) QE71(N)

Program of connected devices

Programs of the connected devices for a QE71(N) can be used for communications with the E71 except for the following programs.

- · Program for file operation-related commands
- Program to access the data link system (A QCPU (Q Mode) cannot be connected to MELSECNET (II).)

However, because the response speed of an E71 is different from that of a QE71(N), the program may not be used as is. Before using the same program, check the operation.

Program for a QE71(N) in the own station

When using a program for the initial process and the termination process, do not write the parameters of the E71 (network parameters) set on the programming tool to the LCPU. Note the following when not using the parameters of an E71 set on the programming tool.

- Because a QE71(N) operates with all of its communication condition setting switches off, set the communication conditions using the reinitialization process.
- When MELSOFT products (such as a programming tool) are directly connected to an E71, the MELSOFT products (such as a programming tool) cannot access an LCPU.

To set the parameters of an E71 using the programming tool, delete the programs for the initial process and the termination process.

Programs for the QE71(N) in the own station can be used for communications with an E71 except for the following programs.

- · Program to access the data link system
- · Program related to the EEPROM
- · Connection number 8 pairing open setting
- · Parameter setting program using the EPRSET instruction

However, because the response speed of an E71 is different from that of a QE71(N), the program may not be used as is. Before using the same program, check the operation.

Program using an I/O signal

Programs cannot be used together with parameter settings on the programming tool.



- For an E71, set the operation mode and communication conditions using the programming tool. Settings cannot be configured using a switch unlike QnA/A series modules. (There is no switch for settings.)
- For an E71, after the Passive open process is executed, the open request cannot be cancelled before open completion. After the open completion, execute the close process.

Appendix 8 Operation Image and Data Structure of Predefined Protocol

Appendix 8.1 Operation image of each communication type of protocol

In the predefined protocol function, communications with connected devices is performed through the communication type "Send Only", "Receive Only", or "Send&Receive".

This section describes the operation images of each communication type.


(1) When the communication type is "Send Only"

The specified packet is sent once.




The operation image of "Send Only" is as follows.

(a) When the instruction ends normally



(b) When the instruction ends abnormally at TCP (timeout error)






For an error occurred when the communication ends abnormally, refer to the error code stored in the buffer memory. (Fig. Page 264, Section 16.7.3)


(2) When the communication type is "Receive Only"

The receive process completes when the data received from a connected device match the receive packet (expected packet). If they do not match, the data are discarded.




The operation image of "Receive Only" is as follows.

(a) When the instruction ends normally



(b) When the instruction ends abnormally (timeout error)




*1 When the receive packet (expected packet) is not matched to the data by the waiting time to receive or when the existence of a connected device cannot be checked within the time specified by the destination alive check timer (the time calculated based on the destination existence confirmation starting interval timer value, destination existence confirmation interval timer value, and Destination existence confirmation resending time), the instruction ends abnormally.

Point P

- When variables are included in receive packet (expected packet) elements, variable data are not verified.
- Receive packets (expected packets) can be specified up to 16.
- When multiple receive packets (expected packets) are specified, the received data are verified with the registered receive
 packet (expected packet) in order of registration. When the receive packet (expected packet) is matched to the data, the
 receive process is completed. The following verification is not performed.
- The receive packet number which is matched in the verification is stored in the control data of the ECPRTCL instruction and the buffer memory.
- For the error occurred when the communication ends abnormally, refer to the error code stored in the buffer memory. (Fig. Page 264, Section 16.7.3)


(3) When the communication type is "Send&Receive"

When the packet is sent once and the sending completes normally, the status of the E71 changes to the receive wait status. The process completes when the data received from a connected device match the receive packet (expected packet) and the receive process is performed.




The operation image of "Send&Receive" is as follows.


(a) When the instruction ends normally



(b) When the instruction ends abnormally (timeout error at sending)



(c) When the instruction ends abnormally (timeout error of waiting time to receive)



*1 When the receive packet (expected packet) is not matched to the data by the waiting time to receive or when the existence of a connected device cannot be checked within the time specified by the destination alive check timer (the time calculated based on the destination existence confirmation starting interval timer value, destination existence confirmation interval timer value, and Destination existence confirmation resending time), the instruction ends abnormally.




For the error occurred when the communication ends abnormally, refer to the error code stored in the buffer memory. (Fig. 264, Section 16.7.3)

Appendix 8.2 Verification operation of receive packet

This section describes the verification operation for a receive packet (expected packet) when the E71 communicates with a connected device with protocols whose communication type includes receiving.


(1) When received data are matched to a receive packet (expected packet)

The receive process is completed when the receive data are compared with the receive packet (expected packet), and they are matched.




(2) When multiple receive packets (expected packets) are specified

The predefined protocol support function enables to register up to 16 receive packets (expected packets). When the data are received, the registered receive packet (expected packet) is verified in order of registration. When the receive packet (expected packet) is matched to the data, the receive process is completed.



(3) When received data are not matched to all receive packets (expected packets)

The received data are discarded.




Appendix 8.3 Data examples of packet elements


This section describes the procedures for the processing and practical data examples of each element placed in a packet.

(1) Length

(a) Procedures

The E71 processes a Length element as follows.





(b) Data flow


Data Flow is used to specify the order of send data and receive data.

"Forward Direction (Upper Byte→Lower Byte)", "Reverse Direction (Lower Byte→Upper Byte)", and "Byte Swap (by Word)" can be used as the Data Flow.

- Forward Direction and Reverse Direction: Available when the Data Length is 2 bytes or more.
- Byte Swap: Available only when the Data Length is 4 bytes.

(c) Calculating range for the length

The following shows the specification examples of calculating range for the length.



Example 1) Calculating range when its start is 3 and end is 3

Example 2) Calculating range when its start is 3 and end is 30

Example 3) Calculating range when its start is 1 and end is 32


(2) Non-conversion Variable

(a) Procedures


The E71 processes a Non-conversion Variable element as follows.

When the setting for "Unit of Stored Data" is "Lower Byte + Upper Byte"

- When the data length of a send packet is an odd number, the upper byte (lower byte for "Byte Swap") of the last device is not sent.
- When the data length of a receive packet is an odd number, the last data is stored with one byte of 00_H.
- When sending data whose length is an odd number



When receiving data whose length is an odd number




When the setting for "Unit of Stored Data" is "Lower Bytes Only"

Twice the size of the data length is occupied.
 For the upper data, the E71 ignores the data at sending and adds 00_H to the data at receiving.

(3) Non-verified Reception

The following shows the usage example for a Non-verified Reception element.

· Example of a packet format of the connected device



Setting the packet format as above and setting the "Non-verified Reception" enable the followings.


- · Only necessary information can be stored in a device of the CPU module or the buffer memory.
- Only one protocol (packet) is required even when the data that may change in each communication are included in the receive packet.

Appendix 9 Sample Program on the Connected Device Side

The following shows a sample program for the connected device on the same Ethernet network as the E71. Each program example describes only the minimum programming that is required to perform a communication test. Change the IP address, port number and other values according to the system configuration used. Other processes such as a process performed upon an error can be added.

(1) Receive process of the connected device

A receive processing example on the connected device side is shown below.



For Ethernet communications, the TCP socket functions are used inside the personal computer. However, these functions do not have any limit. Therefore, when the "send" function is executed once to transmit data, the receiving side needs to execute the "recv" function once or more to read the data ("send" and "recv" are not proportional to 1:1 execution). For this reason, the receive process above is required.

(2) When the receive process of the connected device is not supported

When the receive process of the connected device is not the one shown in (1), the following may occur when "Enable TCP Maximum Segment Size Option transmission" is set for communications.

- When batch reading is executed from the connected device using the MC protocol, data cannot be normally read.
- After replacing the E71 (which does not support the TCP Maximum Segment Size Option transmission function) with the alternative module supporting the function, data cannot be normally read.
- Even though the value in Received TCP packet count (Address: 1B8_H and 1B9_H) in the buffer memory was changed, data cannot be received.

If these errors occur, select "Disable TCP Maximum Segment Size Option transmission".

Appendix 9.1 When Visual C++(R).NET is used

This section describes the program execution environment, data communication details, and a sample program for when Visual C++[®].NET is used on the program of a connected device.

(1) Execution environment of the program example

(a) CPU module side

Item		Description	
A model name of the LCPU in the E71-connected station		L02CPU	
E71 I/O signal		X/Y00 to X/Y1F	
E71 IP address		C0.00.01.FD _H (192.00.01.253)	
E71 port number		2000 _H	
Programming tool setting	Ethernet operation setting	Refer to Page 343, Appendix 9.1 (3) (a).	
	Open setting	Refer to Page 343, Appendix 9.1 (3) (b).	

(b) Connected device side

Item	Description
Operation environment	Microsoft® Windows® XP Professional Operating System Ver.2002 Service Pack2
Ethernet interface board model name	WINSOCK compatible board
Library to link	WSOCK32.LIB
Software development environment	Visual C++®.NET 2003 manufactured by Microsoft® Corporation
MAC address	This setting is not required because the ARP function can be used.
IP address	Received upon an Active open
Port number	Received upon an Active open

(c) Communication protocol

TCP/IP is used.

(2) Outline of the program example

(a) Program on the CPU module side

Because parameters are set on the programming tool, no program is required.

(b) Program on the connected device side


Read/write data from/to the CPU module using the library described above.

- Write in word units (for five points from D0 to D4)
- · Read in word units (for five points from D0 to D4)


(3) Programming tool setting

Set the parameters using the programming tool as shown below.

(a) Ethernet operation setting



(b) Open setting




(4) Sample program on the connected device side

The program example of the connected device accessing the L02CPU in the E71-connected station is described. When this program is executed, the contents of the following communication messages are displayed in order:

- Batch write command message in word units
- · Batch write response message in word units
- · Batch read command message in word units
- · Batch read response message in word units



- The following is an outline of how to compile a program created using Microsoft® Corporation Visual C++®.NET.
 - Start Visual C++[®].NET.
 - Create a project. From [File]—>[New]—>[Project], select ".NET" in "Project Types" and "Empty Project" in "Templates", and set the project name (e.g. AJSAMP) and location.
 - Create a source file. Open Solution Explorer. Then right-click Source Files and select [Add]→[Add New Item]. Set
 the file name (e.g. AJSAMP.cpp) and location, and create a program according to the program example.
 - From the project setting window, get WSOCK32.LIB linked. Open Solution Explorer. Then right-click the project name (AJSAMP) and select [Properties]→[Configuration Properties]→[Linker]→[Command Line]. Type WSOCK32.LIB in Additional Options and press the OK button.
 - · On the Build menu, click Build Solution to create an execution file (AJSAMP.EXE).
 - Exit Visual C++®.NET.
 - Execute AJSAMP.EXE.
- The following is an outline of how to implement a socket routine call.



```
/** Sample program (program name: AJSAMP.CPP) **/
/** This program is a sample program to conduct a **/
/** connection test between the E71 and target device. **/
/** This program accesses the data register (D) of **/
/** the PLC CPU installed together with the E71 **/
/** Copyright(C) 2005 Mitsubishi Electric Corporation **/
/** All Rights Reserved **/
#include <stdio.h>
         #include <winsock.h>
                                      0
        #define FLAG OFF
                                                // Completion flag OFF
        #define FLAG_ON
                                       1
                                                // Completion flag ON
                                      0
         #define SOCK OK
                                                // Normal completion
         #define SOCK NG
                                      -1
                                                // Abnormal completion
         #define BUF SIZE
                                      4096
                                                // Receive buffer size
                                       0
                                                 // Initial error
         #define ERROR_INITIAL
         #define ERROR SOCKET
                                       1
                                                // Socket creation error
                                       2
         #define ERROR BIND
                                                // Bind error
         #define ERROR_CONNECT
                                       3
                                                // Connection error
                                       4
                                                // Send error
         #define ERROR_SEND
         #define ERROR_RECEIVE
                                       5
                                                // Receive error
         #define ERROR_SHUTDOWN
                                       6
                                                // Shutdown error
        #define ERROR CLOSE
                                                 // Line close error
        //Definitions for checking the receiving sizes
        //#define RECV_ANS_1 4 // Receiving size of response message in reply to device write (1E frame)
         #define RECV_ANS_1 22 // Receiving size of response message in reply to device write (3E frame)
        //#define RECV_ANS_2 24 // Receiving size of response message in reply to device read (1E frame)
         #define RECV ANS 2 42 // Receiving size of response message in reply to device read (3E frame)
         typedef struct sck inf{
             struct in_addr my_addr;
             unsigned short my port;
             struct in addr aj addr;
             unsigned short aj_port;
        }sck inf;
```

```
int nErrorStatus;
                                                                // Error information storage variable
                                                               // Dummy key input
int Dmykeyin;
int Closeflag;
                                                                // Connection completion flag
int socketno;
int main()
    WORD wVersionRequested=MAKEWORD(1,1);
                                                               // Winsock Ver 1.1 request
    WSADATA wsaData;
                                                               // Communication data length
    int length;
    unsigned char s buf[BUF SIZE];
                                                               // Send buffer
    unsigned char r_buf[BUF_SIZE];
                                                                // Receive buffer
    int rbuf idx;
                                                               // Receive data storage head index
                                                                // Number of receive data
    int recv_size;
    struct sck inf sc;
    struct sockaddr_in hostdata;
                                                                // External device side data
    struct sockaddr in aj71e71;
                                                               // E71 side data
    void Sockerror(int);
                                                               // Error handling function
    unsigned long ulCmdArg;
                                                               // Non-blocking mode setting flag
    sc.my_addr.s_addr=htonl(INADDR_ANY);
                                                                // External device side IP address
    sc.my_port=htons(0);
                                                                // External device side port number
    sc.aj addr.s addr=inet addr("192.0.1.253");
                                                               // E71 side IP address (C00001FDH)
    sc.aj port=htons(0x2000);
                                                               // E71 side port number
    Closeflag=FLAG OFF;
                                                                // Connection completion flag off
    nErrorStatus=WSAStartup(wVersionRequested,&wsaData); // Winsock Initial processing
    if(nErrorStatus!=SOCK OK) {
         Sockerror(ERROR INITIAL);
                                                                // Error handling
         return(SOCK NG);
    }
    printf("Winsock Version is %Id.%Id\n",HIBYTE(wsaData.wVersion), LOBYTE(wsaData.wVersion));
    printf("AJ_test Start\n");
    socketno=socket(AF_INET,SOCK_STREAM,0);
                                                                // Create socket for TCP/IP
    if(socketno==INVALID_SOCKET){
         Sockerror(ERROR_SOCKET);
                                                                // Error handling
         return(SOCK_NG);
    }
```

```
hostdata.sin_family=AF_INET;
    hostdata.sin_port=sc.my_port;
    hostdata.sin addr.s addr=sc.my addr.s addr;
    if(bind(socketno,(LPSOCKADDR)&hostdata,sizeof(hostdata))!=SOCK_OK){
         Sockerror(ERROR_BIND); // Error handling
         return(SOCK NG);
    }
    aj71e71.sin family=AF INET;
    aj71e71.sin_port=sc.aj_port;
    aj71e71.sin addr.s addr=sc.aj addr.s addr;
    if(connect(socketno,(LPSOCKADDR)&aj71e71,sizeof(aj71e71))!=SOCK OK){
                                                                 // Connection (Active open)
         Sockerror(ERROR_CONNECT); // Error handling
         return(SOCK NG);
    }
    Closeflag=FLAG_ON;
                                                                 // Connection completion flag ON
    // Set to non-blocking mode
ulCmdArg = 1;
ioctlsocket(socketno, FIONBIO, &ulCmdArg);
                                                                 // Set to non-blocking mode
//
    strcpy((char *)(s buf), "03FF000A44200000000500112233445566778899AA");
                                                                 // D0 to D4 batch write request (1E frame)
    strcpy((char *)(s_buf),"500000FF03FF00002C000A14010000D
                                                                 *000000005112233445566778899AA");
                                                                 // D0 to D4 batch write request (3E frame)
    length = strlen((char *)(s_buf));
    if(send(socketno, (char *)(s buf), length, 0) == SOCKET ERROR) {
                                                                 // Data sending
         Sockerror(ERROR SEND); // Error handling
         return (SOCK_NG);
    printf("\n send data\n%s\n",s_buf);
```

```
// Perform receiving size check and receiving processing simultaneously
     rbuf idx = 0;
                                                          // Receive data storage head index initialization
     recv_size = 0;
                                                          // Initialize the number of receive data
     while(1) {
         length = recv(socketno, (char*) (&r_buf[rbuf_idx]), (BUF_SIZE - rbuf_idx), 0);
                                                          // Response data receiving
     if(length == 0) { // Is connection cut off?
          Sockerror(ERROR_RECEIVE);
                                                          // Error handling
         return (SOCK_NG);
     }
     if(length == SOCKET_ERROR) {
          nErrorStatus = WSAGetLastError();
         if(nErrorStatus != WSAEWOULDBLOCK) {
          Sockerror(ERROR RECEIVE);
                                                          // Error handling
         return (SOCK NG);
         } else {
              continue:
                                                          // Repeat until messages are received
    } else {
         rbuf idx += length;
                                                          // Update the receive data storage
                                                          // position
          recv size += length;
                                                          // Update the number of receive data
         if(recv_size >= RECV_ANS_1)
                                                          // Have all response messages been
                                                          // received?
         break:
                                                          // Stop repeating as messages have
                                                          // been received
r_buf[rbuf_idx] = '0';
                                                          // Set NULL at the end of receive data
printf("\n receive data\n%s\n",r_buf);
strcpy((char *)(s_buf), "01FF000A4420000000000500");
                                                          // D0 to D4 batch read request
                                                          // (1E frame)
strcpy((char *)(s_buf), "500000FF03FF000018000A04010000D*000000005");
                                                          // D0 to D4 batch read request
                                                          // (3E frame)
length = strlen((char *)(s_buf));
if(send(socketno, (char *)(s buf), length, 0) == SOCKET ERROR) {
                                                           // Data sending
     Sockerror(ERROR_SEND);
                                                          // Error handling
     return (SOCK_NG);
printf("\n send data\n%s\n",s_buf);
```

```
// Perform receiving size check and receiving processing simultaneously
rbuf idx = 0;
                                                     // Receive data storage head index
                                                     // initialization
recv_size = 0; // Initialize the number of receive data
while(1) {
    length = recv(socketno, (char*)(&r_buf[rbuf_idx]), (BUF_SIZE - rbuf_idx), 0);
                                                     // Response data receiving
    if(length == 0) {
                                                      // Is connection cut off?
              Sockerror(ERROR RECEIVE);
                                                     // Error handling
              return (SOCK NG);
         }
    if(length == SOCKET_ERROR) {
         nErrorStatus = WSAGetLastError();
         if(nErrorStatus != WSAEWOULDBLOCK) {
              Sockerror(ERROR RECEIVE);
                                                     // Error handling
              return (SOCK_NG);
         } else {
              continue;
                                                     // Repeat until messages are received
    } else {
         rbuf_idx += length;
                                                     // Update the receive data storage
                                                     // position
                                                      // Update the number of receive data
         recv_size += length;
         if(recv_size >= RECV_ANS_2)
                                                     // Have all response messages been
                                                     // received?
                                                     // Stop repeating as messages have
              break;
                                                     // been received
    }
r_buf[rbuf_idx] = '0';
                                                      // Set NULL at the end of receive data
printf("\receive data\n%s\n", r_buf);
    if(shutdown(socketno,2)!=SOCK_OK){
                                                      // Processing to disable
                                                      // sending/receiving
         Sockerror(ERROR_SHUTDOWN);
                                                      // Error handling
         return(SOCK NG);
    if(closesocket(socketno)!=SOCK OK){
                                                      // Close processing
         Sockerror(ERROR_CLOSE);
                                                      // Error handling
         return(SOCK_NG);
    }
    Closeflag=FLAG_OFF;
                                                     // Connection completion flag off
                                                     // Release Winsock.DLL
    WSACleanup();
printf("\nAJ test End.\n\n Normally completed. \n");
    printf("Press any key to exit the program.\n");
    Dmykeyin=getchar(); // Wait for key input
    return(SOCK OK);
```

}

```
void Sockerror(int error_kind) // Error handling function
     if(error_kind==ERROR_INITIAL){
         printf("Initial processing is abnormal.");
     else{
         nErrorStatus=WSAGetLastError();
         switch(error_kind){
         case ERROR_SOCKET:
              printf("Failed to create socket.");
              break;
         case ERROR BIND:
              printf("Failed to bind.");
              break;
         case ERROR CONNECT:
              printf("Failed to establish connection.");
              break;
         case ERROR SEND:
              printf("Sending failed.");
              break;
         case ERROR_RECEIVE:
              printf("Receiving failed.");
              break;
         case ERROR_SHUTDOWN:
              printf("Failed to shutdown.");
              break;
         case ERROR CLOSE:
              printf("Failed to close normally.");
              break;
         }
     printf("Error code is %d.\n", nErrorStatus);
     if(Closeflag==FLAG_ON){
         nErrorStatus=shutdown(socketno,2);
                                                      // Shutdown processing
         nErrorStatus=closesocket(socketno);
                                                      // Close processing
         Closeflag=FLAG_OFF;
                                                      // Connection completion flag off
    }
printf("Press any key to exit the program.\n");
     Dmykeyin=getchar();
                                                      // Wait for a key input
     WSACleanup();
                                                     // Release Winsock.DLL
    return;
```

Appendix 9.2 When Visual Basic^(R).NET is used

This section describes the program execution environment, data communication details, and a sample program for when Visual Basic[®].NET is used on the program of the connected device.

(1) Execution environment of the program example

(a) CPU module side

ltem		Description	
A model name of the LCPU in t	ne E71-connected station	L02CPU	
E71 I/O signal		X/Y00 to X/Y1F	
E71 IP address		C0.00.01.FD _H (192.00.01.253)	
E71 port number		2000 _H	
Programming tool setting	Ethernet operation setting	Refer to Page 352, Appendix 9.2 (3) (a).	
	Open setting	Refer to Page 352, Appendix 9.2 (3) (b).	

(b) Connected device side

Item	Description
Operation environment	Microsoft® Windows® XP Professional Operating System Ver.2002 Service Pack2
Ethernet interface board model name	WINSOCK compatible board
Software development environment	Visual Basic [®] .NET 2003 manufactured by Microsoft [®] Corporation
MAC address	This setting is not required because the ARP function can be used.
IP address	An arbitrary number is assigned.
Port number	An arbitrary number is assigned.

(c) Communication protocol

TCP/IP is used.

(2) Outline of the program example

(a) Program on the CPU module side

Because parameters are set on the programming tool, no program is required.


(b) Program on the connected device side

Data (D0 to D4) in the CPU module are read out.


(3) Programming tool setting

Set the parameters using the programming tool as shown below.

(a) Ethernet operation setting



(b) Open setting



Appendix 9 Sample Program on the Connected Device Side Appendix 9.2 When Visual Basic^(R).NET is used

(4) Sample program on the connected device side

The program example of the connected device accessing the L02CPU in the E71-connected station is described. In this program, data of D0 to D4 (five points) in the L02CPU in the E71-connected station are read with an A-compatible 1E frame command (01: Batch read in word units). The following are basic operation procedures:


- Sending a command with the line disconnected (Connect the line. After completing the connection, the E71 sends a command.)
- Reconnecting the line with it connected (Disconnect the line. After the disconnection is completed, reconnect it.)



The following is an outline of how to compile a program created using Microsoft® Corporation Visual Basic®.NET.

- Start Visual Basic[®].NET.
- Create a project. From [File]→[New]→[Project], select "Visual Basic Project" in "Project Types" and "Windows Application" in "Templates", and set the project name (e.g. AJSAMP) and location.
- Create a form and a program. Use the toolbox "Button" to create the sample window shown below (Form1.vb) and create a program referring to the sample program.
- · On the Build menu, click Build Solution to create an execution file (AJSAMP.EXE).
- Exit the Visual Basic[®].NET.
- · Execute the AJSAMP.EXE.

[Window example (Form 1.vb)]



```
[Sample program (Form 1.vb)]
Option Strict Off
Option Explicit ON
Imports System
Imports System.Text
Imports System.Net
Friend Class Form1
    Inherits System. Windows. Forms. Form
#Region "Windows Form Designer generated code"
    Public Sub New()
    MyBase.New()
    If m vb6FormDefInstance Is Nothing Then
         If m_InitializingDefInstance Then
              m vb6FormDefInstance = Me
         Else
                   Try
                   'For the start-up form, the first instance created is the default instance.
                   If System. Reflection. Assembly. GetExecutingAssembly. EntryPoint
                        .DeclaringType Is Me.GetType Then
                        m vb6FormDefInstance = Me
                   EndIf
              Catch
              End Try
         End If
    End If
    ' This call is required by the Windows form designer.
    InitializeComponent()
End Sub
```

```
'Form overrides dispose to clean up the component list.
Protected Overloads Overrides Sub Dispose(ByVal Disposing As Boolean)
    If Disposing Then
         If Not components Is Nothing Then
             components.Dispose()
    End If
End If
MyBase.Dispose(Disposing)
End Sub
'Required by the Windows Form Designer.
Private components As System.ComponentModel.IContainer
Public WithEvents Command5 As System.Windows.Forms.Button
Public WithEvents Command4 As System.Windows.Forms.Button
Public WithEvents Command3 As System.Windows.Forms.Button
Public WithEvents Command2 As System.Windows.Forms.Button
Public WithEvents Command1 As System.Windows.Forms.Button
Dim Ajsock As Sockets.Socket
Private State As Boolean = False
    'NOTE: The following procedure is required by the Windows Form Designer.
    'It can be modified using the Windows Form Designer.
    'Do not modify it using the code editor.
<System.Diagnostics.DebuggerStepThrough()> Private Sub InitializeComponent()
    Me.Command5 = New System.Windows.Forms.Button
    Me.Command4 = New System.Windows.Forms.Button
    Me.Command3 = New System.Windows.Forms.Button
    Me.Command2 = New System.Windows.Forms.Button
    Me.Command1 = New System.Windows.Forms.Button
    Me.SuspendLayout()
    'Command5
    Me.Command5.BackColor = System.Drawing.SystemColors.Control
    Me.Command5.Cursor = System.Windows.Forms.Cursors.Default
    Me.Command5.ForeColor = System.Drawing.SystemColors.ControlText
    Me.Command5.Location = New System.Drawing.Point(64, 152)
    Me.Command5.Name = "Command5"
    Me.Command5.RightToLeft = System.Windows.Forms.RightToLeft.No
    Me.Command5.Size = New System.Drawing.Size(72, 32)
    Me.Command5.TabIndex = 4
    Me.Command5.Text = "Connection status"
    'Command4
```

```
Me.Command4.BackColor = System.Drawing.SystemColors.Control
Me.Command4.Cursor = System.Windows.Forms.Cursors.Default
Me.Command4.ForeColor = System.Drawing.SystemColors.ControlText
Me.Command4.Location = New System.Drawing.Point(144, 152)
Me.Command4.Name = "Command4"
Me.Command4.RightToLeft = System.Windows.Forms.RightToLeft.No
Me.Command4.Size = New System.Drawing.Size(73, 32)
Me.Command4.TabIndex = 3
Me.Command4.Text = "Close"
'Command3
Me.Command3.BackColor = System.Drawing.SystemColors.Control
Me.Command3.Cursor = System.Windows.Forms.Cursors.Default
Me.Command3.ForeColor = System.Drawing.SystemColors.ControlText
Me.Command3.Location = New System.Drawing.Point(64, 96)
Me.Command3.Name = "Command3"
Me.Command3.RightToLeft = System.Windows.Forms.RightToLeft.No
Me.Command3.Size = New System.Drawing.Size(152, 33)
Me.Command3.TabIndex = 2
Me.Command3.Text = "disconnect"
'Command2
Me.Command2.BackColor = System.Drawing.SystemColors.Control
Me.Command2.Cursor = System.Windows.Forms.Cursors.Default
Me.Command2.ForeColor = System.Drawing.SystemColors.ControlText
Me.Command2.Location = New System.Drawing.Point(64, 56)
Me.Command2.Name = "Command2"
Me.Command2.RightToLeft = System.Windows.Forms.RightToLeft.No
Me.Command2.Size = New System.Drawing.Size(152, 31)
Me.Command2.TabIndex = 1
Me.Command2.Text = "Sending a E71 command"
'Command1
Me.Command1.BackColor = System.Drawing.SystemColors.Control
Me.Command1.Cursor = System.Windows.Forms.Cursors.Default
Me.Command1.ForeColor = System.Drawing.SystemColors.ControlText
Me.Command1.Location = New System.Drawing.Point(64, 16)
Me.Command1.Name = "Command1"
Me.Command1.RightToLeft = System.Windows.Forms.RightToLeft.No
Me.Command1.Size = New System.Drawing.Size(152, 31)
Me.Command1.TabIndex = 0
Me.Command1.Text = "connect"
```

```
'Form1
             Me.AutoScaleBaseSize = New System.Drawing.Size(5, 12)
             Me.BackColor = System.Drawing.SystemColors.Control
             Me.ClientSize = New System.Drawing.Size(280, 214)
             Me.Controls.Add(Me.Command5)
             Me.Controls.Add(Me.Command4)
             Me.Controls.Add(Me.Command3)
             Me.Controls.Add(Me.Command2)
             Me.Controls.Add(Me.Command1)
             Me.Cursor = System.Windows.Forms.Cursors.Default
             Me.Location = New System.Drawing.Point(329, 189)
             Me.Name = "Form1"
             Me.RightToLeft = System.Windows.Forms.RightToLeft.No
             Me.StartPosition = System.Windows.Forms.FormStartPosition.Manual
             Me.Text = "Form1"
             Me.ResumeLayout(False)
         End Sub
    #End Region
#Region "Upgrade Wizard support code"
    Private Shared m vb6FormDefInstance As Form1
    Private Shared m InitializingDefInstance As Boolean
    Public Shared Property DefInstance() As Form1
         Get
             If m_vb6FormDefInstance Is Nothing OrElse m_vb6FormDefInstance.IsDisposed Then
                  m_InitializingDefInstance = True
                  m vb6FormDefInstance = New Form1()
                  m InitializingDefInstance = False
             DefInstance = m_vb6FormDefInstance
        End Get
         Set
             m vb6FormDefInstance = Value
         End Set
    End Property
#End Region
```

Private Sub Command1_Click(ByVal eventSender As System.Object, ByVal eventArgs As System. EventArgs) Handles Command 1. Click 'Connect to the Ethernet interface module. Dim sock As New Sockets.Socket(Sockets.AddressFamily.InterNetwork, Sockets.SocketType.Stream, Sockets.ProtocolType.Tcp) Ajsock = sock Dim ip As IPAddress = Dns.Resolve("192.0.1.253").AddressList(0) Dim ipend As IPEndPoint = New IPEndPoint(ip, "8192") Me.Ajsock.Connect(ipend) MsqBox("Connection Completed") State = Me.Ajsock.Connected() End Sub Private Sub Command2_Click(ByVal eventSender As System.Object, ByVal eventArgs As System. EventArgs) Handles Command 2. Click Dim SData As Byte() Dim RData(256) As Byte 'Rend D0 to D4 (5 points) with the A-compatible 1E frame command. SData = Encoding.ASCII.GetBytes("01FF000A442000000000500") 'Read D0 to D4 (5 points) with the QnA-compatible 3E frame command. 'SData = Encoding.ASCII.GetBytes("500000FF03FF000018000A04010000D *000000005") 'Send the data. Me.Ajsock.Send(SData) MsgBox("Send completion", MsgBoxStyle.Information) 'Read the response from the PLC CPU. Me.Ajsock.Receive(RData) MsgBox(Encoding.ASCII.GetString(RData), MsgBoxStyle.Information) End Sub Private Sub Command3 Click(ByVal eventSender As System.Object, ByVal eventArgs As System. EventArgs) Handles Command 3. Click 'Close the TCP (UDP) connection socket (disconnect the line). Me.Ajsock.Shutdown(Net.Sockets.SocketShutdown.Both) Me.Ajsock.Close()

MsgBox("The disconnection was successful", MsgBoxStyle.Information)

State = Me.Ajsock.Connected()

End Sub

End Class

Appendix 10 Checking the Serial Number, Function Version, and MAC address

(1) Checking the serial number and function version

The serial number and function version can be checked on the rating plate or with the system monitor. Refer to the following.

MELSEC-L CPU Module User's Manual (Hardware Design, Maintenance and Inspection)

(2) Checking the MAC address

The MAC address can be checked on the rating plate or with the Ethernet diagnostics.


For how to check the MAC address on the rating plate, refer to the following.


MELSEC-L CPU Module User's Manual (Hardware Design, Maintenance and Inspection)

To use the Ethernet diagnostics, refer to Page 290, Section 16.8 in this manual.

Appendix 11 External Dimension Diagram

This appendix provides the external dimension diagrams of an E71.





Appendix 12 ASCII Code List

The following is the ASCII code table.

		Higher 4 bits									
	Hexad	Hexadecimal		1	2	3	4	5	6	7	8–F
		Binary	0000	0001	0010	0111	0100	0101	0110	0111	1000–1111
Lower 4 bits	0	0000	NUL	DLE	(SP)	0	@	Р	,	р	
	1	0001	SOH	DC1	!	1	Α	Q	а	q	
	2	0010	STX	DC2	=	2	В	R	b	r	
	3	0011	ETX	DC3	#	3	С	S	С	s	
	4	0100	EOT	DC4	\$	4	D	Т	d	t	
	5	0101	ENQ	NAK	%	5	Е	J	е	u	
	6	0110	ACK	SYN	&	6	F	V	f	٧	
	7	0111	BEL	ETB	4	7	G	W	g	W	
	8	1000	BS	CAN	(8	Н	Х	h	Х	
	9	1001	HT	EM)	9	I	Υ	i	у	
	Α	1010	LF	SUB	*	:	J	Z	j	Z	
	В	1011	VT	ESC	+	;	K	[k	{	
	С	1100	FF	FS	,	<	L	\ (¥)	I		
	D	1101	CR	GS	-	=	М]	m	}	
	E	1110	SO	RS		>	N	۸	n	~	
	F	1111	SI	US	/	?	0	_	0	DEL	

INDEX

0 to 9	D
100BASE-TX connection .57 100Mbps hub .57 10BASE-T connection .58 10Mbps hub .58 4E frame .85	Data format
Α	Device
Abnormal codes 263 A-compatible 1E frame 85 Active open 74 Alive check function 187 Always wait for OPEN (communication possible at STOP time) 67 Applicable software 59 Applicable systems 59 Application data 132,158 ARP 16 ASCII code 362	Differences in functions according to the remote password check status (enabled/disabled)
Auto-open UDP port	E71
Basic functions 29 Basic setting 65 Bend radius 62 Broadcast communications 140 Buffer memory 34 BUFRCV 189 BUFRCVS 189 BUFSND 189	E71-connected station 16 ECPRTCL 189 E-mail function 30 Enable online change 66 End codes 259 ERRCLR 189 Error code list 249 ERRD 189 Ethernet diagnostics 290 Ethernet operation setting 66 External dimension diagram 361
С	F
Cascade connection	File transfer (FTP server) function
monitor	General specifications 27 GP.ECPRTCL 199 Group No. 65 GX Developer 16 GX Works2 16,59
Communications using an auto-open UDP port 173 Communications using data link instructions 30 Compliance with EMC and Low Voltage Directives 6 Connecting MELSOFT products and a GOT 81 Connection target	H/W test 65 Handling 62 Hardware test 323 Header 132,157 How to turn off the COM.ERR. LED 293 HTTP 16 Hub connection status monitor function 184

1	Other functiona
ICMP	
Initial process	Р
Initial timing	Packing list
Input format	Pairing open
Installation	Parameter list 64
Intelligent function module	Part names
Interrupt pointer setting	Passive open
Interrupt settings	Performance specifications
IP	PING command
IP address	PING test
IP address in use detection function	POP3
IP address setting	Port numbers used for the E71
	Predefined protocol support function
<u>L</u>	Procedures before operation
Line status check	Processing time
List of buffer memory addresses	Programming tool
List of dedicated instructions	
List of I/O signals	Q
Lock process 175 Logical addresses 166	0.4
Loopback test	QnA-compatible 3E frame
·	_
M	<u>R</u>
	READ
MAC address	RECV
Maximum segment length	RECVS
(maximum cable length) 62	Reinitialization process
MC protocol	Relevant manuals
MC protocol communications	Remote password check
MELSECNET/10	Remote password setting processes
MELSECNET/H 16 MELSECNET/H remote I/O station 16	(unlock and lock processes)
MELSOFT application transmission port (TCP) 299	REQ
MELSOFT application transmission port (UDP) 299	RJ45 connector
MELSOFT connection 82	Router IP address
Mode	Router relay function
Module joint lever	
MSEND	S
MX component	
·	Sample program on the connected device side 340
N	Self-diagnostic tests
	SEND
Network components	Send frame setting
Network No. 65 Network parameter. 64	Setting parameters required for communications 64
Network type	Shielded twisted pair cable (STP)
No procedure	SMTP
Number of connectable modules	Specifications
Number of occupied I/O points 27	SREAD
	Start I/O No
0	Station No
Offline	Straight cable
Online	Subnet mask
OPEN	Subnet mask pattern
Open setting	SWRITE 189
Open system	System configuration

T

TCP existence confirmation setting
Troubleshooting by symptom
U
UDP/IP communications
w
Web function30When using data link instructions190Wiring61WRITE189
<u>Z</u>
Z.BUFRCVS 217 ZNRD 189 ZNWR 189 ZP.BUFRCV 213 ZP.BUFSND 209 ZP.CLOSE 196 ZP.ERRCLR 219 ZP.ERRRD 223 ZP.OPEN 192 ZP.UINI 226

REVISIONS

*The manual number is given on the bottom left of the back cover.

Print date	*Manual number	Revision
February 2013	SH(NA)-081105ENG-A	First edition
June 2013	SH(NA)-081105ENG-B	Revision due to the support for data communications using the predefined
October 2014	SH(NA)-081105ENG-C	Error correction
April 2015	SH(NA)-081105ENG-D	Revision due to the support for Receive buffer full detection signal

Japanese Manual Version SH-081104-E

This manual confers no industrial property rights or any rights of any other kind, nor does it confer any patent licenses. Mitsubishi Electric Corporation cannot be held responsible for any problems involving industrial property rights which may occur as a result of using the contents noted in this manual.

© 2013 MITSUBISHI ELECTRIC CORPORATION

WARRANTY

Please confirm the following product warranty details before using this product.

1. Gratis Warranty Term and Gratis Warranty Range

If any faults or defects (hereinafter "Failure") found to be the responsibility of Mitsubishi occurs during use of the product within the gratis warranty term, the product shall be repaired at no cost via the sales representative or Mitsubishi Service Company.

However, if repairs are required onsite at domestic or overseas location, expenses to send an engineer will be solely at the customer's discretion. Mitsubishi shall not be held responsible for any re-commissioning, maintenance, or testing on-site that involves replacement of the failed module.

[Gratis Warranty Term]

The gratis warranty term of the product shall be for one year after the date of purchase or delivery to a designated place. Note that after manufacture and shipment from Mitsubishi, the maximum distribution period shall be six (6) months, and the longest gratis warranty term after manufacturing shall be eighteen (18) months. The gratis warranty term of repair parts shall not exceed the gratis warranty term before repairs.

[Gratis Warranty Range]

- (1) The range shall be limited to normal use within the usage state, usage methods and usage environment, etc., which follow the conditions and precautions, etc., given in the instruction manual, user's manual and caution labels on the product.
- (2) Even within the gratis warranty term, repairs shall be charged for in the following cases.
 - 1. Failure occurring from inappropriate storage or handling, carelessness or negligence by the user. Failure caused by the user's hardware or software design.
 - 2. Failure caused by unapproved modifications, etc., to the product by the user.
 - 3. When the Mitsubishi product is assembled into a user's device, Failure that could have been avoided if functions or structures, judged as necessary in the legal safety measures the user's device is subject to or as necessary by industry standards, had been provided.
 - 4. Failure that could have been avoided if consumable parts (battery, backlight, fuse, etc.) designated in the instruction manual had been correctly serviced or replaced.
 - 5. Failure caused by external irresistible forces such as fires or abnormal voltages, and Failure caused by force majeure such as earthquakes, lightning, wind and water damage.
 - 6. Failure caused by reasons unpredictable by scientific technology standards at time of shipment from Mitsubishi.
 - 7. Any other failure found not to be the responsibility of Mitsubishi or that admitted not to be so by the user.

2. Onerous repair term after discontinuation of production

- (1) Mitsubishi shall accept onerous product repairs for seven (7) years after production of the product is discontinued. Discontinuation of production shall be notified with Mitsubishi Technical Bulletins, etc.
- (2) Product supply (including repair parts) is not available after production is discontinued.

3. Overseas service

Overseas, repairs shall be accepted by Mitsubishi's local overseas FA Center. Note that the repair conditions at each FA Center may differ.

4. Exclusion of loss in opportunity and secondary loss from warranty liability

Regardless of the gratis warranty term, Mitsubishi shall not be liable for compensation of damages caused by any cause found not to be the responsibility of Mitsubishi, loss in opportunity, lost profits incurred to the user by Failures of Mitsubishi products, special damages and secondary damages whether foreseeable or not, compensation for accidents, and compensation for damages to products other than Mitsubishi products, replacement by the user, maintenance of on-site equipment, start-up test run and other tasks.

5. Changes in product specifications

The specifications given in the catalogs, manuals or technical documents are subject to change without prior notice.

TRADEMARKS

Microsoft, Windows, Windows Vista, Windows NT, Windows XP, Windows Server, Visio, Excel, PowerPoint, Visual Basic, Visual C++, and Access are either registered trademarks or trademarks of Microsoft Corporation in the United States, Japan, and other countries.

Intel, Pentium, and Celeron are either registered trademarks or trademarks of Intel Corporation in the United States and other countries.

Ethernet is a trademark of Xerox Corp.

The SD and SDHC logos are either registered trademarks or trademarks of SD-3C, LLC.

All other company names and product names used in this manual are either trademarks or registered trademarks of their respective companies.





368 SH(NA)-081105ENG-D

<u>SH(NA)-081105ENG-D(1504)MEE</u> MODEL: LJ71E71-U-KI-E

MODEL CODE: 13JZ73

MITSUBISHI ELECTRIC CORPORATION

HEAD OFFICE : TOKYO BUILDING, 2-7-3 MARUNOUCHI, CHIYODA-KU, TOKYO 100-8310, JAPAN NAGOYA WORKS : 1-14 , YADA-MINAMI 5-CHOME , HIGASHI-KU, NAGOYA , JAPAN

When exported from Japan, this manual does not require application to the Ministry of Economy, Trade and Industry for service transaction permission.

Specifications subject to change without notice.