

EDK 350 (868 MHz)
EDK 350U (902 MHz)

EnOcean Developer Kit



Important Notes

This information describes the type of component and shall not be considered as assured characteristics. No responsibility is assumed for possible omissions or inaccuracies. Circuitry and specifications are subject to change without notice. For the latest product specifications, refer to the EnOcean website: <http://www.enocean.com>.

As far as patents or other rights of third parties are concerned, liability is only assumed for modules, not for the described applications, processes and circuits. EnOcean does not assume responsibility for use of modules described and limits its liability to the replacement of modules determined to be defective due to workmanship. Devices or systems containing RF components must meet the essential requirements of the local legal authorities. The modules must not be used in any relation with equipment that supports, directly or indirectly, human health or life or with applications that can result in danger for people, animals or real value. Components of the modules are considered and should be disposed of as hazardous waste. Local government regulations are to be observed.

Packing: Please use the recycling operators known to you. By agreement we will take packing material back if it is sorted. You must bear the costs of transport. For packing material that is returned to us unsorted or that we are not obliged to accept, we shall have to invoice you for any costs incurred.

This development kit and its components are intended for use for evaluation, demonstration or engineering development purposes only. It is not considered to be a finished end product fit for consumer use. Persons handling this developer kit must have electronics expertise and observe good engineering practice standards. As such, the goods being provided are not intended to be complete in terms of required design, marketing, and/or manufacturing related protective considerations, including product safety and environmental measures typically found in end products that incorporate such electronic components or circuit board. EnOcean does not reliable consequences for any HW or SW changes/modifications of the developer board done by the developer.

Important notice for users in Japan: This developer kit is not certified as confirming to technical regulations of radio law of Japan. If you use this kit in Japan, you are required by Radio Law of Japan to follow the instructions below with respect to this product: Use this product in a shielded room or any other test facility as defined in the notification #173 issued by Ministry of Internal Affairs and Communications on March 28, 2006, based on sub-section 1.1 of article 6 of the "Rule for Enforcement of Radio Law of Japan". Use this kit only after you obtained the license of "Test Radio Station" as provided in Radio Law of Japan with respect to this product, or use of this product only after you obtained the technical regulations conformity certification as provided in radio law of Japan with respect to this product. Do not transfer this product, unless you give the same notice above to the transferee. Please note that if you could not follow the instructions above, you will be subject to penalties of Radio Law of Japan.

All product images are for symbolic illustrations. Real product might be different in colour and design.



Observe precautions! Electrostatic sensitive devices!

Index

1	Overview	4
2	First Steps and Demonstrations	5
2.1	Demonstration of '1-Channel Relay Switch' and 'Learn-Concept'	5
2.2	Software Installation	6
2.3	DolphinView Advanced.....	7
2.4	Demonstration of PTM 2xx (standard mode)	8
2.5	Demonstration of PTM 215 security (optional for 868 MHz).....	9
2.6	ECO 200 & PTM 330 – Push Button Generator & Radio Module	10
3	Working with DolphinStudio	11
3.1	DolphinStudio Installation	11
3.2	Check Firmware Version and Update	11
3.3	Update Firmware:	12
3.4	Configuration of Temperature Sensor STM 33x.....	12
4	Write your own Firmware	14
5	References	15
6	EOP 350-2 Circuit & Layout	16

1 Overview

EDK 350 contains everything you need to start implementing innovative solutions with EnOcean's energy harvesting and ultra-low power radio technologies. The kit will help you to demonstrate and configure EnOcean products. Additionally you can easily design new hardware and start software programming.

Content

- User Manual
- USB cable
- USB 300: USB stick gateway
- PTM 21x: Push button switch incl. rocker
- STM 33x: Self-powered temp. sensor
- ECO 200: Mechanical energy harvester incl. housing example
- PTM 330: Push button radio module
- TCM 320: Transceiver module
- STM 300: Radio module on adapter
- EOP 350: Universal programmer board



symbolic product image

Updates for this user manual are available at:
http://www.enocean.com/en/enocean_modules/edk-350/

2 First Steps and Demonstrations


2.1 Demonstration of '1-Channel Relay Switch' and 'Learn-Concept'

The TCM 320 module has already several pre-implemented features for building automation. The 1-channel relay mode is used to switch on and off a module pin. If you connect a relay to this pin you can switch a line-powered device.

1. Plug TCM 320 into EOP 350 and set jumper to 1-CH ACT



2. Connect EOP 350 with USB power (e.g. PC)
3. Learn PTM switch ID to TCM 320:
 - Press LEARN button on EOP 350 > 0.5s
→ LMI LED will light, CH0 will flash
 - Push switch rocker one time to send learn telegram
 - Finish learn mode with LEARN button > 0.5s
4. Push PTM switch to toggle CH0 LED (relay pin)



Attention:

- Example works only with TCM 300/320 standard firmware and rocker on top of PTM switch.
- If you have replaced TCM firmware, load TCM 320 default firmware from website.
- Pushing the switch a second time during learn mode will delete the ID.
- Operating mode can only be changed after deleting all IDs.
- During learn mode supply voltage needs to be stable to avoid flash corruption.

2.2 Software Installation

- Please register your personal account on the EnOcean website:
<http://www.enocean.com/en/download/>

Following software components need to be downloaded and installed:

DolphinView

- Visualize properties of EnOcean radio nodes
- Receives, sends and analyses radio telegrams according to the EnOcean standard
- Get detailed information e.g. sub-telegram timing and signal strength
- Content of telegrams can be analyzed online and logged with time stamp
- Supports remote management features like ping, query and remote learn

DolphinStudio


- DolphinStudio software provides a graphical user interface allowing easy configuration and programming of EnOcean modules with Dolphin chip.

DolphinAPI

- Operating system for self-powered applications
- Source code samples in C-Code for switching, dimming etc.
- Comprehensive software libraries (wireless communication, energy management, ...)

2.3 DolphinView Advanced

- EnOcean DolphinView visualizes and interprets EnOcean radio telegrams. It receives EnOcean telegrams via USB 300 or TCM 320 with DolphinSniffer Software.



- Download DolphinView from EnOcean's Software download website
- Execute the DolphinView setup program and follow instructions
- Connect USB 300 to your PC or notebook.
With USB 300 you will get basic information of EnOcean telegrams.
With TCM 320 and DolphinSniffer FW you will get detailed information (e.g. timing)
- Execute DolphinView and press the connect button

Remark: DolphinView firmware download will overwrite existing TCM 3x0 or STM 300 firmware. In order to get the original function of the modules you need to download and program the corresponding firmware from <http://www.enocean.com/en/download/>

2.4 Demonstration of PTM 21x (standard mode)

The push-button radio transmitter module enables the implementation of wireless remote controls without batteries. Key applications are wall-mounted flat rocker switches with 1 or 2 rockers, as well as handheld remote controls with up to 4 single push-buttons.

- Radio telegrams will be received via USB 300 and shown by DolphinView
- Press rocker to send switch telegram → PTM switch will be shown in node list
- Double click on PTM within the node list → PTM will be added to the node list
- Select node and press "Set Profile" button to interpret Equipment Profile
- Press rocker on I-side (marking on PTM switch) to send "switch on telegram"
- Press rocker on O-side (marking on PTM switch) to send "switch off telegram"




2.5 Demonstration of PTM 215 security (optional for 868 MHz)

PTM 215 has an additional secure mode with a rolling code to prevent copying. It supports normal mode and secure mode. In order to use the secure mode you need a transceiver firmware with encryption firmware or DolphinView to evaluate secure telegrams.

- Use EOP 350 with TCM 320 and DolphinSniffer firmware to receive secure telegrams
- Start DolphinView and connect TCM 320 DolphinSniffer
 - PTM 215 **DA**: Hold down two contacts (1) and press the energy bow (2) **one time**
 - PTM 215 **DB** or higher: Hold down two contacts (1) and press the energy bow **two times** (for details see PTM 215 user manual)
 - PTM will send a learn and synchronisation telegram to the receiver
- Received (telegram log) and interpreted telegram (EEP view) will be shown
- Additional documentation is available at:

www.enocean.com/en/security-specification/ and http://www.enocean.com/en/enocean_modules/ptm-215/



Remark: PTM 215 can be switched from secure mode to normal mode by simultaneously hold down four contact nipples and actuating the energy bow. Before changing the operating mode, make sure to clear the device from all learned receivers, otherwise receivers will ignore the telegrams and the application will not work.

2.6 ECO 200 & PTM 330 – Push Button Generator & Radio Module

The ECO 200 is an energy converter for linear motion. It can be used to power the PTM 330 radio module. The energy output at every actuation is sufficient to transmit multiple sub-telegrams with a free field range of 300m. Possible applications are miniaturized switches and sensors in building technology and industrial automation.

- Radio telegrams will be received via USB 300 and shown by DolphinView Basic
- Press spring to send telegram → PTM 330 will be shown in the node list
- Select node and press “Set Profile” button to interpret Equipment Profile
- Press spring to send telegram “Energy Bow: pressed”
- Pull spring to send telegram “Energy Bow: release”

The diagram illustrates the assembly process. On the left, the ECO 200 module is shown being inserted into a white plastic housing. An arrow points to the assembled unit. A second arrow points to a close-up of the PTM 330 radio module, with a red circle highlighting the contact pins on its top surface. A final arrow points to the DolphinView Basic software interface. In the software, the 'Node List' on the left shows 'ECO 200/330 Device_085' selected and highlighted with a red box. The 'EEP View' window on the right shows the 'Equipment Profile' for 'Energy Bow: pressed', with the 'Set Profile' button highlighted in red. The profile details include:

- NAME: Radio XPS Telegram
- FUNC: Radio Switch, 2 Roller
- TYPE: Light and Blind Control - Application Style 1
- Learn Telegrams: N/A
- Data Telegram Interpretation:
 - Roller 1st action: Button A1: "Switch light off" or "Dim light up" or "Move blind open"
 - Energy Bow: pressed
 - Roller 2nd action: Button A1: "Switch light on" or "Dim light down" or "Move blind closed"
 - 2nd Action: No 2nd action
 - Number of buttons pressed simultaneously (after bit combinations are not valid): no button
 - Energy Bow: pressed


Attention:

In order to simulate a wall switch (PTM 2xx) you need to use the contact pins on top of the board. For details see PTM 330 user manual.

3 Working with DolphinStudio

3.1 DolphinStudio Installation


1. Download DolphinStudio from <http://www.enoclean.com/en/download/>
2. Install DolphinStudio via setup program
3. Unplug jumper on STM 33x and keep for later usage
4. Plug STM 33x temperature sensor on top of EOP 350 (antenna to the left side)
5. Connect EOP 350 via USB cable to PC
6. Start DolphinStudio and select COM port



3.2 Check Firmware Version and Update

Firmware Version:

1. Start DolphinStudio and select "EOPX (Programmer)" tab
2. Select "Chip information"
3. Press "Retrieve" button
4. Current application type and version will be shown



3.3 Update Firmware:

1. Program and compile your own FW or download update from EnOcean website e.g. <http://www.enocean.com/en/download/>
2. Start DolphinStudio and select "EOPX (Programmer)" tab
3. Select "Programmer"
4. Select FW file via "Browse..." button; chip configuration file will be automatically recognized by ending *.cfg.hex
5. Press "Execute" button to start the update process



3.4 Configuration of Temperature Sensor STM 33x

1. Select "Configuration" tab within DolphinStudio
2. Select STM 33x within configuration window
3. Click on read configuration button
4. You will get on overview of the temperature sensor pre-defined configuration
5. STM 33x will only send a LEARN telegram if an "Manufacturer ID" is configured. Change "Manufacturer ID" for example to EnOcean GmbH.
6. You can change the wake up cycle, but keep in mind, this will heavily affect the energy budget. For details see STM 31x user manual.

Typical values for OEM products are:


Cyclic wake-up cycle:	100s (wake up and check temperature value)
Redundant retransmission min:	7 (min send interval every 7. wake up)
Redundant retransmission mx:	14 (max send interval every 14. wake up)

7. Unplug STM 33x from EOP 350 and set jumper as before (near learn button)
8. Start DolphinView Advanced
9. Connect to USB 300 or TCM 320 with DolphinSniffer as gateway
10. Press learn button on STM 33x
→ Learn telegram will be sent, and DolphinView will automatically recognize the temperature sensor (see EEP symbole in node list)
11. Select EEP tab and wait for the first telegram send by the sensor after the retransmission interval
→ Sensor values will be automatical interpreted and plotted into a diagram



4 Write your own Firmware

1. Download DolphinAPI and install from <http://www.enocean.com/en/download/>
2. Acquire PK 51 with C51 compiler and Keil μ Vision IDE from ARM:
<http://www.keil.com/c51/pk51kit.asp>
3. A description and C-cod samples of DolphinAPI can be found within the installation folder
4. Implement your application and upload the firmware via DolphinStudio



STM 300 for sensor applications:

The programmer board EOP 350 has been designed for the demonstration of line powered applications and for programming of EnOcean modules. Due to different wiring for STM 300 sensor applications (e.g. ADIO3/4 as analogue input) we recommend to contact our application engineering to get hints and tips: support@enocean.com

5 References

- Data sheets and user manuals:


868 MHz: http://www.enocean.com/en/enocean_modules/

902 MHz: http://www.enocean.com/en/enocean_modules_902mhz/


- Software can be found at: www.enocean.com/download
- Additional information: <http://www.enocean.com/knowledge-base/>
- Technical support: support@enocean.com
- EnOcean Equipment Profiles: <http://www.enocean-alliance.org/eep/>

6 EOP 350-2 Circuit & Layout

USB serial converter




3.3V DC/DC converter




Programmer interface

Remarks:


- Interface is only for special purposes
e.g. bed of needle adapter
- Connector is not soldered
- Compared to EOP 300, RxD (pin 6)
has been changed with TxD (pin 5)




LEDS




EXT PINS



GATEWAY



1-CH ACTUATOR



BUTTONS

