


**ControlNet
PLC-5
Programmable
Controllers**

Cat. No. 1785-L20C, -L40C



User Manual



Important User Information

Because of the variety of uses for the products described in this publication, those responsible for the application and use of this control equipment must satisfy themselves that all necessary steps have been taken to assure that each application and use meets all performance and safety requirements, including any applicable laws, regulations, codes, and standards.

The illustrations, charts, sample programs and layout examples shown in this guide are intended solely for purposes of example. Since there are many variables and requirements associated with any particular installation, Allen-Bradley does not assume responsibility or liability (to include intellectual property liability) for actual use based on the examples shown in this publication.

Allen-Bradley publication SGI-1.1, Safety Guidelines for the Application, Installation, and Maintenance of Solid-State Control (available from your local Allen-Bradley office), describes some important differences between solid-state equipment and electromechanical devices that should be taken into consideration when applying products such as those described in this publication.

Reproduction of the contents of this copyrighted publication, in whole or in part, without written permission of Allen-Bradley Company, Inc., is prohibited.

Throughout this manual, we use notes to make you aware of safety considerations:



ATTENTION: Identifies information about practices or circumstances that can lead to personal injury or death, property damage or economic loss.

Attention statements help you to:

- identify a hazard
- avoid the hazard
- recognize the consequences

Important: Identifies information that is critical for successful application and understanding of the product.


Table of Contents

Using This Manual	i
Introduction	i
Audience	i
Contents	i
Terminology	ii
Conventions	iii
Related Publications	iii
Installing Your ControlNet PLC-5 Processor	1-1
Using This Chapter	1-1
Before You Begin	1-2
Handling the Processor	1-3
Identifying ControlNet PLC-5 Processor Components	1-4
Setting the I/O Chassis Backplane Switches	1-6
Setting the I/O Chassis Configuration Plug	1-7
Installing Keying Bands for the Processor	1-7
Installing and Disposing of the Processor Battery	1-8
Selecting the DH+ Station Address of Channel 1A	1-10
Specifying the Serial Interface of Channel 0	1-11
Selecting the ControlNet Network Address of Channel 2	1-11
Inserting/Removing the Processor into/from the I/O Chassis	1-12
Installing a Remote I/O Link	1-12
Installing a DH+ Link	1-14
Connecting to a ControlNet Network	1-15
Connecting a Programming Terminal	1-16
Selecting Appropriate Cables	1-18
Planning to Use Your ControlNet PLC-5 Processor	2-1
Using This Chapter	2-1
Understanding ControlNet I/O	2-1
Understanding ControlNet I/O Mapping	2-7
Using the ControlNet PLC-5 Processor in a ControlNet I/O System	2-13
Converting from a Non- ControlNet Remote I/O System to a ControlNet I/O System	2-15

Configuring Your ControlNet System	3-1
Using This Chapter	3-1
Matching the Processor Configuration with the ControlNet Configuration	3-2
Defining Local Rack Characteristics	3-3
Editing ControlNet Node Information	3-4
Editing ControlNet I/O Mapping	3-6
Programming Your ControlNet System	4-1
Using This Chapter	4-1
Using ControlNet Message Instructions	4-2
Using the ControlNet I/O Transfer Instruction	4-4
Using ControlNet Immediate Data Input and Output Instructions ...	4-6
Using Selectable Timed Interrupts with a Program on a ControlNet Network	4-7
Monitoring and Troubleshooting Your ControlNet System	5-1
Using This Chapter	5-1
Using the General Status Indicators	5-2
Using the ControlNet Status Indicators	5-3
Using the 6200 Programming Software to Monitor ControlNet Configuration and Status	5-5
Processor Specifications	A-1
Processor Status File	B-1
S:0-S:2	B-1
S:3-10	B-2
S:11-S:12	B-3
S:12-S:16	B-4
S:17-S:27	B-5
S:28-S:61	B-6
S:62-S:127	B-7
ControlNet Instruction Set	C-1
ControlNet I/O Transfer Instruction	C-1
Message Instructions on a ControlNet Network	C-1
Immediate Data I/O Instructions	C-2
ControlNet I/O Map-Entry Status Words and Error Messages	D-1
I/O Map-Entry Status Words	D-1
Error Messages	D-2

Using This Manual

Introduction



This manual describes how to install your processor as well as how to plan for, configure, and use the features of a PLC-5/20C™ or PLC-5/40C™ programmable controller that are unique to the ControlNet™ network.

For detailed information on features that the PLC-5/20C or PLC-5/40C programmable controllers share with the PLC-5/20™ and -5/40™ processors, see the Enhanced and Ethernet PLC-5 Programmable Controllers User Manual, publication 1785-6.5.12.

Audience



The information in this manual is intended for engineers and technicians who are installing, programming, and maintaining a control system that includes a PLC-5/20C or PLC-5/40C programmable controller.

You should have a background in control-system applications and a basic knowledge of:

- programmable real-time control systems
- the PLC-5® control system
- your operation's required systems and applications

Contents



If you want to read about:	Go to:
Installing your ControlNet PLC-5 processor	Chapter 1
Setting switches	
Installing communication links	
Planning to use your ControlNet PLC-5 processor	Chapter 2
Understanding ControlNet I/O	
Using a ControlNet PLC-5 processor	
Using the 6200 Programming Software to configure your ControlNet system	Chapter 3
Editing your ControlNet configuration	
Editing ControlNet I/O mapping	
Programming your ControlNet system	Chapter 4
Monitoring and troubleshooting your ControlNet system	Chapter 5
Using the status indicators	
Monitoring the 6200 Programming Software configuration and status screens	
Processor specifications	Appendix A
Processor status file	Appendix B
ControlNet instructions	Appendix C
ControlNet I/O map-table entry status words and error messages	Appendix D


Preface
Using This Manual

Terminology

Term	Description
ControlNet network	communication architecture that allows the exchange of data between Allen-Bradley Company, Inc. products and certified third-party products
connection	opened communication path between two nodes on a ControlNet network
discrete I/O data transfer	type of data transfer in which single units of I/O have discrete relationships with values in the processor's data table; uses the processor's input- and output-image tables (I and O files); configured on a per-node basis in the ControlNet I/O map table
frame	single data transfer on a ControlNet link
drop cable	cable that connects a ControlNet node to the trunk cable; integral part of 1786 taps
I/O map table	table that you configure using the programming software to map data from an I/O chassis and other devices on the ControlNet network to particular data-table file addresses
link	collection of ControlNet nodes with unique network addresses in the range of 01-107; segments connected by repeaters make up a link; links connected by bridges make up a network
map-table entry	one entry in the I/O map table that you configure using the programming software to map data from one I/O chassis or other device on ControlNet to particular data-table file addresses
maximum scheduled node	node with the highest network address that can use scheduled time on a ControlNet link
maximum unscheduled node	node with the highest network address that can use unscheduled time on a ControlNet link
network access port (NAP)	port that provides a temporary ControlNet-network connection through an RJ-45 connector
network address	node's address on the ControlNet network
network update interval (NUI)	single occurrence of the ControlNet Network Update Time (NUT)
network update time (NUT)	repetitive time interval in which data can be sent on the ControlNet network
node	port of a physical device connecting to the ControlNet network that requires a network address in order to function on the network; a link may contain a maximum of 107 nodes
non-discrete I/O data transfer	type of data transfer in which blocks of data transferred to or from I/O modules use integer input and output data-table files that you specify; cannot use the processor's input- and output-image tables (I and O files); scheduled transfers are configured in the ControlNet I/O map table, unscheduled transfers make use of ControlNet I/O Transfer (CIO) instructions
owner	device that controls the outputs of an adapter
redundant media	dual-cable system that allows you to receive the best signal over a ControlNet network
repeater	two-port active physical-layer device that reconstructs and retransmits all traffic that it hears on one ControlNet segment to another segment
scheduled transfers	deterministic and repeatable transfers that are continuous and asynchronous to the ladder-logic program scan
segment	trunkline section of ControlNet network with terminators at each end; a segment does not include repeaters; segments connected by repeaters make up a link
tap	component that connects products to the ControlNet trunk cable; a tap is required for each node and for each side of a repeater
terminator	75Ω resistor—mounted in a BNC plug—placed on each end of a ControlNet segment to prevent reflections from occurring at the ends of the cable
trunk cable	bus or central part of the ControlNet cable system
trunk-cable section	length of trunk cable between any two ControlNet taps
unscheduled transfers	non-deterministic data transfers through ladder-initiated communication or programming devices


Conventions

This icon



indicates that the current topic is discussed further in the publication(s) referenced

A series like this



indicates a keystroke procedure for you to follow to get to the correct screen or to complete a task using software



Text that shows what a terminal displays is shown like this: **Press a key**

Text in square brackets indicates an actual key that you press—i.e., [F1]

Text describing information that you must provide is italicized—i.e., *filename*

Related Publications

The 1785 PLC-5 programmable-controller, 6200 programming-software, and ControlNet documentation is organized into manuals according to the tasks that you perform.




For more information on 1785 PLC-5 programmable controllers or the above publications, contact your local Allen-Bradley Company, Inc. sales office or distributor.

Preface
Using This Manual



<p>PLC-5 Programming Software Supplement— ControlNet Support</p> <p>Using the software to configure and monitor a ControlNet network</p> <p>6200-6.4.20</p>	<p>PLC-5 Programming Software Instruction Set Reference</p> <p>Instruction execution, parameters, status bits and examples</p> <p>6200-6.4.11</p>	<p>PLC-5 Programming Software Programming</p> <p>Creating/managing files, saving/restoring files, importing/exporting files creating/editing SFCs, creating/editing ladder</p> <p>6200-6.4.7</p>
<p>PLC-5 Programming Software Software Configuration and Maintenance</p> <p>Installing software, defining data-table files, configuring processor, checking status, clearing faults</p> <p>6200-6.4.6</p>	<p>PLC-5 Programming Software I/O Configuration</p> <p>Configuring intelligent I/O modules</p> <p>6200-6.4.12</p>	

For more information on PLC-5 programming software or the above publications, contact your local Allen-Bradley Company, Inc. sales office or distributor.




For detailed information on different aspects of planning and installing your ControlNet network, see the following publications:


Publication	Publication Number
ControlNet Cable System Component List	AG-2.2
ControlNet Cable System Planning and Installation Manual	1786-6.2.1
ControlNet Coax Tap Installation Instructions	1786-2.3
ControlNet Network Access Cable Installation Instructions	1786-2.6
ControlNet Repeater Installation Instructions	1786-2.7
Industrial Automation Wiring and Grounding Guidelines	1770-4.1

Installing Your ControlNet PLC-5 Processor

Using This Chapter



If you want to read about:	Go to page:
Completing the preliminary setup	1-2
Checking the contents of the processor package	1-2
Handling the processor	1-3
Identifying the processor channels/connectors	1-4
Setting the I/O chassis backplane switches	1-6
Setting the I/O chassis configuration plug	1-7
Installing keying bands for the processor	1-7
Installing and disposing of the processor battery	1-8
Selecting the Data Highway Plus™ (DH+™) station address of Channel 1A	1-10
Specifying the serial interface for Channel 0	1-11
Selecting the ControlNet network address of Channel 2	1-11
Inserting/removing the processor into/from the I/O chassis	1-12
Installing a remote I/O link	1-12
Installing a DH+ link	1-14
Connecting to a ControlNet network	1-15
Connecting a programming terminal	1-16
Selecting appropriate cables	1-18



For detailed information on installing chassis and adapters, see the Enhanced and Ethernet PLC-5 Programmable Controllers User Manual, publication 1785-6.5.12.

Chapter 1

Installing Your ControlNet PLC-5 Processor

Before You Begin



Before installing your ControlNet PLC-5 processor:

1. Complete the following:
 - determine the proper environment
 - configure the proper grounding
 - route the conductors properly




For detailed information on completing these tasks, see the Enhanced and Ethernet PLC-5 Programmable Controllers User Manual, publication 1785-6.5.12.

2. Check your processor package, and make sure that you have the following:

<p>Processor</p> 	<p>ControlNet PLC-5[®] Programmable Controller, 1785-L20C or -L40C</p>
<p>Contents of Tray</p>	<p>1 Lithium Battery, 1770-XYC 1 DIN connector cover 4 Terminating resistors—150Ω^① 2 or 4^② Terminating resistors—82Ω^③ 2 or 4^② 3-pin connectors 2 Keys 1 Battery cover with screw 1 1784-CP7 cable adapter for 1784-CP, -CP5 cables</p>
<p>Documentation</p> 	<p>ControlNet PLC-5 Programmable Controllers User Manual, publication 1785-6.5.14 ControlNet PLC-5 Programmable Controllers Release Notes, publication 1785-6.5.14-RN1 CSA Hazardous Location Approval Supplemental Information, publication AG-4.1 Enhanced and Ethernet PLC-5 Programmable Controllers User Manual, publication 1785-6.5.12 Guidelines for Handling Lithium Batteries, publication AG-5.4 Industrial Automation Wiring and Grounding Guidelines, publication 1770-4.1</p>

① Identified by four colored bands: brown, green, brown, and gold
 ② Two with a PLC-5/20C processor, four with a PLC-5/40C processor
 ③ Identified by four colored bands: gray, red, black, and gold

If any items are missing or incorrect, contact your local Allen-Bradley Company, Inc. sales office or distributor.

Chapter 1**Installing Your ControlNet PLC-5 Processor****Handling the Processor**

Your processor is shipped in a static-shielded container to guard against electrostatic damage. Electrostatic discharge can damage integrated circuits or semiconductors in the processor if you touch backplane connector pins. It can also damage the module when you set configuration plugs or switches inside the module. Avoid electrostatic damage by observing the following precautions.

- Remain in contact with an approved ground point while handling the module—wear a properly grounded wrist strap.
- Do not touch the backplane connector or connector pins.
- When not in use, keep the module in its static-shielded container.


Chapter 1

Installing Your ControlNet PLC-5 Processor

Identifying ControlNet PLC-5 Processor Components

Figure 1.1 and Figure 1.2 show the front panels of the ControlNet PLC-5 processors.


**Figure 1.1
PLC-5/20C Processor Front Panel**



^① Channel 0 is optically coupled (provides high electrical noise immunity) and can be used with most RS-422A equipment as long as:

- termination resistors are not used
- the distance and transmission rate are reduced to comply with RS-423 requirements

Figure 1.2
PLC-5/40C Processor Front Panel



^① Channel 0 is optically coupled (provides high electrical noise immunity) and can be used with most RS-422A equipment as long as:

- termination resistors are not used
- the distance and transmission rate are reduced to comply with RS-423 requirements


Chapter 1

Installing Your ControlNet PLC-5 Processor

Setting the I/O Chassis Backplane Switches

Set the I/O chassis backplane switches using a ball-point pen to set each switch.

Important: Do not use a pencil because the tip can break off and short the switch.




- ① Regardless of this switch setting, outputs are turned off when any of the following occurs:
 - processor detects a runtime error
 - an I/O chassis backplane fault occurs
 - you select Program or Test mode
 - you set a status file bit to reset a local rack
- ② If an EEPROM module is not installed and processor memory is valid, the processor's PROC indicator blinks and the processor sets S:11/9, bit 9 in the major fault status word. To clear this fault, change the processor from Program mode to Run mode and back to Program mode.
- ③ If the processor's keyswitch is set in Remote, the processor enters Remote Run mode after it powers up and has its memory updated by the EEPROM module.
- ④ A processor fault (solid red PROC LED) occurs if processor memory is not valid.
- ⑤ You cannot clear processor memory when this switch is on.

Chapter 1
Installing Your ControlNet PLC-5 Processor

Setting the I/O Chassis Configuration Plug

Set the I/O chassis configuration plug as follows:



1. Locate the chassis configuration plug (between the two left most slots of the chassis).
2. Set the I/O chassis configuration plug.


The default setting is N (not using a power-supply module in the chassis).

Important: You cannot power a single I/O chassis with both a power-supply module and an external power supply.

17075

Installing Keying Bands for the Processor

You receive plastic keying bands with each I/O chassis. Insert the keying bands as follows:



- Install a keying band in the left-most slot between the following pins:
- 40 and 42
 - 54 and 56

ATTENTION: A module inserted into a wrong slot could be damaged by improper voltages connected through the wiring arm. Use keying bands to prevent damage to the module.

12062

Chapter 1**Installing Your ControlNet PLC-5 Processor****Installing and Disposing of the Processor Battery**

The 1770-XYC battery ships with the processor and requires special handling.

For more detailed information on installing and disposing of the battery, see the Allen-Bradley Guidelines for Lithium Battery Handling and Disposal, publication AG-5.4.



ATTENTION: To maintain CSA certification for hazardous areas, do not substitute any other battery for the 1770-XYC.


Tip

You can insert or remove the battery without powering down the processor. If you do not want to lose your program, make sure that the processor is powered on when removing the battery.

Installing or Removing the Processor Battery

To install or remove the battery, follow these steps:

1. Remove the thumb screw on the processor's battery cover, remove the cover, and locate the battery.
2. Install or remove the battery:



To **install** the battery, slide the battery-side connector into the processor-side connector until you hear them snap.

To **remove** the battery, press the lever on the battery-side connector and slide the connectors apart.

19331

3. Replace the battery cover, and secure the battery cover with the thumb screw.
4. On the battery cover, write the date that you installed the last new battery.

Chapter 1**Installing Your ControlNet PLC-5 Processor****Tip**


You can insert or remove the battery without powering down the processor. If you do not want to lose your program, make sure that the processor is powered when replacing the battery.

Replacing the Battery

Replace the lithium battery every year or when the BATT status indicator is red. For estimated battery lifetimes, see the table below:

Processor	Temperature	Worst-Case Battery-Life Estimates		
		Power Off 100%	Power Off 50%	Battery Duration ^①
PLC-5/20C	60°C	218 days	1.17 years	3.7 days
	25°C	1.7 years	3.34 years	15 days
PLC-5/40C	60°C	105 days	207 days	40 hours
	25°C	1.3 years	2.57 years	10.8 days

^① The battery status indicator (BATT) warns you when the battery is low. These durations are based on the battery supplying the only power to the processor—power to the chassis is off—once the status indicator first lights.

Disposing of the Battery

Do not dispose of lithium batteries in a general trash collection when their combined weight is greater than or equal to 0.5 gram. A single 1770-XYC battery contains 0.65 grams of lithium. Check your state and local regulations that deal with the disposal of lithium batteries.



ATTENTION: Follow these precautions:

- ⊗ **Do not** incinerate or expose the battery to high temperatures.
- ⊗ **Do not** solder the battery or leads; the battery could explode.
- ⊗ **Do not** open, puncture, or crush the battery. The battery could explode or toxic, corrosive, and flammable chemicals could be exposed.
- ⊗ **Do not** charge the battery. An explosion may result, or the cell may overheat and cause burns.
- ⊗ **Do not** short positive and negative terminals together. The battery will heat up.


Chapter 1

Installing Your ControlNet PLC-5 Processor

Selecting the DH+ Station Address of Channel 1A

To select the DH+ station address of Channel 1A, set the switches of assembly SW1.

Side View of PLC-5/40C Processor
Switch Assembly SW1



To select:	Set switch:	To:
------------	-------------	-----

DH+ Station Number	1 through 6	(See below)
--------------------	-------------	-------------

Switch 7 is not used—set it to OFF


DH+ Station Number	Switch					
	1	2	3	4	5	6
0	on	on	on	on	on	on
1	off	on	on	on	on	on
2	on	off	on	on	on	on
3	off	off	on	on	on	on
4	on	on	off	on	on	on
5	off	on	off	on	on	on
6	on	off	off	on	on	on
7	off	off	off	on	on	on
10	on	on	on	off	on	on
11	off	on	on	off	on	on
12	on	off	on	off	on	on
13	off	off	on	off	on	on
14	on	on	off	off	on	on
15	off	on	off	off	on	on
16	on	off	off	off	on	on
17	off	off	off	off	on	on
20	on	on	on	on	off	on
21	off	on	on	on	off	on
22	on	off	on	on	off	on
23	off	off	on	on	off	on
24	on	on	off	on	off	on
25	off	on	off	on	off	on
26	on	off	off	on	off	on
27	off	off	off	on	off	on
30	on	on	on	off	off	on
31	off	on	on	off	off	on
32	on	off	on	off	off	on
33	off	off	on	off	off	on
34	on	on	off	off	off	on
35	off	on	off	off	off	on
36	on	off	off	off	off	on
37	off	off	off	off	off	on

DH+ Station Number	Switch					
	1	2	3	4	5	6
40	on	on	on	on	on	off
41	off	on	on	on	on	off
42	on	off	on	on	on	off
43	off	off	on	on	on	off
44	on	on	off	on	on	off
45	off	on	off	on	on	off
46	on	off	off	on	on	off
47	off	off	off	on	on	off
50	on	on	on	off	on	off
51	off	on	on	off	on	off
52	on	off	on	off	on	off
53	off	off	on	off	on	off
54	on	on	off	off	on	off
55	off	on	off	off	on	off
56	on	off	off	off	on	off
57	off	off	off	off	on	off
60	on	on	on	on	off	off
61	off	on	on	on	off	off
62	on	off	on	on	off	off
63	off	off	on	on	off	off
64	on	on	off	on	off	off
65	off	on	off	on	off	off
66	on	off	off	on	off	off
67	off	off	off	on	off	off
70	on	on	on	off	off	off
71	off	on	on	off	off	off
72	on	off	on	off	off	off
73	off	off	on	off	off	off
74	on	on	off	off	off	off
75	off	on	off	off	off	off
76	on	off	off	off	off	off
77	off	off	off	off	off	off

Chapter 1
Installing Your ControlNet PLC-5 Processor

Specifying the Serial Interface of Channel 0


Specify RS-232C, RS-422A, or RS-423 communication for Channel 0 by setting the switches of assembly SW2.



To Specify:	Set Switches:									
	1	2	3	4	5	6	7	8	9	10
RS-232C	ON	ON	ON	OFF	OFF	ON	ON	OFF	ON	OFF
RS-422A	OFF	OFF	ON	OFF	OFF	OFF	OFF	OFF	ON	OFF
RS-423	ON	ON	ON	OFF	OFF	ON	OFF	OFF	ON	OFF

Selecting the ControlNet Network Address of Channel 2

Select your processor's ControlNet network address by setting the two 10-digit rotary switches on the top of the processor.



Tip For optimum throughput, assign addresses to your ControlNet nodes in a sequential order starting with 01 for the controlling processor.


You can select from as many as 99 network addresses (from 01 to 99) for a processor on a ControlNet link. 00 is invalid.

Chapter 1

Installing Your ControlNet PLC-5 Processor

Inserting/Removing the Processor into/from the I/O Chassis

To insert/remove the processor into/from the chassis, do the following:



ATTENTION: Make certain that power to the chassis is off before inserting or removing the processor.

To **insert** a processor into the chassis:

1. Lift the locking bar and the ejector tab.
2. Slide the processor into the left-most slot of the I/O chassis.
3. Press down on the ejector tab, and then close the locking bar over the processor.

To **remove** a processor from the chassis:

1. Save processor memory.
2. Remove power to the processor-resident chassis.
3. Disconnect all cables from the processor's ports.
4. Lift the locking bar and the ejector tab, and then slide the processor from the chassis.

19898

Installing a Remote I/O Link

Install a remote I/O link using 1770-CD cable and either a daisy-chain or trunk-cable/drop-cable configuration.

Trunk-cable/drop-cable considerations:

When using a trunk-cable/drop-cable configuration, use 1770-SC station connectors and follow these cable-length guidelines:

- trunk-cable length—depends on the communication rate of the link; see [Table 1.A](#)
- drop-cable length—30.4 m (100 cable-ft) maximum

Important: When using a trunk-cable/drop-cable configuration, set your communication rate to 57.6kK bit/s.

Verify that your system's design plans specify cable lengths within allowable measurements.

Important: The maximum cable length for remote I/O depends on the transmission rate. Configure all devices on a remote I/O link to communicate at the same rate.

Table 1.A
Correct Cable Length Based on Communication Rate

A remote I/O link using this communication rate:	Cannot exceed this cable length:
57.6K bit/s	3,048 m (approximately 10,000 ft)
115.2K bit/s	1,524 m (approximately 5,000 ft)
230.4K bit/s	762 m (approximately 2,500 ft)



For more information about designing trunk-cable/drop-cable configurations, see the Data Highway/Data Highway Plus/Data Highway II/Data Highway 485 Cable Installation Manual, publication 1770-6.2.2.

For proper operation, terminate **both** ends of a remote I/O link by using the external resistors shipped with the programmable controller. Use either a 150Ω or 82Ω terminator.

Chapter 1
Installing Your ControlNet PLC-5 Processor


If your remote I/O link:	Use this resistor rating:	The maximum number of	
		physical devices that you can connect on the link is:	logical rack numbers that you can scan on the link is:
Operates at 230.4K bit/s	82Ω	32	16
Operates at 57.6K or 115.2K bit/s, and no devices listed below are linked			
Scanners 1771-SN; 1772-SD, -SD2; 1775-SR, -S4A, -S4B; 6008-SQH1, -SQH2 Adapters 1771-AS; 1771-ASB (Series A Only); 1771-DCM Miscellaneous 1771-AF			
Connects to any device listed below:	150Ω	16	16
Scanners 1771-SN; 1772-SD, -SD2; 1775-SR, -S4A, -S4B; 6008-SQH1, -SQH2 Adapters 1771-AS; 1771-ASB (Series A Only); 1771-DCM Miscellaneous 1771-AF			
Operates at 57.6K or 115.2K bit/s, and you do not require over 16 physical devices			

You can install a remote I/O link two ways:

- trunk cable / drop cable—from the drop cable to the connector screw terminals on the remote I/O connectors of the processor
- daisy chain—to the connector screw terminals on the remote I/O connectors of the processor and then to the remote I/O screw terminals of the next remote I/O device

To connect remote I/O cable:

1. Run the 1770-CD cable from the processor to each remote I/O adapter module or processor in the remote I/O system.
2. Connect the signal conductor with **blue** insulation to the 3-pin connector terminal labeled 1 on the processor and to each remote I/O adapter module (or PLC-5 adapter) in the remote I/O system.
3. Connect the **shield** drain wire to the center terminal of the 3-pin connector.
4. Connect the signal conductor with **clear** insulation to the 3-pin connector terminal labeled 2.
5. Tie wrap the remote I/O network cable to the chassis to relieve strain on the cable.
6. Terminate the remote I/O link by connecting an external terminator resistor between the remote I/O terminals labeled 1 and 2.



Chapter 1

Installing Your ControlNet PLC-5 Processor

Installing a DH+ Link

Use 1770-CD cable to connect the processor to a DH+ link.

Follow these guidelines while installing DH+ communication links:

- do not exceed these cable lengths:
 - trunk-cable length—3,048 m (approximately 10,000 cable-ft)
 - drop-cable length—30.4 m (approximately 100 cable-ft)
- do not connect more than 64 stations on a single DH+ link


Use the 3-pin connector on the processor to connect a DH+ link. The connector's port must be configured to support a DH+ communication link.

You can install a DH+ link two ways:


- trunk cable/drop cable—from the drop cable to the connector screw terminals on the DH+ connectors of the processor
- daisy chain—to the connector screw terminals on the DH+ connectors of the processor

To make connections:

1. Connect the signal conductor with **clear** insulation to the 3-pin connector terminal 1 at each end of each cable segment.
2. Connect the **shield** drain wire to the center terminal of the 3-pin connector at both ends of each cable segment.
3. Connect the signal conductor with **blue** insulation to the 3-pin connector terminal 2 at each end of each cable segment.



For more information, see the Data Highway/Data Highway Plus/Data Highway II/Data Highway 485 Cable Installation Manual, publication 1770-6.2.2.



Chapter 1
Installing Your ControlNet PLC-5 Processor

Connecting to a ControlNet Network


Connect a ControlNet PLC-5 processor to a ControlNet network via a tap with a 1-m (39.4-in) drop cable.

Four taps are available from Allen-Bradley Company, Inc.:




We recommend that you use a tap with a straight connector—1786-TPS or 1786-TPYS—when you attach a ControlNet PLC-5 processor to a ControlNet network.

Straight T-tap




1786-TPS

Straight Y-tap




1786-TPYS

Right-angle T-tap



1786-TPR

Right-angle Y-tap



1786-TPYR



Important: ControlNet taps contain passive electronics and must be purchased from Allen-Bradley Company, Inc. for the network to function properly.

After terminating your segments, you connect your node to the network.

Remove the tap's dust cap—located on the straight or right-angle connector—and set it aside.

If your network supports:	Connect the tap's straight or right-angle connector:
nonredundant media	to the channel A connector on the processor—channel B is not used ^①
redundant media	<ul style="list-style-type: none"> from trunk-cable A to channel A on the processor and from trunk-cable B to channel B on the processor

^① Allen-Bradley Company, Inc. recommends using channel A for nonredundant media.



For detailed information on planning and installing your ControlNet system, see the following publications:

Publication	Publication Number
ControlNet Cable System Component List	AG-2.2
ControlNet Cable System Planning and Installation Manual	1786-6.2.1
ControlNet Coax Tap Installation Instructions	1786-2.3
ControlNet Network Access Cable Installation Instructions	1786-2.6
ControlNet Repeater Installation Instructions	1786-2.7
Industrial Automation Wiring and Grounding Guidelines	1770-4.1

Chapter 1

Installing Your ControlNet PLC-5 Processor

Connecting a Programming Terminal

You can connect a programming terminal to a ControlNet PLC-5 processor via a:

- DH+ connection
- serial channel
- ControlNet connection

DH+ Connection

To attach a programming terminal to a ControlNet PLC-5 processor using a DH+ connection:

If you use this card to access a DH+ link:

1784-PCMK



1784-KT, -KT2

1784-KTx, -KTxD

Use cable:

- 1784-PCM6
- 1784-PCM5 with a 1784-CP7 adapter
- 1784-CP6
- 1784-CP6 with a 1784-CP7 adapter
- 1784-CP8 adapter

1784-CP13



Serial Channel

To program the processor using Channel 0, configure the channel for RS-232C using DF1 point-to-point protocol.



If your programming terminal has a:

- 9-pin serial port
- 25-pin serial port

Use cable:

1784-CP10

1784-CP11




ControlNet Connection

ATTENTION: Do not connect the same communication card to both the NAP and a tap on the ControlNet network.


You can connect programming devices to a ControlNet network through:

- the ControlNet network access cable (1786-CP)
- a tap on a ControlNet network


Using 1784-KTCx communication card on coax media^①




Using 1784-KTC or -KTCx communication card and NAP^①



Using 1770-KFC communication interface on coax media^①



Using 1770-KFC communication interface and NAP^①



^① Shown with redundant media

^② The network access cable (1786-CP) can be plugged into any ControlNet product's NAP to provide programming capability on the ControlNet network. A programming terminal connected through this cable is counted as a node and must have a unique address.



ATTENTION: Use the **1786-CP** cable when connecting a programming terminal to the network through a NAP. Using a commercially available RJ-style cable could result in network failure.

Chapter 1

Installing Your ControlNet PLC-5 Processor

Selecting Appropriate Cables



This section lists information about:

- serial cables
- DH+ programming cables
- remote I/O cables
- ControlNet cables

For more information about cables, see the Enhanced and Ethernet PLC-5 Programmable Controllers User Manual, publication 1785-6.5.12.

Serial Cables

You can make your own serial cables or purchase them from Allen-Bradley Company, Inc.

The side label of the processor shows the following table, which lists Channel 0 (serial port) pin assignments.

Pin	RS-232C	RS-422A	RS-423
1	C.GND	C.GND	C.GND
2	TXD.OUT	TXD.OUT ⁻	TXD.OUT
3	RXD.IN	RXD.IN ⁻	RXD.IN
4	RTS.OUT	RTS.OUT ⁺	RTS.OUT
5	CTS.IN	CTS.IN ⁺	CTS.IN
6	DSR.IN	DSR.IN	DSR.IN
7	SIG.GND	SIG.GND	SIG.GND
8	DCD.IN	DCD.IN	DCD.IN
9			
10	NOT USED	DCD.IN	NOT USED
11			
12			
13	NOT USED	CTS.IN ⁻	NOT USED

Pin	RS-232C	RS-422A	RS-423
14	NOT USED	TXD.OUT ⁺	SEND COM
15			
16	NOT USED	RXD.IN ⁺	REC COM
17			
18			
19	NOT USED	RTS.OUT ⁻	NOT USED
20	DTR.OUT	DTR.OUT	DTR.OUT
21			
22	NOT USED	DSR.IN	NOT USED
23	NOT USED	DTR.OUT	NOT USED
24			
25			

The shading indicates that the pin is reserved.

This processor’s serial port can support these configurations:

Digital Interface	Maximum Cable Length
RS-232C	15 m (approximately 50 ft)
RS-422A (compatible)	61 m (approximately 200 ft)
RS-423	61 m (approximately 200 ft)

Chapter 1**Installing Your ControlNet PLC-5 Processor**

Important: Follow these guidelines:

- When Channel 0 is configured for RS-422A compatibility, do not use terminating resistors anywhere on the link.
- When Channel 0 is configured for RS-422A (compatible) and RS-423, do not go beyond 61 m (approximately 200 ft). This distance restriction is independent of the transmission rate.

DH+ Programming Cables

When using this communication card:	Use this cable:
1784-KT, -KT2	<ul style="list-style-type: none"> • 1784-CP6 • 1784-CP with 1784-CP7 adapter • 1784-CP8 adapter
1784-KL, -KL/B	<ul style="list-style-type: none"> • 1784-CP8 adapter
1784-KTK1	1784-CP5 with 1784-CP7 adapter
1784-KTx, KTxD	1784-CP13
1784-PCMK	<ul style="list-style-type: none"> • 1784-PCM6 • 1784-PCM5 with 1784-CP7 adapter

Remote I/O Cables

Use 1770-CD or cable for remote I/O. See page 1-12 for more information.

ControlNet Cables

Several types of RG-6 quad-shield cable may be appropriate for your ControlNet installation—depending on the environmental factors associated with your application and installation site.


Chapter 1**Installing Your ControlNet PLC-5 Processor**

The following ControlNet cable system components are available from the Allen-Bradley Company, Inc.:

Item ^①		Cat. No.
ControlNet Coax Tool Kit		1786-CTK
Coax Tap Kit	Right-angle T-tap	1786-TPR
	Straight T-tap	1786-TPS
	Right-angle Y-tap	1786-TPYR
	Straight Y-tap	1786-TPYS
Repeaters	High-voltage ac & dc	1786-RPT
	Low-voltage dc	1786-RPTD
RG-6 Quad Shield Cable	Standard-PVC CM-CL2	1786-RG6
ControlNet Network Access Cable—3.05 m (10 ft)		1786-CP
BNC Connectors	Barrel (plug to plug)	1786-BNCP
	BNC/RG-6 plug	1786-BNC
	Bullet (jack to jack)	1786-BNCJ
	Isolated-bulkhead (jack to jack)	1786-BNCJI
	Terminators (BNC-75Ω)	1786-XT

^① For a complete list of ControlNet cable system components that are available from Allen-Bradley Company, Inc. and other sources, see the ControlNet Cable System Component List, publication AG-2.2.

Important: Install all wiring for your ControlNet system in accordance with the regulations contained in the National Electric Code (or applicable country codes), state codes, and applicable municipal codes.




For detailed information on ControlNet cabling, see the following:

Publication	Publication Number
ControlNet Cable System Component List	AG-2.2
ControlNet Cable System Planning and Installation Manual	1786-6.2.1
ControlNet Coax Tap Installation Instructions	1786-2.3
ControlNet Network Access Cable Installation Instructions	1786-2.6
ControlNet Repeater Installation Instructions	1786-2.7
Industrial Automation Wiring and Grounding Guidelines	1770-4.1

Planning to Use Your ControlNet PLC-5 Processor

Using This Chapter



Understanding ControlNet I/O

If you want to read about:	Go to page:
Understanding ControlNet I/O	2-1
Understanding ControlNet I/O mapping	2-7
Using the ControlNet PLC-5 processor in a ControlNet I/O system	2-13
Converting from a remote I/O system to a ControlNet I/O system	2-15

The ControlNet system is designed to:

- provide high-speed, repeatable, deterministic I/O transmission
- allow control and message information to co-exist on the same physical media
- make sure that I/O data transfers are not affected by
 - programming-terminal message activity
 - inter-PLC processor message activity on the network

Scheduled Data-Transfer Operations on a ControlNet Network

ControlNet scheduled data transfer on a PLC-5/20C or -5/40C processor:


- is continuous
- transmits asynchronous to the ladder-logic program scan
- occurs at the actual rate displayed on the 6200 Programming Software ControlNet I/O Mapping (Monitor) screen in the **Act Net Pckt Time (ms)**—Actual Network Packet Time—field

In scheduled discrete I/O data transfer, for example, between logic scans—i.e., during “housekeeping”—the following updates occur:

- the gathered input image is moved from a private memory buffer to the processor’s input-image file for use during the next logic scan
- the data from the output-image file is put into a private memory buffer and is sent during the next scheduled communication

Chapter 2Planning to Use Your ControlNet
PLC-5 Processor

A similar method is used for all scheduled data-transfer operations.



The following scheduled data-transfer operations are supported by the PLC-5/20C and -5/40C processors on a ControlNet network:

Table 2.A
ControlNet Scheduled Data-Transfer Operations

Operation	Description
Discrete I/O Data Transfer	Performed in a deterministic and repeatable manner asynchronous to and independent of the ladder-logic program scan. You configure all ControlNet discrete I/O data transfers on a per-node basis in the I/O map table. ^①
Non-discrete I/O Data Transfer	Handled with the same priority as discrete I/O data transfer. You can update analog data without using block-transfer instructions in ladder programs. You do this by including non-discrete I/O data-transfer configurations in the I/O map table. This data is updated in the buffers and data-table files between logic scans in the same manner as that used in discrete I/O data transfer. ^①
Peer-to-peer Communication	Allows the “controlling” processor at network address 01 to communicate with other ControlNet processors on the ControlNet network with the same priority as that of the discrete and non-discrete I/O data transfers discussed above. ^①


^① While scheduled data transfer is asynchronous to program scanning, all data is presented synchronously to the processor and output buffers during housekeeping.

Unscheduled Data-Transfer Operations on a ControlNet Network

The ControlNet network allows you to use unscheduled messaging when deterministic delivery is not required. Unscheduled operations include:

- unscheduled non-discrete I/O data transfers—through ControlNet I/O Transfer (CIO) instructions
- peer-to-peer messaging—through Message (MSG) instructions
- messaging from programming devices

The ControlNet system places your scheduled transfers in the first part of each Network Update Interval (NUI), time is automatically reserved for network maintenance, and unscheduled transfers are performed during the time remaining in the interval.



Unscheduled messaging on a ControlNet network is non-deterministic. Your application and your configuration—number of nodes, application program, NUT, etc.—help determine how much time there is for unscheduled messaging.

Important: The ControlNet network reserves time for at least one unscheduled transfer per NUI.

Chapter 2
 Planning to Use Your ControlNet
 PLC-5 Processor


Table 2.B
ControlNet Unscheduled Data-Transfer Operations

Operation	Description	Features
Non-discrete I/O Data Transfer CIO Instructions	Perform ladder-initiated unscheduled non-discrete I/O data transfers on a ControlNet network by using ControlNet I/O Transfer (CIO) instructions. The data type for these transfers (CT) has the following information: <ul style="list-style-type: none"> • Command: <ul style="list-style-type: none"> 1771 READ reads data from a 1771 non-discrete I/O module 1771 WRITE writes data to a 1771 non-discrete I/O module 1794 FAULT ACTION changes the action a module takes when it faults 1794 IDLE ACTION changes the action a module takes when it is idle 1794 CONFIG DATA changes a module's configuration data 1794 SAFE STATE DATA changes a module's safe-state data • Data-table address in source processor • Size of message in words • Network address of destination node • Slot of destination module • Port number—set to 2 for the ControlNet network • Flags: <ul style="list-style-type: none"> .TO forces a transfer to time out .EW indicates that the transfer is waiting for an open connection .CO transfer is made continuously in Run mode .ER indicates that the transfer was terminated due to an error .DN indicates that the transfer was made without error .ST indicates that the transfer was started .EN indicates that the transfer instruction is enabled • Error code—indicates the error when the .ER bit is set • Done length—indicates the number of words transferred 	<ul style="list-style-type: none"> • As many as 32 1771 READ and/or 1771 WRITE CIOs can be active at a time^① • A minor fault is set when 32 1771 READ and/or 1771 WRITE CIOs are active at a time • You cannot use CIO instructions to read or write blocks of data from or to 1794 Flex I/O modules; but you can use these instructions to configure 1794 features listed in the “Description” column • As many as 8 1794 Flex I/O CIOs can be active at a time^① • A minor fault is set when 8 1794 Flex I/O CIOs are active at a time • Any transfer initiated from a Processor Input Interrupt (PII) or Selectable Timed Interrupt (STI) program suspends execution of the program scan until the transfer is completed • Important: This can extend your program scan by ten's of ms. • No transfer is initiated when the processor is in Program mode • Transfers that have been running with the .CO bit set automatically restart on the Program-to-Run transition when the Continue Last step bit is set and the data table has not changed • A transfer has a maximum size of 64 words • Only the processor “owner” of an adapter can send or receive transfers to or from any of that adapter's modules See pages 4-4 and C-1 for more information.
Peer-to-peer Messaging MSG Instructions	You can use ControlNet message (MSG) instructions and the data-type MG to create unscheduled messages that are initiated by one ControlNet PLC-5 processor and sent to another ControlNet PLC-5 processor. The MG data type for the ControlNet instruction has the following information: <ul style="list-style-type: none"> • Command—PLC-5 TYPED READ or PLC-5 TYPED WRITE • Data-table address in source processor • Size of message in elements • Network address of destination processor • Data-table address in destination processor • Port number—set to 2 for the ControlNet network • Flags: <ul style="list-style-type: none"> .TO forces a message to time out .EW indicates that the message is waiting for an open connection .CO message is sent continuously in Run mode .ER indicates that the message was terminated due to an error .DN indicates that the message was sent without error .ST indicates that the message was started .EN indicates that the message instruction is enabled • Error code—indicates the error when the .ER bit is set 	<ul style="list-style-type: none"> • As many as 32 ControlNet MSGs can be active at a time^① • A minor fault is set when 32 ControlNet MSGs are active at a time • All messages have the same priority • No message is initiated when the processor is in Program mode • Messages that have been running with the .CO bit set automatically restart on the Program-to-Run transition when the Continue Last step bit is set and the data table has not changed • Each message has a maximum size of 1000 elements See pages 4-2 and C-1 for more information.

Operation	Description	Features
①	Because connections are opened and closed as needed, more can exist in a program as long as no more than this number are active at one time.	

Using I/O Forcing Operations

ControlNet I/O forcing occurs in the same way as remote I/O forcing in the PLC-5/20 and -5/40 processors. The processor performs the forcing and transmits the forced data to the output- and input-image tables. You can force any discrete I/O data placed in the I/O image; however, forcing of non-discrete I/O data is not supported.



For detailed information on forcing, see PLC-5 Programming Software Configuration and Maintenance, publication 6200-6.4.6.

Using Immediate Data-Transfer Operations

ControlNet Immediate Data I/O transfers—Immediate Data Input (IDI) and Immediate Data Output (IDO)—perform similarly to the remote-I/O supported immediate I/O transfers—Immediate Input (INN) and Immediate Output (IOT)—which the ControlNet system also supports. The logic scan is temporarily interrupted while the most recent state of one discrete input or output word is read from or written to the private memory buffer.

Chapter 2
 Planning to Use Your ControlNet
 PLC-5 Processor




Table 2.C
ControlNet Immediate Data-Transfer Operations

Instructions	Description
<p>Immediate I/O—ControlNet and Remote I/O</p> <p>001 — (IIN) —</p> <p>001 — (IOT) —</p>	<p>In the case of an IIN, the most recent copy of the specified input word secured in the last discrete I/O data transfer from the corresponding I/O chassis is used. This value is moved from the private memory buffer to the working data table and is used in all subsequent ladder instructions. This data could be as old as the time taken since the last asynchronous I/O update, and it may not actually reflect the latest state of the input word.</p> <p>In the case of an IOT, the current state of the specified output word is copied to the private memory buffer and is used on the next output update to the I/O chassis. The actual change is not communicated until the next asynchronous I/O transfer.</p> <p>Only 1 word of I/O data can be updated per instruction.</p>
<p>ControlNet Immediate Data I/O</p> <p>IDI IMMEDIATE DATA INPUT Data file offset 232 Length 10 Destination N11:232</p> <p>IDO IMMEDIATE DATA OUTPUT Data file offset 175 Length 24 Source N12:175</p>	<p>The ControlNet Immediate Data I/O instructions work in much the same way as the immediate I/O instructions. During an input instruction, the most recent data is copied from the private memory buffer to a data-table address that you specify. In the case of an output instruction, the data is copied from an area that you specified to the private memory buffer and sent on the next I/O update.</p> <p>As many as 64 words can be transferred per instruction.</p> <p>Important: In most cases, you should set the Data file offset and the Source—of an IDO—or the Data file offset and the Destination—of an IDI—to the same address. See page 4-6 for more information on this and other aspects of using ControlNet IDI and IDO instructions.</p>

Chapter 2**Planning to Use Your ControlNet
PLC-5 Processor****Understanding ControlNet
I/O Mapping**

All scheduled data transfers must be mapped on a ControlNet network. You specify where I/O data is to be read from or written to—i.e., mapped. You do this and establish the relationship between processors, I/O adapters, and data-table file addresses by creating and maintaining an I/O map table. An I/O map-table entry is required for each scheduled data transfer. The map table is stored in the configuration section of memory and is not accessible by your application program.

Using the 6200 PLC-5 Programming Software, you can automatically configure and map nodes attached to your ControlNet I/O. See Chapter 3 for information on ControlNet automatic configuration and I/O mapping.

Reserving Space for Non-ControlNet I/O

Non-ControlNet processor-resident local I/O and remote-I/O devices can only use fixed I/O image locations based on rack number for discrete I/O data transfer, while discrete I/O data transfer between ControlNet nodes can be mapped to any unused location in the I/O image tables. Before mapping your ControlNet I/O, therefore, you should configure any processor-resident local I/O and any remote I/O racks on non-ControlNet channels. This allows the 6200 PLC-5 Programming Software to reserve input- and output-image space for all non-ControlNet processor-resident local I/O and remote-I/O chassis.

Processor-Resident Local I/O

If you first configure processor-resident local I/O on your processor, the 6200 PLC-5 Programming Software reserves processor-resident local chassis input- and output-image space starting at offset 0 in both files.

The following table shows the default number of input and output words automatically reserved by the 6200 PLC-5 Programming Software for the different sizes and addressing modes of processor-resident local I/O:

Addressing Mode	Number of Words Reserved			
	4 Slots	8 Slots	12 Slots	16 Slots
2 Slot	8	8	8	8
1 Slot	8	8	16	16
1/2 Slot	8	16	24	32

Important: ControlNet I/O cannot map into any part of a rack number used by the processor-resident rack.

Remote I/O

The following table shows the default number of input and output words reserved by the 6200 PLC-5 Programming Software for the different sizes and addressing modes of non-ControlNet remote I/O if you first configure non-ControlNet remote I/O on your processor:

Addressing Mode	Number of Words Reserved			
	4 Slots	8 Slots	12 Slots	16 Slots
2 Slot	2	4	6	8
1 Slot	4	8	12	16
1/2 Slot	8	16	24	32

The 6200 PLC-5 Programming Software reserves non-ControlNet remote-I/O output- and input-image space according to these guidelines:

- It does not overlap processor-resident local I/O reserved image space
- It addresses input- and output-image space offset in octal from
 - 00-37—for the PLC-5/20C processor
 - 00-177—for the PLC-5/40C processor
- The output-image offset value in the I/O map corresponds to the first slot of the referenced chassis—i.e., in a 4-slot chassis set for 1-slot addressing, the corresponding output-image offset of O:10 would map the words O:10, O:11, O:12, and O:13 to slots 0, 1, 2, and 3 respectively
- The input-image offset corresponds to the first slot in the referenced rack, and the offset location of the input modules in that rack corresponds to the same offset in the image table—i.e., if a chassis set for 1-slot addressing has an input-image offset of I:10 and an input module in slot 3 (of 0-7), the word that corresponds to that input module would be I:10 + 3, or I:13

Mapping ControlNet Data Transfer

The ControlNet I/O map table can contain up to 64 entries. Each map-table entry corresponds to one transfer—either input or output—of data between the ControlNet processor and an I/O rack, an I/O module, or another ControlNet processor.

Table 2.D
Number of ControlNet I/O Map-Table Entries Required

Data-Transfer Type	Number of Entries Required
1771 Discrete I/O Data Transfer	1 per adapter
1771 Non-discrete I/O Data Transfer	1 or 2 per module
1794 Discrete and Non-discrete I/O Data Transfer	2 per adapter
ControlNet PLC-5 Peer-to-peer Communication	1 per message

Table 2.E
Files That You Configure with the I/O Map for Scheduled I/O Usage

File	Description
Status File	User-specified integer data-table file containing status information about all of the ControlNet network's scheduled I/O map-table entries. Each entry has a status-file offset field pointing to three status words associated with the entry.
Data Input File (DIF)	User-specified integer data-table file with a maximum of 1000 words. This space is used for both non-discrete input data and peer-to-peer input over the ControlNet network. Scheduled peer-to-peer inputs can also use the input-image file.
Data Output File (DOF)	User-specified integer data-table file with a maximum of 1000 words. This space is used for both non-discrete output data and peer-to-peer output over the ControlNet network. Scheduled peer-to-peer outputs can also use the output-image file.
Default Configuration File	User-specified integer data-table file used to store non-discrete I/O data transfer configuration data when the automatic-mapping feature is used.

Table 2.F
ControlNet I/O Map-Table Entry Fields

Map-Table Entry Field	Description
Node and Slot/Message Numbers	<p>This is the entry's network location, currently defined as <i>node.slot/message</i>. The node value is the ControlNet network address of the destination device. The slot/message value takes on different meanings with the different communication options:</p> <ul style="list-style-type: none"> • 1771 and 1794 discrete I/O data transfer—the slot value does not apply because the mapping granularity is based on the physical chassis • 1771 non-discrete I/O data transfer—0-15, the slot number is always the physical slot location inside the 1771 chassis regardless of addressing mode within the chassis • 1794 non-discrete I/O data transfer—0-7, the slot number is always the physical location in the 1794 system • peer-to-peer communication—1-16, the message number represents one of sixteen scheduled peer messages available per processor; and it must be the same for both processors involved
Module/Message Type	This allows you to specify the module type or peer-to-peer message type—Peer Out or Peer In—in offline and online programming. It also determines how the map-table entries are configured for the different modules and peer-to-peer messages.
Expected Network Packet Time (ENPT)	You set this to the maximum time allowed for the network to update the requested data.
Actual Network Packet Time (ANPT)	This read-only field displays the actual time it takes for the network to update the requested data.

Chapter 2**Planning to Use Your ControlNet
PLC-5 Processor**

Map-Table Entry Field	Description
Input File and Size	This is the offset in the input file where the data is to be stored and the number of words to be received from the input device. For discrete I/O data transfer, the offset is into the input-image table; for non-discrete I/O data transfer or peer-to-peer communication with another ControlNet processor, the offset is into the Data Input File entered on the ControlNet configuration screen. Scheduled peer-to-peer inputs can also use the input-image file.
Output File and Size	This is the offset in the output file where the data is located and the number of words of the output transfer. For discrete I/O data transfer, the offset is into the output-image table; for non-discrete I/O data transfer or peer-to-peer communication with another ControlNet processor, the offset is into the Data Output File (DOF) entered on the ControlNet configuration screen. Scheduled peer-to-peer outputs can also use the output-image file.
Status File Offset	This is an offset in a status file that points to three words of information on the status of this map-table entry.
Configuration File and Size	Used only in 1771 non-discrete I/O data transfer and 1794 configurations, this is the offset in a configuration file where configuration information needed for this node is located and the size in words of the information.

Discrete I/O Data-Transfer Mapping

Regardless of the type of I/O—e.g., 1771, 1794—all ControlNet discrete I/O data is stored within the processor's I/O image files according to the corresponding I/O map-table entry. Any status information transferred along with the I/O data is stored in a separate status file that you specify during configuration.

Non-discrete I/O Data-Transfer Mapping

All ControlNet non-discrete I/O data is stored in integer files that you specify in a ControlNet configuration screen. The ControlNet processor supports two distinct image files; both are integer data-table files that you specify:

- Data Input File (DIF)
- Data Output File (DOF)

Each map-table entry for a non-discrete I/O data transfer defines an offset into the DIF or DOF where the data is stored. Using separate data-table files for non-discrete I/O data transfer allows the processor to present non-discrete I/O data in the same way as discrete I/O data—continuously transmitted and asynchronous to the ladder-logic program scan.

1771 Modules

ControlNet 1771 discrete I/O data-transfer mapping requires one map-table entry per module. ControlNet 1771 non-discrete I/O data-transfer mapping requires one or two map-table entries per module, depending on the module type.

The PLC-5/20C and -5/40C ControlNet non-discrete I/O data-transfer mechanism makes it possible to eliminate block-transfer programming to communicate with the 1771 modules listed in [Table 2.G](#).

Table 2.G
1771 Non-discrete I/O Data-Transfer Mapping

Module Type	Description ^{①②}	Default Entries per Module	Default Input Size	Valid Input Size(s)	Default Output Size	Valid Output Sizes	Default Config. Size	Valid Configuration Sizes
1771-CFM/A	1771-CFM/A Configurable Flowmeter Module	2	41	0-41	60	0-4, 14, 24, 34, 44, 48, 52, 56, 60	60	0-4, 14, 24, 34, 44, 48, 52, 56, 60
1771-DE/A	1771-DE/A Absolute Encoder Module	2	2	0, 2	20	0, 5, 10, 15, 20, 22	20	0, 5, 10, 15, 20, 22
1771-IE	1771-IE Analog Input Module	1	8	1-8				
1771-IF	1771-IF Analog Input Module	1	8	1-64				
1771-IFE/A	1771-IFE/A Analog Input Module	1	20	5-20			37	0, 3, 37
1771-IFE/B	1771-IFE/B Analog Input Module	1	20	5-22			37	0, 3, 37, 39
1771-IJ	1771-IJ Encoder/Counter Module	2	1	0, 1	3	0-3	3	0-3
1771-IK	1771-IK Encoder/Counter Module							
1771-IL/A	1771-IL/A Isolated Analog Input Mod.	1	12	5-12			19	0, 2, 19
1771-IL/B	1771-IL/B Isolated Analog Input Mod.	1	12	5-15			19	0, 2, 19, 36, 37
1771-IR/A	1771-IR/A RTD Input Module	1	8	3-8			14	0, 2, 8, 14
1771-IR/B	1771-IR/B RTD Input Module	1	8	3-9			14	0, 2, 8, 14, 15
1771-IS	1771-IS Multiplexer Input Module	1	6	1-7				
1771-IXE/A	1771-IXE/A Thermocouple/Millivolt Input Module	1	12	4-12			27	0, 1, 19, 27
1771-IXE/B	1771-IXE/B Thermocouple/Millivolt Input Module	1	12	4-13			27	0, 1, 19, 27, 28
1771-IXHR/A	1771-IXHR/A High-resolution Thermocouple/Millivolt Input Module	1	12	4-13			27	0, 3, 19, 27, 28
1771-OF	1771-OF Analog Output Module	2	1	0-1	4	4-60		
1771-OFE/A	1771-OFE/A Analog Output Module	2	5	0, 5	13	1-5, 13	13	0, 5, 13
1771-OFE/B	1771-OFE/B Analog Output Module							
N-Series/A	1771 N-Series Analog Module	2	28	0, 20-28	59	0, 2-9, 59	59	0, 2-9, 59
1771-QA	1771-QA Stepper Positioning Module	1	4	1-10				
1771-QB	1771-QB Linear Positioning Module	1	5	1-33				
1771-QC	1771-QC Servo Positioning Module	1	6	1-14				
1771-SN	1771-SN Sub I/O Scanner Module	2	16	0, 7-63	16	0, 7-63		
1771-VHSC/A	1771-VHSC Very High-speed Counter Module	2	18	0, 4-26	64	0-2, 4, 12, 20, 24, 29, 34, 39, 44, 49, 54, 59, 64	64	0-2, 4, 12, 20, 24, 29, 34, 39, 44, 49, 54, 59, 64
1771-Generic	1771 Generic Module ^③	1	1	0-64	1	0-64	1	0-64

① ENPT Default = 4 x NUT

② ENPT Range = 2-15000 ms

③ For newly released modules or modules that can have multiple configurations but only one configuration is being used, you can use the generic module type and specify the input and/or output sizes.

Chapter 2**Planning to Use Your ControlNet
PLC-5 Processor**

The types of modules that may be accommodated by the processor's scheduled non-discrete I/O data-transfer mechanism are typically those modules that require a one-time configuration and then continuously read or write.

To communicate with the modules listed in [Table 2.G](#) as well as with other 1771 analog modules, you can also include explicit CIO instructions in your ladder-logic program. See pages [4-4](#) and [C-1](#) for more information.

1794 Modules

ControlNet 1794 Flex I/O mapping requires two map-table entries per adapter.

The ControlNet scheduled transfer mechanism makes it possible to map the 1794 modules listed in [Table 2.H](#).

Table 2.H
1794 Flex I/O Data-Transfer Mapping

Module Type	Description ^{①②}	Default Input Size	Valid Input Size(s)	Default Output Size	Valid Output Size
1794-OE4/A	1794-OE4/A Analog Output Module	1		4	
1794-IE4XOE2/A	1794-IE4XOE2/A Analog I/O Module	5	1-5	2	
1794-IE8/A	1794-IE8/A Analog Input Module	9	1-9		

① ENPT Default = 4 x NUT

② ENPT Range = 2-15000 ms

Other ControlNet Processors

ControlNet scheduled peer-to-peer communications between ControlNet processors require one map-table entry per message. The PLC-5 processor at node 01, the controlling processor, must be included in each message.

The ControlNet transfer mechanism makes it possible to map the scheduled peer-to-peer messages listed in [Table 2.I](#).

Table 2.I
Peer-to-Peer Communications Mapping

Message Type	Description ^{①②}	Default Input Size	Valid Input Sizes
Peer In	Scheduled Peer In	64	1-64
Peer Out to ___	Scheduled Peer Out		

① ENPT Default = 4 x NUT

② ENPT Range = 2-15000 ms

Chapter 2**Planning to Use Your ControlNet
PLC-5 Processor**

To communicate between any ControlNet PLC-5 processors on the ControlNet network, you can include explicit MSG instructions in your ladder-logic program. See pages 4-2 and C-1 for more information.

Using the ControlNet PLC-5 Processor in a ControlNet I/O System


There can be only one PLC-5/20C or -5/40C processor updating I/O adapters on a ControlNet network.

- the PLC-5/20C or -5/40C processor updating the I/O adapters must be at network address 01—this is the “controlling” processor
- only the controlling processor is allowed to send CIO instructions
- additional PLC-5/20C or -5/40C processors can do scheduled transfers to the PLC-5/20C or -5/40C processor at node 01 by using peer-to-peer communications through the map table, but they cannot directly communicate with or control the ControlNet remote I/O


In addition to your controlling processor, you can attach the following ControlNet devices to your network:

Catalog Number(s)	Device(s)	Function
1785-L20C, -L40C	PLC-5/20C and -5/40C Programmable Controllers	Communicate with other PLC-5/20C or -5/40C processors using scheduled or unscheduled peer-to-peer communication
1784-KTC	ControlNet KTC Communication Card	Allows other computer platforms to communicate with the ControlNet network; for programming only
1784-KTCx	ControlNet KTCx Communication Card	Allows other computer platforms to communicate with the ControlNet network; supports redundant media; for programming MMI
1770-KFC	ControlNet Serial/Parallel Communication Interface	Connects a serial or parallel device to a ControlNet network; supports redundant media
1771-ACN	1771 ControlNet I/O Adapter	Allows the PLC-5/20C or -5/40C processor remote access to Allen-Bradley's family of 1771-designated I/O modules via a ControlNet network; nonredundant only
1771-ACNR	1771 ControlNet I/O Adapter	Allows the PLC-5/20C or -5/40C processor remote access to Allen-Bradley's family of 1771-designated I/O modules via a ControlNet network; supports redundant media
1794-ACN	1794 ControlNet Flex I/O Adapter	Allows the PLC-5/20C or -5/40C processor remote access to Allen-Bradley's family of 1794-designated I/O modules via a ControlNet network; nonredundant only

Chapter 2
Planning to Use Your ControlNet
PLC-5 Processor



Example of a ControlNet Network without Redundant Media



Example of a ControlNet Network with Redundant Media

See page 3-4 for more information on ControlNet node configuration.

Converting from a Non-ControlNet Remote I/O System to a ControlNet I/O System

When you download archived files to a PLC-5/20C or -5/40C processor, the 6200 PLC-5 Programming Software ignores Channel 2 configuration information from anything other than a ControlNet-processor program because Channel 2 is reserved for ControlNet communication on the PLC-5/20C and -5/40C processors. The software sets Channel 2 to the ControlNet default configuration.

Program files ^① for this process:	Archived from a:	On channel:	Can be run on a PLC-5/20C or -5/40C channel:	If they fit and are:		
Messaging and I/O	<ul style="list-style-type: none"> • PLC-5/11 • PLC-5/20 • PLC-5/20C • PLC-5/20E • PLC-5/30 • PLC-5/40 • PLC-5/40C 	<ul style="list-style-type: none"> • PLC-5/40E • PLC-5/40L • PLC-5/60 • PLC-5/60L • PLC-5/80 • PLC-5/80E 	0	0	downloaded unchanged	
			1A	1A		
	<ul style="list-style-type: none"> • PLC-5/20 • PLC-5/20C • PLC-5/20E • PLC-5/30 • PLC-5/40 • PLC-5/40C 	<ul style="list-style-type: none"> • PLC-5/40E • PLC-5/40L • PLC-5/60 • PLC-5/60L • PLC-5/80 • PLC-5/80E 	1B	1B		
		<ul style="list-style-type: none"> • PLC-5/20C • PLC-5/40C 		2	2	
		<ul style="list-style-type: none"> • PLC-5/11 • PLC-5/20 • PLC-5/20C • PLC-5/20E • PLC-5/30 • PLC-5/40 • PLC-5/40C 	<ul style="list-style-type: none"> • PLC-5/40E • PLC-5/40L • PLC-5/60 • PLC-5/60L • PLC-5/80 • PLC-5/80E 	1A	2	performed by the ControlNet network—you must make these changes manually by reprogramming ^{②③④}
		<ul style="list-style-type: none"> • PLC-5/20 • PLC-5/20C • PLC-5/20E • PLC-5/30 • PLC-5/40 • PLC-5/40C 	<ul style="list-style-type: none"> • PLC-5/40E • PLC-5/40L • PLC-5/60 • PLC-5/60L • PLC-5/80 • PLC-5/80E 	1B	2	
		<ul style="list-style-type: none"> • PLC-5/40 • PLC-5/60 	<ul style="list-style-type: none"> • PLC-5/80 	2A or 2B	2	
			1A or 1B	performed by DH+ or remote I/O—you must make these changes manually by reprogramming ^⑤		

Chapter 2
 Planning to Use Your ControlNet
 PLC-5 Processor

Program files ^① for this process:	Archived from a:	On channel:	Can be run on a PLC-5/20C or -5/40C channel:	
			If they fit and are:	
I/O	<ul style="list-style-type: none"> • PLC-5/20E • PLC-5/60L • PLC-5/40E • PLC-5/80E • PLC5/40L 	2	1A or 1B	performed by remote I/O—you must make these changes manually by reprogramming ^⑤
			2	performed by the ControlNet network—you must make these changes manually by reprogramming ^{③④⑤}

① These include processor files, data-table files, and port configurations.

② If you do not update the program, the ControlNet processor will fault.


③ You must change block-transfer instructions for the ControlNet system from the standard block transfer read (BTR) and block transfer write (BTW) instructions to scheduled transfers or to unscheduled CIO instructions.

④ You must edit non-ControlNet PLC-5 programs containing references to the I/O Status File for use with I/O connected via the ControlNet network. Information regarding ControlNet status is stored in a separate data file that you specify through the 6200 PLC-5 Programming Software.

⑤ If you do not update the program, the data-table locations corresponding to the “missing” I/O devices will not be updated.


Configuring Your ControlNet System

Using This Chapter




If you want to read about:	Go to page:
Matching the processor configuration with the ControlNet configuration	3-2
Defining local rack characteristics	3-3
Editing the ControlNet node information	3-4
Editing ControlNet I/O mapping	3-6
Editing ControlNet 1794 I/O module action	3-10

ControlNet Configuration Edit Screens in the 6200 Programming Software




Chapter 3
Configuring Your ControlNet System

Matching the Processor Configuration with the ControlNet Configuration



Follow the steps on the left to go to the ControlNet Node Information (Monitor) screen. If the ControlNet information in the processor does not match that on the current ControlNet link, the software redisplay the Channel Overview screen with a new prompt and set of function keys.




If you want to:	Do this:
apply the processor configuration information to the current ControlNet link configuration, then go to the ControlNet Node Information (Monitor) screen	Press [F10]—Apply to Link
return to the original Channel Overview screen	Press [Esc]

Chapter 3 Configuring Your ControlNet System

Defining Local Rack Characteristics

If you are programming offline, configuring Channel 2 for the first time, and entering an edit screen for the first time—or if you follow the steps on the left—the software prompts you to select the number of slots in the local chassis and your addressing mode.



```

ControlNet - Node Information
Channel 2 Configuration
MONITOR
NODE --

Diagnostics file: 0 Network Update Time(ms): 5
Coax Repeaters in Series: 1 Scheduled Bandwidth Usage: 0%
Fiber Repeater Pair A Only 0

Local Rack Characteristics
(for reserving I/O image space)

Node Node Type
Select number of slots: Select addressing mode:
F3 4 Slots F8 2-slot
F4 8 Slots F9 1-slot
F5 12 Slots F10 1/2-slot
F6 16 Slots

Press a function key, or ESC to exit.
>
Rem Prog Forces:None 5/40C File CN
Accept 4 8 12 16 2- 1- 1/2-
Edits Slots Slots Slots Slots Slot Slot Slot
F1 F3 F4 F5 F6 F8 F9 F10
    
```



If you have:	Press:	If you want to:	Do this:
4 slots	[F3]– 4 Slots	apply pending edits and go to the ControlNet Node Information (Edit) screen	<ol style="list-style-type: none"> 1. Press [F1]–Accept Edits The software prompts you to enter the node number of your processor 2. Type the node number of your processor 3. Press [Enter]
8 slots	[F4]– 8 Slots		
12 slots	[F5]– 12 Slots		
16 slots	[F6]– 16 Slots		
2-slot addressing	[F8]– 2-Slot	return to the Channel Overview screen	Press [Esc]
1-slot addressing	[F9]– 1-Slot		
1/2-slot addressing	[F10]– 1/2-Slot		

Chapter 3 Configuring Your ControlNet System

Editing ControlNet Node Information

Follow the steps on the left to go to the ControlNet Node Information (Edit) screen.

Important: Only one user on a network can enter a processor's ControlNet Node Information (Edit) screen at one time.



If you want to:	Do this:
specify and create a diagnostics file	<ol style="list-style-type: none"> 1. Move the cursor to the Diagnostics File field 2. Type an integer file number between N3 and N999 3. Press [Enter]
specify the number of coax repeaters in series that you are using in your ControlNet network	<ol style="list-style-type: none"> 1. Move the cursor to the Coax Repeater in Series field 2. Type a number from 0 through 5 3. Press [Enter]
specify the number of pairs of fiber-optic repeaters that you are using in your ControlNet network	<ol style="list-style-type: none"> 1. Move the cursor to the Fiber Repeater Pairs field 2. Type 0, 1, or 2 3. Press [Enter]
enter the length of fiber cable between repeaters for any fiber-optic repeater pairs that you specify Important: The field(s) for fiber-cable length only appear if the number of fiber-optic repeater pairs is not zero.	<ol style="list-style-type: none"> 1. Move the cursor to the appropriate Pair #x length (meters) field 2. Type a number between 100 and 25500 (the software rounds up to the nearest 100) 3. Press [Enter]
specify the NUT—the repetitive time interval during which data can be sent over the ControlNet network Important: All nodes do not need to transmit each NUI; however, the NUT defines the minimum time during which a node can transfer scheduled data.	<ol style="list-style-type: none"> 1. Move the cursor to the Network Update Time (ms) field 2. Type a number between 2 and 100 3. Press [Enter]


Chapter 3

Configuring Your ControlNet System

If you want to:	Do this:
view the percent of scheduled bandwidth used in the worst case—a percent that changes depending on the ControlNet configuration	See the <code>Scheduled Bandwidth Usage</code> field
specify the redundancy characteristic for the ControlNet channel	<ol style="list-style-type: none"> 1. Move the cursor to the <code>Media Redundancy Usage</code> field 2. Press <code>[F10]</code>—<code>Select Option</code> to toggle to <code>A/B</code>, <code>A Only</code>, or <code>B Only</code>
specify the node with the highest network address that can use scheduled time on the ControlNet link	<ol style="list-style-type: none"> 1. Move the cursor to the <code>Maximum Scheduled Node</code> field 2. Type a number between 1 and 99 3. Press <code>[Enter]</code>
change a node's type	<ol style="list-style-type: none"> 1. Move the cursor to the entry's <code>Node Type</code> field 2. Press <code>[F10]</code>—<code>Select Option</code> to toggle to your selection; or enter a unique substring of the name of the new node type
change a node's series or revision	<ol style="list-style-type: none"> 1. Move the cursor to the entry's <code>Series/Revision</code> field 2. Press <code>[F10]</code>—<code>Select Option</code> to toggle to your selection
change a node's status to active—node is a working/communicating node on the ControlNet network—or inactive—configuration and mapping for node are included in computation of NUT, etc.; but device is not actually connected to the network	<ol style="list-style-type: none"> 1. Move the cursor to the entry's <code>Status</code> field 2. Press <code>[F10]</code>—<code>Select Option</code> to toggle to <code>Active</code> or <code>Inactive</code>
go to the ControlNet I/O Mapping (Edit) screen	<ol style="list-style-type: none"> 1. Press <code>[F2]</code>—<code>Map Edit</code> 2. Go to page 3-6
move a node description to an unused network address	<ol style="list-style-type: none"> 1. Move the cursor to one of the node's cursorable fields 2. Press <code>[F3]</code>—<code>Move Entry</code> 3. Type the new network address 4. Press <code>[Enter]</code>
copy node information to a different network address	<ol style="list-style-type: none"> 1. Move the cursor to one of the original node's cursorable fields 2. Press <code>[F4]</code>—<code>Copy Entry</code> 3. Type the new network address 4. Press <code>[Enter]</code>
automatically add nodes connected to the channel to the node list if you are programming online	Press <code>[F5]</code> — <code>Auto Network</code>
delete all nodes from the list except for the processor that you are editing	Press <code>[F6]</code> — <code>Delete List</code>
insert an entry or range of entries into the node list	<ol style="list-style-type: none"> 1. Press <code>[F7]</code>—<code>Insert to List</code> 2. Type a new network address or range of network addresses—e.g., 5-10 3. Press <code>[Enter]</code>
delete an entry from the node list	<ol style="list-style-type: none"> 1. Move the cursor to one of the node's cursorable fields 2. Press <code>[F8]</code>—<code>Delete Item</code>
apply pending edits and return to the ControlNet Node Information (Monitor) screen	Press <code>[F1]</code> — <code>Accept Edits</code>
return to the ControlNet Node Information (Monitor) screen without saving any pending edits	Press <code>[Esc]</code>

Chapter 3
Configuring Your ControlNet System

Editing ControlNet I/O Mapping



Follow the steps on the left to go to the ControlNet I/O Mapping (Edit) screen.

Important:

- Only one user on a network can enter a processor’s ControlNet I/O Mapping (Edit) screen at one time.
- While you are editing the map-table entries on this screen or accepting pending edits, the screen may display the following message:

Maximum transmit size exceeded—adjustments necessary.

This indicates that you are attempting to configure a node to transmit more data per NUT than the node can support.

```

ControlNet - I/O Mapping
Channel 2 Configuration
EDIT
NODE 1

Status File:      N32      Network Update Time(ms): 5      Sch BW(%): 64
Data Input File:  N34      ----- Processor's ControlNet Resource Usage -----
Data Output File: N36      Map Entries      PLC BW (%)      DIF (%)      DOF (%)
Dflt Config File: N38      8                8                10           8

Node  Mod/Msg Type  Exp Net Pckt  Input      Output      Status      Config
S/M    Time(ms) File   Size  File   Size  Offset  File   Size

1      PLC-5/40C         n/a  n/a   n/a  n/a   n/a   n/a   n/a
1      Peer Out to 3    20   n/a   n/a  N36:0  24   0   n/a   n/a
2      1771-ACN         5    I:010 8  O:010 8    3   n/a   n/a
6      1771-IFE/A       15   N34:0 20  n/a   n/a   6   N38:0 37
7      1771-OFE/A       13   N34:20 5   N36:64 5    9   N36:64 13
3      PLC-5/20C        n/a  n/a   n/a  n/a   n/a   n/a   n/a
1      Peer In          7    N34:25 24  n/a   n/a   15  n/a   n/a

Press a function key, page up or page down, or enter a value.
>
Rem Prog  Forces:None      Display:Slot/Message      5/40C File CN
Accept   Select Node      Auto Clear Insert Delete Edit Select
Edits    Display Edit Mapping * to List * Actions Option
F1       F3       F4       F5       F6       F7       F8       F9       F10
  
```

If you want to:	Do this:
specify and create the status file—the file containing status information on all the ControlNet network’s scheduled I/O map-table entries	<ol style="list-style-type: none"> 1. Move the cursor to the status File field 2. Type an integer file number between N3 and N999 3. Press [Enter]
specify and create the DIF—the file used for both non-discrete and peer-to-peer input data transfer over the ControlNet network	<ol style="list-style-type: none"> 1. Move the cursor to the Data Input File field 2. Type an integer file number between N3 and N999 3. Press [Enter]
specify and create the DOF—the file used for both non-discrete and peer-to-peer output data transfer over the ControlNet network	<ol style="list-style-type: none"> 1. Move the cursor to the Data Output File field 2. Type an integer file number between N3 and N999 3. Press [Enter]
specify and create the Default Configuration File—the file used to store non-discrete I/O data transfer and 1794 Flex I/O configuration information when the automatic-mapping feature is used	<ol style="list-style-type: none"> 1. Move the cursor to the Dflt Config File field 2. Type an integer file number between N3 and N999 3. Press [Enter]

Chapter 3

Configuring Your ControlNet System

If you want to:	Do this:
specify the NUT	<ol style="list-style-type: none"> 1. Move the cursor to the Network Update Time (ms) field 2. Type a number between 2 and 100 3. Press [Enter]
view the percent of scheduled bandwidth used in the worst case—a percent that changes depending on the NUT and the completed map-table entries	See the scheduled Bandwidth Usage field
view the number of scheduled I/O map-table entries indicating data transfers between the scanning processor and other nodes	See the Map Entries field
view the percentage of bandwidth used for the ControlNet PLC-5 processor that you are using	See the PLC BW (%) field
view the percentage of the DIF being used	See the DIF (%) field
view the percentage of the DOF being used	See the DOF (%) field
change a module or message's type	<ol style="list-style-type: none"> 1. Move the cursor to the entry's Type field 2. Press [F10]—Select Option to toggle to your selection; or enter a unique substring of the name of the new module or message type
change the ENPT for a module or message	<ol style="list-style-type: none"> 1. Move the cursor to the entry's Exp Net Pckt Time (ms) field 2. Type a number between the NUT and 15000 3. Press [Enter]
manually enter the destination file for information received from a module or message—e.g., a 1771-ACN, 1794-ACN, or Peer In	<ol style="list-style-type: none"> 1. Move the cursor to the entry's Input File field If the item is a digital module, "I:" is displayed If it is non-discrete or peer-to-peer input, the DIF is displayed (Scheduled peer-to-peer inputs can also use the input-image file) 2. For non-discrete or peer-to-peer input, type an offset between 0 and 999; for discrete or peer-to-peer input, type an offset between 0 and the end of the input image 3. Press [Enter]
manually enter the amount of information received from a module or message—e.g., a 1771-ACN, 1794-ACN, or Peer In	<ol style="list-style-type: none"> 1. Move the cursor to the entry's Input Size field 2. Type a value 3. Press [Enter]
manually enter the source file for information sent to a module or in a message—e.g., a 1771-ACN, 1794-ACN, or Peer Out	<ol style="list-style-type: none"> 1. Move the cursor to the entry's Output File field If the item is a digital module, "O:" is displayed If it is non-discrete or peer-to-peer output, the DOF is displayed (Scheduled peer-to-peer outputs can also use the output-image file) 2. For non-discrete or peer-to-peer output, type an offset between 0 and 999; for discrete or peer-to-peer output, type an offset between 0 and the end of the output image 3. Press [Enter]
manually enter the amount of information sent to a module or in a message—e.g., a 1771-ACN, 1794-ACN, or Peer Out	<ol style="list-style-type: none"> 1. Move the cursor to the entry's Output Size field 2. Type a value 3. Press [Enter]

Chapter 3**Configuring Your ControlNet System**

If you want to:	Do this:
view the offset into the status file that contains the status information for a module or message (determined by the software)	See the <i>Status Offset</i> field for the item
manually enter the file for storing the I/O configuration needed for a module—e.g., a 1771-IFE or 1794-ACN Important: If a 1771 module uses the DOF, this must match.	<ol style="list-style-type: none"> 1. Move the cursor to the module's <i>Config File</i> field 2. Type an integer file number between N3 and N999 3. Press [Enter]
manually enter the amount of information to be stored in the I/O configuration file for a module—e.g., a 1771-IFE	<ol style="list-style-type: none"> 1. Move the cursor to the module's <i>Config Size</i> field 2. Type a valid value 3. Press [Enter]
select the display of slots, messages, or slots and messages in the list <i>Slot Display</i> displays all the non-digital I/O cards configured in physical slots of a chassis and their physical slot numbers <i>Message Display</i> displays all the peer-to-peer messages configured between PLC processors and their message numbers <i>Slot/Message</i> displays all the above	<ol style="list-style-type: none"> 1. Press [F3]—<i>Select Display</i> 2. Press [F2]—<i>Slot Display</i> Or [F3]—<i>Message Display</i> Or [F4]—<i>Slot/Message</i>
go to the ControlNet Node Information (Edit) screen	Press [F4]— <i>Node Edit</i>
have the software automatically map—into available data-table space (I/O or DIF/DOF)—modules and messages that are listed but not mapped	<ol style="list-style-type: none"> 1. Press [F5]—<i>Auto Mapping</i> 2. Select items to be mapped by pressing: <ul style="list-style-type: none"> • [F2]—<i>Select All</i> to select all the items that are not mapped • [F3]—<i>Toggle</i> to select or unselect an item that is highlighted by the cursor • [F4]—<i>Clear All</i> to unselect any items that are selected • [F8]—<i>Auto Module</i> to have the software automatically scan configured nodes for slot information if you are programming online For 1771 I/O, <i>Auto Module</i> determines the size of the chassis For 1794 Flex I/O, <i>Auto Module</i> determines the size of the chassis and lists all the non-discrete I/O data-transfer modules in the chassis 3. Press [F10]—<i>Auto I/O Map</i>
clear the following information on a module or message: <ul style="list-style-type: none"> • input file and offset • output file and offset • status offset • config file and offset 	<ol style="list-style-type: none"> 1. Move the cursor to the slot/message where you want to clear information 2. Press [F6]—<i>Clear *</i> 3. Press [F8]—<i>Clear Item</i>
clear the following information about all modules and messages: <ul style="list-style-type: none"> • input file and offset • output file and offset • status offset • config file and offset 	<ol style="list-style-type: none"> 1. Press [F6]—<i>Clear *</i> 2. Press [F10]—<i>Clear List</i>

Chapter 3

Configuring Your ControlNet System



If you want to:	Do this:
insert an entry or range of entries into the list	<ol style="list-style-type: none"> 1. Move the cursor to the node where you want to add a module or message 2. Press [F7]—Insert to List 3. Type the slot or message number (<i>slot/message</i> or <i>node.slot/message</i>) for a single new entry or range (<i>slot/message-slot/message</i> or <i>node.slot/message-slot/message</i>) for multiple new entries 4. Press [Enter]
delete a module or message	<ol style="list-style-type: none"> 1. Move the cursor to the item that you want to delete 2. Press [F8]—Delete * 3. Press [F8]—Delete Item
delete all modules and messages	<ol style="list-style-type: none"> 1. Press [F8]—Delete * 2. Press [F10]—Delete List
go to the ControlNet I/O Action screen Important: This option is not available if the display mode is set to Message Display on this screen by using [F3]—Select Display.	<ol style="list-style-type: none"> 1. Move the cursor to the 1794 Flex I/O module entry who's actions you want to edit 2. Press [F9]—Edit Actions
apply pending edits and return to the ControlNet I/O Mapping (Monitor) screen	Press [F1]—Accept Edits
return to the ControlNet I/O Mapping (Monitor) screen without saving any pending edits	Press [Esc]

Chapter 3
Configuring Your ControlNet System

Editing ControlNet 1794 I/O Module Action

Follow the steps on the left to the ControlNet I/O Action (Edit) screen.

Important: Only one user on a network can enter a processor's ControlNet 1794 I/O Module Action screen at one time.



If you want to:	Do this:
change a system's fault action —i.e., the action that it takes when it faults	<ol style="list-style-type: none"> 1. Move the cursor to the Fault Action column 2. Press [F8]—Toggle All to toggle between: <ul style="list-style-type: none"> • Reset—to change all outputs to zero • Hold Last—to maintain all current output values • Safe—to change all outputs to user-specified fail-safe values
change a system's idle action —i.e., the action that it takes when it becomes idle	<ol style="list-style-type: none"> 1. Move the cursor to the Idle Action column 2. Press [F8]—Toggle All to toggle between: <ul style="list-style-type: none"> • Reset—to change all outputs to zero • Hold Last—to maintain all current output values • Safe—to change all outputs to user-specified fail-safe values
change a system's fault action from idle—i.e., the action that it takes when it faults from idle	<ol style="list-style-type: none"> 1. Move the cursor to the Fault Action From Idle column 2. Press [F8]—Toggle All to toggle between: <ul style="list-style-type: none"> • Idle—to use the idle action • Fault—to use the fault action
change a module's fault action —i.e., the action that it takes when it faults	<ol style="list-style-type: none"> 1. Move the cursor to the module's field Fault Action field 2. Press [F10]—Toggle Entry to toggle between: <ul style="list-style-type: none"> • Reset—to change all outputs to zero • Hold Last—to maintain all current output values • Safe—to change all outputs to user-specified fail-safe values

Chapter 3

Configuring Your ControlNet System

If you want to:	Do this:
change a module's idle action—i.e., the action that it takes when it becomes idle	<ol style="list-style-type: none"> 1. Move the cursor to the module's Idle Action field 2. Press [F10]—Toggle Entry to toggle between: <ul style="list-style-type: none"> • Reset—to change all outputs to zero • Hold Last—to maintain all current output values • Safe—to change all outputs to user-specified fail-safe values
change a module's fault action from idle—i.e., the action that it takes when it faults from idle	<ol style="list-style-type: none"> 1. Move the cursor to the module's Fault Action From Idle field 2. Press [F10]—Toggle Entry to toggle between: <ul style="list-style-type: none"> • Idle—to use the idle action • Fault—to use the fault action
apply pending edits and return to the ControlNet I/O Mapping (Edit) screen	Press [F1]—Accept Edits
go back to the ControlNet I/O Mapping (Edit) screen	Press [F2]—Map Edit or [Esc]

Programming Your ControlNet System

Using This Chapter




If you want to read about using:	Go to page:
ControlNet message instructions	4-2
ControlNet I/O transfer instructions	4-4
ControlNet immediate data input and output instructions	4-6
Using Selectable Timed Interrupts (STIs) in a program on a ControlNet network	4-7

Chapter 4
Programming Your ControlNet System

Using ControlNet Message Instructions

You can use the existing MG data type to send two message commands over the ControlNet system within the local ControlNet link—PLC-5 TYPED WRITE and PLC-5 TYPED READ.

Follow the steps on the left to go to the Instruction Entry for Message Block screen.



```

    Instruction Entry for Message Block MG20:50


    Communication Command:      PLC-5 TYPED WRITE
    PLC-5 Data Table Address:    N8:0
    Size in Elements:           1

    Local ControlNet Node:      1
    Destination Data Table Address: N11:0
    Port Number:                2

    BLOCK SIZE = 56 WORDS

    Press a key to change a parameter or <ENTER> to accept parameters.
    >
    Rem Prog  Forces:None      Edits:None                5/40C File CN
    Command  PLC-5 Size in      Local  Destin  Port
    Type     Address Elemnts    Node   Address Number
    F1       F2       F3                F8     F9     F10
  
```

If you want to:	Do this:
change the command type	Press [F1]—Command Type to toggle between: <ul style="list-style-type: none"> • PLC-5 TYPED WRITE—to select a write operation to another PLC-5 processor • PLC-5 TYPED READ—to select a read operation from another PLC-5 processor
enter a PLC-5 data-table address	<ol style="list-style-type: none"> 1. Press [F2]—PLC-5 Address 2. Type the PLC-5 data-table address 3. Press [Enter]
enter the size in elements	<ol style="list-style-type: none"> 1. Press [F3]—Size in Elemnts 2. Type a number of elements from 1 to 1000 3. Press [Enter]
enter the destination network address	<ol style="list-style-type: none"> 1. Press [F8]—Local Node 2. Type a number from 1 to 99 3. Press [Enter]
enter a destination data-table address	<ol style="list-style-type: none"> 1. Press [F9]—Destin Address 2. Type the destination data-table address 3. Press [Enter]



Follow the steps on the left to go to the Data Monitor for Message Control Block screen.

```

    Data Monitor for Message Control Block MG20:50

    Communication Command:      PLC-5 TYPED WRITE
    PLC-5 Data Table Address:    N8:0      ignore if timed-out: 0 TO
    Size in Elements:           1          to be retried:      0 NR
                                          awaiting execution: 0 EW
                                          continuous:       0 CO
                                          error:           0 ER
                                          message done:    0 DN
                                          message transmitting: 0 ST
                                          message enabled: 0 EN


    Local ControlNet Node:      1
    Destination Data Table Address: N11:0
    Port Number:                2

    Error Code: 0000 (HEX)

    Press a function key or enter a value.
    MG20:50.TO =
    Rem Prog  Forces:None  Data:Decimal  Addr:Decimal  5/40C File CN
             Toggle Size in Specify Next Prev Next Prev
             Bit  Elemnts  Address      File  File  Element Element
             F2   F3      F5           F7   F8   F9     F10
    
```

The fields of the MG data type that you can directly address are:


.TO	Abort (Time out) control bit	word 0, bit 08
.NR	No-response flag bit—not used	word 0, bit 09
.EW	Enabled-waiting flag bit	word 0, bit 02
.CO	Continuous control bit	word 0, bit 03
.ER	Errored flag bit	word 0, bit 04
.DN	Done flag bit	word 0, bit 05
.ST	Started flag bit	word 0, bit 06
.EN	Enabled flag bit	word 0, bit 07
.ERR	Error-code word	word 1
.RLEN	Requested length word	word 2



For more detailed information on writing ladder programs and using message instructions, see the PLC-5 Programming Software Instruction Set Reference, publication 6200-6.4.11, and PLC-5 Programming Software Programming, publication 6200-6.4.7.

Chapter 4
Programming Your ControlNet System

Using the ControlNet I/O Transfer Instruction



You can use the ControlNet I/O Transfer (CIO) instruction and the ControlNet Transfer (CT) data type to make ControlNet I/O transfers within the local ControlNet link. Follow the steps on the left to go to the Instruction Entry for ControlNet I/O Transfer Block screen.

```

Instruction Entry for ControlNet I/O Transfer Block CT21:50

Communication Command:      1771 WRITE
PLC-5 Data Table Address:   N7:3
Size in Elements:          10
Elements Transmitted:      0

Local ControlNet Node:     1
Slot Number:               0
Port Number:               2


BLOCK SIZE = 22 WORDS

Press a key to change a parameter or <ENTER> to accept parameters.
>
Rem Prog  Forces:None  Edits:None  5/40C File CN
Command  PLC-5 Size in  Local Slot
Type    Address Elemnts  Node  Number
F1      F2      F3              F8    F9
    
```

If you want to:	Do this:
change the command type	Press [F1]—Command Type to toggle between: <ul style="list-style-type: none"> • 1771 READ—reads input data from 1771 non-discrete I/O module • 1771 WRITE—writes output data to 1771 non-discrete I/O module • 1794 FAULT ACTION—changes the action that a module takes when it faults • 1794 IDLE ACTION—changes the action that a module takes when it is idle • 1794 CONFIG DATA—changes a module’s configuration data • 1794 SAFE STATE DATA—changes a module’s safe-state data
enter a PLC-5 data-table address	<ol style="list-style-type: none"> 1. Press [F2]—PLC-5 Address 2. Type the data-table address 3. Press [Enter]
enter the size in elements	<ol style="list-style-type: none"> 1. Press [F3]—Size in Elemnts 2. Type the number of elements: <ul style="list-style-type: none"> • 1 for 1794 FAULT ACTION or 1794 IDLE ACTION • 1 to 15 for 1794 CONFIG DATA or 1794 SAFE STATE DATA • 0^① to 64 for 1771 READ or 1771 WRITE 3. Press [Enter]
enter the destination network address	<ol style="list-style-type: none"> 1. Press [F8]—Local Node 2. Type a number from 1 to 99 3. Press [Enter]
enter the destination slot number	<ol style="list-style-type: none"> 1. Press [F9]—Slot Number 2. Type the number of the slot that holds the I/O device—number from 0 to 15 3. Press [Enter]

^① If you enter a 0, the module determines the size of the transfer. In this case, you must make sure that your data-table can accomodate up to 64 words.

Chapter 4 Programming Your ControlNet System



Follow the steps on the left to go to the Data Monitor for ControlNet I/O Transfer Block screen.

```

    Data Monitor for ControlNet I/O Transfer Block CT21:50


    Communication Command:      1771 Write
    PLC-5 Data Table Address:   N7:3          ignore if timed-out: 0 TO
    Size in Elements:          10             awaiting execution: 0 EW
    Elements Transmitted:      0              continuous: 0 CO
                                           error: 0 ER
                                           transfer done: 0 DN
    Local ControlNet Node:     1              transfer started: 0 ST
    Slot Number:               0              transfer enabled: 0 EN
    Port Number:               2

    Error Code: 0000 (HEX)

    Press a function key or enter a value.
    CT21:50.TO =
    Rem Prog  Forces:None      Data:Decimal  Addr:Decimal  5/40C File CN
             Toggle Size in  Specify      Next      Prev Next      Prev
             Bit  Elemnts    Address     File      File  Element Element
             F2   F3         F5         F7       F8   F9      F10
    
```

The fields of the CT data type that you can directly address are:


.TO	Abort (Time out) control bit	word 0, bit 08
.EW	Enabled-waiting flag bit	word 0, bit 02
.CO	Continuous control bit	word 0, bit 03
.ER	Errored flag bit	word 0, bit 04
.DN	Done flag bit	word 0, bit 05
.ST	Started flag bit	word 0, bit 06
.EN	Enabled flag bit	word 0, bit 07
.ERR	Error-code word	word 1
.RLEN	Requested length word	word 2
.DLEN	Done length word	word 3
.FILE	Transfer file number	word 4
.ELEM	Transfer element number	word 5



For more detailed information on writing ladder programs, see the PLC-5 Programming Software Instruction Set Reference, publication 6200-6.4.11, and PLC-5 Programming Software Programming, publication 6200-6.4.7.


Chapter 4
Programming Your ControlNet System

Using ControlNet Immediate Data Input and Output Instructions



You can use two instructions for immediate data input and output on a ControlNet network—Immediate Data Input (IDI) and Immediate Data Output (IDO).

Follow the steps on the left to add IDI and IDO instructions to your program.



In the example above, an IDI is initiated that updates the destination file from the private buffer before the next normal input-image update. The Data File Offset (232) is the offset into the buffer where the data is stored. The Length (10) identifies the number of words in the transfer—it can be an immediate value ranging from 1 to 64 or a logical address that specifies the number of words to be transferred. The Destination (N11:232) is the destination of the words to be transferred. The Destination should be the matching data-table address in the DIF except when you use the instruction to ensure data-block integrity in the case of Selectable Timed Interrupts (STIs). See page 4-7.

An IDO is initiated that updates the private memory output buffer from the source file before the next normal output- image update. The Data File Offset (175) is the offset into the buffer where the data is stored. The Length (24) identifies the number of words in the transfer or a logical address that specifies the number of words to be transferred. The Source (N12:175) is the source of the words to be transferred. The Source should be the matching data-table address in the DOF except when you use the instruction to ensure data-block integrity in the case of Selectable Timed Interrupts (STIs). See page 4-7.



For more detailed information on writing ladder programs, see the PLC-5 Programming Software Instruction Set Reference, publication 6200-6.4.11, and PLC-5 Programming Software Programming, publication 6200-6.4.7.


For information on programming ControlNet I/O transfers using Immediate Input (INN) and Immediate Output (IOT) instructions, see the PLC-5 Programming Software Instruction Set Reference, publication 6200-6.4.11.

Using Selectable Timed Interrupts with a Program on a ControlNet Network

You must be careful when using Selectable Timed Interrupts (STIs) with a program on a ControlNet network.

A Selectable Timed Interrupt (STI) periodically interrupts primary program execution in order to run a subprogram to completion. If an STI occurs while a normal ControlNet non-discrete I/O data transfer or a ControlNet Immediate Data I/O instruction (IDO or IDI) is in progress and they both operate on the same set of data, the integrity of that block of data is jeopardized.

To ensure data-block integrity, write your STI routine so that it operates on its own copy of the data block that it needs. Use ControlNet Immediate Data I/O instructions (IDO and IDI) within your STI to copy the needed block of data out to and back from a temporary location that is different from that used by the normal data table.



For detailed information on STIs, see PLC-5 Programming Software Configuration and Maintenance, publication 6200-6.4.6.

Monitoring and Troubleshooting Your ControlNet System

Using This Chapter




If you want to read about:	See page:
Using the general status indicators	5-2
Using the ControlNet status indicators	5-3
Monitoring the ControlNet configuration and status screens	5-5

Chapter 5

Monitoring and Troubleshooting Your ControlNet System

Using the General Status Indicators

The general status indicators inform you of the general operational state of the processor.




Indicator	State	Description	Probable Cause(s)	Recommended Action(s)
BATT	Steady Red	Battery low	Battery low	Replace battery within 10 days (typical)
	Off	Battery good	Normal operation	None
PROC	Steady Green	Processor in Run mode and fully operational	Normal operation	None
	Flashing Green	Processor memory being transferred to EEPROM		
	Flashing Red	Major fault	Run-time error	<ol style="list-style-type: none"> 1. Check major fault bit in status file (S:11) for error definition 2. Clear fault bit 3. Correct problem 4. Return to Run mode
	Alternating Red and Green	Processor in FLASH-memory programming mode	Normal operation if processor's FLASH memory is being reprogrammed	None
			Processor FLASH memory checksum error	Contact your local A-B representative for a field firmware update
	Steady Red	Major fault	Processor memory checksum error	Clear memory and reload program
			Memory-module error	Correct backplane switch settings, and/or insert correct memory module
			Internal diagnostics failed	<ol style="list-style-type: none"> 1. Turn power off, reseat processor, then power up 2. Clear memory and reload your program 3. Replace EEPROM with new program 4. If still an error, replace the processor
Off	Processor in Program Load or Test mode	Normal operation if mode correct	None	
FORCE	Steady Amber	SFC and/or I/O forces enabled	Normal operation	None
	Flashing Amber	SFC and/or I/O forces present but not enabled		
	Off	SFC and/or I/O forces not present		
COMM	Off	No transmission on Channel 0	Normal operation if channel not being used	None
	Flashing Green	Transmission on Channel 0	Normal operation if channel being used	

Chapter 5
Monitoring and Troubleshooting Your ControlNet System

Using the ControlNet Status Indicators

The ControlNet status indicators inform you of the operational state of the ControlNet network.



Indicator	State	Description	Probable Cause(s)	Recommended Action(s)
I/O	Off	ControlNet I/O not present or not operating	Normal operation if Channel 2 not being used	None
	Steady Green	All nodes configured in the ControlNet map table present and operating properly	Normal operation	None
	Flashing Green/Off	At least one node configured for the ControlNet network not present or not operating properly	Cable(s) or connector(s) broken or not connected	Repair or replace cable(s) or connector(s), and reconnect
			Destination module(s) bad or missing	Repair or replace module(s)
			Node(s) not on network	Connect node to network
	Flashing Red/Off	All nodes configured for ControlNet not present or not operating properly	Cable(s) or connector(s) broken or not connected	Repair or replace cable(s) or connector(s), and reconnect
Nodes not on network			Connect nodes to network	

Chapter 5
Monitoring and Troubleshooting Your
ControlNet System

Indicator	State ^①	Probable Cause	Recommended Action(s)
 and  A and B	Off	No power	None Power up
	Steady Red	Faulted unit	Cycle power or reset unit If fault persists, contact your Allen-Bradley Company, Inc. representative or distributor
	Alternating Red/Green	Self-test	None
	Alternating Red/Off	Incorrect node configuration	Check network address and other ControlNet configuration parameters
 or  A or B	Off	Channel disabled	None Configure for ControlNet communication
	Steady Green	Normal operation	None
	Flashing Green/Off	Temporary errors	None Make sure that ControlNet is properly terminated
		Node is not configured to go online	Make sure the Configuration Manager node is present and working ^②
	Flashing Red/Off	Media fault	Check media for broken cables, loose connectors, missing terminators, etc.
		No other nodes present on network	Add other nodes to the network
Flashing Red/Green	Incorrect network configuration	Cycle power or reset unit If fault persists, contact your Allen-Bradley Company, Inc. representative or distributor	

^① Definition of terms:


- **alternating**—the two indicators alternate between the two defined states at the same time (applies to both indicators *viewed together*); the two indicators are always in opposite states, out of phase
- **flashing**—the indicator alternates between the two defined states (applies to each indicator *viewed independent* of the other); if both indicators are flashing, they flash together, in phase
- **steady**—indicator is on continuously in the defined state

^② The Configuration Manager node—at node 01, the controlling processor—is the node responsible for distributing ControlNet configuration data to all nodes on the ControlNet network.

Using the 6200 Programming Software to Monitor ControlNet Configuration and Status

This section shows you how to use the ControlNet configuration monitor and status screens found in the 6200 PLC-5 Programming Software, release 5.1 or later.



ControlNet Configuration Monitor and Status Screens in the 6200 Programming Software



Chapter 5
Monitoring and Troubleshooting Your
ControlNet System

Using the ControlNet Node Information (Monitor) Screen

Follow the steps on the left to go to the ControlNet Node Information (Monitor) screen.




The ControlNet Node Information (Monitor) screen lists the nodes that you have entered for the ControlNet network; and it shows the node type, product series/revision, and status (active or inactive) that you have configured for each node.

If you want to:	Press:
quickly position the cursor on a specific node in the list	1. Type the node number and a period (.)—e.g., 2. 2. Press [Enter]
go to the ControlNet I/O Mapping (Monitor) screen	Press [F2]—Map Monitor
go to the ControlNet Node Information (Edit) screen	Press [F4]—Node Edit
define the characteristics of the local chassis (for reserving I/O image space) Important: This option is not available if you are programming online.	Press [F7]—Define LclRack
go to the ControlNet Channel 2 Status screen	Press [F9]—Chan 2 Status
go to the Channel Overview screen	Press [Esc]

Chapter 5
Monitoring and Troubleshooting Your ControlNet System

Using the ControlNet I/O Mapping (Monitor) Screen

Follow the steps on the left to go to the ControlNet I/O Mapping (Monitor) screen.



```

ControlNet - I/O Mapping
Channel 2 Configuration
MONITOR
NODE 1

Status File: N32      Network Update Time(ms): 5    Sch BW(%): 64
Data Input File: N34  ----- Processor's ControlNet Resource Usage -----
Data Output File: N36  Map Entries      PLC BW (%)    DIF (%)    DOF (%)
Dflt Config File: N38      8              8            10         8

Node  Mod/Msg Type  Act Net Pckt  Input      Output      Status      Config
S/M    Time(ms)      File      Size  File      Size  Offset  File      Size

1      PLC-5/40C        n/a        n/a      n/a      n/a      n/a      n/a      n/a
1      Peer Out to 3    20        n/a      n/a      N36:0    64      0      n/a      n/a
2      1771-ACN         5          I:010    8      O:010    8        3      n/a      n/a
6      1771-IFE/A       10         N34:0    20     n/a      n/a      6      N38:0    37
7      1771-OPE/A       10         N34:20   5      N36:64   5        9      N36:64   13
3      PLC-5/20C        n/a        n/a      n/a      n/a      n/a      n/a      n/a      n/a
1      Peer In          5          N34:25   24     n/a      n/a      15     n/a      n/a


Press a function key, page up or page down, or enter a node.s/m number.
>
Rem Prog  Forces:None      Display:Slot/Message  5/40C File CN
Map  Select  Node  View  Monitor  Define  I/O  Monitor
Edit  Display  Monitor  Times  Status  LclRack  Monitor  Actions
F2    F3    F4    F5    F6    F7    F8    F9
  
```

If you want to:	Do this:
quickly position the cursor on a specific entry in the list	<ol style="list-style-type: none"> Type the node number, a period (.), and the slot or message number of the entry—e.g., 2.7 Press [Enter]
go to the ControlNet I/O Mapping (Edit) screen	Press [F2]—Map Edit
select the display of slots, messages, or slots and messages in the list	<ol style="list-style-type: none"> Press [F3]—Select Display Press [F2]—Slot Display Or [F3]—Message Display Or [F4]—Slot/Message
go to the ControlNet Node Information (Monitor) screen	Press [F4]—Node Monitor
view the Actual Network Packet Time (ANPT) and Expected Network Packet Time (ENPT) instead of the input, output, status, and configuration information	Press [F5]—view Times
go to the ControlNet Map Entries Status screen	Press [F6]—Monitor Status
define the characteristics of the local chassis Important: This option is not available if you are programming online.	Press [F7]—Define LclRack
go to the I/O Configuration Monitor Utility	<ol style="list-style-type: none"> Move your cursor to an analog entry Press [F8]—I/O Monitor
go to the ControlNet I/O Action (Monitor) screen Important: This option is not available if the display mode is set to Message Display on this screen or the ControlNet View Times screen by using [F3]—Select Display.	<ol style="list-style-type: none"> Move the cursor to the 1794 I/O module entry who's actions you want to monitor Press [F9]—Monitor Actions
return to the ControlNet Node Information (Monitor) screen	Press [Esc]

Chapter 5
Monitoring and Troubleshooting Your
ControlNet System

Using the ControlNet View Times Screen

Follow the steps on the left to go to the ControlNet View Times screen.



```

ControlNet - View Times
Channel 2 Configuration
MONITOR
NODE 1

Status File: N32      Network Update Time(ms): 5      Sch BW(%): 64
Data Input File: N34  ----- Processor's ControlNet Resource Usage -----
Data Output File: N36  Map Entries      PLC BW (%)      DIP (%)      DOF (%)
Dflt Config File: N38      8                8                10           8

Node  Mod/Msg Type  Act Net Pckt Exp Net Pckt
S/M                               Time(ms)    Time(ms)

1      PLC-5/20C      n/a         n/a
1      Peer Out To 3  20          20
2      1771-ACN       5           5
6      1771-IFE/A     10          15
7      1771-OFE/A     10          13
3      PLC-5/20C      n/a         n/a
1      Peer In      5           7



Press a function key, page up or page down, or enter a node.s/m number.
>
Rem Prog  Forces:None      Display:Slot/Message  5/40C File CN
Map  Select  Node  View  Monitor  I/O  Monitor
Edit  Display Monitor Mapping Status  Monitor Actions
F2    F3    F4    F5    F6          F8    F9
  
```

If you want to:	Do this:
quickly position the cursor on a specific entry in the list	<ol style="list-style-type: none"> Type the node number, a period (.), and the slot or message number of the entry Press [Enter]
see the ANPT for an entry—the actual time it takes for the network to update the data	Look at the Act Net Pckt Time (ms) field for that entry
see the ENPT for an entry—the maximum time allowed for the network to update the data	Look at the Exp Net Pckt Time (ms) field for that entry
go to the ControlNet I/O Mapping (Edit) screen	Press [F2]—Map Edit
select the display of slots, messages, or slots and messages in the list	<ol style="list-style-type: none"> Press [F3]—Select Display Press [F2]—Slot Display Or [F3]—Message Display Or [F4]—Slot/Message
go to the ControlNet Node Information (Monitor) screen	Press [F4]—Node Monitor
toggle back to view input, output, status, and configuration information	Press [F5]—View Mapping
go to the ControlNet Map Entries Status screen	Press [F6]—Monitor Status
go to the I/O Configuration Monitor Utility	<ol style="list-style-type: none"> Move your cursor to an analog entry Press [F8]—I/O Monitor
go to the ControlNet I/O Action (Monitor) screen	<ol style="list-style-type: none"> Move the cursor to the 1794 I/O module entry who's actions you want to monitor Press [F9]—Monitor Actions
return to the ControlNet Node Information (Monitor) screen	Press [Esc]

Chapter 5
Monitoring and Troubleshooting Your ControlNet System

Using the ControlNet Map Entries Status Screen

Follow the steps on the left to go to the ControlNet Map Entries Status screen.





If you want to:	Do this:
select the display of slots, messages, or slots and messages in the list	<ol style="list-style-type: none"> 1. Press [F3]—Select Display 2. Press [F2]—Slot Display Or [F3]—Message Display Or [F4]—Slot/Message
see whether an entry is a Read (R) or Write (W) operation	Look at the field to the right of the S/M field for that entry
view the current status of an entry	Look at the status field for that entry See Appendix D for a list of errors that may be displayed
see where the three status words associated with an entry are located in the Status File	Look at the status Offset field for that entry
see whether the data associated with an entry is valid or invalid	Look at the Data Valid field for that entry For all I/O modules except 1794: <ul style="list-style-type: none"> • YES—indicates that the status data for the slot are valid • NO—indicates that the status data for the slot are not valid For all 1794 I/O modules: <ul style="list-style-type: none"> • Y—indicates that the status data for the slot are valid • N—indicates that the status data for the slot are not valid • X—indicates that the slot is not configured For example, a 1794 I/O module field of YXNXXYX indicates: <ul style="list-style-type: none"> • the status data for slots 0, 1, and 6 are valid • the status data for slots 3 and 4 are not valid • slots 2, 5, and 7 are not configured
set the inhibit bit so that the processor will not attempt to establish a connection with the module or message	<ol style="list-style-type: none"> 1. Move the cursor to the Inhibit field for that entry 2. Type a 1 3. Press [Enter]

Chapter 5Monitoring and Troubleshooting Your
ControlNet System

If you want to:	Do this:
clear the inhibit bit so that the processor will attempt to establish a connection with the module or message	<ol style="list-style-type: none"> 1. Move the cursor to the <code>Inhibit</code> field for that entry 2. Type a <code>0</code> 3. Press <code>[Enter]</code>
set the reset bit so that the processor will set the output module or message's Run/Program command to Program mode	<ol style="list-style-type: none"> 1. Move the cursor to the <code>Reset</code> field for that entry 2. Type a <code>1</code> 3. Press <code>[Enter]</code>
clear the reset bit so that the processor will set the output module or message's Run/Program command to the processor's mode	<ol style="list-style-type: none"> 1. Move the cursor to the <code>Reset</code> field for that entry 2. Type a <code>0</code> 3. Press <code>[Enter]</code>
return to the ControlNet I/O Mapping (Monitor) screen	Press <code>[Esc]</code>

Using the ControlNet I/O Action (Monitor) Screen

Follow the steps on the left to go to the ControlNet I/O Action (Monitor) screen.




If you want to:	Do this:
go to the ControlNet I/O Mapping (Monitor) screen	Press [Esc] or [F2]—Map Monitor
define the characteristics of the local chassis Important: This option is not available if you are programming online.	Press [F7]—Define LclRack
view a module's fault action—i.e., the action that it takes when it faults	Look at the module's field in the Fault Action column <ul style="list-style-type: none"> • Reset—changes all outputs to zero • Hold Last—maintains all current output values • Safe—changes all outputs to user-specified fail-safe values
view a module's idle action—i.e., the action that it takes when it becomes idle	Look at the module's field in the Idle Action column <ul style="list-style-type: none"> • Reset—changes all outputs to zero • Hold Last—maintains all current output values • Safe—changes all outputs to user-specified fail-safe values
view a module's fault action from idle—i.e., the action that it takes when it faults from idle	Look at the module's field in the Fault Action From Idle column <ul style="list-style-type: none"> • Idle—uses the idle action • Fault—uses the fault action
go to the ControlNet I/O Action (Edit) screen	Press [F9]—Edit Actions

Chapter 5
Monitoring and Troubleshooting Your
ControlNet System

Using the ControlNet Channel 2 Status Screen

Follow the steps on the left to go to the ControlNet Channel 2 Status screen.



```

ControlNet
Channel 2 Status

                                COUNTERS LOCKED
                                media usage:      A Only
Frames
transmitted good:      0 transmitted aborted: 0 channel A errors:  0
received good:        0 received aborted:  0 channel B errors: n/a
total received:      0 received bad:      0 channel warnings: none

Network Capacity
update time overload: 0 blockage:          0

Moderator Node:      1
mismatch events:    0 unheard occurrences: 0

Misc
out of step events: 0 network silent:    0 noise detected:    0
commands received: 0 collisions:      0

Press a function key.
>
Rem Prog  Forces:None      5/40C File CN
Clear  Unlock              Chan 2
Counter Counter           Config
F1     F2                  F9
  
```

If you want to:	Do this:
clear all the ControlNet diagnostic counters	Press [F1]—Clear Counter
toggle to lock all the counters on the screen (while they continue to run in the background); then toggle back to unlock the counters so that they are updated continuously	1. Press [F2]—Lock Counter 2. Press [F2]—Unlock Counter
go to the ControlNet Node Information (Monitor) screen	Press [F9]—Chan 2 Config
go to the Channel Overview screen	Press [Esc]

Chapter 5

Monitoring and Troubleshooting Your ControlNet System

This status field:	Word; Bits: ^①	Displays: ^②
COUNTERS LOCKED		when the display of the counters stops changing—the counters continue to run in the background; current values are continuously updated when COUNTERS LOCKED is not displayed
media usage		the media redundancy characteristic for the ControlNet channel—A/B, A Only, Or B Only
Frames		
transmitted good	6; 15-08 5; 07-00 5; 15-08	number of good frames transmitted
transmitted aborted	9; 07-00	number of frames that could not be transmitted completely and were aborted during transmission
received good	7; 07-00 7; 15-08 6; 07-00	number of good frames received on the active channel
received aborted	12; 07-00	number of frames received that were aborted during transmission on the active channel
received bad	8; 15-08	number of unusable frames received on the active channel
total received		number of frames—good and bad—received on the active channel
channel A errors	8; 07-00	number of frames received on channel A that were unusable independent of the active channel—channel selected for reception
channel B errors	9; 15-08	number of frames received on channel B that were unusable independent of the active channel—channel selected for reception
channel warnings	23; 07-06	any channel that is receiving a low level of unusable frames—i.e., frames containing data errors
Network Capacity		
update time overload	10; 07-00	number of times that a NUI passes with no opportunity to transmit
blockage	11; 07-00	number of times that a NUI does not contain enough room to allow the transmission of a particular frame
moderator node	15; 15-08	network address of the node that is transmitting the moderator frame—always the lowest active network address
mismatch events	16; 15-08	number of times a moderator frame was received with network parameters different from those in the receiving node
unheard occurrences	16; 07-00	number of times a node can receive a frame from a lower network address but cannot receive a moderator
Misc		
out of step events	10; 15-08	number of times any event prevents a frame from being transmitted in the NUI in which it should be transmitted
network silent	13; 15-08	number of times a node cannot hear any network activity for three consecutive NUIs number of times that a start of frame could not be detected
noise detected	14; 15-08	number of station commands received directly from the network that bypass the node's host processor
commands received	17; 15-08	
collisions	14; 07-00	number of times that a node prevents the transmission of a frame because it would cause a collision to occur

^① In user-specified Diagnostics File


^② All counters display only the status of the node being examined

Chapter 5
Monitoring and Troubleshooting Your
ControlNet System

Using the ControlNet WHO ACTIVE—Active Node Identification Screen

Important: Keep the following in mind:

- ControlNet WHO screens are available only when your programming device is communicating through a 1784-KTC card, 1784-KTCx card, or 1770-KFC interface on the ControlNet network.
- When you view the WHO screens while your ControlNet system is operating, you affect the performance of unscheduled I/O operations.



The ControlNet WHO ACTIVE—Active Node Identification screen displays the active nodes up to the number of maximum unscheduled nodes. Follow the steps on the left to go to the ControlNet WHO ACTIVE—Active Node Identification screen.

```

+----- ControlNet WHO ACTIVE - Active Node Identification -----+
| 01 5/40C      CN                                             |
| 02 1771-ACN                                         |
| 03 5/20C                                           |
| 04 1794-ACN                                         |
| 05                                                    |
| 06                                                    |
| 07                                                    |
| 08                                                    |
| 09                                                    |
| 10                                                    |
| 11                                                    |
| 12                                                    |
| 13                                                    |
| 14                                                    |
| 15                                                    |
+--- ESC exits --[ WHO rate = 4 sec ]----[ Maximum Unscheduled Nodes = 15 ]----+

Press a function key, or page up or page down.

Net Channel A Status: Cable Good      Net Channel B Status: Cable Inactive
Online  Node                               Channel Network      Save  Who
Program Diags                             Diags  Diags          Config Rate
F1      F2                                F5     F6                 F9     F10
    
```

If you want to:	Press:
attach to the PLC-5 processor node of the highlighted entry	[F1]—Online Program
go to the ControlNet WHO ACTIVE—Active Node Status screen	[F2]—Node Diags
go to the ControlNet WHO ACTIVE—Channel Status screen	[F5]—Channel Diags
go to the ControlNet WHO ACTIVE—Network Status screen	[F6]—Network Diags
save the current ControlNet WHO configuration as the permanent ControlNet WHO configuration	[F9]—Save Config
enter a new ControlNet WHO rate	[F10]—WHO Rate
go to the ControlNet WHO screen	[Esc]

Chapter 5
Monitoring and Troubleshooting Your
ControlNet System

This field:	Displays:
Net Channel Status Line	the status of channel A and channel B <ul style="list-style-type: none">• Cable Good = channel is usable• Cable WARN = channel is experiencing problems but still usable• Cable FAULTED = channel is not usable• Cable Inactive = channel unused (in non-redundant network)


Chapter 5
Monitoring and Troubleshooting Your
ControlNet System

Using the ControlNet WHO ACTIVE—Active Node Status Screen

Important: Keep the following in mind:

- ControlNet WHO screens are available only when your programming device is communicating through a 1784-KTC card, 1784-KTCx card, or 1770-KFC interface on the ControlNet network.
- When you view the WHO screens while your ControlNet system is operating, you affect the performance of unscheduled I/O operations.

Follow the steps on the left to go to the ControlNet WHO ACTIVE—Active Node Status screen.



```

+--- ControlNet WHO ACTIVE - Active Node Status ---+
| Frames                                             |
| transmitted good:      0 transmitted aborted: 0   | media usage:      A Only|
| received good:        0 received aborted:   0   | channel A errors:  0   |
| total received:       0 received bad:       0   | channel B errors:  0   |
|                                                               | channel warnings: none|
| Network Capacity                                         |
| update time overload:  0 blockage:           0   |
| Moderator Node:      1                                     |
| mismatch events:     0 unheard occurrences  0   |
| Misc                                                         |
| out of step events:  0 network silent:       0   | noise detected:     0   |
| commands received:  0 collisions:           0   |
+--- ESC exits ---[ WHO rate = 4 sec ]-----+

Press a function key.

Remote Program      PLC-5/40C Series C Revision A      CNET Node 1
Clear Lock          Save Who
Counter Counter    Config Rate
F2 F3              F9 F10
    
```

If you want to:	Do this:
clear all the ControlNet diagnostic counters	Press [F2]—Clear Counter
toggle to lock all the counters on the screen (while they continue to run in the background); then toggle back to unlock the counters so that they are updated continuously	1. Press [F3]—Lock Counter 2. Press [F3]—Unlock Counter
save the current ControlNet WHO configuration as the permanent ControlNet WHO configuration	Press [F9]—Save Config
enter a new ControlNet WHO rate	Press [F10]—WHO Rate
go to the ControlNet WHO ACTIVE—Active Node Identification screen	Press [Esc]

For descriptions of the status fields on the ControlNet WHO ACTIVE—Active Node Status screen, see page 5-13.

Using the ControlNet WHO ACTIVE—Channel Status Screen

Important: Keep the following in mind:

- ControlNet WHO screens are available only when your programming device is communicating through a 1784-KTC card, 1784-KTCx card, or 1770-KFC interface on the ControlNet network.
- When you view the WHO screens while your ControlNet system is operating, you affect the performance of unscheduled I/O operations.

Follow the steps on the left to go to the ControlNet WHO ACTIVE—Channel Status screen.



```

+--- ControlNet WHO ACTIVE - Channel Status -----+
| Node  Active Channel A Channel B   Bad frame received from node number |
|      Channel Status  Status      most recent to least recent   |
+-----+-----+-----+-----+
| 01    A    Good    Inactive                                     |
| 02    A    Good    Inactive                                     |
| 03    A    Good    Inactive                                     |
| 04    A    Good    Inactive                                     |
| 05                                          |
| 06                                          |
| 07                                          |
| 08                                          |
| 09                                          |
| 10                                          |
| 11                                          |
| 12                                          |
+-----+-----+-----+-----+
+--- ESC exits --[ WHO rate = 4 sec ]---[ Maximum Unscheduled Nodes = 12 ]---+

Press a function key, or page up or page down.

Net Channel A Status: Cable Good      Net Channel B Status: Cable Inactive
Network                                     Save   Who
Diags                                       Config Rate
F6                                           F9    F10
    
```

If you want to:	Press:
go to the ControlNet WHO ACTIVE—Network Status screen	[F6]—Network Diags
save the current ControlNet WHO configuration as the permanent ControlNet WHO configuration	[F9]—Save Config
enter a new ControlNet WHO update rate	[F10]—WHO Rate
go to the ControlNet WHO ACTIVE—Active Node Identification screen	[Esc]

This field:	Displays:
Node	a device's network address
Active Channel	the channel that the node is using
Channel A Status	the status of the channel A for the specified node <ul style="list-style-type: none"> Good = channel A is receiving no unusable frames WARN = channel A is receiving a low level of unusable frames FAULTED = channel A is receiving a high level of unusable frames; it is not usable Inactive = channel A is not currently active

Processor Specifications

Heat Dissipation	54 BTU/hr
Environmental Conditions	Operating Temperature: 0 to 60° C (32-140° F) Storage Temperature: -40 to 85° C (-40 to 185° F) Relative Humidity: 5 to 95% (without condensation)
Shock and Vibration	Vibration Testing (operating and non-operating): 1 g @ 10 to 500 Hz 0.012 inches peak-to-peak displacement Shock: Operating 30 g peak acceleration for 11±1 ms duration Non-operating 50 g peak acceleration for 11±1 ms duration
Time-of-Day Clock/Calendar	Maximum Variations at 60° C: ± 5 min per month Typical Variations at 20° C: ± 20 s per month Timing Accuracy: 1 program scan
Battery	1770-XYC
Memory Modules	<ul style="list-style-type: none"> • 1785-ME16 • 1785-ME32 • 1785-ME64 • 1785-M100
I/O Modules	Bulletin 1771 I/O, 1794 I/O, 1746 I/O, and 1791 I/O including 8-, 16-, 32-pt, and intelligent modules
Hardware Addressing	2-slot <ul style="list-style-type: none"> • Any mix of 8-pt modules • 16-pt modules must be I/O pairs • No 32-pt modules 1-slot <ul style="list-style-type: none"> • Any mix of 8- or 16-pt modules • 32-pt modules must be I/O pairs 1/2-slot—Any mix of 8-, 16-, or 32-pt modules
Communication	<ul style="list-style-type: none"> • Serial • DH+ • DH using 1785-KA • Remote I/O • ControlNet
Location	1771-A1B, -A2B, A3B, -A3B1, -A4B, -AM1, -AM2 chassis; left-most slot
Weight	PLC-5/40C: 3 lbs, 2 oz (1.42 kg) PLC-5/20C: 3 lbs, 3 oz (1.45 kg)
Keying	<ul style="list-style-type: none"> • Between 40 and 42 • Between 54 and 56
Agency Certification (When product is marked)	<ul style="list-style-type: none"> • CSA Class I, Division 2, Groups A, B, C, D • UL listed

Appendix A
Processor Specifications

		PLC-5/20C	PLC-5/40C
Maximum User Memory Words		16K	48K ^①
Maximum Total I/O	Any Mix	512	2048
	Complimentary	512 in and 512 out	2048 in and 2048 out
Program Scan Time		0.5 ms per K word (bit logic) 2 ms per K word (typical)	
ControlNet I/O^②	Maximum Non-discrete I/O Data-Transfer Data-Table Size	1000 words in and 1000 words out	
	Transmission Rate	5M bit/s	
	Network Update Time (NUT)	2-100 ms (user selectable)	
	Number of ControlNet Ports	1	
	Number of Redundant Media ControlNet Ports	1	
	Maximum Number of Nodes per Link without a Repeater	48—with 250 m (approx. 820 ft) cable length	
	Maximum Number of Nodes per Link with Repeaters	107	
	Maximum Link Cable Length without a Repeater	1,000 m (approximately 3,280 ft)—with 2 nodes 500 m (approximately 1,640 ft)—with 32 nodes 250 m (approximately 820 ft)—with 48 nodes	
	Maximum Link Cable Length with Repeaters	6,000 m (approximately 19,680 ft)—with 2 nodes 3,000 m (approximately 9,840 ft)—typical	
	Maximum Number of Repeaters in Series per Link	5	
	Maximum Number of Segments in Series per Link	6	
Non-ControlNet Remote I/O	Transmission Rate	57.6K bit/s 115.2K bit/s 230.4K bit/s	
	I/O Scan Time (Typical)	10 ms per rack @ 57.6K bit/s 7 ms per rack @ 115.2K bit/s 3 ms per rack @ 230K bit/s	
	Maximum Number of Remote I/O Racks	4	16
	Maximum Number of Remote I/O Devices	12	60
	Number of Ports Configurable for DH+ or Remote I/O (Adapter or Scanner)	1	2
	Number of Dedicated DH+ Ports	1	0
Number of Serial Ports		1	
Number of Coprocessor Ports		1	
Maximum Number of MCPs		16	
Backplane Current Load	Maximum	3.0 A	
	Typical	2.7 A	

^① The PLC-5/40C processor has a limit of 32K words per data-table file.

^② See the ControlNet Cable System Planning and Installation Manual, publication 1786-6.2.1, for more information.

Processor Status File

Processor status data is stored in data-file 2.

S:0-S:2

This word of the status file:	Stores:																																		
S:0	Arithmetic flags <ul style="list-style-type: none"> • bit 0 = carry • bit 1 = overflow • bit 2 = zero • bit 3 = sign 																																		
S:1	Processor status and flags <table border="1"> <thead> <tr> <th>Bit</th> <th>Description</th> </tr> </thead> <tbody> <tr><td>0</td><td>RAM checksum is invalid at power-up</td></tr> <tr><td>1</td><td>processor in Run mode</td></tr> <tr><td>2</td><td>processor in Test mode</td></tr> <tr><td>3</td><td>processor in Program mode</td></tr> <tr><td>4</td><td>processor burning EEPROM</td></tr> <tr><td>5</td><td>enabled download operation</td></tr> <tr><td>6</td><td>enabled test edit mode</td></tr> <tr><td>7</td><td>mode select switch in Remote position</td></tr> <tr><td>8</td><td>forces enabled</td></tr> <tr><td>9</td><td>forces present</td></tr> <tr><td>10</td><td>processor successfully burned EEPROM</td></tr> <tr><td>11</td><td>performing online programming</td></tr> <tr><td>12</td><td>processor in Debug mode</td></tr> <tr><td>13</td><td>user program checksum done</td></tr> <tr><td>14</td><td>last scan of ladder or SFC step</td></tr> <tr><td>15</td><td>processor started fist program scan or the first scan of the next step in an SFC</td></tr> </tbody> </table>	Bit	Description	0	RAM checksum is invalid at power-up	1	processor in Run mode	2	processor in Test mode	3	processor in Program mode	4	processor burning EEPROM	5	enabled download operation	6	enabled test edit mode	7	mode select switch in Remote position	8	forces enabled	9	forces present	10	processor successfully burned EEPROM	11	performing online programming	12	processor in Debug mode	13	user program checksum done	14	last scan of ladder or SFC step	15	processor started fist program scan or the first scan of the next step in an SFC
Bit	Description																																		
0	RAM checksum is invalid at power-up																																		
1	processor in Run mode																																		
2	processor in Test mode																																		
3	processor in Program mode																																		
4	processor burning EEPROM																																		
5	enabled download operation																																		
6	enabled test edit mode																																		
7	mode select switch in Remote position																																		
8	forces enabled																																		
9	forces present																																		
10	processor successfully burned EEPROM																																		
11	performing online programming																																		
12	processor in Debug mode																																		
13	user program checksum done																																		
14	last scan of ladder or SFC step																																		
15	processor started fist program scan or the first scan of the next step in an SFC																																		
S:2	Switch setting information <ul style="list-style-type: none"> • bits 0-7 DH+ station number • bit 11-12 are set based on the I/O chassis backplane switches <table border="1"> <thead> <tr> <th>bit 12</th> <th>bit 11</th> <th>I/O chassis addressing</th> </tr> </thead> <tbody> <tr><td>0</td><td>0</td><td>illegal</td></tr> <tr><td>1</td><td>0</td><td>1/2-slot</td></tr> <tr><td>0</td><td>1</td><td>1-slot</td></tr> <tr><td>1</td><td>1</td><td>2-slot</td></tr> </tbody> </table> <ul style="list-style-type: none"> • bit 13: 1 = load from EEPROM • bit 14: 1 = RAM backup not configured • bit 15: 1 = memory unprotected 	bit 12	bit 11	I/O chassis addressing	0	0	illegal	1	0	1/2-slot	0	1	1-slot	1	1	2-slot																			
bit 12	bit 11	I/O chassis addressing																																	
0	0	illegal																																	
1	0	1/2-slot																																	
0	1	1-slot																																	
1	1	2-slot																																	

Appendix B

Processor Status File

S:3-10

This word of the status file:	Stores:																																		
S:3 to S:6	Active Node table for channel 1A <table border="1"> <thead> <tr> <th>Word</th> <th>Bits</th> <th>DH+ Station #</th> </tr> </thead> <tbody> <tr> <td>3</td> <td>0-15</td> <td>00-17</td> </tr> <tr> <td>4</td> <td>0-15</td> <td>20-37</td> </tr> <tr> <td>5</td> <td>0-15</td> <td>40-57</td> </tr> <tr> <td>6</td> <td>0-15</td> <td>60-77</td> </tr> </tbody> </table>	Word	Bits	DH+ Station #	3	0-15	00-17	4	0-15	20-37	5	0-15	40-57	6	0-15	60-77																			
Word	Bits	DH+ Station #																																	
3	0-15	00-17																																	
4	0-15	20-37																																	
5	0-15	40-57																																	
6	0-15	60-77																																	
S:7	Global status bits: <ul style="list-style-type: none"> • low 8 bits—rack fault bits for racks 0-7 • high 8 bits—rack queue-full bits for racks 0-7 																																		
S:8	Last program scan (in ms)																																		
S:9	Maximum program scan (in ms)																																		
S:10	Minor fault (word 1) <table border="1"> <thead> <tr> <th>Bit</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>battery is missing or low (replace in 1-2 days)</td> </tr> <tr> <td>1</td> <td>DH+ table has changed (active node table)</td> </tr> <tr> <td>2</td> <td>STI delay too short, interrupt program overlap</td> </tr> <tr> <td>3</td> <td>EEPROM memory transfer at power-up</td> </tr> <tr> <td>4</td> <td>edits prevent SFC continuing</td> </tr> <tr> <td>5</td> <td>invalid I/O status file</td> </tr> <tr> <td>6</td> <td>memory-cartridge battery low</td> </tr> <tr> <td>7</td> <td>no more command blocks exist</td> </tr> <tr> <td>8</td> <td>not enough memory on the memory module to upload the program from the processor</td> </tr> <tr> <td>9</td> <td>no MCP is configured to Run</td> </tr> <tr> <td>10</td> <td>MCP not allowed</td> </tr> <tr> <td>11</td> <td>PII word number not in local rack</td> </tr> <tr> <td>12</td> <td>PII overlap</td> </tr> <tr> <td>13</td> <td>no command blocks exist to get PII</td> </tr> <tr> <td>14</td> <td>arithmetic overflow</td> </tr> <tr> <td>15</td> <td>SFC action overlap</td> </tr> </tbody> </table>	Bit	Description	0	battery is missing or low (replace in 1-2 days)	1	DH+ table has changed (active node table)	2	STI delay too short, interrupt program overlap	3	EEPROM memory transfer at power-up	4	edits prevent SFC continuing	5	invalid I/O status file	6	memory-cartridge battery low	7	no more command blocks exist	8	not enough memory on the memory module to upload the program from the processor	9	no MCP is configured to Run	10	MCP not allowed	11	PII word number not in local rack	12	PII overlap	13	no command blocks exist to get PII	14	arithmetic overflow	15	SFC action overlap
Bit	Description																																		
0	battery is missing or low (replace in 1-2 days)																																		
1	DH+ table has changed (active node table)																																		
2	STI delay too short, interrupt program overlap																																		
3	EEPROM memory transfer at power-up																																		
4	edits prevent SFC continuing																																		
5	invalid I/O status file																																		
6	memory-cartridge battery low																																		
7	no more command blocks exist																																		
8	not enough memory on the memory module to upload the program from the processor																																		
9	no MCP is configured to Run																																		
10	MCP not allowed																																		
11	PII word number not in local rack																																		
12	PII overlap																																		
13	no command blocks exist to get PII																																		
14	arithmetic overflow																																		
15	SFC action overlap																																		

Appendix B

Processor Status File

S:11-S:12

This word of the status file:	Stores:																																																																						
S:11	<p>Major fault</p> <table border="1"> <thead> <tr> <th>Bit</th> <th>Description</th> </tr> </thead> <tbody> <tr><td>0</td><td>corrupted program file (codes 10-19)</td></tr> <tr><td>1</td><td>corrupted address in ladder file (codes 10-29)</td></tr> <tr><td>2</td><td>programming error (codes 30-49)</td></tr> <tr><td>3</td><td>SFC fault (codes 71-79)</td></tr> <tr><td>4</td><td>error while assembling program (code 70)</td></tr> <tr><td>5</td><td>start-up protection fault</td></tr> <tr><td>6</td><td>peripheral device fault</td></tr> <tr><td>7</td><td>jumped to fault routine (codes 0-9)</td></tr> <tr><td>8</td><td>watchdog faulted</td></tr> <tr><td>9</td><td>system configured wrong (codes 80-89)</td></tr> <tr><td>10</td><td>recoverable hardware error</td></tr> <tr><td>11</td><td>MCP does not exist or is not ladder or SFC file</td></tr> <tr><td>12</td><td>PII does not exist or is not ladder</td></tr> <tr><td>13</td><td>STI does not exist or is not ladder</td></tr> <tr><td>14</td><td>fault routine does not exist or is not ladder</td></tr> <tr><td>15</td><td>fault routine file is not a ladder file</td></tr> </tbody> </table>	Bit	Description	0	corrupted program file (codes 10-19)	1	corrupted address in ladder file (codes 10-29)	2	programming error (codes 30-49)	3	SFC fault (codes 71-79)	4	error while assembling program (code 70)	5	start-up protection fault	6	peripheral device fault	7	jumped to fault routine (codes 0-9)	8	watchdog faulted	9	system configured wrong (codes 80-89)	10	recoverable hardware error	11	MCP does not exist or is not ladder or SFC file	12	PII does not exist or is not ladder	13	STI does not exist or is not ladder	14	fault routine does not exist or is not ladder	15	fault routine file is not a ladder file																																				
Bit	Description																																																																						
0	corrupted program file (codes 10-19)																																																																						
1	corrupted address in ladder file (codes 10-29)																																																																						
2	programming error (codes 30-49)																																																																						
3	SFC fault (codes 71-79)																																																																						
4	error while assembling program (code 70)																																																																						
5	start-up protection fault																																																																						
6	peripheral device fault																																																																						
7	jumped to fault routine (codes 0-9)																																																																						
8	watchdog faulted																																																																						
9	system configured wrong (codes 80-89)																																																																						
10	recoverable hardware error																																																																						
11	MCP does not exist or is not ladder or SFC file																																																																						
12	PII does not exist or is not ladder																																																																						
13	STI does not exist or is not ladder																																																																						
14	fault routine does not exist or is not ladder																																																																						
15	fault routine file is not a ladder file																																																																						
S:12	<p>Fault codes</p> <table border="1"> <thead> <tr> <th>Code</th> <th>Description</th> </tr> </thead> <tbody> <tr><td>0-9</td><td>user-defined</td></tr> <tr><td>10</td><td>failed data table check</td></tr> <tr><td>11</td><td>bad user program checksum</td></tr> <tr><td>12</td><td>bad integer operand type</td></tr> <tr><td>13</td><td>bad mixed mode operand type</td></tr> <tr><td>14</td><td>not enough operands for instruction</td></tr> <tr><td>15</td><td>too many operands for instruction</td></tr> <tr><td>16</td><td>bad instruction found</td></tr> <tr><td>17</td><td>no expression end</td></tr> <tr><td>18</td><td>missing end of edit zone</td></tr> <tr><td>19</td><td>download aborted</td></tr> <tr><td>20</td><td>indirect address out of range (high)</td></tr> <tr><td>21</td><td>indirect address out of range (low)</td></tr> <tr><td>22</td><td>attempt to access undefined file</td></tr> <tr><td>23</td><td>file number less than 0 or greater than number of defined files; or, indirect reference to file 0, 1, 2; or bad file number</td></tr> <tr><td>24</td><td>indirect reference to wrong file type</td></tr> <tr><td>30</td><td>subroutine jump nesting level exceeded</td></tr> <tr><td>31</td><td>too few subroutine parameters</td></tr> <tr><td>32</td><td>jump to non-ladder file</td></tr> <tr><td>33</td><td>CAR routine not 68000 code</td></tr> <tr><td>34</td><td>bad timer parameters entered</td></tr> <tr><td>35</td><td>bad PID delta time entered</td></tr> <tr><td>36</td><td>PID setpoint out of range</td></tr> <tr><td>37</td><td>invalid I/O specified in an immediate I/O instruction</td></tr> <tr><td>38</td><td>invalid use of return instruction</td></tr> <tr><td>39</td><td>FOR loop missing NXT</td></tr> <tr><td>40</td><td>control file too small</td></tr> <tr><td>41</td><td>NXT instruction with no FOR</td></tr> <tr><td>42</td><td>jump target does not exist</td></tr> <tr><td>43</td><td>file is not an SFC</td></tr> <tr><td>44</td><td>error using SFR</td></tr> <tr><td>45</td><td>invalid channel number entered</td></tr> <tr><td>46</td><td>IDI or IDO instruction length operand too long (> 64 words)</td></tr> <tr><td>47-69</td><td>reserved</td></tr> </tbody> </table>	Code	Description	0-9	user-defined	10	failed data table check	11	bad user program checksum	12	bad integer operand type	13	bad mixed mode operand type	14	not enough operands for instruction	15	too many operands for instruction	16	bad instruction found	17	no expression end	18	missing end of edit zone	19	download aborted	20	indirect address out of range (high)	21	indirect address out of range (low)	22	attempt to access undefined file	23	file number less than 0 or greater than number of defined files; or, indirect reference to file 0, 1, 2; or bad file number	24	indirect reference to wrong file type	30	subroutine jump nesting level exceeded	31	too few subroutine parameters	32	jump to non-ladder file	33	CAR routine not 68000 code	34	bad timer parameters entered	35	bad PID delta time entered	36	PID setpoint out of range	37	invalid I/O specified in an immediate I/O instruction	38	invalid use of return instruction	39	FOR loop missing NXT	40	control file too small	41	NXT instruction with no FOR	42	jump target does not exist	43	file is not an SFC	44	error using SFR	45	invalid channel number entered	46	IDI or IDO instruction length operand too long (> 64 words)	47-69	reserved
Code	Description																																																																						
0-9	user-defined																																																																						
10	failed data table check																																																																						
11	bad user program checksum																																																																						
12	bad integer operand type																																																																						
13	bad mixed mode operand type																																																																						
14	not enough operands for instruction																																																																						
15	too many operands for instruction																																																																						
16	bad instruction found																																																																						
17	no expression end																																																																						
18	missing end of edit zone																																																																						
19	download aborted																																																																						
20	indirect address out of range (high)																																																																						
21	indirect address out of range (low)																																																																						
22	attempt to access undefined file																																																																						
23	file number less than 0 or greater than number of defined files; or, indirect reference to file 0, 1, 2; or bad file number																																																																						
24	indirect reference to wrong file type																																																																						
30	subroutine jump nesting level exceeded																																																																						
31	too few subroutine parameters																																																																						
32	jump to non-ladder file																																																																						
33	CAR routine not 68000 code																																																																						
34	bad timer parameters entered																																																																						
35	bad PID delta time entered																																																																						
36	PID setpoint out of range																																																																						
37	invalid I/O specified in an immediate I/O instruction																																																																						
38	invalid use of return instruction																																																																						
39	FOR loop missing NXT																																																																						
40	control file too small																																																																						
41	NXT instruction with no FOR																																																																						
42	jump target does not exist																																																																						
43	file is not an SFC																																																																						
44	error using SFR																																																																						
45	invalid channel number entered																																																																						
46	IDI or IDO instruction length operand too long (> 64 words)																																																																						
47-69	reserved																																																																						

Appendix B

Processor Status File

S:12-S:16

This word of the status file:	Stores:																																																																																		
S:12 (continued)	Fault codes <table border="1"> <thead> <tr> <th>Code</th> <th>Description</th> </tr> </thead> <tbody> <tr><td>70</td><td>duplicate labels</td></tr> <tr><td>71</td><td>SFC subchart is already executing</td></tr> <tr><td>72</td><td>tried to stop an SFC that is not running</td></tr> <tr><td>73</td><td>maximum number of SFC subcharts exceeded</td></tr> <tr><td>74</td><td>SFC file error</td></tr> <tr><td>75</td><td>SFC contains too many active steps</td></tr> <tr><td>77</td><td>SFC references a step, transition, subchart, or SC file that is missing, empty, or too small</td></tr> <tr><td>78</td><td>SFC could not continue after power loss</td></tr> <tr><td>79</td><td>error in downloading an SFC to a processor that cannot run SFCs or this specific PLC processor does not support this enhanced SFC</td></tr> <tr><td>80</td><td>I/O configuration error</td></tr> <tr><td>81</td><td>illegal setting of I/O chassis backplane switch</td></tr> <tr><td>82</td><td>illegal cartridge type</td></tr> <tr><td>83</td><td>user watchdog fault</td></tr> <tr><td>84</td><td>error in user-configured adapter mode block transfers</td></tr> <tr><td>85</td><td>bad cartridge</td></tr> <tr><td>86</td><td>cartridge incompatible with host</td></tr> <tr><td>87</td><td>rack overlap (includes any adapter channel)</td></tr> <tr><td>88</td><td>scanner channels are overloading the remote I/O buffer; too much data for the processor to process</td></tr> <tr><td>90</td><td>coprocessor extensive memory test failed</td></tr> <tr><td>91</td><td>coprocessor undefined message type</td></tr> <tr><td>92</td><td>coprocessor illegal pool index</td></tr> <tr><td>93</td><td>coprocessor illegal maximum pool size</td></tr> <tr><td>94</td><td>coprocessor illegal ASCII message</td></tr> <tr><td>95</td><td>coprocessor reported fault</td></tr> <tr><td>96</td><td>coprocessor present signal lost</td></tr> <tr><td>97</td><td>coprocessor illegal minimum pool size</td></tr> <tr><td>98</td><td>coprocessor first/last 16 bytes RAM test failed</td></tr> <tr><td>99</td><td>coprocessor to processor data transfer faulted</td></tr> <tr><td>100</td><td>processor to coprocessor transfer failed</td></tr> <tr><td>101</td><td>coprocessor end of scan transfer failed</td></tr> <tr><td>102</td><td>file number specified for raw data transfer through the coprocessor is an illegal value</td></tr> <tr><td>103</td><td>element number specified for raw data transfer through the coprocessor is an illegal value</td></tr> <tr><td>104</td><td>size of the transfer requested through the coprocessor is an illegal size</td></tr> <tr><td>105</td><td>offset into the raw transfer segment of the coprocessor is an illegal value</td></tr> <tr><td>106</td><td>coprocessor transfer protection violation</td></tr> <tr><td>200</td><td>ControlNet output transfer missed</td></tr> <tr><td>201</td><td>ControlNet input data missed</td></tr> <tr><td>202</td><td>ControlNet diagnostic data missed</td></tr> <tr><td>203</td><td>ControlNet scheduled transmit data overflow</td></tr> <tr><td>204</td><td>ControlNet configuration too complex for the PLC-5 processor</td></tr> </tbody> </table>	Code	Description	70	duplicate labels	71	SFC subchart is already executing	72	tried to stop an SFC that is not running	73	maximum number of SFC subcharts exceeded	74	SFC file error	75	SFC contains too many active steps	77	SFC references a step, transition, subchart, or SC file that is missing, empty, or too small	78	SFC could not continue after power loss	79	error in downloading an SFC to a processor that cannot run SFCs or this specific PLC processor does not support this enhanced SFC	80	I/O configuration error	81	illegal setting of I/O chassis backplane switch	82	illegal cartridge type	83	user watchdog fault	84	error in user-configured adapter mode block transfers	85	bad cartridge	86	cartridge incompatible with host	87	rack overlap (includes any adapter channel)	88	scanner channels are overloading the remote I/O buffer; too much data for the processor to process	90	coprocessor extensive memory test failed	91	coprocessor undefined message type	92	coprocessor illegal pool index	93	coprocessor illegal maximum pool size	94	coprocessor illegal ASCII message	95	coprocessor reported fault	96	coprocessor present signal lost	97	coprocessor illegal minimum pool size	98	coprocessor first/last 16 bytes RAM test failed	99	coprocessor to processor data transfer faulted	100	processor to coprocessor transfer failed	101	coprocessor end of scan transfer failed	102	file number specified for raw data transfer through the coprocessor is an illegal value	103	element number specified for raw data transfer through the coprocessor is an illegal value	104	size of the transfer requested through the coprocessor is an illegal size	105	offset into the raw transfer segment of the coprocessor is an illegal value	106	coprocessor transfer protection violation	200	ControlNet output transfer missed	201	ControlNet input data missed	202	ControlNet diagnostic data missed	203	ControlNet scheduled transmit data overflow	204	ControlNet configuration too complex for the PLC-5 processor
Code	Description																																																																																		
70	duplicate labels																																																																																		
71	SFC subchart is already executing																																																																																		
72	tried to stop an SFC that is not running																																																																																		
73	maximum number of SFC subcharts exceeded																																																																																		
74	SFC file error																																																																																		
75	SFC contains too many active steps																																																																																		
77	SFC references a step, transition, subchart, or SC file that is missing, empty, or too small																																																																																		
78	SFC could not continue after power loss																																																																																		
79	error in downloading an SFC to a processor that cannot run SFCs or this specific PLC processor does not support this enhanced SFC																																																																																		
80	I/O configuration error																																																																																		
81	illegal setting of I/O chassis backplane switch																																																																																		
82	illegal cartridge type																																																																																		
83	user watchdog fault																																																																																		
84	error in user-configured adapter mode block transfers																																																																																		
85	bad cartridge																																																																																		
86	cartridge incompatible with host																																																																																		
87	rack overlap (includes any adapter channel)																																																																																		
88	scanner channels are overloading the remote I/O buffer; too much data for the processor to process																																																																																		
90	coprocessor extensive memory test failed																																																																																		
91	coprocessor undefined message type																																																																																		
92	coprocessor illegal pool index																																																																																		
93	coprocessor illegal maximum pool size																																																																																		
94	coprocessor illegal ASCII message																																																																																		
95	coprocessor reported fault																																																																																		
96	coprocessor present signal lost																																																																																		
97	coprocessor illegal minimum pool size																																																																																		
98	coprocessor first/last 16 bytes RAM test failed																																																																																		
99	coprocessor to processor data transfer faulted																																																																																		
100	processor to coprocessor transfer failed																																																																																		
101	coprocessor end of scan transfer failed																																																																																		
102	file number specified for raw data transfer through the coprocessor is an illegal value																																																																																		
103	element number specified for raw data transfer through the coprocessor is an illegal value																																																																																		
104	size of the transfer requested through the coprocessor is an illegal size																																																																																		
105	offset into the raw transfer segment of the coprocessor is an illegal value																																																																																		
106	coprocessor transfer protection violation																																																																																		
200	ControlNet output transfer missed																																																																																		
201	ControlNet input data missed																																																																																		
202	ControlNet diagnostic data missed																																																																																		
203	ControlNet scheduled transmit data overflow																																																																																		
204	ControlNet configuration too complex for the PLC-5 processor																																																																																		
S:13	Program file where fault occurred																																																																																		
S:14	Rung number where fault occurred																																																																																		
S:15	VME status file																																																																																		
S:16	I/O Status File																																																																																		

Appendix B

Processor Status File

S:17-S:27

This word of the status file:	Stores:																																		
S:17	Minor fault (word 2) <table border="1"> <thead> <tr> <th>Bit</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>BT queue full to remote I/O</td> </tr> <tr> <td>1</td> <td>queue full—channel 1A</td> </tr> <tr> <td>2</td> <td>queue full—channel 1B</td> </tr> <tr> <td>3</td> <td>queue full—channel 2A</td> </tr> <tr> <td>4</td> <td>queue full—channel 2B</td> </tr> <tr> <td>5</td> <td>no modem on serial port</td> </tr> <tr> <td>6</td> <td>remote I/O rack in local rack table; or, remote I/O rack is greater than the image size</td> </tr> <tr> <td>7</td> <td>plug firmware revision does not match processor firmware revision</td> </tr> <tr> <td>8</td> <td>ASCII instruction error</td> </tr> <tr> <td>9</td> <td>duplicate network address</td> </tr> <tr> <td>10</td> <td>DF1 master poll list error</td> </tr> <tr> <td>11</td> <td>protected-processor data-table element violation</td> </tr> <tr> <td>12</td> <td>protected-processor file violation</td> </tr> <tr> <td>13</td> <td>using all 32 ControlNet MSGs</td> </tr> <tr> <td>14</td> <td>using all 32 ControlNet 1771 READ and/or 1771 WRITE CIOs</td> </tr> <tr> <td>15</td> <td>using all 8 ControlNet Flex I/O CIOs</td> </tr> </tbody> </table>	Bit	Description	0	BT queue full to remote I/O	1	queue full—channel 1A	2	queue full—channel 1B	3	queue full—channel 2A	4	queue full—channel 2B	5	no modem on serial port	6	remote I/O rack in local rack table; or, remote I/O rack is greater than the image size	7	plug firmware revision does not match processor firmware revision	8	ASCII instruction error	9	duplicate network address	10	DF1 master poll list error	11	protected-processor data-table element violation	12	protected-processor file violation	13	using all 32 ControlNet MSGs	14	using all 32 ControlNet 1771 READ and/or 1771 WRITE CIOs	15	using all 8 ControlNet Flex I/O CIOs
Bit	Description																																		
0	BT queue full to remote I/O																																		
1	queue full—channel 1A																																		
2	queue full—channel 1B																																		
3	queue full—channel 2A																																		
4	queue full—channel 2B																																		
5	no modem on serial port																																		
6	remote I/O rack in local rack table; or, remote I/O rack is greater than the image size																																		
7	plug firmware revision does not match processor firmware revision																																		
8	ASCII instruction error																																		
9	duplicate network address																																		
10	DF1 master poll list error																																		
11	protected-processor data-table element violation																																		
12	protected-processor file violation																																		
13	using all 32 ControlNet MSGs																																		
14	using all 32 ControlNet 1771 READ and/or 1771 WRITE CIOs																																		
15	using all 8 ControlNet Flex I/O CIOs																																		
S:18	Processor clock year																																		
S:19	Processor clock month																																		
S:20	Processor clock day																																		
S:21	Processor clock hour																																		
S:22	Processor clock minute																																		
S:23	Processor clock second																																		
S:24	Indexed addressing offset																																		
S:26	User control bits <table border="1"> <thead> <tr> <th>Bit</th> <th>Description</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>Restart/continuous SFC: when reset, processor restarts at first step in SFC. When set, processor continues with active step after power loss or change to Run</td> </tr> <tr> <td>1</td> <td>Start-up protection after power loss: when reset, no protection. When set, processor executes fault routine at power-up (sets word 11, bit 5).</td> </tr> <tr> <td>2</td> <td>Define the address of the local rack: when reset, local rack address is 0. When set, local rack address is 1.</td> </tr> <tr> <td>3</td> <td>Set complementary I/O: when reset, complementary I/O is not enabled. When set, complementary I/O is enabled.</td> </tr> <tr> <td>4</td> <td>Local block transfer compatibility bit: when reset, normal operation. When set, eliminates frequent checksum errors to certain BT modules.</td> </tr> <tr> <td>5</td> <td>When set (1), delay adapter channel response by 1 s for compatibility with PLC-3 scanners. When reset (0), operate in normal response time.</td> </tr> </tbody> </table>	Bit	Description	0	Restart/continuous SFC: when reset, processor restarts at first step in SFC. When set, processor continues with active step after power loss or change to Run	1	Start-up protection after power loss: when reset, no protection. When set, processor executes fault routine at power-up (sets word 11, bit 5).	2	Define the address of the local rack: when reset, local rack address is 0. When set, local rack address is 1.	3	Set complementary I/O: when reset, complementary I/O is not enabled. When set, complementary I/O is enabled.	4	Local block transfer compatibility bit: when reset, normal operation. When set, eliminates frequent checksum errors to certain BT modules.	5	When set (1), delay adapter channel response by 1 s for compatibility with PLC-3 scanners. When reset (0), operate in normal response time.																				
Bit	Description																																		
0	Restart/continuous SFC: when reset, processor restarts at first step in SFC. When set, processor continues with active step after power loss or change to Run																																		
1	Start-up protection after power loss: when reset, no protection. When set, processor executes fault routine at power-up (sets word 11, bit 5).																																		
2	Define the address of the local rack: when reset, local rack address is 0. When set, local rack address is 1.																																		
3	Set complementary I/O: when reset, complementary I/O is not enabled. When set, complementary I/O is enabled.																																		
4	Local block transfer compatibility bit: when reset, normal operation. When set, eliminates frequent checksum errors to certain BT modules.																																		
5	When set (1), delay adapter channel response by 1 s for compatibility with PLC-3 scanners. When reset (0), operate in normal response time.																																		
S:27	Rack control bits: <ul style="list-style-type: none"> low 8 bits—I/O rack inhibit bits for racks 0-7 high 8 bits—I/O rack reset bits for racks 0-7 																																		

Appendix B

Processor Status File

S:28-S:61

This word of the status file:	Stores:
S:28	Program watchdog setpoint
S:29	Fault routine file
S:30	STI setpoint
S:31	STI file number
S:32	Global status bits: <ul style="list-style-type: none"> • low 8 bits—rack fault bits for racks 10-17 (octal) • high 8 bits—rack queue-full bits for racks 10-17
S:33	Rack control bits: <ul style="list-style-type: none"> • low 8 bits—I/O rack inhibit bits for racks 10-17 • high 8 bits—I/O rack reset bits for racks 10-17
S:34	Global status bits: <ul style="list-style-type: none"> • low 8 bits—rack fault bits for racks 20-27 (octal) • high 8 bits—rack queue-full bits for racks 20-27
S:35	Rack control bits: <ul style="list-style-type: none"> • low 8 bits—I/O rack inhibit bits for racks 20-27 • high 8 bits—I/O rack reset bits for racks 20-27
S:46	PII program file number
S:47	PII module group
S:48	PII bit mask
S:49	PII compare value
S:50	PII down count
S:51	PII changed bit
S:52	PII events since last interrupt
S:53	STI scan time (in ms)
S:54	STI maximum scan time (in ms)
S:55	PII last scan time (in ms)
S:56	PII maximum scan time (in ms)
S:57	User program checksum
S:59	Extended-local I/O channel discrete transfer scan (in ms)
S:60	Extended-local I/O channel discrete maximum scan (in ms)
S:61	Extended-local I/O channel block-transfer scan (in ms)

Appendix B

Processor Status File

S:62-S:127

This word of the status file:	Stores:
S:62	Extended-I/O channel maximum block-transfer scan (in ms)
S:63	Protected-processor data-table protection-file number
S:64	Number of remote block-transfer command blocks being used by channel-pair 1A/1B
S:76	Number of slots in processor-resident local rack 0 Illegal 1 4 slots 2 12 slots 3 8 slots 4 16 slots
S:77	Communication time slice for communication housekeeping functions (in ms)
S:78	MCP I/O update disable bits Bit 0 for MCP A Bit 1 for MCP B etc.
S:79	MCP inhibit bits Bit 0 for MCP A Bit 1 for MCP B etc.
S:80-S:127	MCP file number MCP scan time (in ms) MCP max scan time (in ms) The above sequence applies to each MCP; therefore, each MCP has 3 status words. For example, word 80: file number for MCP A word 81: scan time for MCP A word 82: maximum scan time for MCP A word 83: file number for MCP B word 84: scan time for MCP B etc.

ControlNet Instruction Set

ControlNet I/O Transfer Instruction

Instruction	Description
<div style="border: 1px solid black; padding: 5px; display: inline-block;"> CIO CNET I/O TRANSFER Control block CT21:50 </div>	<p>ControlNet I/O Transfer CT</p> <p>If the input conditions go from false to true, the data is transferred according to the instruction parameters you set when you enter the ControlNet I/O transfer instruction. The Control Block (CT21:50) contains status and instruction parameters.</p> <p><u>Status Bits</u> TO—Time-Out Bit EW—Enabled-Waiting Bit CO—Continuous Bit ER—Error Bit DN—Done Bit ST—Start Bit EN—Enable Bit</p> <p>You cannot use N (integer) control blocks on the ControlNet network.</p> <p>For continuous CIOs, condition the rung to be true for only one scan.</p>

Message Instructions on a ControlNet Network

Instruction	Description
<div style="border: 1px solid black; padding: 5px; display: inline-block;"> MSG SEND/RECEIVE MESSAGE Control block MG10:10 </div>	<p>Message MSG</p> <p>If the input conditions go from false to true, the data is transferred according to the instruction parameters you set when you enter the message instruction. The Control Block (MG10:10) contains status and instruction parameters.</p> <p><u>Status Bits</u> TO—Time-Out Bit EW—Enabled-Waiting Bit CO—Continuous Bit ER—Error Bit DN—Done Bit ST—Start Bit EN—Enable Bit</p> <p>You cannot use N (integer) control blocks on the ControlNet network.</p> <p>For continuous MSGs, condition the rung to be true for only one scan.</p>

Appendix C

ControlNet Instruction Set

Immediate Data I/O Instructions

Instruction	Description										
<table border="1"> <tr> <td colspan="2" style="text-align: center;">— IDI —</td> </tr> <tr> <td colspan="2">IMMEDIATE DATA INPUT</td> </tr> <tr> <td>Data file offset</td> <td style="text-align: right;">232</td> </tr> <tr> <td>Length</td> <td style="text-align: right;">10</td> </tr> <tr> <td>Destination</td> <td style="text-align: right;">N11:232</td> </tr> </table>	— IDI —		IMMEDIATE DATA INPUT		Data file offset	232	Length	10	Destination	N11:232	<p>Immediate Data Input IDI</p> <p>If the input conditions are true, an immediate data input is initiated that updates the destination file from the private buffers before the next normal input-image update. The Data file offset (232) is where the data is stored. The Length (10) identifies the number of words in the transfer—it can be an immediate value ranging from 1 to 64 or a logical address that specifies the number of words to be transferred. The Destination (N11:232) is the destination of the words to be transferred. The Destination should be the matching data-table address in the DIF except when you use the instruction to ensure data-block integrity in the case of Selectable Timed Interrupts (STIs). See page 4-7.</p>
— IDI —											
IMMEDIATE DATA INPUT											
Data file offset	232										
Length	10										
Destination	N11:232										
<table border="1"> <tr> <td colspan="2" style="text-align: center;">— IDO —</td> </tr> <tr> <td colspan="2">IMMEDIATE DATA OUTPUT</td> </tr> <tr> <td>Data file offset</td> <td style="text-align: right;">175</td> </tr> <tr> <td>Length</td> <td style="text-align: right;">24</td> </tr> <tr> <td>Source</td> <td style="text-align: right;">N12:175</td> </tr> </table>	— IDO —		IMMEDIATE DATA OUTPUT		Data file offset	175	Length	24	Source	N12:175	<p>Immediate Data Output IDO</p> <p>If the input conditions are true, an immediate data output is initiated that updates the private memory output buffers from the source file before the next normal output-image update. The Data file offset (175) is the offset into the buffer where the data is stored. The Length (24) identifies the number of words in the transfer—it can be an immediate value ranging from 1 to 64 or a logical address that specifies the number of words to be transferred. The Source (N12:175) is the source of the words to be transferred. The Source should be the matching data-table address in the DOF except when you use the instruction to ensure data-block integrity in the case of Selectable Timed Interrupts (STIs). See page 4-7.</p>
— IDO —											
IMMEDIATE DATA OUTPUT											
Data file offset	175										
Length	24										
Source	N12:175										




For detailed information on the instruction set for programming PLC-5 processors, see the Enhanced and Ethernet PLC-5 Programmable Controllers User Manual, publication 1785-6.5.12, and the PLC-5 Programming Software Instruction Set Reference, publication 6200-6.4.11.

ControlNet I/O Map-Entry Status Words and Error Messages


I/O Map-Entry Status Words

The ControlNet status file is an integer data-table file that you specify and configure with the I/O map for scheduled-I/O usage. It containing status information about all of the ControlNet network's scheduled I/O connections. Each I/O map-table entry has a status-file offset field pointing to three status words associated with the connection.

First Word



Second and Third Words



If these status words are for a 1794 Flex I/O module and there is no connection error, any 1's set in bits 00 through 07 of the third word indicate errors in the corresponding slots (numbered 0 through 7)

If these status words are for a Peer In or a Peer Out and there is no connection error, a 1 set in bit 00 of the third word indicates that the other (peer) processor is in Run mode

Appendix D**ControlNet I/O Map-Entry Status Words
and Error Messages****Error Messages**

The following is a list of ControlNet error codes, messages, possible causes, and possible corrective actions:

Decimal Code	Hex. Code	Error Message	Explanation / Possible Cause(s)	Possible Corrective Action(s)
Various	Various	CONFIGURATION DATA CORRUPTED	More than one configured and/or programmed data transfer is trying to use the same location in the data table	Re-configure map entry overlapping map-table locations or Re-enter overlapping ladder instructions
2	0x0002	SCHED BANDWIDTH NOT AVAILABLE	There are too many words scheduled for transmission	Reduce the number of words scheduled for transmission
			The network update time (NUT) is too small	Increase the network update time (NUT)
			The target node is not configured	Correctly configure the target node as an active node on the ControlNet network and save your ControlNet configuration
18	0x0012	TARGET NODE NOT RESPONDING	The ControlNet cable to the target node is broken and/or disconnected	Fix and/or reconnect the ControlNet cable to the target node
			No power is being received by the target node	Supply power to the target node
			The target node is offline	Correctly configure the target node as an active node on the ControlNet network and save your ControlNet configuration
20	0x0014	DEST SLOT/MSG NOT PRESENT	The slot number that you entered for an adapter is not in the valid range	Correct the map-table entry
			The number that you entered for a peer-to-peer message is not in the valid range	
			The peer-to-peer message map-table entry in the target node is inhibited	Clear the inhibit bit in the map-table entry of the target node
256	0x0100	CONNECTION IN USE	The connection that the originating node is trying to use is already in use	No action required—connection can be re-established after the target node times out the old connection
260	0x0104	NODE TYPE MISMATCH	You entered a node type in the map table that does not match the target node	Correct the map-table entry or Replace the target node with the node type entered in the map table
262	0x0106	CONNECTION USED BY OTHER NODE	The originating node attempted to open a connection that is already being used by another node	Delete or inhibit any other node's connection so that the preferred node can open the connection
263	0x0107	CONNECTION ALREADY CLOSED	The connection that the originating node is trying to close is already closed	No action required
265	0x0109	INVALID CONNECTION SIZE	The originating node attempted to open a connection with a larger size than the target node can support	Reduce the size that is entered in the map table or Use a rack with a greater number of slots or Use a rack with higher density
272	0x0110	NODE NOT CONFIGURED	The target node is offline	Correctly configure the target node as an active node on the ControlNet network and save your ControlNet configuration
			The target node is not configured	

Appendix D
ControlNet I/O Map-Entry Status Words
and Error Messages

Decimal Code	Hex. Code	Error Message	Explanation / Possible Cause(s)	Possible Corrective Action(s)
273	0x0111	EXP NET PCKT TIME INVALID	The target node cannot produce the data at or faster than the expected net packet time entered in the map table	Increase the expected net packet time entered in the map table
511	0x01FF	INVALID WHEN NODE IS IDLE The originating node attempted to open a data-transfer connection before a node connection was opened	The ControlNet cable to the target node is broken and/or disconnected	Fix and/or reconnect the ControlNet cable to the target node
			No power is being received by the target node	Supply power to the target node
			The target node is offline	Correctly configure the target node as an active node on the ControlNet network and save your ControlNet configuration
			The target adapter is in Processor Restart Lockout	Press the reset button on the target adapter
513	0x0201	CONNECTION ALREADY CLOSED	The connection that the originating node is trying to close has not been opened by the target node	No action required
515	0x0203	CONNECTION TIMED OUT	The ControlNet cable to the target node has become broken and/or disconnected	Fix and/or reconnect the ControlNet cable to the target node
			Power is no longer being received by the target node	Supply power to the target node
65281	0xFF01	CONNECTION REJECTED	The ControlNet cable to the target node is broken and/or disconnected	Fix and/or reconnect the ControlNet cable to the target node
			No power is being received by the target node	Supply power to the target node
			The target node is offline	Correctly configure the target node as an active node on the ControlNet network and save your ControlNet configuration
65294	0xFF0E	ATTRIBUTE CANNOT BE SET	Your program attempted to set an attribute that cannot be set for a specific module—e.g., a CIO instruction tried to send safe-state data to a flex module that does not support safe-state data	Change your program so that it does not attempt to set the attribute
				Insert a module that can have this attribute set
65299	0xFF13	NOT ENOUGH DATA	The transfer length is zero	Increase the length of the transfer
			The processor data table is too small	Increase the size of the data table to accommodate the transfer length
65301	0xFF15	TOO MUCH DATA	The transfer length is too large	Decrease the length of the transfer
65522	0xFFF2	CONFIG FROM MAP ENTRY FAILED	The ControlNet cable to the target node is broken and/or disconnected	Fix and/or reconnect the ControlNet cable to the target node
			No power is being received by the target node	Supply power to the target node
			The node or slot contains the wrong module type	Insert the proper module in the correct slot of the target node
			An incorrect module type was entered in the map table	Enter the correct module type in the map-table entry
65523	0xFFF3	CONTROLNET TRANSFER QUEUE FULL	The immediate CIO transfer could not be executed because the queue is full	Keep the number of active 1771 READ and/or 1771 WRITE CIOs at or under the maximum of 32

Appendix D**ControlNet I/O Map-Entry Status Words
and Error Messages**

Decimal Code	Hex. Code	Error Message	Explanation / Possible Cause(s)	Possible Corrective Action(s)
65527	0xFFFF7	MODULE TIMED OUT	The node or slot contains the wrong module type	Insert the proper module in the correct slot of the target node
			An incorrect module type was entered in the map table	Enter the correct module type in the map-table entry
65529	0xFFFF9	COMM ERROR CAUSED LOSS OF DATA	A communication error between the module and adapter caused data to be lost	Make sure that the proper module is properly seated in the correct slot of the target node Make sure that the correct module type is entered in the map-table entry
65530	0xFFFFA	MODULE DECLARED INVALID LENGTH	The node or slot contains the wrong module type	Insert the proper module in the correct slot of the target node
			An incorrect module type was entered in the map table	Enter the correct module type in the map-table entry
65531	0xFFFFB	READ DATA INVALID	The node or slot contains the wrong module type	Insert the proper module in the correct slot of the target node
			An incorrect module type was entered in the map table	Enter the correct module type in the map-table entry
65532	0xFFFFC	WRITE DATA INVALID	The node or slot contains the wrong module type	Insert the proper module in the correct slot of the target node
			An incorrect module type was entered in the map table	Enter the correct module type in the map-table entry
65533	0xFFFFD	DATA TABLE TOO SMALL	The processor data table is too small	Increase the size of the data table to accommodate the transfer length



Allen-Bradley Publication Problem Report

If you find a problem with our documentation, please complete and return this form.

Pub. Name _____

Cat. No. _____ Pub. No. _____ Pub. Date _____ Part No. _____

Check Problem(s) Type:	Describe Problem(s):	Internal Use Only
<input type="checkbox"/> Technical Accuracy	<input type="checkbox"/> text <input type="checkbox"/> illustration	
<input type="checkbox"/> Completeness What information is missing?	<input type="checkbox"/> procedure/step <input type="checkbox"/> illustration <input type="checkbox"/> definition <input type="checkbox"/> example <input type="checkbox"/> guideline <input type="checkbox"/> feature <input type="checkbox"/> explanation <input type="checkbox"/> other	<input type="checkbox"/> info in manual (accessibility) <input type="checkbox"/> info not in manual
<input type="checkbox"/> Clarity What is unclear?		
<input type="checkbox"/> Sequence What is not in the right order?		
<input type="checkbox"/> Other Comments Use back for more comments.		

Your Name _____ Location/Phone _____

Return to: Technical Communication, Allen-Bradley Co., 1 Allen-Bradley Drive, Mayfield Hts., OH 44124


Phone: (216)646-3166
 FAX: (216)646-4320

PLEASE FASTEN HERE (DO NOT STAPLE)


Other Comments

Lined area for writing comments.

PLEASE FOLD HERE



NO POSTAGE
NECESSARY
IF MAILED
IN THE
UNITED STATES



PLEASE REMOVE

BUSINESS REPLY MAIL
FIRST-CLASS MAIL PERMIT NO. 18235 CLEVELAND OH

POSTAGE WILL BE PAID BY THE ADDRESSEE



Allen-Bradley

1 ALLEN BRADLEY DR
MAYFIELD HEIGHTS OH 44124-9705



Numbers

- 1770-CD, [1-14](#), [1-19](#)
- 1770-KFC Communication Interface, [2-13](#)
- 1770-KFC Communication Interface, [1-17](#)
- 1771 Generic, [2-11](#)
- 1771 N-Series Analog Modules, [2-11](#)
- 1771-AF, [1-13](#)
- 1771-AS, [1-13](#)
- 1771-DCM, [1-13](#)
- 1771-IE, IF, and IFE Analog Input Modules, [2-11](#)
- 1771-IL Isolated Analog Input Modules, [2-11](#)
- 1771-IR RTD Input Modules, [2-11](#)
- 1771-IS Multiplexer Input Modules, [2-11](#)
- 1771-OF Analog Output Modules, [2-11](#)
- 1771-OFE1, -OFE2, and OFE3 Analog Output Modules, [2-11](#)
- 1771-SN, [1-13](#)
- 1771-ACN and -ACNR ControlNet I/O Adapters, [2-13](#)
- 1771-ASB, [1-13](#)
- 1771-CFM Configurable Flowmeter Modules, [2-11](#), [2-12](#)
- 1771-DE/A Absolute Encoder Modules, [2-11](#)
- 1771-IJ and -IK Encoder/Counter Modules, [2-11](#)
- 1771-IXE Thermocouple/Millivolt Input Modules, [2-11](#)
- 1771-IXHR High-resolution Thermocouple/Millivolt Input Modules, [2-11](#)
- 1771-QA Stepper Positioning Modules, [2-11](#)
- 1771-QB Linear Positioning Modules, [2-11](#)
- 1771-QC Servo Positioning Modules, [2-11](#)
- 1771-VHSC Very High-speed Counter Modules, [2-11](#)
- 1772-SD, -SD2, [1-13](#)
- 1775-S4A, -S4B, [1-13](#)
- 1775-SR, [1-13](#)
- 1784-CP10, [1-16](#)
- 1784-CP8, [1-16](#), [1-19](#)
- 1784-KL, [1-19](#)
- 1784-KL/B, [1-19](#)
- 1784-KTC Communication Card, [2-13](#)
- 1784-CP, [1-16](#), [1-19](#)
- 1784-CP11, [1-16](#)
- 1784-CP13, [1-16](#), [1-19](#)
- 1784-CP5, [1-19](#)
- 1784-CP6, [1-16](#), [1-19](#)
- 1784-CP7, [1-16](#), [1-19](#)
- 1784-KT, -KT2, [1-16](#), [1-19](#)
- 1784-KTC Communication Card, [1-17](#)
- 1784-KTCx Communication Card, [1-17](#), [2-13](#)
- 1784-KTK1, [1-19](#)
- 1784-KTx, [1-16](#), [1-19](#)
- 1784-KTxD, [1-16](#), [1-19](#)
- 1784-PCM5, [1-16](#), [1-19](#)
- 1784-PCM6, [1-16](#), [1-19](#)
- 1784-PCMK, [1-16](#), [1-19](#)
- 1786-CP, [1-17](#)
- 1786-BNC BNC Connector, [1-20](#)
- 1786-BNCJ BNC Connector, [1-20](#)
- 1786-BNCJI BNC Connector, [1-20](#)
- 1786-BNCP BNC Connector, [1-20](#)
- 1786-CP ControlNet Network Access Cable, [1-20](#)
- 1786-CTK ControlNet Tool Kit, [1-20](#)
- 1786-RG-6 Quad Shield Cable, [1-20](#)
- 1786-RPT Repeater, [1-20](#)
- 1786-RPTD Repeater, [1-20](#)
- 1786-TPR Tap, [1-15](#), [1-20](#)
- 1786-TPS Tap, [1-15](#), [1-20](#)
- 1786-TPVR Tap, [1-20](#)
- 1786-TPVS Tap, [1-20](#)
- 1786-TPYR Tap, [1-15](#)
- 1786-TPYS Tap, [1-15](#)
- 1786-XT BNC Terminator, [1-20](#)
- 1794 flex I/O data-transfer mapping, [2-12](#) features, [2-12](#) number of map-table entries required, [2-12](#)

1794-ACN ControlNet Flex I/O Adapter, [2-13](#)
 1794-IE4XOE2/A Analog I/O Modules, [2-12](#)
 1794-IE8/A Analog Input Modules, [2-12](#)
 1794-OE4/A Analog Output Modules, [2-12](#)
 6008-SQH1, -SQH2, [1-13](#)

A

automatic I/O mapping, [2-7](#)
 avoiding electrostatic damage, [1-3](#)

B

battery, specifications, [A-1](#)
 battery compartment, [1-4](#), [1-5](#)
 location of
 on PLC-5/20C, [1-4](#)
 on PLC-5/40C, [1-5](#)
 battery life, [1-9](#)
 battery status indicator, [1-4](#), [1-5](#)

C

cables, remote I/O, [1-12](#)
 cabling, [1-19](#)
 certification, [A-1](#)
 Channel 0, [1-4](#), [1-5](#)
 Channel 0 communication ACTIVE/FAULT status indicator, [1-4](#), [1-5](#)
 channel 1 status indicators, [1-5](#)
 Channel 1A, [1-4](#), [1-5](#), [2-15](#)
 Channel 1B, [1-4](#), [1-5](#), [2-15](#)
 Channel 2, [1-4](#), [1-5](#)
 Channel 2 ControlNet status indicators, [1-4](#), [1-5](#)
 Channel 2 Status screen, fields
 COUNTERS LOCKED, [5-13](#)
 Frames
 channel A errors, [5-13](#)
 channel B errors, [5-13](#)
 channel warnings, [5-13](#)
 received aborted, [5-13](#)
 received bad, [5-13](#)
 received good, [5-13](#)
 total received, [5-13](#)
 transmitted aborted, [5-13](#)
 transmitted good, [5-13](#)
 media usage, [5-13](#)

Misc

collisions, [5-13](#)
 commands received, [5-13](#)
 network silent, [5-13](#)
 noise detected, [5-13](#)
 out of step events, [5-13](#)
 Network Capacity
 blockage, [5-13](#)
 mismatch events, [5-13](#)
 moderator node, [5-13](#)
 unheard occurrences, [5-13](#)
 update time overload, [5-13](#)

CIOs. See ControlNet I/O Transfer instructions

clock, processor, [A-1](#)

communication, specifications, [A-1](#)

communication ports, location of
 on PLC-5/20C, [1-4](#)
 on PLC-5/40C, [1-5](#)

configuring your ControlNet system, where to go, [3-1](#)

connecting a programming terminal, [1-16](#)

connecting to a ControlNet network, [1-15](#)

connection, definition of, [ii](#)

ControlNet cabling, [1-19](#)

ControlNet I/O

 error messages, [D-2](#)

 features, [2-1](#)

 files configured with map

 Data Input File (DIF), [2-9](#), [2-10](#)

 Data Output File (DOF), [2-9](#), [2-10](#)

 Default Configuration File, [2-9](#)

 I/O Status File, [2-9](#)

 I/O forcing, [2-5](#)

 immediate data-transfer operations, [2-5](#)

 map table

 creating, [2-7](#)

 entries, [2-7](#)

 map-table entry

 configuration file, [2-10](#)

 module/message type, [2-9](#)

 mapping scheduled data transfers, [2-7](#)

 map-table entry fields

 Expected Network Packet Time (ENPT), [2-9](#)

 Input File and Size, [2-10](#)

 Module/Message Type, [2-9](#)

 Node, [2-9](#)

 Output File and Size, [2-10](#)

 Slot/Message, [2-9](#)

 Status File Offset, [2-10](#)

 scheduled data-transfer operations, [2-1](#)
 descriptions of, [2-2](#)

- scheduled discrete I/O data transfer, [2-1](#)
- scheduled operations
 - discrete I/O data transfer, [2-2](#)
 - non-discrete I/O data transfer, [2-2](#)
 - peer-to-peer communication, [2-2](#)
- understanding, [2-1](#)
- unscheduled data-transfer operations, [2-3](#)
- unscheduled non-discrete I/O data transfer, [2-3](#)
- unscheduled operations
 - ControlNet I/O Transfer (CIO) instruction, description, [C-1](#)
 - ControlNet I/O Transfer (CIO) instructions
 - description, [2-4](#)
 - features, [2-4](#)
 - I/O transfer instructions, programming, [4-4](#)
 - immediate data I/O instructions, programming, [4-6](#)
 - ladder-rung messages, [2-3](#)
 - messaging from programming devices, [2-3](#)
 - non-discrete I/O data transfer, description, [2-4](#)
 - non-discrete I/O data transfers
 - description, [C-1](#)
 - features, [2-4](#), [C-1](#)
 - peer-to-peer messaging instructions, programming, [4-2](#), [C-1](#)
 - peer-to-peer messaging, [2-3](#)
 - description, [2-4](#)
 - features, [2-4](#)
- ControlNet I/O automatic mapping, [2-7](#)
- ControlNet I/O mapping
 - automatic, [2-7](#)
 - reserving rack space for remote-I/O linked racks before mapping, [2-7](#)
 - understanding, [2-7](#)
 - discrete I/O data-transfer mapping, [2-10](#)
 - mapping data transfers, [2-9](#)
 - non-discrete I/O data-transfer mapping, [2-10](#)
 - modules that may be accommodated, [2-12](#)
- ControlNet I/O status indicator, [1-4](#), [1-5](#)
- ControlNet I/O Transfer (CIO) instructions, [2-3](#), [2-4](#), [C-1](#)
- ControlNet immediate data I/O instructions
 - Immediate Data Input (IDI), [2-6](#), [C-2](#)
 - Immediate Data Output (IDO), [2-6](#), [C-2](#)
- process, [C-2](#)
- ControlNet immediate data I/O instructions, process, [2-6](#)
- ControlNet Immediate Data Input (IDI) instruction, [2-6](#)
- ControlNet Immediate Data Output (IDO) instruction, [2-6](#)
- ControlNet network
 - definition of, [ii](#)
 - locating additional information, [iv](#)
- ControlNet Network Access Port (NAP), [1-4](#), [1-5](#)
- ControlNet PLC-5/20C processor, identifying components of, [1-4](#)
- ControlNet PLC-5/40C processor, identifying components of, [1-5](#)
- ControlNet processor
 - configuring your ControlNet system, [3-1](#)
 - fault codes, [B-4](#)
 - installing, [1-1](#)
 - planning to use, [2-1](#)
 - programming your system, [4-1](#)
- ControlNet system
 - cabling, [1-19](#)
 - configuring, [3-1](#)
 - automatically adding nodes to the node list, [3-5](#)
 - automatically mapping modules and messages that are not mapped, [3-8](#)
 - changing a 1794 I/O module's fault action, [2-4](#), [3-10](#), [4-4](#)
 - changing a 1794 I/O module's fault action from idle, [3-11](#)
 - changing a 1794 I/O module's idle action, [2-4](#), [3-11](#), [4-4](#)
 - changing a 1794 system's fault action, [3-10](#)
 - changing a 1794 system's fault action from idle, [3-10](#)
 - changing a 1794 system's idle action, [3-10](#)
 - changing a module or message's type, [3-7](#)
 - changing a node's series or revision, [3-5](#)
 - changing a node's status, [3-5](#)
 - changing a node's type, [3-5](#)
 - changing the Expected Network Packet Time (ENPT) for a module or message, [3-7](#)
 - clearing information about a module or message, [3-8](#)
 - clearing information about all modules and messages, [3-8](#)

- copying node information to a new address, [3-5](#)
 - defining local rack characteristics, [3-3](#)
 - deleting a module or message, [3-9](#)
 - deleting a node from the node list, [3-5](#)
 - deleting all modules and messages, [3-9](#)
 - deleting all nodes from the node list, [3-5](#)
 - editing 1794 I/O module action, [3-10](#)
 - editing ControlNet I/O mapping, [3-6](#)
 - editing node information, [3-4](#)
 - editing the ControlNet node-information configuration, [3-4](#)
 - entering the length of cable between repeaters, [3-4](#)
 - entering the number of coax repeaters, [3-4](#)
 - entering the number of fiber-optic repeaters, [3-4](#)
 - inserting an entry at an unused slot or message address, [3-9](#)
 - inserting nodes into the node list, [3-5](#)
 - manually entering the amount of information received from a module or message, [3-7](#)
 - manually entering the amount of information sent to a module or in a message, [3-7](#)
 - manually entering the amount of information to be stored in the I/O configuration file for a module, [3-8](#)
 - manually entering the destination file for information received from a module or message, [3-7](#)
 - manually entering the file for storing the I/O configuration needed for a module, [3-8](#)
 - manually entering the source file for information sent from a module or in a message, [3-7](#)
 - matching the processor and ControlNet configurations, [3-2](#)
 - moving a node description to a new address, [3-5](#)
 - specifying the Data Input File (DIF), [3-6](#)
 - specifying the Data Output File (DOF), [3-6](#)
 - specifying the Default Configuration File, [3-6](#)
 - specifying the Diagnostics File, [3-4](#)
 - specifying the I/O Status File, [3-6](#)
 - specifying the maximum scheduled node address, [3-5](#)
 - specifying the Network Update Time (NUT), [3-4](#), [3-7](#)
 - specifying the number of coax repeaters, [3-4](#)
 - specifying the redundancy characteristic of the ControlNet media, [3-5](#)
 - viewing the maximum percent of scheduled bandwidth, [3-5](#)
 - viewing the number of scheduled I/O map-table entries indicating data transfers to and from the processor, [3-7](#)
 - viewing the percent of scheduled bandwidth used in the worst case, [3-7](#)
 - viewing the percentage of the Data Input File (DIF) being used, [3-7](#)
 - viewing the percentage of the Data Output File (DOF) being used, [3-7](#)
 - configuring nodes, [2-7](#), [2-14](#)
 - locating additional information, [iii](#)
 - monitoring, [5-1](#)
 - viewing a 1794 system's fault action, [5-11](#)
 - viewing a 1794 system's fault action from idle, [5-11](#)
 - viewing a 1794 system's idle action, [5-11](#)
 - network maintenance, [2-3](#)
 - network update cycle, what happens in, [2-3](#)
 - scheduled operations, [2-3](#)
 - selecting devices to connect, [2-13](#)
 - setting the switches, [1-11](#)
 - troubleshooting, [5-1](#)
 - unscheduled operations, [2-3](#)
 - using ControlNet PLC-5 processors in, [2-13](#)
- ControlNet WHO ACTIVE—Network Status screen, fields**
- Bad Frames Received, [5-19](#)
 - Errors / 100,000 Frames—Chan A, [5-19](#)
 - Errors / 100,000 Frames—Chan B, [5-19](#)
 - Good Frames Received, [5-19](#)
 - Node, [5-19](#)
 - Total Errors—Chan A, [5-19](#)
 - Total Errors—Chan B, [5-19](#)
- D**
- Data Input File**
- description, [2-9](#), [2-10](#)
 - specifying, [3-6](#)

Data Output File
 description, [2-9](#), [2-10](#)
 specifying, [3-6](#)

Default Configuration File
 description, [2-9](#)
 specifying, [3-6](#)

defining local rack characteristics, [3-3](#)

DH+, trunk-cable/drop-cable connection,
[1-14](#)

DH+ programming-terminal connection
 (PTC), [1-4](#), [1-5](#)

Diagnostics File, [5-13](#)

DIF. *See* Data Input File

discrete I/O data transfer
 definition of, [ii](#)
 description, [2-2](#)

discrete I/O data transfers, number of
 map-table entries required, [2-9](#)

discrete I/O data-transfer mapping, [2-10](#)

disposing of the processor battery, [1-9](#)

DOF. *See* Data Output File

drop cable, definition of, [ii](#)

E

ENPT. *See* Expected Network Packet Time

environment, specifications, [A-1](#)

error codes, [D-2](#)

Expected Network Packet Time
 1771 non-discrete I/O data-transfer
 mapping
 default, [2-11](#), [2-12](#)
 range, [2-11](#)
 1794 flex I/O data-transfer mapping
 default, [2-12](#)
 range, [2-12](#)
 description, [2-9](#)

F

fault codes, [B-4](#)

files
 configuration, [2-10](#)
 configured with I/O map for scheduled
 I/O usage, [2-9](#)
 Data Input, [2-9](#), [2-10](#), [3-6](#)
 Data Output, [2-9](#), [2-10](#), [3-6](#)
 Default Configuration, [2-9](#), [3-6](#)
 Diagnostics, [3-4](#), [5-13](#)
 I/O Status, [2-9](#), [2-10](#), [2-16](#), [3-6](#),
[D-1](#)

I/O status, [2-9](#)
 input, [2-10](#)
 input image, [2-1](#), [2-9](#), [2-10](#)
 output, [2-10](#)
 output image, [2-1](#), [2-10](#)
 processor status, [B-1](#)

force status indicator, [1-4](#), [1-5](#)

frame, definition of, [ii](#)

front panel
 PLC-5/20C processor, [1-4](#)
 PLC-5/40C processor, [1-5](#)

H

handling the processor, [1-3](#)

heat dissipation, specifications, [A-1](#)

I

I/O, ControlNet, [2-1](#)
 automatic mapping, [2-7](#)
 automatically mapping modules and
 messages that are not mapped,
[3-8](#)
 changing a module or message's type,
[3-7](#)
 changing the Expected Network Packet
 Time (ENPT) for a module or
 message, [3-7](#)
 clearing information about a module or
 message, [3-8](#)
 clearing information about all modules
 and messages, [3-8](#)
 deleting a module or message, [3-9](#)
 deleting all modules and messages, [3-9](#)
 discrete I/O data-transfer mapping, [2-10](#)
 editing 1794 I/O module action, [3-10](#)
 editing mapping, [3-6](#)
 files configured with map
 Data Input File (DIF), [2-9](#), [2-10](#)
 Data Output File (DOF), [2-9](#), [2-10](#)
 Default Configuration File, [2-9](#)
 I/O Status File, [2-9](#)
 I/O forcing, [2-5](#)
 immediate data transfer, [2-5](#)
 inserting an I/O entry into the node list,
[3-9](#)
 manually entering the amount of
 information received from a module
 or message, [3-7](#)
 manually entering the amount of
 information sent to a module or in a
 message, [3-7](#)

- manually entering the amount of information to be stored in the I/O configuration file for a module, [3-8](#)
- manually entering the destination file for information received from a module or message, [3-7](#)
- manually entering the file for storing the I/O configuration needed for a module, [3-8](#)
- manually entering the source file for information sent to a module or in a message, [3-7](#)
- map table
 - creating, [2-7](#)
 - entries, [2-7](#)
 - maximum number of entries, [2-9](#)
- map-table entry
 - configuration file, [2-10](#)
 - module/message type, [2-9](#)
- mapping, [2-7](#)
- mapping data transfers, [2-9](#)
- map-table entry fields
 - Expected Network Packet Time (ENPT), [2-9](#)
 - Input File and Size, [2-10](#)
 - Module/Message Type, [2-9](#)
 - Node, [2-9](#)
 - Output File and Size, [2-10](#)
 - Slot/Message, [2-9](#)
 - Status File Offset, [2-10](#)
- non-discrete I/O data-transfer mapping, [2-10](#)
 - modules that may be accommodated, [2-12](#)
- reserving rack space for remote-I/O
 - linked racks before mapping, [2-7](#)
- scheduled data transfer, [2-1](#)
- scheduled discrete I/O data transfer, [2-1](#)
- scheduled operations
 - discrete I/O data transfer, [2-2](#)
 - non-discrete I/O data transfer, [2-2](#)
 - peer-to-peer communication, [2-2](#)
- specifying the Data Input File (DIF), [3-6](#)
- specifying the Data Output File (DOF), [3-6](#)
- specifying the Default Configuration File, [3-6](#)
- specifying the I/O Status File, [3-6](#)
- specifying the Network Update Time (NUT), [3-7](#)
- unscheduled
 - I/O data-transfer instructions, [4-4](#)
 - immediate data I/O instructions, [4-6](#)
 - Message instruction, [2-4](#), [4-2](#), [C-1](#)
 - non-discrete I/O data transfers, [2-4](#), [C-1](#)
 - non-discrete I/O data-transfer instructions, [4-4](#)
 - unscheduled data transfer, [2-3](#)
 - unscheduled non-discrete I/O data transfer, [2-3](#)
 - unscheduled operations
 - messaging from programming devices, [2-3](#)
 - non-discrete I/O data transfer, [2-3](#)
 - peer-to-peer messaging, [2-3](#)
 - viewing the number of scheduled I/O map-table entries indicating data transfers to and from the processor, [3-7](#)
 - viewing the percentage of the Data Input File (DIF) being used, [3-7](#)
 - viewing the percentage of the Data Output File (DOF) being used, [3-7](#)
- I/O addressing, [A-1](#)
- I/O forcing, [2-5](#)
- I/O map table, definition of, [ii](#)
- I/O map-entry status words, [D-1](#)
- I/O modules, specifications, [A-1](#)
- I/O Status File, specifying, [3-6](#)
- I/O status indicator, [5-3](#)
- IDI. *See* ControlNet Immediate Data Input instruction
- IDO. *See* ControlNet Immediate Data Output instruction
- IIN. *See* Immediate Input instruction
- Immediate Data Input (IDI) instruction, [C-2](#)
- Immediate Data Output (IDO) instruction, [C-2](#)
- immediate data-transfer operations, [2-5](#)
- immediate I/O, process, [2-6](#)
- Immediate I/O instructions, [2-6](#)
- Immediate Input (IIN) instruction, [2-6](#)
- Immediate Output (IOT) instruction, [2-6](#)
- indicators
 - PLC-5/20C, [1-4](#)
 - PLC-5/40C, [1-5](#)
- installing keying bands for the processor, [1-7](#)
- installing the processor battery, [1-8](#)
- installing your processor
 - checking your processor package, [1-2](#)
 - connecting a programming terminal, [1-16](#)
 - ControlNet connection, [1-17](#)
 - DH+ connection, [1-16](#)
 - serial channel, [1-16](#)
 - connecting to a ControlNet network, [1-15](#)

disposing of the battery, [1-9](#)
 handling the processor, [1-3](#)
 identifying the components of the processor, [1-4](#)
 installing a DH+ link, [1-14](#)
 installing a remote I/O link, [1-12](#)
 installing keying bands for the processor, [1-7](#)
 installing the battery, [1-8](#)
 installing the processor in the chassis, [1-12](#)
 locating additional information, [1-1](#)
 preparing for, [1-2](#)
 removing the processor from the chassis, [1-12](#)
 selecting cables
 ControlNet cables, [1-19](#)
 DH+ programming, [1-19](#)
 remote I/O, [1-19](#)
 serial, [1-18](#)
 selecting the ControlNet network address, [1-11](#)
 selecting the DH+ station address of Channel 1A, [1-10](#)
 setting the I/O chassis backplane switches, [1-6](#)
 setting the I/O chassis configuration plug, [1-7](#)
 specifying the serial interface of Channel 0, [1-11](#)
 where to go, [1-1](#)

instructions
 ControlNet I/O Transfer (CIO), [2-4](#), [C-1](#)
 how to use, [4-4](#)
 when to use, [2-12](#), [2-16](#)
 ControlNet Immediate Data Input (IDI), [2-6](#), [C-2](#)
 how to use, [4-6](#)
 ControlNet Immediate Data Output (IDO), [2-6](#), [C-2](#)
 how to use, [4-6](#)
 ControlNet Message (MSG), how to use, [4-2](#)
 Immediate Input (IIN), [2-6](#)
 Immediate Output (IOT), [2-6](#)
 Message (MSG), [2-4](#)
 how to use, [C-1](#)
 when to use, [2-13](#)

IOT. *See* Immediate Output instruction

K

keyswitch, location of
 on PLC-5/20C, [1-4](#)
 on PLC-5/40C, [1-5](#)

L

ladder-rung messaging, [2-3](#)
 link, definition of, [ii](#)

M

map table, [2-7](#)
 map-table entries, [2-7](#)
 fields, [2-9](#)
 number required for data-transfer types, [2-9](#)
 map-table entry, definition of, [ii](#)
 maximum scheduled node, definition of, [ii](#)
 maximum unscheduled node, definition of, [ii](#)
 memory module space, [1-4](#), [1-5](#)
 memory modules, specifications, [A-1](#)
 memory-module space, location of
 on PLC-5/20C, [1-4](#)
 on PLC-5/40C, [1-5](#)
 Message instructions, [2-3](#), [2-4](#), [C-1](#)
 monitoring ControlNet configuration and status screens, [5-5](#)
 MSGs. *See* Message instructions

N

NAP. *See* Network Access Port
 Network Access Port, [1-4](#), [1-5](#)
 definition of, [ii](#)
 when to use, [1-17](#)
 network address, definition of, [ii](#)
 Network Update Interval, [2-3](#), [3-4](#)
 definition of, [ii](#)
 Network Update Time, [3-4](#)
 definition of, [ii](#)
 specifying, [3-7](#)
 node, definition of, [ii](#)
 non-discrete I/O data transfer
 definition of, [ii](#)
 description, [2-2](#)
 non-discrete I/O data transfers, number of map-table entries required, [2-9](#)
 non-discrete I/O data-transfer mapping, [2-10](#)
 1771 modules, [2-10](#)
 features, [2-11](#)

number of map-table entries required, [2-10](#)
 nonredundant media, [1-15](#)
 NUI. *See* Network Update Interval
 NUT. *See* Network Update Time

O

owner, definition of, [ii](#)

P

Peer In, [2-12](#)
 Peer Out, [2-12](#)
 planning to use your processor, where to go, [2-1](#)
 PLC-5 processors, locating additional information, [iii](#)
 PLC-5 programming software, locating additional information, [iii](#)
 processor
 connecting DH+ link, [1-14](#)
 front panel
 PLC-5/20C, [1-4](#)
 PLC-5/40C, [1-5](#)
 specifications
 backplane current load
 maximum, [A-2](#)
 typical, [A-2](#)
 battery, [A-1](#)
 certification, [A-1](#)
 clock/calendar, [A-1](#)
 communication, [A-1](#)
 ControlNet I/O
 maximum link cable length with repeaters, [A-2](#)
 maximum link cable length without a repeater, [A-2](#)
 maximum non-discrete I/O data-transfer data-table size, [A-2](#)
 maximum number of nodes per link with repeaters, [A-2](#)
 maximum number of nodes per link without a repeater, [A-2](#)
 maximum number of repeaters in series per link, [A-2](#)
 maximum number of segments in series per link, [A-2](#)
 Network Update Time (NUT), [A-2](#)
 number of ControlNet ports, [A-2](#)
 number of redundant media ControlNet ports, [A-2](#)
 transmission rate, [A-2](#)
 environmental conditions, [A-1](#)

hardware addressing, [A-1](#)
 heat dissipation, [A-1](#)
 I/O modules, [A-1](#)
 keying, [A-1](#)
 location, [A-1](#)
 maximum number of MCPs, [A-2](#)
 maximum total I/O
 any mix, [A-2](#)
 complimentary, [A-2](#)
 maximum user memory words, [A-2](#)
 memory modules, [A-1](#)
 non-ControlNet remote I/O
 I/O scan time, [A-2](#)
 maximum number of devices, [A-2](#)
 maximum number of ports
 configurable for DH+ or remote I/O, [A-2](#)
 maximum number of racks, [A-2](#)
 number of dedicated DH+ ports, [A-2](#)
 transmission rate, [A-2](#)
 number of coprocessor ports, [A-2](#)
 number of serial ports, [A-2](#)
 program scan time, [A-2](#)
 shock and vibration, [A-1](#)
 weight, [A-1](#)
 processor RUN/FAULT status indicator, [1-4](#), [1-5](#)
 processor status file, [B-1](#)
 layout, [B-1](#)
 processor-resident local I/O, reserving space for, [2-7](#)
 programming a processor, through Channel 0, [1-16](#)
 programming terminal, connecting, [1-16](#)
 programming your ControlNet system, where to go, [4-1](#)

R

redundant media, [1-15](#)
 definition of, [ii](#)
 remote I/O
 cable lengths, [1-12](#)
 non-ControlNet, reserving space for, [2-8](#)
 remote-I/O link, [2-15](#)
 remote-I/O immediate I/O transfers, [2-5](#), [4-7](#)
 repeater, definition of, [ii](#)
 replacing a non-ControlNet remote I/O network with a ControlNet network, [2-15](#)
 changing block-transfer instructions, [2-16](#)

changing I/O status files, [2-16](#)
 downloading archived files, [2-15](#)
 I/O performed on Channel 2 of
 PLC-5/40L processor, [2-16](#)
 messaging and I/O performed on
 Channels 1A and 1B, [2-15](#)
 messaging and I/O performed on
 Channels 2A and 2B of PLC-5/40B
 processor, [2-15](#)
 using automatic mapping, [2-7](#)
 replacing the processor battery, [1-9](#)

S

scheduled data-transfer operations, [2-1](#)
 descriptions of, [2-2](#)
 scheduled discrete I/O data transfer,
 process, [2-1](#)
 scheduled peer-to-peer communication
 description, [2-2](#)
 number of map-table entries required,
[2-9](#)
 scheduled peer-to-peer communications,
 number of map-table entries required,
[2-12](#)
 scheduled peer-to-peer communications
 mapping, [2-12](#)
 features, [2-12](#)
 scheduled transfers, definition of, [ii](#)
 screens
 Channel 2 Status, [5-12](#)
 Channel Overview, [3-2](#)
 Data Monitor for ControlNet I/O Transfer
 Block, [4-5](#)
 Data Monitor for Message Control Block,
[4-3](#)
 I/O Action (Edit), [3-10](#)
 I/O Action (Monitor), [5-11](#)
 I/O Mapping (Edit), [3-6](#)
 I/O Mapping (Monitor), [5-7](#)
 Instruction Entry for ControlNet I/O
 Transfer Block, [4-4](#)
 Instruction Entry for Message Block, [4-2](#)
 Local Rack Characteristics, [3-3](#)
 Map Entries Status, [5-9](#)
 Node Information, [3-4](#)
 View Times (Monitor), [5-8](#)
 WHO ACTIVE--Network Status, [5-19](#)
 WHO ACTIVE--Active Node
 Identification, [5-14](#)
 WHO ACTIVE--Active Node Status,
[5-16](#)
 WHO ACTIVE--Channel Status, [5-17](#)
 segment
 definition of, [ii](#)

terminating, [1-15](#)
 Selectable Timed Interrupts (STIs), using
 with ControlNet system, [4-7](#)
 selecting a ControlNet network address,
[1-11](#)
 selecting the DH+ station address of
 Channel 1A, [1-10](#)
 setting the I/O chassis backplane switches,
[1-6](#)
 addressing switches, [1-6](#)
 EEPROM-transfer switches, [1-6](#)
 last-state switch, [1-6](#)
 processor memory-protection switch,
[1-6](#)
 setting the I/O chassis configuration plug,
[1-7](#)
 shock and vibration, specifications, [A-1](#)
 specifying the serial interface of Channel 0,
[1-11](#)
 status, layout for the processor, [B-1](#)
 Status File, [D-1](#)
 I/O, description, [2-9](#)
 status file, processor, [B-1](#)
 status indicators
 location of
 on PLC-5/20C, [1-4](#)
 on PLC-5/40C, [1-5](#)
 using, [5-2](#), [5-3](#)
 status words, I/O map entry, [D-1](#)

T

tap, [1-17](#)
 connecting, [1-15](#)
 definition of, [ii](#)
 using, [1-15](#)
 terminator, definition of, [ii](#)
 trunk cable, definition of, [ii](#)
 trunk-cable section, definition of, [ii](#)
 trunk-cable/drop-cable connection, [1-14](#)

U

unscheduled data-transfer operations, [2-3](#)
 unscheduled non-discrete I/O data transfer,
[2-3](#)
 unscheduled transfers, definition of, [ii](#)
 using ControlNet I/O Transfer (CIO)
 instructions, [4-4](#)

- using ControlNet Immediate Data I/O instructions, [4-6](#)
- using ControlNet Message (MSG) instructions, [4-2](#)
- using the ControlNet Channel 2 Status screen, [5-12](#)
- using the ControlNet I/O Action (Monitor) screen, [5-11](#)
- using the ControlNet I/O Mapping (Monitor) screen, [5-7](#)
- using the ControlNet Map Entries Status screen, [5-9](#)
- using the ControlNet Node Information Channel 2 Configuration (Monitor) screen, [5-6](#)
- using the ControlNet status indicators, [5-3](#)
- using the ControlNet View Times (Monitor) screen, [5-8](#)
- using the ControlNet WHO ACTIVE—Active Node Identification screen, [5-14](#)
- using the ControlNet WHO ACTIVE—Active Node Status screen, [5-16](#)
- using the ControlNet WHO ACTIVE—Channel Status screen, [5-17](#)
- using the ControlNet WHO ACTIVE—Network Status screen, [5-19](#)
- using the general status indicators, [5-2](#)
- using this manual
 - conventions used, [iii](#)
 - intended audience for, [i](#)
 - introduction to, [i](#)
 - recommended preparation for, [i](#)
 - related terminology, [ii](#)
 - where to go, [i](#)



Allen-Bradley, a Rockwell Automation Business, has been helping its customers improve productivity and quality for more than 90 years. We design, manufacture, and support a broad range of control and automation products worldwide. They include logic processors, power and motion control devices, man-machine interfaces, sensors, and a variety of software. Rockwell is one of the world's leading technology companies.

Worldwide representation.



Algeria • Argentina • Australia • Austria • Bahrain • Belgium • Brazil • Bulgaria • Canada • Chile • China, PRC • Colombia • Costa Rica • Croatia • Cyprus • Czech Republic
Denmark • Ecuador • Egypt • El Salvador • Finland • France • Germany • Greece • Guatemala • Honduras • Hong Kong • Hungary • Iceland • India • Indonesia • Ireland
Israel • Italy • Jamaica • Japan • Jordan • Korea • Kuwait • Lebanon • Malaysia • Mexico • Netherlands • New Zealand • Norway • Pakistan • Peru • Philippines • Poland
Portugal • Puerto Rico • Qatar • Romania • Russia-CIS • Saudi Arabia • Singapore • Slovakia • Slovenia • South Africa, Republic • Spain • Sweden • Switzerland • Taiwan
Thailand • Turkey • United Arab Emirates • United Kingdom • United States • Uruguay • Venezuela • Yugoslavia

Allen-Bradley Headquarters, 1201 South Second Street, Milwaukee, WI 53204 USA, Tel: (1) 414 382-2000 Fax: (1) 414 382-4444