75 GALLON ULTRA LOW NOx SUPPLEMENT TO INSTRUCTION MANUAL P/N 238-47759-00 MINIMUM CLEARANCES (Replaces pg. 8 in instruction manual)

Failure to adhere to these installation and operating instructions may create a hazard to life and property and will nullify the warranty.

This installation must allow access to the front of the water heater and adequate clearance must be provided for servicing and operating this water heater. The water heater may be installed on either a combustible or non-combustible floor. If the water heater is to be installed directly on carpeting, it must be installed on top of a metal or wood panel (or equivalent) extending beyond the full width and depth of the appliance by at least three (3) inches (7.6 cm) in any direction or, if the appliance is to be installed in an alcove or closet, the entire floor must be covered by the panel. If the rating plate or the label on the front of the water heater specifies minimum clearances less than those listed in the below table, the water heater may be installed in accordance with the minimum clearances listed on the rating plate or the label on the front of the water heater.

If it is necessary to install this water heater in an alcove, use the clearances listed in the following table and Figure 1.





Minimum Clearances from Combustible Materials for Alcove Installation

m)
1)

Figure 1

LIGHTING & SHUTDOWN INSTRUCTIONS FOR HONEYWELL GAS CONTROLS. (Replaces pg. 18 in instruction manual)



BURNER FLAME CHECKS (Replaces pg. 21 of instruction manual)

These models are equipped with self-adjusting air mixture and do not have an adjustable air shutter. At periodic intervals, a visual check of the main burner and pilot flames should be made to determine if they are burning properly. The main burner flame should light smoothly from the pilot. The burner flame should be soft and undefined. After five minutes of burner operation the burner face should be glowing orange and emitting an orange flame.



Figure 6

(Replaces pg. 24 of instruction manual)

Manufactured under one or more of the following U.S. Patents: RE.34,534; B1 5,341,770; 4,416,222; 4,628,184; 4,669,448; 4,672,919; 4,808,356; 4,829,983; 4,861,968; 4,904,428; 5,000,893; 5,023,031; 5,052,346; 5,081,696; 5,092,519; 5,115,767; 5,199,385; 5,277,171; 5,372,185; 5,485,879; 5,574,822; 5,596,952; 5,660,165; 5,682,666; 5,761,379; 5,943,984; 5,954,492; 5,988,117; 6,142,216; 6,395,280; 6,684,821; 7,063,132; 7,007,748 Other U.S. and Foreign patent applications pending. Current Canadian Patents: 1,272,914; 1,280,043; 1,289,832; 2,045,862; 2,092,105; 2,107,012; 2,108,186; 2,112,515
Complete the following information and retain for future reference:
Model No:
Serial No:
Service Phone Days:Nights:
Address:
Supplier:
Supplier Phone No:
1/4" RISE PER FOT VENT CONNECTOR(S) 1/1" CLI CM/M) (MINIMUM) VENT CONNECTOR(S) HOT WATER OUTLET WAIVE MUST BE 1/1" O FRITURES OLD WATER OULD WATER OLD WATER OWEINATION ANODE-HOT ORAFT DIVERTER OWEINATION ANOTO ORAFT DIVERTER OWEIN TENNIATED OTATION ANOTO ORAFT DI



PART NAME AND DESCRIPTION		
1. Draft Diverter	15. Drain Valve	
2. Jacket Head Pan	16. Gas Control Valve	
3. Jacket	17. Manifold Bracket	
4. Outer Door	18. Re-Settable Thermal Switch Wire Harness	
5. NIpple-Hot Water Outlet	19. Burner Assembly	
6. Flue Baffle Assembly	20. Re-settable Thermal Switch	
7. Dip Tube-Cold Water Inlet	21. Burner Assembly Cover	
8. Temperature and Pressure Relief Valve	22. Gas Feedline	
9. Glass Lined Tank	23. Orifice	
10. Heat Radiation Shield	24. Thermopile Wire	
11. Foam Insulation	25. Igniter Wire	
12. Combustion Chamber Assembly	26. Pilot Gas Feedline	
13. Jacket Base Pan	27. Pilot Assembly	
14. Inner Door Assembly	28. Magnesium Anode-Hex Head	
14A. #8 x ¾ screw		

THE FOLLOWING INSTRUCTIONS ARE FOR INSTALLATION OF: GAS WATER HEATERS SUITABLE FOR WATER (POTABLE) HEATING AND SPACE HEATING (Replaces pg. 28 of instruction manual)

- All piping components connected to this water heater for space heating applications must be suitable for use with potable water. In Massachusetts, space heating piping length **must not** exceed 50 feet.
- 2. Toxic chemicals, such as those used for boiler treatment, **must not** be introduced into potable water used for space heating.
- This water heater **must not** be connected to an existing heating system or component(s) previously used with a non-potable water heating appliance.
- 4. When the system requires water for space heating at temperatures higher than required for other means, such as an ASSE approved mixing valve must be installed to temper the water for those uses in order to reduce the scald hazard potential.

Please refer to the illustrations below for the suggested piping arrangement.



NOTES

NOTES