

PowerFlex 750-Series Safe Torque Off

Catalog Numbers 20-750-S



Original Instructions

Important User Information

Solid-state equipment has operational characteristics differing from those of electromechanical equipment. Safety Guidelines for the Application, Installation and Maintenance of Solid State Controls (publication [SGI-1.1](#) available from your local Rockwell Automation® sales office or online at <http://www.rockwellautomation.com/literature/>) describes some important differences between solid-state equipment and hard-wired electromechanical devices. Because of this difference, and also because of the wide variety of uses for solid-state equipment, all persons responsible for applying this equipment must satisfy themselves that each intended application of this equipment is acceptable.

In no event will Rockwell Automation, Inc. be responsible or liable for indirect or consequential damages resulting from the use or application of this equipment.

The examples and diagrams in this manual are included solely for illustrative purposes. Because of the many variables and requirements associated with any particular installation, Rockwell Automation, Inc. cannot assume responsibility or liability for actual use based on the examples and diagrams.

No patent liability is assumed by Rockwell Automation, Inc. with respect to use of information, circuits, equipment, or software described in this manual.

Reproduction of the contents of this manual, in whole or in part, without written permission of Rockwell Automation, Inc., is prohibited.

Throughout this manual, when necessary, we use notes to make you aware of safety considerations.

	WARNING: Identifies information about practices or circumstances that can cause an explosion in a hazardous environment, which may lead to personal injury or death, property damage, or economic loss.
	ATTENTION: Identifies information about practices or circumstances that can lead to personal injury or death, property damage, or economic loss. Attentions help you identify a hazard, avoid a hazard, and recognize the consequence.
	SHOCK HAZARD: Labels may be on or inside the equipment, for example, a drive or motor, to alert people that dangerous voltage may be present.
	BURN HAZARD: Labels may be on or inside the equipment, for example, a drive or motor, to alert people that surfaces may reach dangerous temperatures.
IMPORTANT	Identifies information that is critical for successful application and understanding of the product.

Allen-Bradley, Rockwell Software, Rockwell Automation, and PowerFlex are trademarks of Rockwell Automation, Inc.

Trademarks not belonging to Rockwell Automation are property of their respective companies.

This manual contains new and updated information.

New and Updated Information

This table contains the changes made to this revision.

Topic	Page
Drive Frames 1 and 10 added.	Throughout
PFD and PFH for 20-year Proof Test Interval table updated.	12
Important installation notes added.	24
Environmental Specifications added.	34
Compliance clarified under CE in Certifications section.	35
Evaluations and Certification s are not listed in this publication. Please visit www.rockwellautomation.com/products/certification/ for certification details.	35

General Description	Chapter 1	
	What Is the PowerFlex 750-Series Safe Torque Off Option?	7
	Safety of Machinery Standards	8
Safety Concept	Chapter 2	
	Introduction	9
	Safety Certification	9
	Functional Proof Tests	11
	PFD and PFH Definitions	11
	PFD and PFH Data	12
	Safe State	12
	Safety Reaction Time	12
	Considerations for Safety Ratings	13
	Contact Information if Safety Option Failure Occurs	13
Installation and Wiring	Chapter 3	
	Access Drive Control Pod	16
	Configure Safety Enable	20
	Option Module Installation	23
	Wiring	24
	Verify Operation	25
Description of Operation	Chapter 4	
	PowerFlex 750-Series Safe Torque Off Operation	27
Specifications	Appendix A	
	Introduction	33
	General Specifications	33
	Environmental Specifications	34
	Certifications	35
	CE Conformity	35

General Description

The Safe Torque Off option is just one component in a safety control system. Components in the system must be chosen and applied appropriately to achieve the desired level of operational safety.

What Is the PowerFlex 750-Series Safe Torque Off Option?

The PowerFlex 750-Series Safe Torque Off option:

- Is designed to help safely remove power from the gate firing circuits of the drive's output power devices (IGBT's). This helps prevent the drive's output power devices from switching in the pattern necessary to generate AC power to the motor.
- Can be used in combination with other safety devices to satisfy the requirements of IEC 61508, IEC 61800-5-2 SIL 3, ISO 13849-1 PL e, and Category 3 (EN 954-1) for Safe Torque Off (STO).

IMPORTANT This option is suitable for performing mechanical work on the drive system or affected area of a machine only. It does not provide electrical safety.

This option should not be used as a control for starting and/or stopping the drive.



ATTENTION: Electrical Shock Hazard. Verify that all sources of AC and DC power are deenergized and locked out or tagged out in accordance with the requirements of ANSI/NFPA 70E, Part II.



ATTENTION: To avoid an electric shock hazard, verify that the voltage on the bus capacitors has discharged before performing any work on the drive. Measure the DC bus voltage at the +DC and -DC terminals or test points (refer to your drive's User Manual for locations). The voltage must be zero.



ATTENTION: In safe-off mode, hazardous voltages may still be present at the motor. To avoid an electric shock hazard, disconnect power to the motor and verify that the voltage is zero before performing any work on the motor.



ATTENTION: In the event of the failure of two output IGBTs in the drive, when the PowerFlex 750-Series Safe Torque Off option has controlled the drive outputs to the off state, the drive may provide energy for up to 180° of rotation in a 2-pole motor before torque production in the motor ceases.

Safety of Machinery Standards

The Safe Torque Off option helps to satisfy requirements in the following standards:

- IEC 61508: 2000 SIL 3
- IEC 61800-5-2: 2007 SIL 3
- IEC 61800-3: 2004
- IEC 62061: 2005
- ISO 13849-1: 2006 Performance Level e, Category 3
- EN 954-1: 1996 – Category 3
- IEC 60204-1: 2005
- NFPA 79: 2007

Safety Concept

Introduction

This section describes the safety performance level concept and how the PowerFlex 750-Series drives can meet the requirements for SIL CL3, CAT 3, or PL e applications.

Safety Certification

The PowerFlex 750-Series safety option is certified for use in safety applications up to and including SIL 3 according to EN 61800-5-2, EN 61508, and EN 62061, Performance Level PL e and Category 3 according to ISO 13849-1. Safety requirements are based on the standards current at the time of certification.

The TÜV Rheinland group has approved the PowerFlex 750-Series safety option for use in safety-related applications where the de-energized state is considered to be the safe state. All of the examples in this manual are based on achieving de-energization as the safe state for typical Machine Safety and Emergency Shutdown (ESD) systems.

Important Safety Considerations

The system user is responsible for:

- the set-up, safety rating, and validation of any sensors or actuators connected to the system.
- completing a system-level risk assessment and reassessing the system any time a change is made.
- certification of the system to the desired safety performance level.
- project management and proof testing.
- programming the application software and the safety option configurations in accordance with the information in this manual.
- access control to the system.
- analyzing all configuration settings and choosing the proper setting to achieve the required safety rating.

IMPORTANT When applying Functional Safety, restrict access to qualified, authorized personnel who are trained and experienced.



ATTENTION: When designing your system, consider how personnel will exit the machine if the door locks while they are in the machine. Additional safeguarding devices may be required for your specific application.

Safety Category 3 Performance Definition

To achieve Safety Category 3 according to ISO 13849-1:2006, the safety-related parts have to be designed such that:

- the safety-related parts of machine control systems and/or their protective equipment, as well as their components, shall be designed, constructed, selected, assembled, and combined in accordance with relevant standards so that they can withstand expected conditions.
- basic safety principles shall be applied.
- a single fault in any of its parts does not lead to a loss of safety function.
- a single fault is detected at or before the next demand of the safety function, or, if this detection is not possible, then an accumulation of faults shall not lead to a loss of the safety function.
- the average diagnostic coverage of the safety-related parts of the control system shall be high, including the accumulation of faults.
- the mean time to dangerous failure of each of the redundant channels shall be high.
- measures against common cause failure shall be applied.

Stop Category Definitions

The selection of a stop category for each stop function must be determined by a risk assessment.

- Stop Category 0 is achieved with immediate removal of power to the actuator, resulting in an uncontrolled coast to stop. Safe Torque Off accomplishes a Stop Category 0 stop.
- Stop Category 1 is achieved with power available to the machine actuators to achieve the stop. Power is removed from the actuators when the stop is achieved.
- Stop Category 2 is a controlled stop with power available to the machine actuators. The stop is followed by a holding position under power.

IMPORTANT	When designing the machine application, timing and distance should be considered for a coast to stop (Stop Category 0 or Safe Torque Off). For more information regarding stop categories, refer to EN 60204-1.
------------------	---

Performance Level and Safety Integrity Level (SIL) CL3

For safety-related control systems, Performance Level (PL), according to ISO 13849-1, and SIL levels, according to EN 61508 and EN 62061, include a rating of the system's ability to perform its safety functions. All of the safety-related components of the control system must be included in both a risk assessment and the determination of the achieved levels.

Refer to the ISO 13849-1, EN 61508, and EN 62061 standards for complete information on requirements for PL and SIL determination.

Functional Proof Tests

The functional safety standards require that functional proof tests be performed on the equipment used in the system. Proof tests are performed at user-defined intervals and are dependent upon PFD and PFH values.

IMPORTANT Your specific application determines the time frame for the proof test interval.

PFD and PFH Definitions

Safety-related systems can be classified as operating in either a Low Demand mode, or in a High Demand/Continuous mode.

- Low Demand mode: where the frequency of demands for operation made on a safety-related system is no greater than one per year or no greater than twice the proof-test frequency.
- High Demand/Continuous mode: where the frequency of demands for operation made on a safety-related system is greater than once per year or greater than twice the proof test interval.

The SIL value for a low demand safety-related system is directly related to order-of-magnitude ranges of its average probability of failure to satisfactorily perform its safety function on demand or, simply, average probability of failure on demand (PFD). The SIL value for a High Demand/continuous mode safety-related system is directly related to the probability of a dangerous failure occurring per hour (PFH).

PFD and PFH Data

PFD and PFH calculations are based on the equations from Part 6 of EN 61508.

This table provides data for a 20-year proof test interval and demonstrates the worst-case effect of various configuration changes on the data.

PFD and PFH for 20-year Proof Test Interval

Attribute	Value			
	Drive Frames 1...7	Drive Frame 8	Drive Frame 9	Drive Frame 10
PFD	3.29E-5	3.81E-04	2.65E-4	3.56E-4
PFH	3.75E-10	4.46E-09	3.04E-9 1/h	4.09E-9 1/h
SFF	99.5%	98.4%	98.2%	98.2%
DC	99.5% ⁽¹⁾	90.0%	90.0%	90.0%
SIL CL	3	3	3	3
PL	e	e	e	e
CAT.	3	3	3	3
HFT	1 (1002)	1 (1002)	1 (1002)	1 (1002)
PTI (Proof Test Interval)	20 years	20 years	20 years	20 years

(1) Without connection to external equipment.

Safe State

The Safe State encompasses all operation that occurs outside of the other monitoring and stopping behavior defined as part of the Safe Torque Off Option module.

If a Safe State Fault is detected, the safety option goes to the Safe State. This includes faults related to integrity of hardware or firmware.

Safety Reaction Time

The safety reaction time is the amount of time from a safety-related event as input to the system until the system is in the Safe State.

The safety reaction time from an input signal condition that triggers a safe stop, to the initiation of the configured Stop Type, is 10 ms (maximum) for drive Frames 1...10.

Considerations for Safety Ratings

The achievable safety rating of an application using the safety option installed in PowerFlex 750-Series drives is dependent upon many factors, drive options, and the type of motor.

For applications that rely on the immediate removal of power to the actuator, resulting in an uncontrolled coast to stop, a safety rating up to and including SIL CL3, PL e, and Category 3 can be achieved.

Contact Information if Safety Option Failure Occurs

If you experience a failure with any safety-certified device, contact your local Rockwell Automation distributor. With this contact, you can:

- return the device to Rockwell Automation so the failure is appropriately logged for the catalog number affected and a record is made of the failure.
- request a failure analysis (if necessary) to determine the probable cause of the failure.

Notes:

Installation and Wiring

Installation must be in accordance with the following steps and must be carried out by competent personnel. The Safe Torque Off option is intended to be part of the safety related control system of a machine. Before installation, a risk assessment should be performed that compares the Safe Torque Off option specifications and all foreseeable operational and environmental characteristics of the machine to which it is to be fitted.

A safety analysis of the machine section controlled by the drive is required to determine how often the safety function should be tested for proper operation during the life of the machine.




ATTENTION: The following information is merely a guide for proper installation. Rockwell Automation, Inc. cannot assume responsibility for the compliance or the noncompliance to any code, national, local or otherwise for the proper installation of this equipment. A hazard of personal injury and/or equipment damage exists if codes are ignored during installation.

Access Drive Control Pod


1. Remove drive cover.

Frames 1...5




- Squeeze locking tabs and pull out bottom of cover.
- Pull cover down and away from the chassis

Frames 6...7



- Loosen door screws.
- Gently pry the door open to remove.


Frames 8...10



- Remove top screws.
- Loosen bottom screws.
- Remove the right front cover.


2. Frame 1 – Lift the chassis cover.
Frames 2...7 – Lift the Human Interface Module (HIM) cradle.

Frame 1




- Loosen the retention screw.
- Use a screwdriver to release the chassis cover locking tabs.
- Lift the chassis until the latch engages.

Frames 2...7



- Loosen the retention screw.
- Lift the cradle until the latch engages.

Frames 8...10




- Loosen the retention screw.
- Lift the cradle until the latch engages.

Configure Safety Enable


Safety Enable Jumper

When installing the Safe Torque Off option module, ensure the safety enable jumper (SAFETY) on the Main Control Board is removed.

PowerFlex 753 - SAFETY Jumper Location



PowerFlex 755 - SAFETY Jumper Location (Frames 1...7 Only)




Note: Frame 8...10 drives do not have a safety enable jumper.


Hardware Enable Jumper

When installing the Safe Torque Off option module, ensure the hardware enable jumper (ENABLE) on the Main Control Board is installed.


PowerFlex 753 - ENABLE Jumper Location



PowerFlex 755 - ENABLE Jumper Location (Frames 1...7)



PowerFlex 755 - ENABLE Jumper Location (Frames 8...10)



Option Module Installation



ATTENTION: Hazard of equipment damage exists if an option module is installed or removed while the drive is powered. To avoid damaging the drive, verify that the voltage on the bus capacitors has discharged before performing any work on the drive.

Frames 1...7: Measure the DC bus voltage at the Power Terminal Block by measuring between the +DC and -DC terminals, between the +DC terminal and the chassis, and between the -DC terminal and the chassis. The voltage must be zero for all three measurements.

Frames 8...10: Measure the DC bus voltage at the DC+ and DC- TESTPOINT sockets on the front of the power module.

To install the Safe Torque Off option module:


1. Firmly press the module edge connector into the desired port.

IMPORTANT The Safe Torque Off option module can be installed in any drive port. However, when used in an Integrated Motion application, the module must be installed in port 6.

2. Tighten the top and bottom retaining screws.
 - Recommended torque = 0.45 N•m (4.0 lb•in)
 - Recommended screwdriver = T15 Hexalobular



IMPORTANT Do not over-tighten retaining screws.



Wiring


Important points to remember about wiring:


- Always use tinned copper wire.
- Wire with an insulation rating of 600V or greater is recommended.
- Control wires should be separated from power wires by at least 0.3 meters (1 foot).


Table 1 - Safe Torque Off Option Terminal Block Specifications

Wire Size Range		Wire Type	Strip Length
Maximum	Minimum		
0.8 mm ² (18 AWG)	0.3 mm ² (28 AWG)	Multi-conductor shielded cable	10 mm (0.39 in.)

Table 2 - TB2 Terminal Designations

	Terminal	Name	Description
	SP+	+24 Volt Safety Power	User-supplied power: 24 volt ±10% 45 mA typical
	SP-	Safety Power Common	
	SE+	+24 Volt Safety Enable	User-supplied power: 24 volt ±10% 25 mA typical
	SE-	Safety Enable Common	
	Sd	Shield	Terminating point for wiring shields when an EMC plate or conduit box is not installed.
	Sd	Shield	



Safety Input	Connection Example
Power Supply	

Important Safe Torque Off Option Module Installation Notes

Cabling

- Safety input wiring must be protected against external damage by cable ducting, conduit, armored cable or other means.
- Shielded cable is required.

Port Assignment

- When used in an Integrated Motion application, the Safe Torque Off option must be installed in port 6.
- Only one safety option module can be installed at a time. Multiple safety options or duplicate safety option installations are not supported.

Jumper Settings

- Ensure the hardware enable jumper (ENABLE) on the main control board is installed. Refer to [page 21](#) for location. If not installed, the drive will fault when powered up.
- Ensure the safety enable jumper (SAFETY) on the main control board is removed (Frames 1...7 only). Refer to [page 20](#) for location.

Verify Operation

Test the safety function for proper operation after initial installation of the Safe Torque Off option module. Retest the safety function at the intervals determined by the safety analysis described on [page 15](#).

Verify that both safety channels are functioning according to [Table 3](#).

Table 3 - Channel Operation and Verification

Safety Function Status	Drive In Not Enabled State	Drive In Not Enabled State	Drive In Not Enabled State	Drive Able To Run (Ready)
Safety Channel Operation				
Safe Torque Off Option Terminals SP+ & SP- (Safety Power)	No Power Applied	Power Applied	No Power Applied	Power Applied
Safe Torque Off Option Terminals SE+ & SE- (Safety Enable)	No Power Applied	No Power Applied	Power Applied	Power Applied

IMPORTANT If an external fault is present on the wiring or circuitry controlling the Safety Enable or Safety Power inputs for a period of time, the Safe Torque Off option will not detect this condition. When the external fault condition is removed the Safe Torque Off option will allow an enable condition.

TIP No tell back contact is provided on the Safe Torque Off option. This is a solid state relay that uses a test pulse from the safety circuit to verify operation.

Notes:

Description of Operation

PowerFlex 750-Series Safe Torque Off Operation

The PowerFlex 750-Series Safe Torque Off option module (see [Figure 1](#)) disables the drive's output IGBT's by either disconnecting the power supply to the gate control driver IC or disabling the output of the gate control driver IC. The system satisfies the requirements of SIL3 for safe turn off of torque.

IMPORTANT The Safe Torque Off option does not eliminate dangerous voltages at the drive output. Input power to the drive must be turned off and safety procedures followed before performing any electrical work on the drive or motor.




ATTENTION: In the event of the failure of two output IGBTs in the drive, when the PowerFlex 750-Series Safe Torque Off option has controlled the drive outputs to the off state, the drive may provide energy for up to 180° of rotation in a 2-pole motor before torque production in the motor ceases.

Under normal operation, 24V DC is applied to both the Safety Power and Safety Enable inputs of the Safe Torque Off option module. If the Safety Enable or Safety Power is de-energized, the outputs of the gate control driver IC are disabled and IGBT firing is disabled. Parameter 933 [Start Inhibits] will indicate that IGBTs are inhibited and the HIM will indicate that the drive is not enabled.




ATTENTION: By itself, the PowerFlex 750-Series Safe Torque Off option initiates a coast-to-stop action. Additional protective measures will need to be applied when an application requires a different stopping action.

Figure 1 - Drive Safe Torque Off Circuitry



Example 1 - PowerFlex 750-Series Drives, Frames 1...10 Safe Torque Off Connection with Coast-to-Stop Action, Dual Channel

Figure 2 - Stop Category 0 – Coast



Circuit Status

Circuit shown with guard door closed and system ready for normal drive operation.

Operating Principle


This is a dual channel system with monitoring of the Safe Torque Off circuit and drive. Opening the guard door will switch the input circuits (S13-S14 & S21-S22) to the Minotaur monitoring safety relay unit. The output circuits (13-14 & 23-24) will cause the Safe Torque Off option and drive Enable circuit to trip and the motor will coast to stop. To restart the drive, the Minotaur safety relay must first be reset followed by a valid start command to the drive.

Fault Detection

A single fault detected on the Minotaur safety input circuits will result in the lock-out of the system at the next operation and will not cause loss of the safety function.

Example 2 - PowerFlex 750-Series Drives, Frames 1...10 Safe Torque Off Connection with Coast-to-Stop Action, Dual Channel

Figure 3 - Stop Category 0 – Coast



Circuit Status

Circuit shown with guard door closed and system ready for normal drive operation.

Operating Principle

This is a dual channel system with monitoring of the Safe Torque Off circuit and drive. Opening the guard door will switch the input circuits (S11-S12 & S21-S22) to the Minotaur monitoring safety relay unit. The output circuits (13-14 & 23-24) cause the drive Enable circuit to trip and the motor will coast to stop. After the programmed delay, the timed output circuits (57-58) will cause the Safe Torque Off option circuit to trip. To restart the drive, the Minotaur safety relay must first be reset followed by a valid start command to the drive.


Application Considerations

When the hazard analysis for the overall machine determines the need for external mechanical brakes or other stopping means, the external means shall be activated after the removal of power for Stop Category 0.

If the Safe Torque Off option sticks ON, the motor will stop on command due to the enable input. The system cannot be reset when this fault condition exists.

Example 3 - All Drives Safe Torque Off Connection with Controlled Stop Action, Dual Channel

Figure 4 - Stop Category 1 – Controlled



Circuit Status

Circuit shown with guard door closed and system ready for normal operation.

Operating Principle

This is a dual channel system with monitoring of the Safe Torque Off circuit and drive. Opening the guard door will switch the input circuits (S11-S12 & S21-S22) to the Minotaur monitoring safety relay unit. The output circuits (13-14) will issue a Stop command to the drive and cause a controlled deceleration. After the programmed delay, the timed output circuits (47-48 & 57-58) will cause the Safe Torque Off option and the drive Enable circuit to trip. If the motor is rotating when the trip occurs, it will coast to stop. To restart the drive, the Minotaur safety relay must first be reset followed by a valid start command to the drive.

Fault Detection

A single fault detected on the Minotaur safety input circuits will result in the lock-out of the system at the next operation and will not cause loss of the safety function.

If the Safe Torque Off option sticks ON, the motor will stop on command due to the enable input. The system cannot be reset when this fault condition exists.

Notes:

Specifications

Introduction

This appendix provides general specifications for the Safe Torque Off Option module.

General Specifications

Attribute	Value
Standards	IEC/EN60204-1, ISO13489-1, IEC 61508, IEC 61800-5-2
Safety category	Cat. 3 and PL e per EN ISO 13849-1; SIL CL3 per IEC 61508 and EN 62061
Power supply (user I/O)	24V DC $\pm 10\%$, 0.8...1.1 x rated voltage ⁽¹⁾ PELV or SELV
Power consumption	4.4 watts
Safety enable SE+, SE–	24V DC, 25 mA
Safety power SP+, SP–	24V DC, 45 mA
Input ON Voltage, min	24V DC $\pm 10\%$, 21.6...26.4V DC
Input OFF Voltage, max	5V
Input OFF Current, max	2.5 mA @ 5V DC
Conductor type	Multi-conductor shielded cable
Conductor size ⁽²⁾	0.3...0.8 mm ² (28...18 AWG)
Strip length	10 mm (0.39 in.)

(1) Safety outputs need additional fuse for reverse voltage protection of the control circuit. Install a 6 A slow-blow or 10 A fast-acting fuse.

(2) Refer to Industrial Automation Wiring and Grounding Guidelines, publication 1770-4.1.

Environmental Specifications

Category	Specification														
Maximum Surrounding Air Temperature															
IP20, NEMA/UL Open Type:	0...50 °C (32...122 °F) Frame 1...5, All Ratings														
IP00, NEMA/UL Open Type:	0...50 °C (32...122 °F) Frame 6...7, All Ratings														
IP20, NEMA/UL Type 1 (w/Hood):	0...40 °C (32...104 °F) Frame 1...5, All Ratings														
IP20, NEMA/UL Type 1 (w/Label):	0...40 °C (32...104 °F) Frame 6...7, All Ratings														
IP20, NEMA/UL Type 1 (MCC Cabinet):	0...40 °C (32...104 °F) Frame 8...10, All Ratings														
Flange Mount – Front:															
IP20, NEMA/UL Open Type:	0...50 °C (32...122 °F) Frame 2...5, All Ratings														
IP00, NEMA/UL Open Type:	0...50 °C (32...122 °F) Frame 6...7, All Ratings														
Back/Heat Sink:															
IP66, NEMA/UL Type 4X	0...40 °C (32...104 °F) Frame 2...7, All Ratings														
Stand-alone/Wall Mount – IP54, NEMA/UL Type 12	0...40 °C (32...104 °F) Frame 2...7, All Ratings														
Storage Temperature (all const.):	-40...70 °C (-40...158 °F)														
Atmosphere:	Important: Drive must not be installed in an area where the ambient atmosphere contains volatile or corrosive gas, vapors or dust. If the drive is not going to be installed for a period of time, it must be stored in an area where it will not be exposed to a corrosive atmosphere.														
UV Radiation	The HIM and IP54, NEMA/UL Type 12 drive plastics are not UV rated.														
Relative Humidity:	5...95% non-condensing														
Shock - Operating	Frame 1...6: 15 g peak for 11 ms duration (± 1.0 ms) Frame 7: 10 g peak for 11 ms duration (± 1.0 ms) Frame 8...10: Power Core - 10 g peak for 11 ms duration (± 1.0 ms) in Cabinet w/Option Bay - 5 g peak for 11 ms duration (± 1.0 ms)														
Shock - Packaged for Shipment	Frame 1...2: 381 mm (15 in.) drop height Frame 3...4: 330 mm (13 in.) drop height Frame 5: 305 mm (12 in.) drop height Frame 6...10: Meets International Safe Transit Association (ISTA) test procedure 2B														
Vibration - Operating	Frame 1...2: 1.000 mm (0.040 in.) displacement, 2 g peak Frame 3...5: 1.000 mm (0.040 in.) displacement, 1.5 g peak Frame 6...7: 1.000 mm (0.040 in.) displacement, 1 g peak Frame 8...10: Power Core, Drive in Cabinet w/Option Bay - 1.000 mm (0.040 in.) displacement, 1 g peak														
Vibration - Packaged for Shipment															
Sinusoidal Loose Load:	Frame 1...5: 20.0 mm (0.8 in.) peak to peak, 2...5.186 Hz; 1.1 g peak from 5.186...20 Hz Frame 6...10: Meets ISTA 2B packaging standards														
Random Secured:	Frame 1...5: <table border="1"> <thead> <tr> <th>Frequency (Hz)</th> <th>PSD (g^2/Hz)</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>0.00005</td> </tr> <tr> <td>4</td> <td>0.01</td> </tr> <tr> <td>16</td> <td>0.01</td> </tr> <tr> <td>40</td> <td>0.001</td> </tr> <tr> <td>80</td> <td>0.001</td> </tr> <tr> <td>200</td> <td>0.00001</td> </tr> </tbody> </table> Frame 6...10: Meets International Safe Transit Association (ISTA) test procedure 2B	Frequency (Hz)	PSD (g^2/Hz)	1	0.00005	4	0.01	16	0.01	40	0.001	80	0.001	200	0.00001
Frequency (Hz)	PSD (g^2/Hz)														
1	0.00005														
4	0.01														
16	0.01														
40	0.001														
80	0.001														
200	0.00001														

Certifications

See the Product Certification link at www.rockwellautomation.com/products/certification/ for Declarations of Conformity, Certificates, and other certifications details.

Certification ⁽¹⁾	Value
c-UL-us ⁽²⁾	UL Listed, certified for US and Canada.
CE	European Union 2004/108/EC EMC Directive, compliant with: EN 61800-3; PowerFlex 750-Series AC Drive, Emissions and Immunity EN 62061; Safety Function, Immunity European Union 2006/42/EC Machinery Directive: EN ISO 13849-1; Safety Function EN ISO 13849-2; Safety Function EN 60204-1; Safety Function EN 62061; Safety Function EN 61800-5-2; Safety Function
C-Tick	Australian Radiocommunications Act, compliant with: EN 61800-3; categories C2 and C3
TÜV	Certified by TÜV for Functional Safety: up to SIL CL3, according to EN 61800-5-2, EN 61508, and EN 62061; up to Performance Level PL e and Category 4, according to EN ISO 13849-1; when used as described in this PowerFlex 750-Series Safe Torque Off User Manual, publication 750-UM002.

(1) When product is marked, refer to www.rockwellautomation.com/products/certification/ for Declarations of Conformity Certificates.

(2) Underwriters Laboratories Inc. has not evaluated the safe-off, safe torque-off, or safe speed-monitoring options for functional safety.

CE Conformity

CE Declarations of Conformity are available online at:

www.rockwellautomation.com/products/certification/

The 20-750-S Safe Torque Off module is in conformity with the essential requirements of the 2006/42/EC Machinery Directive and the 2004/108/EC EMC Directive when installed and maintained in accordance with the instructions contained in this document. The following standards have been applied to demonstrate conformity:

Machinery Directive (2006/42/EC)

- EN ISO 13849-1:2008 Safety of machinery - Safety related parts of control systems - Part 1: General principles for design
- EN ISO 13849-2:2008 Safety of machinery - Safety related parts of control systems - Part 2: Validation
- EN 60204-1:2006 Safety of machinery - Electrical equipment of machines - Part 1: General requirements
- EN 62061:2005 Safety of machinery - Functional safety of safety-related electrical, electronic and programmable electronic control systems
- EN 61800-5-2:2007 Adjustable speed electrical power drive systems - Part 5-2: Safety requirement - Functional

EMC Directive (2004/108/EC)

- EN 61800-3:2004 - Adjustable speed electric power drive systems - Part 3: EMC requirements and specific test methods

Notes:

Rockwell Automation Support

Rockwell Automation provides technical information on the Web to assist you in using its products.

At <http://www.rockwellautomation.com/support/>, you can find technical manuals, a knowledge base of FAQs, technical and application notes, sample code and links to software service packs, and a MySupport feature that you can customize to make the best use of these tools.

For an additional level of technical phone support for installation, configuration, and troubleshooting, we offer TechConnectSM support programs. For more information, contact your local distributor or Rockwell Automation representative, or visit <http://www.rockwellautomation.com/support/>.

Installation Assistance

If you experience a problem within the first 24 hours of installation, review the information that is contained in this manual. You can contact Customer Support for initial help in getting your product up and running.

United States or Canada	1.440.646.3434
Outside United States or Canada	Use the Worldwide Locator at http://www.rockwellautomation.com/support/americas/phone_en.html , or contact your local Rockwell Automation representative.

New Product Satisfaction Return

Rockwell Automation tests all of its products to ensure that they are fully operational when shipped from the manufacturing facility. However, if your product is not functioning and needs to be returned, follow these procedures.

United States	Contact your distributor. You must provide a Customer Support case number (call the phone number above to obtain one) to your distributor to complete the return process.
Outside United States	Please contact your local Rockwell Automation representative for the return procedure.

Documentation Feedback

Your comments will help us serve your documentation needs better. If you have any suggestions on how to improve this document, complete this form, publication [RA-DU002](#), available at <http://www.rockwellautomation.com/literature/>.

Rockwell Otomasyon Ticaret A.Ş., Kar Plaza İş Merkezi E Blok Kat:6 34752 İçerenköy, İstanbul, Tel: +90 (216) 5698400

www.rockwellautomation.com

Power, Control and Information Solutions Headquarters

Americas: Rockwell Automation, 1201 South Second Street, Milwaukee, WI 53204-2496 USA, Tel: (1) 414.382.2000, Fax: (1) 414.382.4444

Europe/Middle East/Africa: Rockwell Automation NV, Pegasus Park, De Kleetlaan 12a, 1831 Diegem, Belgium, Tel: (32) 2 663 0600, Fax: (32) 2 663 0640

Asia Pacific: Rockwell Automation, Level 14, Core F, Cyberport 3, 100 Cyberport Road, Hong Kong, Tel: (852) 2887 4788, Fax: (852) 2508 1846

Publication 750-UM002E-EN-P - February 2012

Supersedes Publication 750-UM002C-EN-P - September 2011

Copyright © 2012 Rockwell Automation, Inc. All rights reserved. Printed in the U.S.A.