

SIEMENS

SIPROTEC

Multi-Functional Protective Relay with Local Control 7SJ68

V4.71

IEC 61850

PIXIT

Preface, Table of Contents

Applications 1

Basics 2

Mapping 3

Literature, Index

Disclaimer of Liability

We have checked the text of this manual against the hardware and software described. However, deviations from the description cannot be completely ruled out, so that no liability can be accepted for any errors or omissions contained in the information given.

The information given in this document is reviewed regularly and any necessary corrections will be included in subsequent editions. We appreciate any suggestions for improvement.

We reserve the right to make technical improvements without notice.

Document Release V04.02.02
Edition 01.2012

Copyright

Copyright © Siemens AG 2009

Dissemination or reproduction of this document, or evaluation and communication of its contents, is not authorized except where expressly permitted. Violations are liable for damages. All rights reserved, particularly for the purposes of patent application or trademark registration.

Registered Trademarks

SIPROTEC, SINAUT, SICAM and DIGSI are registered trademarks of Siemens AG. Other designations in this manual might be trademarks whose use by third parties for their own purposes would infringe the rights of the owner.

Preface

Purpose of this manual

In this Manual, you will find the

- ❑ Specification of the applications of the IEC 61850 interface
- ❑ General information about the effects of configuration of your device to the different Logical Nodes and DOIs
- ❑ Mapping of device relevant information to Logical Nodes as part of protocol IEC61850

Target audience

This manual is intended mainly for all persons who configure, parameterize and operate a SIPROTEC Devices 7SJ68.

Scope of validity of this Manual

SIPROTEC 7SJ68, Version 4.71

Standards

This document has been created according to the ISO 9001 quality standards.

Further Support

If you have questions about SIPROTEC IEC 61850 interface, please contact your Siemens sales representative.

Table of contents

1	Applications	7
1.1	General	8
1.2	Association model	9
1.3	Server model	10
1.4	Data set model	11
1.5	Substitution model	12
1.6	Setting group control model	13
1.7	Reporting model	14
1.7.1	Unbuffered Report	14
1.7.2	Buffered Report	15
1.8	Logging model	17
1.9	Generic substation model	18
1.10	Transmission of sample values model	20
1.11	Control model	21
1.12	Time and time synchronisation model	23
1.13	File transfer model	24
1.14	General items	25
1.15	TISSUES	26
2	Basics	29
2.1	General	30
2.2	Effects of Configuration on the Logical Nodes	32
2.2.1	Function parameters	32
2.2.2	Function parameters SIPROTEC 7SJ68	33
2.3	Allocation of Logical Nodes to Logical Devices	37
2.4	Logical Node LLN0	41
2.4.1	Logical Device PROT	41
2.4.2	Logical Devices MEAS, DR and EXT	43
2.4.3	Logical Device CTRL	44
2.5	DOI Behavior	46
2.5.1	Logical Device PROT	46
2.5.2	Logical Devices MEAS, CTRL, DR and EXT	47

3	Mapping	49
3.1	Device (LPHD1, CALH1)	50
3.1.1	Error with a summary alarm and Alarm summary event	51
3.2	Oscillographic Fault Records (RDRE1)	53
3.3	DMT / IDMT (PTOCx, PTRC2)	55
3.3.1	DMT/IDMT Phase (PTOC6, PTOC7, PTOC1, PTOC18)	55
3.3.2	DMT/IDMT Earth (PTOC8, PTOC9, PTOC2)	61
3.3.3	DMT/IDMT Phase and Earth (PTRC2)	65
3.4	DMT / IDMT Directional (PTOCx, PTRC3)	68
3.4.1	DMT/IDMT Directional Phase (PTOC10, PTOC11, PTOC3)	68
3.4.2	DMT/IDMT Directional Earth (PTOC12, PTOC13, PTOC4)	72
3.4.3	DMT/IDMT Directional Phase and Earth (PTRC3)	76
3.5	Voltage Protection (PTUVx, PTOVx)	80
3.5.1	Undervoltage Protection (PTUV1, PTUV2)	80
3.5.2	Overvoltage Protection (PTOV1)	83
3.6	Unbalanced Load (Negative Sequence) (PTOC14, PTOC15, PTOC5)	86
3.7	Motor Protection (PMSS1, PMRI1)	90
3.7.1	Startup Time Supervision for Motors (PMSS1)	90
3.7.2	Startup Counter for Motors (PMRI1)	92
3.8	Load Jam Protection (PMLJ1)	93
3.9	Frequency Protection (PTUFx, PTOFx)	95
3.9.1	Underfrequency Protection F1 (PTUF1, PTUF2, PTUF3, PTUF4)	95
3.9.2	Overfrequency Protection F1 (PTOF1, PTOF2, PTOF3, PTOF4)	103
3.10	Thermal Overload Protection (PTTR1)	111
3.11	Earth Fault Protection (sensitive) (PHIZ1, PSDE1 PSDE2)	113
3.12	Automatic Reclose Function (RREC1)	120
3.13	Circuit breaker failure protection 50BF(RBRF1)	122
3.14	SYNC Function 1 (RSYN1)	124
3.15	Three-pole tripping CB Breaker (XCBR1)	127
3.16	Tripping Logic of the Entire Device (PTRC1)	131
3.17	Measurement (MMXU1, MSQI1, MMTR1)	133
3.17.1	Measures (MMXU1)	133
3.17.2	Measured values, symmetrical components (MSQI1)	138
3.17.3	Power Metering (MMTR1)	141

Literature

Index

Applications

Contents

This chapter specifies the protocol implementation extra information for testing (PIXIT) of the IEC 61850 interface in SIPROTEC 7SJ68 V4.71

1.1	General	8
1.2	Association model	9
1.3	Server model	10
1.4	Data set model	11
1.5	Substitution model	12
1.6	Setting group control model	13
1.7	Reporting model	14
1.8	Logging model	17
1.9	Generic substation model	18
1.10	Transmission of sample values model	20
1.11	Control model	21
1.12	Time and time synchronisation model	23
1.13	File transfer model	24
1.14	General items	25
1.15	TISSUES	26

1.1 General

This chapter specifies the protocol implementation extra information for testing (PIXIT) of the IEC 61850 interface in SIPROTEC 7SJ68 V4.71.

It is based on the service subset definition given in the protocol implementation conformance statement (PICS), which is specified within the user manual *SIPROTEC 4 Ethernet Module EN 100 IEC 61850 Electrical Interface 100 MBit, Manual /1/*.

The following applicable ACSI service models are specified:

- Association model
- Server model
- Data set model
- Substitution model
- Setting group control model
- Reporting model
- Logging model
- Generic substitution model
- Transmission of sample values model
- Control model
- Time and time synchronisation model
- File transfer model
- General items

Together with the PICS and the MICS the PIXIT forms the basis for a conformance test according to IEC 61850-10.

The mapping between the IEC 61850 server data model and the SIPROTEC specific data is specified in Chapter 3.

1.2 Association model

Description	Value / Clarification
Maximum number of clients that can set-up an association simultaneously	5
Lost connection detection time range (default range of TCP_KEEPALIVE is 1 – 20 seconds)	10 seconds
Is authentication supported	N
What called association parameters are necessary for successful association ?	Transport selector Y Session selector Y Presentation selector Y AP Title ANY AE Qualifier ANY Where Y means: as defined within the ICD-File ANY means: any value accepted
What is the maximum and minimum MMS PDU size ?	Max MMS PDU size 32768 Min MMS PDU size
What is the typical startup time after a power supply interrupt ?	15 SECONDS
<additional items>	

1.3 Server model

Description	Value / Clarification
Which analogue value (MX) quality bits are supported (can be set by server) ?	Validity: Y Good, Y Invalid, N Reserved, Y Questionable Y Overflow Y OutofRange N BadReference N Oscillatory Y Failure Y OldData N Inconsistent Y Inaccurate Source: Y Process N Substituted Y Test Y OperatorBlocked
Which status value (ST) quality bits are supported (can be set by server) ?	Validity: Y Good, Y Invalid, N Reserved, Y Questionable N BadReference Y Oscillatory Y Failure Y OldData N Inconsistent N Inaccurate Source: Y Process Y Substituted Y Test Y OperatorBlocked
What is the maximum number of data values in one GetDataValues request ?	Not restricted; depends on the max. MMS PDU size given above.
What is the maximum number of data values in one SetDataValues request ?	Not restricted; depends on the max. MMS PDU size given above. No Data Attribute within our object directory is writable with the service SetDataValues.
<additional items>	

1.4 Data set model

Description	Value / Clarification
Maximum number of data elements in one data set	Not limited by an internal configuration parameter. It depends on the available memory.
How many persistent data sets can be created by one or more clients ?	64 data sets for each LD. It depends on the available memory.
How many non-persistent data sets can be created by one or more clients ?	10 data sets. It depends on the available memory.
additional items:	
Maximum number of data sets	Could not be defined, it depends on the available memory space. In principle, this information it not necessary from type conformance testing standpoint.

1.5 Substitution model

This service will not be supported (see also *SIPROTEC 4 Ethernet Module EN 100 IEC 61850 Electrical Interface 100 MBit, Manual /1/*).

1.6 Setting group control model

Description	Value / Clarification
What is the number of supported setting groups for each logical device ?	Setting groups available for LLN0 only in LD PROT. The number of supported setting groups is 1 or 4, it depends on the given configuration. Specified in the ICD-File.
What is the effect of when and how the non-volatile storage is updated ? (compare IEC 61850-8-1 §16.2.4)	Just SelectActiveSG service will supported according to PICS.
<additional items>	

1.7 Reporting model

1.7.1 Unbuffered Report

Description	Value / Clarification
The supported trigger conditions are	Y Integrity Y Data change Y Quality change Y Data update Y General Interrogation
The supported optional fields are	Y Sequence-number Y Report-time-stamp Y Reason-for-inclusion Y Data-set-name Y Data-reference N Buffer-overflow N EntryID Y Conf-rev Y Segmentation
Can the server send segmented reports ?	Y
Mechanism on second internal data change notification of the same analogue data value within buffer period (Compare IEC 61850-7-2 §14.2.2.9)	Send report immediately
Multi client URCB approach (Compare IEC 61850-7-2 §14.2.1)	All clients can access all URCB's
additional items:	
Interrupt of general interrogation	Running GI could not be interrupted. If a new GI request occurs during a running GI, the current GI will be finished first before the second GI request will be processed.
Integrity period	Configurable ≥ 1 second;
Dynamic URCB reservation after an abort of the client/server association	Reservation of the URCB is lost. After a re-establishment of the association the URCB reservation has to be done by the client before. This behavior is implemented to avoid unnecessary memory residuals if temporarily client associations (e.g. for maintenance) are established.
Configured URCB reservation after an abort of the client/server association	Reservation of the URCB is not lost.

1.7.2 Buffered Report

Description	Value / Clarification
The supported trigger conditions are	Y Integrity Y Data change Y Quality change Y Data update Y General Interrogation
The supported optional fields are	Y Sequence-number Y Report-time-stamp Y Reason-for-inclusion Y Data-set-name Y Data-reference Y Buffer-overflow Y EntryID Y Conf-rev Y Segmentation
Can the server send segmented reports ?	Y
Mechanism on second internal data change notification of the same analogue data value within buffer period (Compare IEC 61850-7-2 §14.2.2.9)	Buffer the Entry Send report if the report is enabled
Multi client BRCB approach (Compare IEC 61850-7-2 §14.2.1)	All clients can access all BRCB's
What is the format of EntryID ?	First 2 Byte : Integer Last 6 Bytes: BTime6 time stamp
What is the buffer size for each BRCB or how many reports can be buffered ?	About 1 MB are available for the buffering. Each BRCB has an extension attribute Memory that display the percentage of those 1 MB that have been reserved/forseen for its own entries. Default amount 1 MB/(2*Number of logical devices)
additional items:	
Interrupt of general interrogation	Running GI could not be interrupted. If a new GI request occurs during a running GI, the current GI will be finished first before the second GI request will be processed.
Integrity period	Configurable >=1 second;
Dynamic BRCB reservation after an abort of the client/server association	Reservation of the BRCB has been fixed with TISSUE 453. The value of the attribute ResvTms delivers the time interval during which the reservation is still active after the connection has been lost. In case a BRCB is still reserved, and a client connects with the same IP address as the one used during the reservation, then the BRCB attribute can be written by this client without prior setting the ResvTms attribute as long as the reservation timer has not expired.

<p>Configured BRCB reservation after an abort of the client/server association</p>	<p>Reservation of the BRCB is not lost for BRCBs that have been pre-associated to a specific client (pre-association defined with means of the CLientLN element with the BRCB instantiation in the SCD file). Reservation of a BRCB is lost for BRCBs, that have not been pre-associated to a specific client, after the expiration of the reservation timer set with the ResvTms attribute. In case ResvTms is not set (backward compatibility), ResvTms will get a default value for all preconfigured BRCBs that are not pre-associated to a specific client.</p>
<p>Optional use of a flow control for transmitting history of a BRCB</p>	<p>As specified in the IEC61850-7-2, transmission of entries may required some times, depending of the amount of entries that have to be transmitted. Therefore, the SIPROTEC has an optional flow control feature to accelerate the transmission of the entries: each BRCB has an extended attribute MaxOutReports that can be set from the associated-client to change the transmission strategy of the entries. The number ordered will then be transmitted as long as they exist in the buffer; the server then reset the attribute to 0 and wait for the client to set it again in order to continue the history transmission with MaxOutReports entries. The attribute only influences the flow control of entries while dealing with the history, and not after the history transmission has completed.</p>

1.8 Logging model

This service will not be supported (see also *SIPROTEC 4 Ethernet Module EN 100 IEC 61850 Electrical Interface 100 MBit, Manual /1/*).

1.9 Generic substation model

Description	Value / Clarification
What is the behavior when one subscribed GOOSE message isn't received or syntactically incorrect ?	The telegram will be discarded (i.e not forwarded to the application) since it is corrupt or syntactically incorrect and therefore not readable. The data objects will be declared as invalid after a timeout detection since no telegram have been received by the application.
What is the behavior when a subscribed GOOSE message is out-of-order ?	Error message will be stored into the error buffer (could be accessed by EN100 web-server). All expected data objects will be declared as invalid.
What is the behavior when a subscribed GOOSE message is duplicated ?	The sequence number given in the GOOSE-message is out-of-order. Error message will be stored into the error buffer (could be accessed by EN100 web-server). All expected data objects will be declared as invalid.
additional items:	
Maximum number of GOOSE messages which could be sent	<= 16 ; It depends on the available memory.
Maximum number of GOOSE messages which could be received	<= 128 ; It depends on the available memory.
Interpretation of GOOSE messages at subscriber side	1. Received GOOSE data objects without assigned quality attribute are interpreted as invalid. 2. Received GOOSE data objects which quality attribute are set to questionable are changed to invalid.
GOOSE subscriber behavior in case of missing GOOSE messages	After a GOOSE multicast application association has been interrupted, the reception of the second consecutive GOOSE telegram is required to validate the state of this GOOSE association again. However, the IED tolerates a missing telegram as long as the next telegram (expected n, received n+1) is received within the time allowed to live time out detection (the time allowed to live timeout detection occurs after 2*TAL).
GOOSE subscriber behaviour in case of multiple GOOSE messages	If a message is received twice or more, the IED already reports an error after the second reception. Therefore, network configuration error can be more easily tracked.
What is the behavior when a GOOSE header parameter is mismatching with the expected one? (datSet, goID, confRev, numDatSetEntries, number of allData)	Error message will be stored into the error buffer (could be accessed by EN100 web-server). All expected data objects will be declared as invalid.
What is the behavior when a timeAllowedToLive is 0?	Error message will be stored into the error buffer (could be accessed by EN100 web-server) since the timeAllowedToLive expired. All expected data objects will be declared as invalid.

What is the behavior when there is an out-of-order entry in the allData?	The confRev attribute in the header guarantees that the allData entries are in the correct order. Therefore, it's necessary to check the confRev attribute. There is no chance to detect such an out-of-order.
What is the behavior when no telegram is received within a TAL timeout?	To avoid an incorrect timeout detection, the subscriber detects a timeout after a period of 2×TAL. The information is then declared as questionable, oldData.
What is the behavior when a GOOSE header parameter goCBRef is mismatching with the expected one?	Since the goCBRef shall be unique stationwide, the received telegram with the mismatched goCBRef will be discarded: it has not been published. In that case only the timeout detection will set the data to invalid.
What is the behavior when a GOOSE header parameter APPID is mismatching with the expected one?	The APPID is a link layer parameter. It is used as a filter on link layer. If the APPID is mismatching, the telegram will therefore be discarded on link layer without notifying the application. Only the timeout detection will set the data to invalid.
What is the behavior when a GOOSE header parameter t is not increasing?	The t parameter is not checked. Therefore it doesn't lead to any error detection.
What is the behavior when numDatSetEntries and number of allData are inconsistent?	The telegram is discarded since it is corrupt (not well formed). After the timeout detection (no telegram forwarded to the application) the data objects are declared invalid.

1.10 Transmission of sample values model

Compare the “Implementation Guidelines for Electrical Current and Voltage Transducers according to IEC 60044-7/8 with Digital Output according to IEC 61850-9-2; Version 1.0; as specified by ABB, Areva, Landis+Gyr, OMICRON and SIEMENS

This service will not be supported (see also *SIPROTEC 4 Ethernet Module EN 100 IEC 61850 Electrical Interface 100 MBit, Manual /1/*).

1.11 Control model

Description	Value / Clarification
What control models are supported ?	Y Status-only Y Direct-with-normal-security N Sbo-with-normal-security Y Direct-with-enhanced-security Y Sbo-with-enhanced-security
Is Time activated operate (operTm) supported	N
What is the behavior when the test attribute is set in the SelectWithValue and/or Operate request ?	Will be acknowledged with negative response. The AddCause attribute will be set to "not supported"
What are the conditions for the time (T) attribute in the SelectWithValue and/or Operate request ?	Time attribute is not relevant.
Is "operate-many" supported ?	N
Is pulse configuration supported ?	N
What check conditions are supported ?	Y Synchrocheck Y Interlock-check
What service error types are supported ?	Y Instance-not-available Y Instance-in-use Y Access-violation Y Access-not-allowed-in-current-state Y Parameter-value-inappropriate Y Parameter-value-inconsistent Y Class-not-supported Y Instance-locked-by-other-client Y Control-must-be-selected Y Type-conflict Y Failed-due-to-communications Y Constraint failed-due-to-server-constraint

What additional cause diagnosis are supported ?	N Blocked-by-switching-hierarchy Y Select-failed Y Invalid-position Y Position-reached Y Parameter-change-in-execution Y Step-limit Y Blocked-by-Mode Y Blocked-by-process Y Blocked-by-interlocking Y Blocked-by-synchrocheck Y Command-already-in-execution N Blocked-by-health Y 1-of-n-control Y Abortion-by-cancel Y Time-limit-over N Abortion-by-trip Y Object-not-selected
additional items:	
What additional cause diagnosis extensions are supported ?	Y Plausibility_error Y Parameter_setting_invalid Y Hardware_error Y System_overload Y Internal_fault Y Command_sequence_error
Changing the control services by configuration	N
Inconsistency between Select and (Oper or cancel)	Oper or cancel will be acknowledged with negative response if inconsistencies to the select request are detected. The following attributes will not be checked in this case: T (Time)
Cancel request could be sent after an operate request.	Y
Format of the control time stamp attribute ?	TimeStamp instead of EntryTime acc. to the 7-2 Errata List.
Negative response for select request could be performed only	If test mode is activated or If the selection is always done.

1.12 Time and time synchronisation model

Description	Value / Clarification
What kind of quality bits are supported ?	N LeapSecondsKnown Y ClockFailure Y ClockNotSynchronized
What kind of quality accuracy bits are supported ?	Y Invalid N Unspecified
What is the behavior when the time synchronization signal/messages are lost ?	The quality attribute "ClockFailure" will be set to TRUE after a configured time period.
What is the behaviour when the time synchronisation messages indicate that the stratum is greater than 3?	A stratum with a value greater than 3 with the SNTP time synchronization messages indicates that the time server has a questionable synchronisation. It might also indicate that no GPS connection are available. Therefore the time quality attribute "ClockNotSynchronized" will be set to TRUE as long as the stratum content is greater than 3.
additional items:	
What is the behavior at start up time when a time synchronization via SNTP is configured ?	The "ClockNotSynchronized" attribute is set to TRUE as long as no time synchronization is established.

1.13 File transfer model

Description	Value / Clarification
What is structure of files and directories?	Directory name / COMTRADE / *; Directory name / LD / *; Files according to the comtrade standard.
What is the resulting behavior if no file specification is present in the file directory request?	If no file specification is present in the directory request, all files are returned - not only the files in the root directory.
Is the IETF FTP protocol also implemented ?	N
Directory names are separated from the file name by	"/"
The maximum file name size including path (default 64 chars)	64
Are directory/file name case sensitive	Case sensitive
Maximum file size	Not limited by implementation or configuration. Depends on available memory.
additional items:	
Maximum number of clients that can use the FTP service simultaneously	1
Maximum number of files that can be accessed simultaneously	1

1.14 General items

Description	Value / Clarification
IED behavior when the Logical Device is blocked : LLN0.Mod.stVal = blocked	Unlike the definition of the Data Objects "Mod/Beh" in IEC 61850-7-4, outputs to the process will be generated. Details to this behavior are specified in <i>SIPROTEC 4 Ethernet Module EN 100 IEC 61850 Electrical Interface 100 MBit, Manual /1/</i>
additional items:	
GOOSE Proxy object	To be able to subscribe Data over GOOSE, Proxy Objects are added into the object directory. Typically, they are Data of GGIO logical nodes: SPCSOxx, DPCSOxx, ISCSOxx. The Data Attributes of those Data are ctlVal, q and t. The control model associated to those Data is status-only. They are not controllable from an IEC61850 client, and their function is only to enable the GOOSE subscribing.
What is the type of the attribute actVal in the BCR (Binary Counter Reading) CDC?	The type is integer 32 (INT32).

1.15 TISSUES

Topic	TISSUE -No.	Link	Description	Impact of Interoper.
Object Model	120	http://www.tissue.iec61850.com/tissue.msp?issueid=120	Type - Mod.stVal and Mod.ctlVal	-
	146	http://www.tissue.iec61850.com/tissue.msp?issueid=146	CtxInt	-
	173	http://www.tissue.iec61850.com/tissue.msp?issueid=173	Ctl modelling harmonization	-
	234	http://www.tissue.iec61850.com/tissue.msp?issueid=234	New type CtxInt	x
Services	377	http://www.tissue.iec61850.com/tissue.msp?issueid=377	DeleteDataSet response-	-
	276	http://www.tissue.iec61850.com/tissue.msp?issueid=276	File Services Negative Responses	-
	183	http://www.tissue.iec61850.com/tissue.msp?issueid=183	GetNameList error handling	x
	165	http://www.tissue.iec61850.com/tissue.msp?issueid=165	Improper Error Response for GetDataSetValues	x
	116	http://www.tissue.iec61850.com/tissue.msp?issueid=116	GetNameList with empty response?	x
Reporting	474	http://www.tissue.iec61850.com/tissue.msp?issueid=474	GI for URCB	-
	453	http://www.tissue.iec61850.com/tissue.msp?issueid=453	Reporting & Logging model revision	x
	438	http://www.tissue.iec61850.com/tissue.msp?issueid=438	EntryTime base should be GMT	-
	349	http://www.tissue.iec61850.com/tissue.msp?issueid=349	BRCB TimeOfEntry has two definitions	x
	348	http://www.tissue.iec61850.com/tissue.msp?issueid=348	URCB class and report	x

Reporting	344	http://www.tissue.iec61850.com/tissue.msp?issueid=344	TimeOfEntry misspelled	-
	335	http://www.tissue.iec61850.com/tissue.msp?issueid=335	Clearing of BufOvfl	x
	332	http://www.tissue.iec61850.com/tissue.msp?issueid=332	Ambiguity in use of trigger options	x
	329	http://www.tissue.iec61850.com/tissue.msp?issueid=329	Reporting and BufOvfl	x
	322	http://www.tissue.iec61850.com/tissue.msp?issueid=322	Write Configuration attribute of BRCBs	
	301	http://www.tissue.iec61850.com/tissue.msp?issueid=301	SqNum in Buffered Reports	-
	300	http://www.tissue.iec61850.com/tissue.msp?issueid=300	Attribute Resv in BRCB	x
	298	http://www.tissue.iec61850.com/tissue.msp?issueid=298	Type of SqNum	x
	297	http://www.tissue.iec61850.com/tissue.msp?issueid=297	Sequence number	x
	278	http://www.tissue.iec61850.com/tissue.msp?issueid=278	EntryId not valid for a server	x
	275	http://www.tissue.iec61850.com/tissue.msp?issueid=275	Confusing statement on GI usage	x
	191	http://www.tissue.iec61850.com/tissue.msp?issueid=191	BRCB: Integrity and buffering reports	x
	190	http://www.tissue.iec61850.com/tissue.msp?issueid=190	BRCB: EntryId and TimeOfEntry	x
	177	http://www.tissue.iec61850.com/tissue.msp?issueid=177	Ignoring OptFlds bits for URBCB	-
	52	http://www.tissue.iec61850.com/tissue.msp?issueid=52	Ambiguity GOOSE SqNum	x
	49	http://www.tissue.iec61850.com/tissue.msp?issueid=49	BRCB TimeOfEntry?	x
Control Model	46	http://www.tissue.iec61850.com/tissue.msp?issueid=46	Synchro check cancel	x
	44	http://www.tissue.iec61850.com/tissue.msp?issueid=44	AddCause - Object not sel	x
	30	http://www.tissue.iec61850.com/tissue.msp?issueid=30	control parameter T	x

Basics

Contents

This chapter contains general information about the effects of device configuration on Logical Nodes and DOIs.

2.1	General	30
2.2	Effects of Configuration on the Logical Nodes	32
2.3	Allocation of Logical Nodes to Logical Devices	37
2.4	Logical Node LLN0	41
2.5	DOI Behavior	46

2.1 General

The protocol IEC 61850 was developed to define a standard that can be internationally employed for the transmission of power automation system data.

This cross national standard enables an interoperability between automation systems and devices made by different manufacturers.

The devices and high voltage bay control units of the SIPROTEC 4 series can be equipped with an Ethernet module EN100 via which the protocol IEC 61850 is interpreted.

The configuration of the protocol and the integration of the device with redundant IEC 61850 interfaces in your network are performed via the configuration system DIGSI.

For details please refer to the manuals:

- ❑ *SIPROTEC 4 Ethernet Module EN 100 IEC 61850 Electrical Interface 100 MBit, Manual /1/ and*
- ❑ *SIPROTEC 4 System Description /2/.*



Note

The following definitions are taken mainly from standard IEC 61850, Technical Specification IEC TS 61850-2.

Logical Devices

LD Logical Devices represent a functional structuring of the LN Logical Nodes of a SIPROTEC device.

The following Logical Devices are present:

- ❑ Logical Device Protection PROT
- ❑ Logical Device Measurement MEAS
- ❑ Logical Device Disturbance Recorder DR
- ❑ Logical Device Control CTRL
- ❑ Logical Device Extended EXT

Each LD contains LN LLN0 and LN LPHD1.

The allocation of the Logical Nodes to the Logical Devices is listed in Chapter 2.3.

Logical Node LN

Smallest part of a function that exchanges data. A logical node is an object defined by its data and methods.

Data object instance DOI

A Data object is part of a logical node object representing specific information for example status of measurement. From an object-oriented point of view, a data object is an instance of a data class. Specific data classes carry the semantic within a logical node.

Data attribute instance DAI

A Data attribute defines the name (semantic), format, range of possible values, and representation of values while being communicated.

Annunciation types via GOOSE

Generic Object Oriented Substation Event

A GOOSE report enables high speed trip signals to be issued with a high probability of delivery.

The following types of information can be configured via GOOSE.

- External single point indication O/O
- External single point indication I/O
- External double point indication
- External double point indication, fast
- External operational measured values
- External metered values

2.2 Effects of Configuration on the Logical Nodes

2.2.1 Function parameters

Depending on the configuration of the function parameters the functions of the SIPROTEC are enabled or disabled. If a function is disabled, the corresponding Logical Node is not available.

The following Logical Nodes are always available:

Logical Device Protection: LLN0, LPHD1, XCBR1,
PTRC1

Logical Device Measurement: LLN0, LPHD1, MMXU1,
MMTR1, MSQI1

Logical Device Control: LLN0, LPHD1, CALH1

2.2.2 Function parameters SIPROTEC 7SJ68

The following table shows which Logical Nodes are available when setting the corresponding function parameter.

The setting (-) implies that no corresponding LN is available.

Table 2-1 SIPROTEC 7SJ68 - Effects of Function parameters to the Logical Nodes

No.	Function	Setting	Logical Nodes
103	Setting Group Change Option		No effect
104	Oscillographic Fault Records	Disabled	-
		Enabled	RDRE1
112	DMT / IDMT Phase Overcurrent Protection	Disabled	-
		Definite Time	PTOC6, PTOC7, PTOC18, PTRC2
		TOC IEC	PTOC6, PTOC7, PTOC1 PTOC18, PTRC2
		TOC ANSI	PTOC6, PTOC7, PTOC1, PTOC18, PTRC2
		User Defined PU	PTOC6, PTOC7, PTOC1 PTOC18, PTRC2
		Userdef. Reset	PTOC6, PTOC7, PTOC1, PTOC18, PTRC2
113	DMT / IDMT Earth Overcurrent Protectionn	Disabled	-
		Definite Time	PTOC8, PTOC9, PTRC2
		TOC IEC	PTOC8, PTOC9, PTOC2, PTRC2
		TOC ANSI	PTOC8, PTOC9, PTOC2, PTRC2
		User Defined PU	PTOC8, PTOC9, PTOC2, PTRC2
		Userdef. Reset	PTOC8, PTOC9, PTOC2, PTRC2

Table 2-1 SIPROTEC 7SJ68 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Function	Setting	Logical Nodes
115	DMT / IDMT Directional Phase Directional Overcurrent Protection	Disabled	-
		Definite Time	PTOC10, PTOC11, PTRC3
		TOC IEC	PTOC10, PTOC11, PTOC3, PTRC3
		TOC ANSI	PTOC10, PTOC11, PTOC3, PTRC3
		User Defined PU	PTOC10, PTOC11, PTOC3, PTRC3
		Userdef. Reset	PTOC10, PTOC11, PTOC3, PTRC3
116	DMT / IDMT Directional Earth Directional Overcurrent Protection	Disabled	-
		Definite Time	PTOC12, PTOC13, PTRC3
		TOC IEC	PTOC12, PTOC13, PTOC4, PTRC3
		TOC ANSI	PTOC12, PTOC13, PTOC4, PTRC3
		User Defined PU	PTOC12, PTOC13, PTOC4, PTRC3
		Userdef. Reset	PTOC12, PTOC13, PTOC4, PTRC3
117	Cold Load Pickup		No effect
122	2nd Harmonic Inrush Restraint		No effect
131	(sensitive) Earth fault	Disabled	-
		Definite Time	PHIZ1, PSDE1, PSDE2
133	Intermittent earth fault protection		No effect

Table 2-1 SIPROTEC 7SJ68 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Function	Setting	Logical Nodes
140	Unbalance Load (Negative Sequence)	Disabled	-
		TOC ANSI	PTOC14, PTOC15, PTOC5
		TOC IEC	PTOC14, PTOC15, PTOC5
		Definite Time	PTOC14, PTOC15
141	Startup Time Supervision for Motors	Disabled	-
		Enabled	PMSS1
142	Thermal Overload Protection	Disabled	-
		No ambient temp	PTTR1
		With amb. temp.	PTTR1
143	Startup Counter for Motors	Disabled	-
		Enabled	PMRI1
144	Load Jam Protection	Disabled	-
		Enabled	PMLJ1
150	Under/Overtage Protection	Disabled	-
		Enabled	PTUV1, PTUV2, PTOV1, PTOV2
154	Over/Underfrequency Protection	Disabled	-
		Enabled	PTOF1 – PTOF4, PTUF1 – PTUF4
161	Function group 1 Synchronism and Voltage Check	Disabled	-
		SYNCHROCHECK	RSYN1
171	Auto-Reclose Function	Disabled	-
		Enabled	RREC1

Table 2-1 SIPROTEC 7SJ68 - Effects of Function parameters to the Logical Nodes (Cont.)

No.	Function	Setting	Logical Nodes
182	74TC Trip Circuit Supervision	Disabled	-
		2 Binary Inputs	DOI CirSpv, LN XCBR LD PROT
		1 Binary Input	DOI CirSpv, LN XCBR LD PROT
190	External Temperature Input		No effect
191	Ext. Temperature Input Connection Type		No effect

2.3 Allocation of Logical Nodes to Logical Devices

All Logical Nodes (LN) are allocated to Logical Devices (LD). The following tables show this allocation and the DOIs available for each LN.

LD PROT

The Logical Device PROT (Protection) contains the following LNs:

Table 2-2 LD PROT - Logical Nodes

LN	Function	DOI
LLN0	General	Mod, Beh, Health, NamPlt, OpTmh
PTRC1	General device pickup General OFF	Mod, Beh, Health, NamPlt, Str,Tr,FinTr
XCBR1	CB Breaker Three-pole tripping	Mod, Beh, Health, NamPlt, Loc, OpCnt, Pos BlkOpn, BlkCls, CBOpCap SumSwARs1, SumSwARs2, SumSwARs3
PTOC6 PTOC7 PTOC1 PTOC18 PTRC2	DMT / IDMT Phase	Mod, Beh, Health, NamPlt, Str, Op, ChgSet
PTOC8 PTOC9 PTOC2 PRTC2	DMT / IDMT Earth	Mod, Beh, Health, NamPlt, Str, Op, ChgSet
PTOC10 PTOC11 PTOC3 PTRC3	DMT / IDMT Directional Phase	Mod, Beh, Health, NamPlt, Str, Op, ChgSet
PTOC12 PTOC13 PTOC4 PRTC2	DMT / IDMT Directional Earth	Mod, Beh, Health, NamPlt, Str, Op, ChgSet
PTUV1 PTUV2	Undervoltage Protection	Mod, Beh, Health, NamPlt, Str, Op
PTOV1 PTOV2	Overtoltage Protection	Mod, Beh, Health, NamPlt, Str, Op
PTOC14 PTOC15 PTOC5	Unbalanced Load (Negative Sequence)	Mod, Beh, Health, NamPlt, Str, Op

Table 2-2 LD PROT - Logical Nodes (Cont.)

LN	Function	DOI
PMSS1	Startup Time Supervision for Motors	Mod, Beh, Health, NamPlt, Str, Op
PMRI1	Startup Counter for Motors	Mod, Beh, Health, NamPlt, Op, StrInhTmm
PMLJ1	Load Jam Protection	Mod, Beh, Health, NamPlt, Str, Op, LDJamAlm, ChgSet
PTUF1 PTUF2 PTUF3 PTUF4	Underfrequency Protection	Mod, Beh, Health, NamPlt, Str, Op, BlkV
PTOF1 PTOF2 PTOF3 PTOF4	Overfrequency Protection	Mod, Beh, Health, NamPlt, Str, Op, BlkV
PTTR1	Thermal Overload Protection	Mod, Beh, Health, NamPlt, Str, Op, AlmThm
PSDE1 PSDE2	(sensitive) Earth Fault	Mod, Beh, Health, NamPlt, Str, Op
PHIZ1	(sensitive) Earth Fault	Mod, Beh, Health, NamPlt, Str, Op
RREC1	Auto-Reclose Function	Mod, Beh, Health, NamPlt, Op, AutoRecSt
LPHD1	Device	PhyNam, PhyHealth, Proxy

LD MEAS

The Logical Device MEAS (Measurement) contains the following LNs:

Table 2-3 LD MEAS - Logical Nodes

LN	Function	DOIs
LLN0	General	Mod, Beh, Health, NamPlt
MMXU1	Operational measured values	Mod, Beh, Health, NamPlt, TotW, TotVAr, TotVA, TotPF, PPV, PhV, A
MMTR1	Power Metering	Mod, Beh, Health, NamPlt, SupWh, SupVArh, DmdWh, DmdVArh
MSQI1	Measured values, symmetrical components	Mod, Beh, Health, NamPlt, SeqA, SeqV
LPHD1	Device	PhyNam, PhyHealth, Proxy

LD DR

The Logical Device DR (Disturbance Recorder) contains the following LNs:

Table 2-4 LD DR - Logical Nodes

LN	Function	DOIs
LLN0	General	Mod, Beh, Health, NamPlt
RDRE1	Oscillographic Fault Records	Mod, Beh, Health, NamPlt, RcdMade, RcdStr FitNum, GriFitNum
LPHD1	Device	PhyNam, PhyHealth, Proxy

LD CTRL

The Logical Device CTRL (Control) contains the following LNs:

Table 2-5 LD CTRL - Logical Nodes

LN	Function	DOIs
LLN0	General	Mod, Beh, Health, NamPlt, LEDRs, Loc
RSYN1	Function group 1 SYNCHOCHECK	Mod, Beh, Health, NamPlt, Rel, VInd, AngInd, HzInd, SynPrg, DifVClc, DifHzClc, DifAngClc
CALH1	Error with a summary alarm and Alarm summary event	Mod, Beh, Health, NamPlt, GrAlm, GrWrn, ErrBoard1
LPHD1	Device	PhyNam, PhyHealth, Proxy, CtlNum, DevStr

LD EXT

The Logical Device EXT (Extended) contains the following LNs:

Table 2-6 LD EXT - Logical Nodes

LN	Function	DOIs
LLN0	General	Mod, Beh, Health, NamPlt, LEDRs, Loc
LPHD1	Device	PhyNam, PhyHealth, Proxy, CtlNum

The Logical Nodes of the switching (and userdefined) objects will be created by DIGSI during the parameterization of your SIPROTEC device.

MICS, Model Implementation Conformance Statement, shows the assignment of the DOIs; you can use DIGSI to print the MICS.

LLN0.OpTmh

No.	Information	Value	
1020	Counter of operating hours (Op.Hours=)	LLN0.OpTmh.stVal	Operating hours (Absolute value)

2.4.2 Logical Devices MEAS, DR and EXT

LLN0.Mod

No.	Information				
51	Device is Operational and Protecting (Device OK)	x	x	x	x
	Test mode (Test mode)	1	1	0	0
	Stop data transmission (DataStop)	1	0	1	0
LLN0.Mod.stVal		4	3	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

LLN0.Beh

No.	Information					
51	Device is Operational and Protecting (Device OK)	0	1	1	1	1
	Test mode (Test mode)	x	0	0	1	1
	Stop data transmission (DataStop)	x	0	1	0	1
LLN0.Beh.stVal		5	1	2	3	4

device annunciation / setting: 1 - ON / TRUE IEC Status Beh.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

LLN0.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
LLN0.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

LLN0.OpTmh

No.	Information	Value	
1020	Counter of operating hours (Op.Hours=)	LLN0.OpTmh.stVal	Operating hours (Absolute value)

2.4.3 Logical Device CTRL

LLN0.Mod

No.	Information					
55	Reset Device (Reset Device)	1	1	1	1	1
51	Device is Operational and Protecting (Device OK)	1	1	1	1	0
	Test mode (Test mode)	1	1	0	0	0
	Stop data transmission (DataStop)	1	0	1	0	0
LLN0.Mod.stVal		4	3	2	1	5

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

LLN0.Beh

No.	Information					
55	Reset Device (Reset Device)	1	1	1	1	1
51	Device is Operational and Protecting (Device OK)	1	1	1	1	0
	Test mode (Test mode)	1	1	0	0	0
	Stop data transmission (DataStop)	1	0	1	0	0
LLN0.Beh.stVal		4	3	2	1	5

device annunciation / setting: 1 - ON / TRUE IEC Status Beh.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

2.5 DOI Behavior

2.5.1 Logical Device PROT

For the Logical Nodes of the PROT Logical Device, **LNx.Beh.stVal** is formed from **LNx.Mod.stVal** of the Logical Node and the status of the following device messages:

- Test mode (Test mode),
- Stop data transmission and
- At Least 1 Protection Funct. is Active.

No.	Information									
	Test mode (Test mode)	x	0	1	0	1	0	1	x	
	Stop data transmission (DataStop)	x	0	0	1	1	x	x	x	
52	At Least 1 Protection Funct. is Active (ProtActive)	x	1	1	1	1	1	1	0	
	LNx .Mod.stVal	5	1	1	1	1	2	2	x	
LNx.Beh.stVal		5	1	3	2	4	2	4	5	

device annunciation / setting: 1 - ON / TRUE IEC Status stVal:
 0 - OFF / FALSE
 x - irrelevant

1 - ON
 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

2.5.2 Logical Devices MEAS, CTRL, DR and EXT

For the Logical Nodes of the MEAS, CTRL, DR and EXT Logical Devices, **LNx.Beh.stVal** is formed from **LNx.Mod.stVal** of the Logical Node and the status of the following device messages:

- Test mode (Test mode),
- Stop data transmission.

No.	Information								
	Test mode (Test mode)	x	0	1	0	1	0	1	
	Stop data transmission (DataStop)	x	0	0	1	1	x	x	
	LNx .Mod.stVal	5	1	1	1	1	2	2	
LNx.Beh.stVal		5	1	3	2	4	2	4	

device annunciation / setting: 1 - ON / TRUE
 0 - OFF / FALSE
 x - irrelevant

IEC Status stVal:

1 - ON
 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

Mapping

Contents

This chapter shows the mapping of the information relevant to the device on the Logical Node of protocol IEC61850. It is structured according to function. In Chapter 2 you can find what consequences non-configured functions have on the Logical Nodes as well as general information about IEC 61850 mapping of information.

3.1	Device (LPHD1, CALH1)	50
3.2	Oscillographic Fault Records (RDRE1)	53
3.3	DMT / IDMT (PTOCx, PTRC2)	55
3.4	DMT / IDMT Directional (PTOCx, PTRC3)	68
3.5	Voltage Protection (PTUVx, PTOVx)	80
3.6	Unbalanced Load (Negative Sequence) (PTOC14, PTOC15, PTOC5)	86
3.7	Motor Protection (PMSS1, PMRI1)	90
3.8	Load Jam Protection (PMLJ1)	93
3.9	Frequency Protection (PTUFx, PTOFx)	95
3.10	Thermal Overload Protection (PTTR1)	111
3.11	Earth Fault Protection (sensitive) (PHIZ1, PSDE1 PSDE2)	113
3.12	Automatic Reclose Function (RREC1)	120
3.13	Circuit breaker failure protection 50BF(RBRF1)	122
3.14	SYNC Function 1 (RSYN1)	124
3.15	Three-pole tripping CB Breaker (XCBR1)	127
3.16	Tripping Logic of the Entire Device (PTRC1)	131
3.17	Measurement (MMXU1, MSQI1, MMTR1)	133

3.1 Device (LPHD1, CALH1)

LPHD1.DevStr

No.	Information				
56	Initial Start of Device (Initial Start)	0	0	1	1
67	Resume (Resume)	0	1	0	1
LPHD1.DevStr.stVal		T	2	1	T

device annunciation: 1 - ON IEC Status DevStr.stVal: 1 - Initial Start
 0 - OFF 2 - Resume
 T - toggle between 1 and 2

LPHD1.Proxy

No.	Information		
55	Reset Device (Reset Device)	0	1
LPHD1.Proxy.stVal		1	0

device annunciation: 1 - ON IEC Status Proxy.stVal: 0 - DEVICE is not a PROXY
 0 - OFF 1 - DEVICE is a PROXY

LPHD1.PhyHealth

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
LPHD1.PhyHealth.stVal		3	1

device annunciation: 1 - ON IEC Status PhyHealth.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

3.1.1 Error with a summary alarm and Alarm summary event

CALH1.Mod

No.	Information		
51	Device is Operational and Protecting (Device OK)	1	0
CALH1.Mod.stVal		1	5

device annunciation: 1 - ON IEC Status Mod.stVal: 1 - ON
 0 - OFF 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

CALH1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
CALH1.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

CALH1.GrAlm

No.	Information		
140	Error with a summary alarm (Error Sum Alarm)	1	0
CALH1.GrAlm.stVal		1	0

device annunciation: 1 - ON IEC Status GrAlm.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

CALH1.GrWrn

No.	Information		
160	Alarm Summary Event (Alarm Sum Event)	1	0
CALH1.GrWrn.stVal		1	0

device annunciation: 1 - ON IEC Status GrWrn.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

CALH1.ErrBoard1

No.	Information		
183	Error Board 1 (Error Board 1)	1	0
CALH1.ErrBoard1.stVal		1	0

device annunciation: 1 - ON IEC Status ErrBoard1.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

3.2 Oscillographic Fault Records (RDRE1)

RDRE1.Mod

No.	Information	
55	Reset Device (Reset Device)	x
RDRE1.Mod.stVal		1

device annunciation: 1 - ON
0 - OFF
x - irrelevant

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

RDRE1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
RDRE1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

RDRE1.RcdMade

No.	Information		
30053	Fault recording is running (Fault rec. run.)	0	1
RDRE1.RcdMade.stVal		1	0

device annunciation: 1 - ON
0 - OFF

IEC Status RcdMade.stVal: 0 - FALSE
1 - TRUE
(Recording complete)

RDRE1.FltNum

No.	Information	Value	
302	Fault Event (Fault Event)	RDRE1.FltNum.stVal	Present fault number

RDRE1.GriFltNum

No.	Information	Value	
301	Power System fault (Pow.Sys.Flt.)	RDRE1.GriFltNum.stVal	Network fault number

RDRE1.RcdStr

No.	Information		
30053	Fault recording is running (Fault rec. run.)	0	1
RDRE1.RcdStr.stVal		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status RcdStr.stVal: 0 - FALSE
1 - TRUE

3.3 DMT / IDMT (PTOCx, PTRC2)

3.3.1 DMT/IDMT Phase (PTOC6, PTOC7, PTOC1, PTOC18)

PTOC6.Mod

No.	Information					
1753	Time Overcurrent Phase is ACTIVE (O/C Phase ACT)	x	x	x	x	x
1752	Time Overcurrent Phase is BLOCKED (O/C Phase BLK)	x	x	x	1	0
1751	Time Overcurrent Phase is OFF (O/C Phase OFF)	1	x	0	0	0
	I> PICKUP (P1204) = ∞	x	1	0	0	0
	Frequency range is exceeded	x	x	1	x	0
PTOC6.Mod.stVal		5	5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTOC6.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC6.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTOC6.Str

No.	Information		
1810	I> picked up (I> picked up)	0	1
PTOC6.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PTOC6.Op

No.	Information		
1815	I> TRIP (I> TRIP)	0	1
PTOC6.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOC6.ChgSet

No.	Information		
1997	Dynamic settings are ACTIVE (Dyn set. ACTIVE)	0	1
PTOC6.ChgSet.stVal		0	1

device annunciation: 1 - ON IEC Status ChgSet.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PTOC7.Mod

No.	Information					
1753	Time Overcurrent Phase is ACTIVE (O/C Phase ACT)	x	x	x	x	x
1752	Time Overcurrent Phase is BLOCKED (O/C Phase BLK)	x	x	x	1	0
1751	Time Overcurrent Phase is OFF (O/C Phase OFF)	1	x	0	0	0
	I>> PICKUP (P1202) = ∞	x	1	0	0	0
	Frequency range is exceeded	x	x	1	x	0
PTOC7.Mod.stVal		5	5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOC7.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC7.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
0 - OFF 2 - WARNING
3 - ALARM

PTOC7.Str

No.	Information		
1800	I>> picked up (I>> picked up)	0	1
PTOC7.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOC7.Op

No.	Information		
1805	I>> TRIP (I>> TRIP)	0	1
PTOC7.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOC7.ChgSet

No.	Information		
1997	Dynamic settings are ACTIVE (Dyn set. ACTIVE)	0	1
PTOC7.ChgSet.stVal		0	1

device annunciation: 1 - ON IEC Status ChgSet.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PTOC1.Mod

No.	Information					
1753	Time Overcurrent Phase is ACTIVE (O/C Phase ACT)	x	x	x	x	x
1752	Time Overcurrent Phase is BLOCKED (O/C Phase BLK)	x	x	x	1	0
1751	Time Overcurrent Phase is OFF (O/C Phase OFF)	1	x	0	0	0
	I _p PICKUP (P1207) = ∞	x	1	0	0	0
	Frequency range is exceeded	x	x	1	x	0
PTOC1.Mod.stVal		5	5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOC1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

PTOC1.Str

No.	Information		
1820	Ip picked up (Ip picked up)	0	1
PTOC1.Str.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Str.general: 0 - FALSE
1 - TRUE

PTOC1.Op

No.	Information		
1825	Ip TRIP (Ip TRIP)	0	1
PTOC1.Op.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Op.general: 0 - FALSE
1 - TRUE

PTOC1.ChgSet

No.	Information		
1997	Dynamic settings are ACTIVE (Dyn set. ACTIVE)	0	1
PTOC1.ChgSet.stVal		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status ChgSet.stVal: 0 - FALSE
1 - TRUE

PTOC18.Mod

No.	Information					
1753	Time Overcurrent Phase is ACTIVE (O/C Phase ACT)	x	x	x	x	x
1752	Time Overcurrent Phase is BLOCKED (O/C Phase BLK)	x	x	x	1	0
1751	Time Overcurrent Phase is OFF (O/C Phase OFF)	1	x	0	0	0
	>>> PICKUP(P1217) = ∞	x	1	0	0	0
	Frequency range is exceeded	x	x	1	x	0
PTOC18.Mod.stVal		5	5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTOC18.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC18.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTOC18.Str

No.	Information		
1767	>>> picked up (>>> picked up)	0	1
PTOC18.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PTOC18.Op

No.	Information		
1769	I>>> TRIP (I>>> TRIP)	0	1
PTOC18.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
 0 - OFF 1 - TRUE

PTOC18.ChgSet

No.	Information		
1997	Dynamic settings are ACTIVE (Dyn set. ACTIVE)	0	1
PTOC18.ChgSet.stVal		0	1

device annunciation: 1 - ON IEC Status ChgSet.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

3.3.2 DMT/IDMT Earth (PTOC8, PTOC9, PTOC2)

PTOC8.Mod

No.	Information					
1758	Time Overcurrent Earth is ACTIVE (O/C Earth ACT)	x	x	x	x	x
1757	Time Overcurrent Earth is BLOCKED (O/C Earth BLK)	x	x	x	1	0
1756	Time Overcurrent Earth is OFF (O/C Earth OFF)	1	x	0	0	0
	IE> PICKUP (P1304) = ∞	x	1	0	0	0
	Frequency range is exceeded	x	x	1	x	0
PTOC8.Mod.stVal		5	5	2	2	1

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE
x - irrelevant

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOC8.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC8.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

PTOC8.Str

No.	Information		
1834	IE> picked up (IE> picked up)	0	1
PTOC8.Str.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Str.general: 0 - FALSE
1 - TRUE

PTOC8.Op

No.	Information		
1836	IE> TRIP (IE> TRIP)	0	1
PTOC8.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOC8.ChgSet

No.	Information		
1997	Dynamic settings are ACTIVE (Dyn set. ACTIVE)	0	1
PTOC8.ChgSet.stVal		0	1

device annunciation: 1 - ON IEC Status ChgSet.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PTOC9.Mod

No.	Information					
1758	Time Overcurrent Earth is ACTIVE (O/C Earth ACT)	x	x	x	x	x
1757	Time Overcurrent Earth is BLOCKED (O/C Earth BLK)	x	x	x	1	0
1756	Time Overcurrent Earth is OFF (O/C Earth OFF)	1	x	0	0	0
	IE>> PICKUP (P1302) = ∞	x	1	0	0	0
	Frequency range is exceeded	x	x	1	x	0
PTOC9.Mod.stVal		5	5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOC9.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC9.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
0 - OFF 2 - WARNING
3 - ALARM

PTOC9.Str

No.	Information		
1831	IE>> picked up (IE>> picked up)	0	1
PTOC9.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOC9.Op

No.	Information		
1833	IE>> TRIP (IE>> TRIP)	0	1
PTOC9.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOC9.ChgSet

No.	Information		
1997	Dynamic settings are ACTIVE (Dyn set. ACTIVE)	0	1
PTOC9.ChgSet.stVal		0	1

device annunciation: 1 - ON IEC Status ChgSet.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PTOC2.Mod

No.	Information					
1758	Time Overcurrent Earth is ACTIVE (O/C Earth ACT)	x	x	x	x	x
1757	Time Overcurrent Earth is BLOCKED (O/C Earth BLK)	x	x	x	1	0
1756	Time Overcurrent Earth is OFF (O/C Earth OFF)	1	x	0	0	0
	IEp PICKUP (P1307) = ∞	x	1	0	0	0
	Frequency range is exceeded	x	x	1	x	0
PTOC2.Mod.stVal		5	5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOC2.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC2.Health.stVal		3	1

device annunciation: 1 - ON 0 - OFF IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

PTOC2.Str

No.	Information		
1837	IEp picked up (IEp picked up)	0	1
PTOC2.Str.general		0	1

device annunciation: 1 - ON 0 - OFF IEC Status Str.general: 0 - FALSE
1 - TRUE

PTOC2.Op

No.	Information		
1839	IEp TRIP (IEp TRIP)	0	1
PTOC2.Op.general		0	1

device annunciation: 1 - ON 0 - OFF IEC Status Op.general: 0 - FALSE
1 - TRUE

PTOC2.ChgSet

No.	Information		
1997	Dynamic settings are ACTIVE (Dyn set. ACTIVE)	0	1
PTOC2.ChgSet.stVal		0	1

device annunciation: 1 - ON 0 - OFF IEC Status ChgSet.stVal: 0 - FALSE
1 - TRUE

3.3.3 DMT/IDMT Phase and Earth (PTRC2)

PTRC2.Mod

No.	Information				
1753 1758	Time Overcurrent Phase is ACTIVE (O/C Phase ACT) or Time Overcurrent Earth is ACTIVE (O/C Earth ACT)	x	x	x	x
1752 1757	Time Overcurrent Phase is BLOCKED (O/C Phase BLK) and Time Overcurrent Earth is BLOCKED (O/C Earth BLK)	x	x	1	0
1751 1756	Time Overcurrent Phase is OFF (O/C Phase OFF) and Time Overcurrent Earth is OFF (O/C Earth OFF)	1	0	0	0
	Frequency range is exceeded	x	1	x	0
PTRC2.Mod.stVal		5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTRC2.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTRC2.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTRC2.Str

No.	Information		
1761	Time Overcurrent picked up (Overcurrent PU)	0	1
PTRC2.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC2.Str.dirGeneral

No.	Information		
PTRC2.Str.dirGeneral		0	

device annunciation: IEC Status Str.dirGeneral: 0 - UNKNOWN

PTRC2.Str.dirPhsC

No.	Information		
PTRC2.Str.dirPhsC		0	

device annunciation: IEC Status Str.dirPhsC: 0 - UNKNOWN

PTRC2.Str.neut

No.	Information		
1765	Time Overcurrent Earth picked up (O/C Earth PU)	0	1
PTRC2.Str.neut		0	1

device annunciation: 1 - ON IEC Status Str.neut: 0 - FALSE
0 - OFF 1 - TRUE

PTRC2.Str.dirNeut

No.	Information		
PTRC2.Str.dirNeut		0	

device annunciation: IEC Status Str.dirPhsC: 0 - UNKNOWN

PTRC2.Op

No.	Information		
1791	Time Overcurrent TRIP (OvercurrentTRIP)	0	1
PTRC2.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

3.4 DMT / IDMT Directional (PTOCx, PTRC3)

3.4.1 DMT/IDMT Directional Phase (PTOC10, PTOC11, PTOC3)

PTOC10.Mod

No.	Information					
2653	Dir. time overcurrent PHASE is ACTIVE (DIR. Ph O/C ACT)	x	x	x	x	x
2652	Dir. time overcurrent PHASE is BLOCKED (DIR. Ph O/C BLK)	x	x	x	1	0
2651	Dir. time overcurrent PHASE is OFF (DIR. Ph O/C OFF)	1	x	0	0	0
	I> PICKUP (P1504) = ∞	x	1	0	0	0
	Frequency range is exceeded	x	x	1	x	0
PTOC10.Mod.stVal		5	5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTOC10.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC10.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTOC10.Str

No.	Information		
2660	I> Directional picked up (I> DIR. PU)	0	1
PTOC10.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PTOC10.Op

No.	Information		
2665	I> Directional TRIP (I> DIR. TRIP)	0	1
PTOC10.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOC10.ChgSet

No.	Information		
1997	Dynamic settings are ACTIVE (Dyn set. ACTIVE)	0	1
PTOC10.ChgSet.stVal		0	1

device annunciation: 1 - ON IEC Status ChgSet.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PTOC11.Mod

No.	Information					
2653	Dir. time overcurrent PHASE is ACTIVE (DIR. Ph O/C ACT)	x	x	x	x	x
2652	Dir. time overcurrent PHASE is BLOCKED (DIR. Ph O/C BLK)	x	x	x	1	0
2651	Dir. time overcurrent PHASE is OFF (DIR. Ph O/C OFF)	1	x	0	0	0
	I>> PICKUP (P1502) = ∞	x	1	0	0	0
	Frequency range is exceeded	x	x	1	x	0
PTOC11.Mod.stVal		5	5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOC11.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC11.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
0 - OFF 2 - WARNING
3 - ALARM

PTOC11.Str

No.	Information		
2642	I>> Directional picked up (I>> DIR. PU)	0	1
PTOC11.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PTOC11.Op

No.	Information		
2649	I>> Directional TRIP (I>> DIR. TRIP)	0	1
PTOC11.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
 0 - OFF 1 - TRUE

PTOC11.ChgSet

No.	Information		
1997	Dynamic settings are ACTIVE (Dyn set. ACTIVE)	0	1
PTOC11.ChgSet.stVal		0	1

device annunciation: 1 - ON IEC Status ChgSet.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

PTOC3.Mod

No.	Information					
2653	Dir. time overcurrent PHASE is ACTIVE (DIR. Ph O/C ACT)	x	x	x	x	x
2652	Dir. time overcurrent PHASE is BLOCKED (DIR. Ph O/C BLK)	x	x	x	1	0
2651	Dir. time overcurrent PHASE is OFF (DIR. Ph O/C OFF)	1	x	0	0	0
	I _p PICKUP (P1507) = ∞	x	1	0	0	0
	Frequency range is exceeded	x	x	1	x	0
PTOC3.Mod.stVal		5	5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

3.4.2 DMT/IDMT Directional Earth (PTOC12, PTOC13, PTOC4)

PTOC12.Mod

No.	Information					
2658	Dir. time overcurrent EARTH is ACTIVE (DIR. E O/C ACT)	x	x	x	x	x
2657	Dir. time overcurrent EARTH is BLOCKED (DIR. E O/C BLK)	x	x	x	1	0
2656	Dir. time overcurrent EARTH is OFF (DIR. E O/C OFF)	1	x	0	0	0
	IE> PICKUP (P1604) = ∞	x	1	0	0	0
	Frequency range is exceeded	x	x	1	x	0
PTOC12.Mod.stVal		5	5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTOC12.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC12.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTOC12.Str

No.	Information		
2681	67N-1 picked up (67N-1 picked up)	0	1
PTOC12.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PTOC12.Op

No.	Information		
2683	67N-1 TRIP (67N-1 TRIP)	0	1
PTOC12.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOC12.ChgSet

No.	Information		
1997	Dynamic settings are ACTIVE (Dyn set. ACTIVE)	0	1
PTOC12.ChgSet.stVal		0	1

device annunciation: 1 - ON IEC Status ChgSet.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PTOC13.Mod

No.	Information					
2658	Dir. time overcurrent EARTH is ACTIVE (DIR. E O/C ACT)	x	x	x	x	x
2657	Dir. time overcurrent EARTH is BLOCKED (DIR. E O/C BLK)	x	x	x	1	0
2656	Dir. time overcurrent EARTH is OFF (DIR. E O/C OFF)	1	x	0	0	0
	IE>> PICKUP (P1602) = ∞	x	1	0	0	0
	Frequency range is exceeded	x	x	1	x	0
PTOC13.Mod.stVal		5	5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOC13.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC13.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
0 - OFF 2 - WARNING
3 - ALARM

PTOC13.Str

No.	Information		
2646	67N-2 picked up (67N-2 picked up)	0	1
PTOC13.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOC13.Op

No.	Information		
2679	67N-2 TRIP (67N-2 TRIP)	0	1
PTOC13.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOC13.ChgSet

No.	Information		
1997	Dynamic settings are ACTIVE (Dyn set. ACTIVE)	0	1
PTOC13.ChgSet.stVal		0	1

device annunciation: 1 - ON IEC Status ChgSet.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PTOC4.Mod

No.	Information					
2658	Dir. time overcurrent EARTH is ACTIVE (DIR. E O/C ACT)	x	x	x	x	x
2657	Dir. time overcurrent EARTH is BLOCKED (DIR. E O/C BLK)	x	x	x	1	0
2656	Dir. time overcurrent EARTH is OFF (DIR. E O/C OFF)	1	x	0	0	0
	M.of PU TD (P1630) = ∞	x	1	0	0	0
	Frequency range is exceeded	x	x	1	x	0
PTOC4.Mod.stVal		5	5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

3.4.3 DMT/IDMT Directional Phase and Earth (PTRC3)

PTRC3.Mod

No.	Information				
2653 2658	Dir. time overcurrent PHASE is ACTIVE (DIR. Ph O/C ACT) or Dir. time overcurrent EARTH is ACTIVE (DIR. E O/C ACT)	x	x	x	x
2652 2657	Dir. time overcurrent PHASE is BLOCKED (DIR. Ph O/C BLK) and Dir. time overcurrent EARTH is BLOCKED (DIR. E O/C BLK)	x	x	1	0
2651 2656	Dir. time overcurrent PHASE is OFF (DIR. Ph O/C OFF) and Dir. time overcurrent EARTH is OFF (DIR. E O/C OFF)	1	0	0	0
	Frequency range is exceeded	x	1	x	0
PTRC3.Mod.stVal		5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTRC3.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTRC3.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTRC3.Str

No.	Information		
2691	Directional time overcurrent picked up (DIR O/C PU)	0	1
PTRC3.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC3.Str.dirGeneral

No.	Information					
2691	Directional time overcurrent picked up (DIR O/C PU)	0	1	1	1	1
2628 2629 2630 2635	Phase L1 forward (Ph L1 forward) or Phase L2 forward (Ph L2 forward) or Phase L3 forward (Ph L3 forward) or Earth forward (Earth forward)	x	0	1	0	1
2632 2633 2634 2636	Phase L1 reverse (Ph L1 reverse) or Phase L2 reverse (Ph L2 reverse) or Phase L3 reverse (Ph L31 reverse) or Earth reverse (Earth reverse)	x	0	0	1	1
PTRC3.Str.dirGeneral		0	0	1	2	3

device annunciation:

1 - ON
0 - OFF

IEC Status Str.dirGeneral:

0 - UNKNOWN
1 - FORWARD
2 - BACKWARD
3 - BOTH**PTRC3.Str.phsA**

No.	Information		
2692	DIR. time overcurrent Ph L1 picked up (DIR L1 PU)	0	1
PTRC3.Str.phsA		0	1

device annunciation:

1 - ON
0 - OFF

IEC Status Str.phsA:

0 - FALSE
1 - TRUE**PTRC3.Str.dirPhsA**

No.	Information					
2692	DIR. time overcurrent Ph L1 picked up (DIR L1 PU)	0	1	1	1	1
2628	Phase L1 forward (Phase L1 forward)	x	0	1	0	1
2632	Phase L1 reverse (Phase L1 reverse)	x	0	0	1	1
PTRC3.Str.dirPhsA		0	0	1	2	3

device annunciation:

1 - ON
0 - OFF
x - irrelevant

IEC Status Str.dirPhsA:

0 - UNKNOWN
1 - FORWARD
2 - BACKWARD

PTRC3.Str.phsB

No.	Information		
2693	DIR. time overcurrent Ph L2 picked up (DIR L2 PU)	0	1
PTRC3.Str.phsB		0	1

device annunciation: 1 - ON IEC Status Str.phsB: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC3.Str.dirPhsB

No.	Information					
2693	DIR. time overcurrent Ph L2 picked up (DIR L2 PU)	0	1	1	1	1
2629	Phase L2 forward (Phase L2 forward)	x	0	1	0	1
2633	Phase L2 reverse (Phase L2 reverse)	x	0	0	1	1
PTRC3.Str.dirPhsB		0	0	1	2	3

device annunciation: 1 - ON IEC Status Str.dirPhsB: 0 - UNKNOWN
 0 - OFF 1 - FORWARD
 x - irrelevant 2 - BACKWARD

PTRC3.Str.phsC

No.	Information		
2694	DIR. time overcurrent Ph L3 picked up (DIR L3 PU)	0	1
PTRC3.Str.phsC		0	1

device annunciation: 1 - ON IEC Status Str.phsC: 0 - FALSE
 0 - OFF 1 - TRUE

PTRC3.Str.dirPhsC

No.	Information					
2694	DIR. time overcurrent Ph L3 picked up (DIR L3 PU)	0	1	1	1	1
2630	Phase L3 forward (Phase L3 forward)	x	0	1	0	1
2634	Phase L3 reverse (Phase L3 reverse)	x	0	0	1	1
PTRC3.Str.dirPhsC		0	0	1	2	3

device annunciation: 1 - ON IEC Status Str.dirPhsC: 0 - UNKNOWN
 0 - OFF 1 - FORWARD
 x - irrelevant 2 - BACKWARD

PTRC3.Str.neut

No.	Information		
2695	DIR. time overcurrent EARTH picked up (DIR E picked up)	0	1
PTRC3.Str.neut		0	1

device annunciation: 1 - ON IEC Status Str.neut: 0 - FALSE
0 - OFF 1 - TRUE

PTRC3.Str.dirNeut

No.	Information					
2695	DIR. time overcurrent EARTH picked up (DIR E picked up)	0	1	1	1	1
2635	Earth forward (Earth forward)	x	0	1	0	1
2636	Earth reverse (Earth reverse)	x	0	0	1	1
PTRC3.Str.dirNeut		0	0	1	2	3

device annunciation: 1 - ON IEC Status Str.dirPhsC: 0 - UNKNOWN
0 - OFF 1 - FORWARD
x - irrelevant 2 - BACKWARD

PTRC3.Op

No.	Information		
2696	Directional time overcurrent TRIP (DIR O/C TRIP)	0	1
PTRC3.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

3.5 Voltage Protection (PTUVx, PTOVx)

3.5.1 Undervoltage Protection (PTUV1, PTUV2)

PTUV1.Mod

No.	Information				
6532	Undervoltage protection is ACTIVE (Under Volt. ACT)	x	x	x	x
6531	Undervoltage protection is BLOCKED (Under Volt. BLK)	x	x	1	0
170	VT Fuse Failure (alarm instantaneous) (VT FuseFail)	x	1	x	0
6530	Undervoltage protection switched OFF (Under Volt. OFF)	1	0	0	0
PTUV1.Mod.stVal		5	2	2	1

device annunciation:
 1 - ON
 0 - OFF
 x - irrelevant

IEC Status Mod.stVal:
 1 - ON
 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTUV1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTUV1.Health.stVal		3	1

device annunciation:
 1 - ON
 0 - OFF

IEC Status Health.stVal:
 1 - OK
 2 - WARNING
 3 - ALARM

PTUV1.Str

No.	Information			
6533	U< Undervoltage picked up (U< picked up)	0	x	1
6534	U< Undervoltage PICKUP w/curr. superv (U< PU CS)	0	1	x
PTUV1.Str.general		0	1	1

device annunciation:
 1 - ON
 0 - OFF
 x - irrelevant

IEC Status Str.general:
 0 - FALSE
 1 - TRUE

PTUV1.Op

No.	Information		
6539	U< Undervoltage TRIP (U< TRIP)	0	1
PTUV1.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
 0 - OFF 1 - TRUE

PTUV2.Mod

No.	Information				
6532	Undervoltage protection is ACTIVE (Under Volt. ACT)	x	x	x	x
6531	Undervoltage protection is BLOCKED (Under Volt. BLK)	x	x	1	0
170	VT Fuse Failure (alarm instantaneous) (VT FuseFail)	x	1	x	0
6530	Undervoltage protection switched OFF (Under Volt. OFF)	1	0	0	0
PTUV2.Mod.stVal		5	2	2	1

device annunciation: 1 - ON IEC Status Mod.stVal: 1 - ON
 0 - OFF 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTUV2.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTUV2.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

3.5 Voltage Protection (PTUVx, PTOVx)

PTUV2.Str

No.	Information			
6537	U<< Undervoltage picked up (U<< picked up)	0	x	1
6538	U<< Undervoltage PICKUP w/curr. superv (U<< PU CS)	0	1	x
PTUV2.Str.general		0	1	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE
 X - irrelevant

PTUV2.Op

No.	Information		
6540	U<< Undervoltage TRIP (U<< TRIP)	0	1
PTUV2.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
 0 - OFF 1 - TRUE

PTOV1.Op

No.	Information		
6570	U> TRIP (U> TRIP)	0	1
PTOV1.Op.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Op.general: 0 - FALSE
1 - TRUE

PTOV2.Mod

No.	Information				
6567	Overvoltage protection is ACTIVE (Over Volt. ACT)	x	x	x	x
6566	Overvoltage protection is BLOCKED (Over Volt. BLK)	x	x	1	0
6565	Overvoltage protection switched OFF (Over Volt. OFF)	1	0	0	0
	Frequency range is exceeded	x	1	x	0
PTOV2.Mod.stVal		5	2	2	1

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE
x - irrelevant

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOV2.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOV2.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

3.6 Unbalanced Load (Negative Sequence) (PTOC14, PTOC15, PTOC5)

PTOC14.Mod

No.	Information				
5153	I2 is ACTIVE (I2 ACTIVE)	x	x	x	x
5152	I2 is BLOCKED (I2 BLOCKED)	x	x	1	0
5151	I2 switched OFF (I2 OFF)	1	0	0	0
	Frequency range is exceeded	x	1	x	0
PTOC14.Mod.stVal		5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTOC14.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC14.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTOC14.Str

No.	Information		
5165	I2> picked up (I2> picked up)	0	1
PTOC14.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PTOC14.Op

No.	Information		
5170	I2 TRIP (I2 TRIP)	0	1
PTOC14.Op.general		0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

PTOC15.Mod

No.	Information				
5153	I2 is ACTIVE (I2 ACTIVE)	x	x	x	x
5152	I2 is BLOCKED (I2 BLOCKED)	x	x	1	0
5151	I2 switched OFF (I2 OFF)	1	0	0	0
	Frequency range is exceeded	x	1	x	0
PTOC15.Mod.stVal		5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOC15.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC15.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
0 - OFF 2 - WARNING
3 - ALARM

PTOC15.Str

No.	Information		
5159	I2>> picked up (I2>> picked up)	0	1
PTOC15.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOC15.Op

No.	Information		
5170	I2 TRIP (I2 TRIP)	0	1
PTOC15.Op.general		0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

PTOC5.Mod

No.	Information				
5153	I2 is ACTIVE (I2 ACTIVE)	x	x	x	x
5152	I2 is BLOCKED (I2 BLOCKED)	x	x	1	0
5151	I2 switched OFF (I2 OFF)	1	0	0	0
	Frequency range is exceeded	x	1	x	0
PTOC5.Mod.stVal		5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTOC5.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOC5.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
0 - OFF 2 - WARNING
3 - ALARM

PTOC5.Str

No.	Information		
5166	I2p picked up (I2p picked up)	0	1
PTOC5.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE

PTOC5.Op

No.	Information		
5170	I2 TRIP (I2 TRIP)	0	1
PTOC5.Op.general		0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

3.7 Motor Protection (PMSS1, PMRI1)

3.7.1 Startup Time Supervision for Motors (PMSS1)

PMSS1.Mod

No.	Information				
6813	Motor Startup Time Supervision ACTIVE (Mot.St.Sup. ACT)	x	x	x	x
6812	Motor Startup Time Supervision BLOCKED (Mot.St.Sup. BLK)	x	x	1	0
6811	Motor Startup Time Supervision OFF (Mot.St.Sup. OFF)	1	0	0	0
	Frequency range is exceeded	x	1	x	0
PMSS1.Mod.stVal		5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PMSS1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PMSS1.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PMSS1.Str

No.	Information		
6823	Motor Startup Time Superv. pickup (Mot.SSup.pickup)	0	1
PMSS1.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE

PMSS1.Op

No.	Information		
6821	Motor Startup Time Supervision TRIP (Mot.St.Sup.TRIP)	0	1
PMSS1.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

3.7.2 Startup Counter for Motors (PMR1)

PMR1.Mod

No.	Information			
4826	Motor Startup Counter ACTIVE (Mot.St.Cnt.ACT)	x	x	x
4825	Motor Startup Counter BLOCKED (Mot.St.Cnt.BLK)	x	1	0
4824	Motor Startup Counter OFF (Mot.St.Cnt.OFF)	1	0	0
PMR1.Mod.stVal		5	2	1

device annunciation: 1 - ON
0 - OFF
x - irrelevant

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PMR1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PMR1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

PMR1.Op

No.	Information		
4827	Motor Startup Counter TRIP (Mot.St.Cnt.TRIP)	0	1
PMR1.Op.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Op.general: 0 - FALSE
1 - TRUE

PMR1.StrInhTmm

No.	Information	Value	
809	Time until release of reclose-blocking (T reclose=)	PMR1.StrInhTmm.stVal	Absolute value

3.8 Load Jam Protection (PMLJ1)

PMLJ1.Mod

No.	Information				
10023	Load Jam Protection is ACTIVE (Load Jam ACTIVE)	x	x	x	1
10021	Load Jam Protection is BLOCKED (Load Jam BLOCK.)	x	x	1	0
10022	Load Jam Protection is OFF (Load Jam OFF)	1	0	0	0
	Frequency range is exceeded	x	1	0	0
PMLJ1.Mod.stVal		5	5	2	1

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE
x - irrelevant

IEC Status Mod.stVal:

1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PMLJ1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PMLJ1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal:

1 - OK
2 - WARNING
3 - ALARM

3.8 Load Jam Protection (PMLJ1)

PMLJ1.Str

No.	Information		
10025	Load Jam Protection picked up (Load Jam pickup)	0	1
PMLJ1.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE

PMLJ1.Op

No.	Information		
10026	Load Jam Protection TRIP (Load Jam TRIP)	0	1
PMLJ1.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PMLJ1.LodJamAlm

No.	Information		
10024	Load Jam Protection alarm (Load Jam alarm)	0	1
PMLJ1.LodJamAlm.stVal		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PMLJ1.ChgSet

No.	Information		
1997	Dynamic settings are ACTIVE (Dyn set. ACTIVE)	0	1
PMLJ1.ChgSet.stVal		0	1

device annunciation: 1 - ON IEC Status ChgSet.stVal: 0 - FALSE
0 - OFF 1 - TRUE

PTUF2.Mod

No.	Information						
5213	Frequency Protection is ACTIVE (Freq. ACTIVE)	x	x	x	x	x	x
5212	Frequency Protection is BLOCKED (Freq. BLOCKED)	x	x	x	x	1	0
5207	>BLOCK F2 (>BLOCK F2)	x	x	x	1	x	0
5214	Frequency Protection Under Voltage Blk (Freq UnderV Blk)	x	x	1	x	x	0
5211	Frequency Protection is OFF (Freq. OFF)	x	1	0	0	0	0
	F2 PICKUP (P5406) < Rated Frequency (50 Hz)	0	1	1	1	1	1
PTUF2.Mod.stVal		5	5	2	2	2	1

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE
x - irrelevant

IEC Status Mod.stVal:

1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTUF2.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTUF2.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal:

1 - OK
2 - WARNING
3 - ALARM

PTUF2.Str

No.	Information				
5233	F2 picked up (F2 picked up)	0	0	1	1
	f2 PICKUP (P5406) < Rated Frequency (50 Hz)	0	1	0	1
PTUF2.Str.general		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Str.general: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

PTUF2.Op

No.	Information				
5237	F2 TRIP (F2 TRIP)	0	0	1	1
	F2 PICKUP (P5406) < Rated Frequency (50 Hz)	0	1	0	1
PTUF2.Op.general		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

PTUF2.BlkV

No.	Information				
5214	Frequency Protection Under Voltage Blk (Freq UnderV Blk)	0	0	1	1
	F2 PICKUP (P5406) < Rated Frequency (50 Hz)	0	1	0	1
PTUF2.BlkV.stVal		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status BlkV.stVal: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

PTUF3.Mod

No.	Information						
5213	Frequency Protection is ACTIVE (Freq. ACTIVE)	x	x	x	x	x	x
5212	Frequency Protection is BLOCKED (Freq. BLOCKED)	x	x	x	x	1	0
5208	>BLOCK F3 (>BLOCK F3)	x	x	x	1	x	0
5214	Frequency Protection Under Voltage Blk (Freq UnderV Blk)	x	x	1	x	x	0
5211	Frequency Protection is OFF (Freq. OFF)	x	1	0	0	0	0
	F3 PICKUP (P5409) < Rated Frequency (50 Hz)	0	1	1	1	1	1
PTUF3.Mod.stVal		5	5	2	2	2	1

device annunciation / setting: 1 - ON / TRUE
 0 - OFF / FALSE
 x - irrelevant

IEC Status Mod.stVal:

1 - ON
 2 - BLOCKED
 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTUF3.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTUF3.Health.stVal		3	1

device annunciation: 1 - ON
 0 - OFF

IEC Status Health.stVal:

1 - OK
 2 - WARNING
 3 - ALARM

PTUF3.Str

No.	Information				
5234	F3 picked up (F3 picked up)	0	0	1	1
	F3 PICKUP (P5409) < Rated Frequency (50 Hz)	0	1	0	1
PTUF3.Str.general		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Str.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

PTUF3.Op

No.	Information				
5238	F3 TRIP (F3 TRIP)	0	0	1	1
	F3 PICKUP (P5409) < Rated Frequency (50 Hz)	0	1	0	1
PTUF3.Op.general		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

PTUF3.BIkV

No.	Information				
5214	Frequency Protection Under Voltage Blk (Freq UnderV Blk)	0	0	1	1
	F3 PICKUP (P5409) < Rated Frequency (50 Hz)	0	1	0	1
PTUF3.BIkV.stVal		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status BlkV.stVal: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

PTUF4.Mod

No.	Information						
5213	Frequency Protection is ACTIVE (Freq. ACTIVE)	x	x	x	x	x	x
5212	Frequency Protection is BLOCKED (Freq. BLOCKED)	x	x	x	x	1	0
5209	>BLOCK F4 (>BLOCK F4)	x	x	x	1	x	0
5214	Frequency Protection Under Voltage Blk (Freq UnderV Blk)	x	x	1	x	x	0
5211	Frequency Protection is OFF (Freq. OFF)	x	1	0	0	0	0
	F4 PICKUP (P5412) < Rated Frequency (50 Hz)	0	1	1	1	1	1
PTUF4.Mod.stVal		5	5	2	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTUF4.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTUF4.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTUF4.Str

No.	Information				
5235	F4 picked up (F4 picked up)	0	0	1	1
	F4 PICKUP (P5412) < Rated Frequency (50 Hz)	0	1	0	1
PTUF4.Str.general		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Str.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

PTUF4.Op

No.	Information				
5239	F4 TRIP (F4 TRIP)	0	0	1	1
	F4 PICKUP (P5412) < Rated Frequency (50 Hz)	0	1	0	1
PTUF4.Op.general		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

PTUF4.BIkV

No.	Information				
5214	Frequency Protection Under Voltage Blk (Freq UnderV Blk)	0	0	1	1
	F4 PICKUP (P5412) < Rated Frequency (50 Hz)	0	1	0	1
PTUF4.BIkV.stVal		0	0	0	1

device annunciation / setting: 1 - ON / TRUE IEC Status BlkV.stVal: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

PTOF1.Str

No.	Information				
5232	F1 picked up (F1 picked up)	0	0	1	1
	F1 PICKUP (P5403) < Rated Frequency (50 Hz)	0	1	0	1
PTOF1.Str.general		0	0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

PTOF1.Op

No.	Information				
5236	F1 TRIP (F1 TRIP)	0	0	1	1
	F1 PICKUP (P5403) < Rated Frequency (50 Hz)	0	1	0	1
PTOF1.Op.general		0	0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

PTOF1.BlkV

No.	Information				
5214	Frequency Protection Under Voltage Blk (Freq UnderV Blk)	0	0	1	1
	F1 PICKUP (P5403) < Rated Frequency (50 Hz)	0	1	0	1
PTOF1.BlkV.stVal		0	0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status BlkV.stVal: 0 - FALSE
0 - OFF / FALSE 1 - TRUE

PTOF3.Mod

No.	Information							
5213	Frequency Protection is ACTIVE (Freq. ACTIVE)	x	x	x	x	x	x	x
5212	Frequency Protection is BLOCKED (Freq. BLOCKED)	x	x	x	x	x	1	0
5208	>BLOCK F3 (>BLOCK F3)	x	x	x	x	1	x	0
5214	Frequency Protection Under Voltage Blk (Freq UnderV Blk)	x	x	x	1	x	x	0
5211	Frequency Protection is OFF (Freq. OFF)	x	x	1	0	0	0	0
	F3 PICKUP (P5409) ≤ Rated Frequency (50 Hz)	x	1	x	0	0	0	0
PTOF1.Mod.stVal		5	5	5	2	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
 0 - OFF / FALSE 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

PTOF3.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTOF3.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PTOF4.Str

No.	Information				
5235	F4 picked up (F4 picked up)	0	0	1	1
	F4 PICKUP (P5412) < Rated Frequency (50 Hz)	0	1	0	1
PTOF4.Str.general		0	0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Str.general: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

PTOF4.Op

No.	Information				
5239	F4 TRIP (F4 TRIP)	0	0	1	1
	F4 PICKUP (P5412) < Rated Frequency (50 Hz)	0	1	0	1
PTOF4.Op.general		0	0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status Op.general: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

PTOF4.BIkV

No.	Information				
5214	Frequency Protection Under Voltage Blk (Freq UnderV Blk)	0	0	1	1
	F4 PICKUP (P5412) < Rated Frequency (50 Hz)	0	1	0	1
PTOF4.BIkV.stVal		0	0	1	0

device annunciation / setting: 1 - ON / TRUE IEC Status BlkV.stVal: 0 - FALSE
 0 - OFF / FALSE 1 - TRUE

3.10 Thermal Overload Protection (PTTR1)

PTTR1.Mod

No.	Information			
1513	Thermal Overload Protection ACTIVE (Th.Overload ACT)	x	x	x
1512	Thermal Overload Protection BLOCKED (Th.Overload BLK)	x	1	0
1511	Thermal Overload Protection OFF (Th.Overload OFF)	1	0	0
PTTR1.Mod.stVal		5	2	1

device annunciation:

1 - ON
0 - OFF
x - irrelevant

IEC Status Mod.stVal:

1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PTTR1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PTTR1.Health.stVal		3	1

device annunciation:

1 - ON
0 - OFF

IEC Status Health.stVal:

1 - OK
2 - WARNING
3 - ALARM

PTTR1.Str

No.	Information		
1517	Winding Overload (Winding O/L)	0	1
PTTR1.Str.general		0	1

device annunciation:

1 - ON
0 - OFF

IEC Status Str.general:

0 - FALSE
1 - TRUE

3.10 Thermal Overload Protection (PTTR1)

PTTR1.Op

No.	Information		
1521	Thermal Overload TRIP (ThOverload TRIP)	0	1
PTTR1.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PTTR1.AlmThm

No.	Information		
1516	Overload Alarm! Near Thermal Trip (O/L ⊖ Alarm)	0	1
PTTR1.AlmThm.general		0	1

device annunciation: 1 - ON IEC Status AlmThm.general: 0 - FALSE
0 - OFF 1 - TRUE

3.11 Earth Fault Protection (sensitive) (PHIZ1, PSDE1 PSDE2)

PHIZ1.Mod

No.	Information								
1212	Sensitive Earth fault prot. is ACTIVE (Sens. Earth ACT)	x	x	x	x	x	x	x	x
1230	Sensitive Earth fault detection BLOCKED (Sens. E BLOCKED)	x	1	x	x	x	x	x	0
170	VT Fuse Failure (alarm instantaneous) (VT FuseFail)	x	x	1	x	x	x	x	0
6509	>Failure: Feeder VT (>FAIL:FEEDER VT)	x	x	x	1	x	x	x	0
6510	>Failure: Busbar VT (>FAIL: BUS VT)	x	x	x	x	1	x	x	0
1211	Sensitive Earth fault protection is OFF (Sens. Earth OFF)	1	0	0	0	0	0	0	0
	Frequency range is exceeded	x	x	x	x	x	1	x	0
PHIZ1.Mod.stVal		5	2	2	2	2	2	2	1

device annunciation / setting: 1 - ON / TRUE
0 - OFF / FALSE
x - irrelevant

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

PHIZ1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PHIZ1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

PHIZ1.Str

No.	Information		
1215	$U_{e>/3U_0}$ Earth displacement voltage PU ($U_{e>/3U_0}$ Pickup)	0	1
PHIZ1.Str.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Str.general: 0 - FALSE
1 - TRUE

3.11 Earth Fault Protection (sensitive) (PHIZ1, PSDE1 PSDE2)

PHIZ1.Str.dirGeneral

No.	Information						
1276	Sensitive E fault in forward direction (Sens E Forward)	x	0	1	0	1	x
1277	Sensitive E fault in reverse direction (Sens E Reverse)	x	0	0	1	1	x
1278	Sensitive E fault direction undefined (Sens E undef.)	x	0	0	0	0	1
PHIZ1.Str.dirGeneral		0	0	1	2	3	0

device annunciation:
1 - ON
0 - OFF
x - irrelevant

IEC Status Str.dirGeneral:
0 - UNKNOWN
1 - FORWARD
2 - BACKWARD
3 - BOTH

PHIZ1.Str.phsA

No.	Information						
1215	Ue>/3U0 Earth displacement voltage PU (Ue>/3U0 Pickup)	0	x	1	1	1	1
1276	Sensitive E fault in forward direction (Sens E Forward)	x	x	1	0	1	x
1277	Sensitive E fault in reverse direction (Sens E Reverse)	x	x	0	1	1	x
1278	Sensitive E fault direction undefined (Sens E undef.)	x	x	0	0	x	1
1272	Sensitive Earth fault picked up in Ph L1 (Sens. E Ph L1)	x	0	1	1	1	1
PHIZ1.Str.phsA		0	0	1	1	1	1

device annunciation:
1 - ON
0 - OFF

IEC Status Str.phsA:
0 - FALSE
1 - TRUE

PHIZ1.Str.dirPhsA

No.	Information						
1215	Ue>/3U0 Earth displacement voltage PU (Ue>/3U0 Pickup)	0	x	1	1	1	1
1276	Sensitive E fault in forward direction (Sens E Forward)	x	x	1	0	1	x
1277	Sensitive Gnd fault in reverse direction (SensGnd Reverse)	x	x	0	1	1	x
1278	Sensitive Gnd fault direction undefined (SensGnd undef.)	x	x	0	0	x	1
1272	Sensitive Earth fault picked up in Ph L1 (Sens. E Ph L1)	x	0	1	1	1	1
PHIZ1.Str.dirPhsA		0	0	1	2	0	0

device annunciation:
1 - ON
0 - OFF
x - irrelevant

IEC Status Str.dirPhsA:
0 - UNKNOWN
1 - FORWARD
2 - BACKWARD

PHIZ1.Op

No.	Information		
1217	Ue>/3U0 Earth displacement voltage TRIP (Ue>/3U0 TRIP)	0	1
PHIZ1.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PSDE1.Mod

No.	Information				
1212	Sensitive Earth fault prot. is ACTIVE (Sens. Earth ACT)	x	x	x	x
1230	Sensitive Earth fault detection BLOCKED (Sens. E BLOCKED)	x	x	1	0
1211	Sensitive Earth fault protection is OFF (Sens. Earth OFF)	1	0	0	0
	Frequency range is exceeded	x	1	x	0
PSDE1.Mod.stVal		5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

PSDE1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PSDE1.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
0 - OFF 2 - WARNING
3 - ALARM

PSDE1.Str

No.	Information		
1224	IEE> Pickup (IEE> Pickup)	0	1
PSDE1.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
0 - OFF 1 - TRUE

PSDE1.Str.dirGeneral

No.	Information						
1224	IEE> Pickup (IEE> Pickup)	0	1	1	1	1	1
1276	Sensitive E fault in forward direction (Sens E Forward)	x	0	1	0	1	x
1277	Sensitive E fault in reverse direction (Sens E Reverse)	x	0	0	1	1	x
1278	Sensitive E fault direction undefined (Sens E undef.)	x	0	0	0	0	1
PSDE1.Str.dirGeneral		0	0	1	2	3	0

device annunciation: 1 - ON IEC Status Str.dirGeneral: 0 - UNKNOWN
0 - OFF 1 - FORWARD
x - irrelevant 2 - BACKWARD
3 - BOTH

PSDE1.Op

No.	Information		
1226	IEE> TRIP (IEE> TRIP)	0	1
PSDE1.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
0 - OFF 1 - TRUE

PSDE2.Mod

No.	Information				
1212	Sensitive Earth fault prot. is ACTIVE (Sens. Earth ACT)	x	x	x	x
1230	Sensitive Earth fault detection BLOCKED (Sens. E BLOCKED)	x	x	1	0
1211	Sensitive Earth fault protection is OFF (Sens. Earth OFF)	1	0	0	0
	Frequency range is exceeded	x	1	x	0
PSDE2.Mod.stVal		5	2	2	1

device annunciation / setting: 1 - ON / TRUE IEC Status Mod.stVal: 1 - ON
0 - OFF / FALSE 2 - BLOCKED
x - irrelevant 3 - TEST
4 - TEST/BLOCKED
5 - OFF

PSDE2.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
PSDE2.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

PSDE2.Str

No.	Information		
1221	IEE>> Pickup (IEE>> Pickup)	0	1
PSDE2.Str.general		0	1

device annunciation: 1 - ON IEC Status Str.general: 0 - FALSE
 0 - OFF 1 - TRUE

PSDE2.Str.dirGeneral

No.	Information						
1221	IEE>> Pickup (IEE>> Pickup)	0	1	1	1	1	1
1276	Sensitive E fault in forward direction (Sens E Forward)	x	0	1	0	1	x
1277	Sensitive E fault in reverse direction (Sens E Reverse)	x	0	0	1	1	x
1278	Sensitive E fault direction undefined (Sens E undef.)	x	0	0	0	0	1
PSDE2.Str.dirGeneral		0	0	1	2	3	0

device annunciation: 1 - ON IEC Status Str.dirGeneral: 0 - UNKNOWN
 0 - OFF 1 - FORWARD
 x - irrelevant 2 - BACKWARD
 3 - BOTH

PSDE2.Op

No.	Information		
1223	IEE>> TRIP (IEE>> TRIP)	0	1
PSDE2.Op.general		0	1

device annunciation: 1 - ON IEC Status Op.general: 0 - FALSE
 0 - OFF 1 - TRUE

3.12 Automatic Reclose Function (RREC1)

RREC1.Mod

No.	Information			
2782	Auto recloser is switched ON (Auto recl. ON)	x	x	x
2785	Auto-reclose is dynamically BLOCKED (AR DynBlock)	x	1	0
2781	Auto recloser is switched OFF (Auto recl. OFF)	1	0	0
RREC1.Mod.stVal		5	2	1

device annunciation: 1 - ON
0 - OFF
x - irrelevant

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

RREC1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
RREC1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

3.13 Circuit breaker failure protection 50BF(RBRF1)

RBRF1.Mod

No.	Information		
1451	Breaker failure is switched OFF (BkrFail OFF)	1	0
RBRF1.Mod.stVal		5	1

device annunciation: 1 - ON
0 - OFF

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

RBRF1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
RBRF1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

RBRF1.str

No.	Information				
1456	50BF (internal) PICKUP (50BF int Pickup)	0	0	1	1
1457	50BF (external) PICKUP (50BF ext Pickup)	0	1	0	1
RBRF1.str.general		0	1	1	1

device annunciation: 1 - ON
0 - OFF

IEC Status Rel.stVal: 0 - FALSE
1 - TRUE

RBRF1.OpEx

No.	Information		
1481	50BF (external) TRIP (50BF ext TRIP)	0	1
RBRF1.OpEx.general		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status OpEx.general 0 - FALSE
1 - TRUE

RBRF1.OpIn

No.	Information		
1480	50BF (internal TRIP (50BF int TRIP))	0	1
RBRF1.OpIn.general		0	1

device annunciation:

1 - ON
0 - OFF

IEC Status OpLn.general:

0 - FALSE
1 - TRUE

3.14 SYNC Function 1 (RSYN1)

RSYN1.Mod

No.	Information			
170.0051	Sync-group 1 is BLOCKED (Sy1 BLOCK)	0	1	x
170.2101	Sync-group 1 is switched OFF (Sy1 OFF)	0	0	1
RSYN1.Mod.stVal		1	2	5

device annunciation: 1 - ON
0 - OFF
x - irrelevant

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

RSYN1.Health

No.	Information				
170.0050	Synchronization Error (Sync. Error)	x	x	1	0
51	Device is Operational and Protecting (Device OK)	x	x	1	1
170.2096	Sync. Multiple selection of func-groups (Sync FG-Error)	1	x	0	0
170.2097	Sync. setting error (Sync Set-Error)	x	1	0	0
RSYN1.Health.stVal		3	3	2	1

device annunciation: 1 - ON
0 - OFF
x - irrelevant

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

RSYN1.Rel

No.	Information		
170.0049	Sync. Release of CLOSE Command (Sync. CloseRel)	0	1
RSYN1.Rel.stVal		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status Rel.stVal: 0 - FALSE
1 - TRUE

RSYN1.VInd

No.	Information		
170.2030	Sync. Voltage difference (Udiff) okay (Sync. Udiff ok)	0	1
RSYN1.VInd.stVal		1	0

device annunciation: 1 - ON IEC Status VInd.stVal: 0 - FALSE
0 - OFF 1 - TRUE

RSYN1.AngInd

No.	Information		
170.2032	Sync. Angle difference (adiff) okay (Sync. α ok)	0	1
RSYN1.AngInd.stVal		1	0

device annunciation: 1 - ON IEC Status AngInd.stVal: 0 - FALSE
0 - OFF 1 - TRUE

RSYN1.HzInd

No.	Information		
170.2031	Sync. Frequency difference (fdiff) okay (Sync. fdiff ok)	0	1
RSYN1.HzInd.stVal		1	0

device annunciation: 1 - ON IEC Status HzInd.stVal: 0 - FALSE
0 - OFF 1 - TRUE

RSYN1.SynPrg

No.	Information		
170.2022	Sync-group 1: measurement in progress (Sy1 measu.)	0	1
RSYN1.SynPrg.stVal		0	1

device annunciation: 1 - ON IEC Status SynPrg.stVal: 0 - FALSE
0 - OFF 1 - TRUE

RSYN1.DifVClc

No.	Information	Value		
170.2054	dU = (dU =)	RSYN1.DifVClc.mag.f	Measured value	Absolute value
		RSYN1.DifVClc.units.SIUnit	29	V (Volt)
		RSYN1.DifVClc.units.multiplier	3	Kilo

RSYN1.DifHzClc

No.	Information	Value		
170.2055	df = (df =)	RSYN1. DifHzClc.mag.f	Measured value	Absolute value
		RSYN1. DifHzClc.units.SIUnit	33	Hz
		RSYN1. DifHzClc.units.multiplier	0	1

RSYN1.DifAngClc

No.	Information	Value		
170.2056	dalpha = (dα =)	RSYN1. DifAngClc.mag.f	Measured value	Absolute value
		RSYN1. DifAngClc.units.SIUnit	9	° (Degree)
		RSYN1. DifAngClc.units.multiplier	0	1

3.15 Three-pole tripping CB Breaker (XCBR1)

XCBR1.Mod

No.	Information		
52	At Least 1 Protection Funct. is Active (ProtActive)	1	0
XCBR1.Mod.stVal		1	5

device annunciation: 1 - ON
0 - OFF

IEC Status Mod.stVal: 1 - ON
2 - BLOCKED
3 - TEST
4 - TEST/BLOCKED
5 - OFF

XCBR1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
XCBR1.Health.stVal		3	1

device annunciation: 1 - ON
0 - OFF
x - irrelevant

IEC Status Health.stVal: 1 - OK
2 - WARNING
3 - ALARM

XCBR1.Loc

No.	Information		
55	Reset Device (Reset Device)	1	0
XCBR1.Loc.stVal		1	0

device annunciation: 1 - ON
0 - OFF

IEC Status Loc.stVal: 0 - FALSE
1 - TRUE

XCBR1.OpCnt

No.	Information	Value		
	Number of TRIPs= (#of TRIPs=)	XCBR1.OpCnt.stVal	Metered value	Absolute value

3.15 Three-pole tripping CB Breaker (XCBR1)

XCBR1.Pos

No.	Information				
4601	>Breaker contact (OPEN, if bkr is open) (>Brk Aux NO)	0	1	0	1
4602	>Breaker contact(OPEN, if bkr is closed) (>Brk Aux NC)	0	0	1	1
XCBR1.Pos.stVal - if spontan information		11	01	10	11
XCBR1.Pos.stVal - if command is running		00	01	10	00

device annunciation: 1 - ON
0 - OFF

IEC Status Pos.stVal: 00 - INTERMEDIATE STATE
01 - OFF
10 - ON
11 - BAD STATE

XCBR1.BlkOpn

No.	Information		
55	Reset Device (Reset Device)	1	0
XCBR1.BlkOpn.stVal		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status BlkOpn.stVal: 0 - FALSE
1 - TRUE

XCBR1.BlkCls

No.	Information		
55	Reset Device (Reset Device)	1	0
XCBR1.BlkCls.stVal		0	1

device annunciation: 1 - ON
0 - OFF

IEC Status BlkCls.stVal: 0 - FALSE
1 - TRUE

XCBR1.CBOPCap

No.	Information	
XCBR1.CBOPCap.stVal		1

device annunciation: IEC Status CBOpCap.stVal: 1 - NONE

XCBR1.CirSpv

No.	Information		
6865	Failure Trip Circuit (FAIL: Trip cir.)	0	1
XCBR1.CirSpv.stVal		0	1

device annunciation: 1 - ON IEC Status CirSpv.stVal: 0 - FALSE
 0 - OFF 1 - TRUE

XCBR1.SumSwARs1

No.	Information	Value		
1021	Accumulation of interrupted current L1 ($\Sigma L1 =$)	XCBR1.SumSwARs1.actVal	Metered value	Current value of accumulated interrupted current = actVal \times pulsQty
		XCBR1.SumSwARs1.units.SIUnit	5	A (Ampere)
		XCBR1.SumSwARs1.units.multiplier	3	Kilo
		XCBR1.SumSwARs1.pulsQty	1.000000e-002	A / Metered value

XCBR1.SumSwARs2

No.	Information	Value		
1022	Accumulation of interrupted current L2 ($\Sigma L2 =$)	XCBR1.SumSwARs2.actVal	Metered value	Current value of accumulated interrupted current = actVal \times pulsQty
		XCBR1.SumSwARs2.units.SIUnit	5	A (Ampere)
		XCBR1.SumSwARs2.units.multiplier	3	Kilo
		XCBR1.SumSwARs2.pulsQty	1.000000e-002	A / Metered value

XCBR1.SumSwARs3

No.	Information	Value		
1023	Accumulation of interrupted current L3 ($\Sigma L3 =$)	XCBR1.SumSwARs3.actVal	Metered value	Current value of accumulated interrupted current = actVal \times pulsQty
		XCBR1.SumSwARs3.units.SIUnit	5	A (Ampere)
		XCBR1.SumSwARs3.units.multiplier	3	Kilo
		XCBR1.SumSwARs3.pulsQty	1.000000e-002	A / Metered value

MMXU1.TotW

No.	Information	Value		
641	P (active power) (P =)	MMXU1.TotW.mag.f	Measured value	Absolute value
		MMXU1.TotW.units.SIUnit	62	W (Watt)
		MMXU1.TotW.units.multiplier	6	Mega

MMXU1.TotVAr

No.	Information	Value		
642	Q (reactive power) (Q =)	MMXU1.TotVAr.mag.f	Measured value	Absolute value
		MMXU1.TotVAr.units.SIUnit	63	VAr
		MMXU1.TotVAr.units.multiplier	6	Mega

MMXU1.TotVA

No.	Information	Value		
645	S (apparent power) (S =)	MMXU1.TotVA.mag.f	Measured value	Absolute value
		MMXU1.TotVA.units.SIUnit	61	VA
		MMXU1.TotVA.units.multiplier	6	Mega

MMXU1.TotPF

No.	Information	Value		
901	Power Factor (PF =)	MMXU1.TotPF.mag.f	Measured value	Absolute value
		MMXU1.TotPF.units.SIUnit	1	NONE
		MMXU1.TotPF.units.multiplier	0	1

MMXU1.Hz

No.	Information	Value		
644	Frequency (Freq=)	MMXU1.Hz.mag.f	Measured value	Absolute value
		MMXU1.Hz.units.SIUnit	33	Hz
		MMXU1.Hz.units.multiplier	0	1

MMXU1.A

No.	Information	Value		
601	I L1 (IL1 =)	MMXU1.A.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU1.A.phsA.units.SIUnit	5	A (Ampere)
		MMXU1.A.phsA.units.multiplier	0	1

No.	Information	Value		
602	I L2 (IL2 =)	MMXU1.A.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU1.A.phsB.units.SIUnit	5	A (Ampere)
		MMXU1.A.phsB.units.multiplier	0	1

No.	Information	Value		
603	I L3 (IL3 =)	MMXU1.A.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU1.A.phsC.units.SIUnit	5	A (Ampere)
		MMXU1.A.phsC.units.multiplier	0	1

No.	Information	Value		
604	IE (IE =)	MMXU1.A.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU1.A.phsC.units.SIUnit	5	A (Ampere)
		MMXU1.A.phsC.units.multiplier	0	1

MMXU1.PPV

No.	Information	Value		
624	U L12 (UL12=)	MMXU1.PPV.phsAB.cVal.mag.f	Measured value	Absolute value
		MMXU1.PPV.phsAB.units.SIUnit	29	V (Volt)
		MMXU1.PPV.phsAB.units.multiplier	3	Kilo

No.	Information	Value		
625	U L23 (UL23=)	MMXU1.PPV.phsBC.cVal.mag.f	Measured value	Absolute value
		MMXU1.PPV.phsBC.units.SIUnit	29	V (Volt)
		MMXU1.PPV.phsBC.units.multiplier	3	Kilo

No.	Information	Value		
626	U L31 (UL31=)	MMXU1.PPV.phsCA.cVal.mag.f	Measured value	Absolute value
		MMXU1.PPV.phsCA.units.SIUnit	29	V (Volt)
		MMXU1.PPV.phsCA.units.multiplier	3	Kilo

MMXU1.PhV

No.	Information	Value		
621	U L1-E (UL1E=)	MMXU1.PhV.phsA.cVal.mag.f	Measured value	Absolute value
		MMXU1.PhV.phsA.units.SIUnit	29	V (Volt)
		MMXU1.PhV.phsA.units.multiplier	3	Kilo

No.	Information	Value		
622	U L2-E (UL2E=)	MMXU1.PhV.phsB.cVal.mag.f	Measured value	Absolute value
		MMXU1.PhV.phsB.units.SIUnit	29	V (Volt)
		MMXU1.PhV.phsB.units.multiplier	3	Kilo

No.	Information	Value		
623	U L3-E (UL3E=)	MMXU1.PhV.phsC.cVal.mag.f	Measured value	Absolute value
		MMXU1.PhV.phsC.units.SIUnit	29	V (Volt)
		MMXU1.PhV.phsC.units.multiplier	3	Kilo

No.	Information	Value		
627	Uen (Uen =)	MMXU1.PhV.neut.cVal.mag.f	Measured value	Absolute value
		MMXU1.PhV.neut.units.SIUnit	29	V (Volt)
		MMXU1.PhV.neut.units.multiplier	3	Kilo

MSQI1.SeqA

No.	Information	Value		
605	I1 (positive sequence) (I1 =)	MSQI1.SeqA.c1.cVal.mag.f	Measured value	Absolute value
		MSQI1.SeqA.c1.units.SIUnit	5	A (Ampere)
		MSQI1.SeqA.c1.units.multiplier	0	1

No.	Information	Value		
606	I2 (negative sequence) (I2 =)	MSQI1.SeqA.c2.cVal.mag.f	Measured value	Absolute value
		MSQI1.SeqA.c2.units.SIUnit	5	A (Ampere)
		MSQI1.SeqA.c2.units.multiplier	0	1

No.	Information	Value		
831	3I0 (zero sequence) (3I0 =)	MSQI1.SeqA.c3.cVal.mag.f	Measured value	Absolute value
		MSQI1.SeqA.c3.units.SIUnit	5	A (Ampere)
		MSQI1.SeqA.c3.units.multiplier	0	1

MSQI1.SeqV

No.	Information	Value		
629	U1 (positive sequence) (U1 =)	MSQI1.SeqV.c1.cVal.mag.f	Measured value	Absolute value
		MSQI1.SeqV.c1.units.SIUnit	29	V (Volt)
		MSQI1.SeqV.c1.units.multiplier	3	Kilo

No.	Information	Value		
630	U2 (negative sequence) (U2 =)	MSQI1.SeqV.c2.cVal.mag.f	Measured value	Absolute value
		MSQI1.SeqV.c2.units.SIUnit	29	V (Volt)
		MSQI1.SeqV.c2.units.multiplier	3	Kilo

No.	Information	Value		
832	U0 (zero sequence) (U0 =)	MSQI1.SeqV.c3.cVal.mag.f	Measured value	Absolute value
		MSQI1.SeqV.c3.units.SIUnit	29	V (Volt)
		MSQI1.SeqV.c3.units.multiplier	3	Kilo

No.	Information	Value		
632	U _{sync} (synchronism) (U _{sync} =)	MSQI1.SeqV.c3.cVal.mag.f	Measured value	Absolute value
		MSQI1.SeqV.c3.units.SIUnit	29	V (Volt)
		MSQI1.SeqV.c3.units.multiplier	3	Kilo

No.	Information	Value		
633	U _x (separate VT) (U _x =)	MSQI1.SeqV.c3.cVal.mag.f	Measured value	Absolute value
		MSQI1.SeqV.c3.units.SIUnit	29	V (Volt)
		MSQI1.SeqV.c3.units.multiplier	3	Kilo

3.17.3 Power Metering (MMTR1)

MMTR1.Mod

No.	Information	
55	Reset Device (Reset Device)	x
MMTR1.Mod.stVal		1

device annunciation: 1 - ON IEC Status Mod.stVal: 1 - ON
 0 - OFF 2 - BLOCKED
 x - irrelevant 3 - TEST
 4 - TEST/BLOCKED
 5 - OFF

MMTR1.Health

No.	Information		
51	Device is Operational and Protecting (Device OK)	0	1
MMTR1.Health.stVal		3	1

device annunciation: 1 - ON IEC Status Health.stVal: 1 - OK
 0 - OFF 2 - WARNING
 3 - ALARM

MMTR1.SupWh

No.	Information	Value		
924	Wp Forward (WpForward)	MMTR1.SupWh.actVal	Metered value	Current value of accumulated interrupted current = actVal × pulsQty
		MMTR1.SupWh.units.SIUnit	72	Wh
		MMTR1.SupWh.units.multiplier	6	Mega
		MMTR1.SupWh.pulsQty	3.464200e-005	Wh / Metered value

MMTR1.SupVArh

No.	Information	Value		
925	Wq Forward (WqForward)	MMTR1.SupVArh.actVal	Metered value	Current value of accumulated interrupted current = $actVal \times pulsQty$
		MMTR1.SupVArh.units.SIUnit	73	VArh
		MMTR1.SupVArh.units.multiplier	6	Mega
		MMTR1.SupVArh.pulsQty	3.464200e-005	VArh / Metered value

MMTR1.DmdWh

No.	Information	Value		
928	Wp Reverse (WpReverse)	MMTR1.DmdWh.actVal	Metered value	Current value of accumulated interrupted current = $actVal \times pulsQty$
		MMTR1.DmdWh.units.SIUnit	72	Wh
		MMTR1.DmdWh.units.multiplier	6	Mega
		MMTR1.DmdWh.pulsQty	3.464200e-005	Wh / Metered value

MMTR1.DmdVArh

No.	Information	Value		
929	Wq Reverse (WqReverse)	MMTR1.DmdVArh.actVal	Metered value	Current value of accumulated interrupted current = $actVal \times pulsQty$
		MMTR1.DmdVArh.units.SIUnit	73	VArh
		MMTR1.DmdVArh.units.multiplier	6	Mega
		MMTR1.DmdVArh.pulsQty	3.464200e-005	VArh / Metered value

Literature

- /1/ SIPROTEC 4 Ethernet Module EN 100 IEC 61850 Electrical Interface 100 MBit, Manual
C54000-G1176-C167
- /2/ SIPROTEC 4 System Description
E50417-H1176-C151
- /3/ SIPROTEC DIGSI, StartUP
E50417-G1176-C152
- /4/ DIGSI CFC, Manual
E50417-H1176-C098
- /5/ SIPROTEC SIGRA 4, Manual
E50417-H1176-C1100-C070
- /6/ SIPROTEC Multi-Functional Protective Relay with Local Control 7SJ68, Manual
C53000-G1176-C171

Index

C

CALH1 32, 40, 51
ErrBoard1 52
GrAlm 51
GrWrn 51
Health 51
Mod 51

D

DOI 31

F

Function parameters 32
Functional Scope
7SJ68 33

L

LD
CTRL (Control) 32, 40
DR (Disturbance Recorder) 39
EXT (Extended) 40
Logical Device 30
MEAS (Measurement) 32, 39
PROT (Protection) 32, 37
LLN0 30, 32, 37, 39, 40
Beh 41, 43, 44
Health 41, 43, 45
Mod 43, 44
OpTmh 42, 44, 45
Logical Node 31, 32, 33, 37
LPHD1 30, 32, 38, 39, 40, 50
DevStr 50
PhyHealth 50
Proxy 50

M

MMTR1 32, 39, 141
DmdVArh 142
DmdWh 142
Health 141
Mod 141
SupVArh 142
SupWh 141
MMXU1 32, 39, 133
A 135, 138
Health 133
Hz 135
Mod 133

PhV 137
PPV 136
TotPF 134
TotVA 134
TotVAr 134
TotW 134
MSQI1 32, 39, 138
Health 138
Mod 138
SeqA 139
SeqV 140

P

PHIZ1 34, 38, 113
Health 113
Mod 113
Op 117
Str.dirGeneral 114
Str.dirPhsA 114
Str.dirPhsB 115
Str.dirPhsC 116
Str.general 113
Str.phsA 114
Str.phsB 115
Str.phsC 116
PMLJ1 35, 38, 93
ChgSet 94
Health 93
LodJamAlm 94
Mod 93
Op 94
Str 94
PMRI1 35, 38, 92
Health 92
Mod 92
Op 92
StrInhTmm 92
PMSS1 35, 38, 90
Health 90
Mod 90
Op 91
Str 91
PSDE1 34, 38, 117
Health 117
Mod 117
Op 118
Str.dirGeneral 118
Str.general 117

PSDE2 34, 38, 118
 Health 119
 Mod 118
 Op 119
 Str.dirGeneral 119
 Str.general 119

PTOC1 33, 37, 57
 ChgSet 58
 Health 58
 Mod 57
 Op 58
 Str 58

PTOC10 34, 37, 68
 ChgSet 69
 Health 68
 Mod 68
 Op 69
 Str 68

PTOC11 34, 37, 69
 ChgSet 70
 Health 69
 Mod 69
 Op 70
 Str 70

PTOC12 34, 37, 72
 ChgSet 73
 Health 72
 Mod 72
 Op 73
 Str 72

PTOC13 34, 37, 73
 ChgSet 74
 Health 73
 Mod 73
 Op 74
 Str 74

PTOC14 35, 37, 86
 Health 86
 Mod 86
 Op 87
 Str 86

PTOC15 35, 37, 87
 Health 87
 Mod 87
 Op 88
 Str 87

PTOC18 33, 37
 Health 59
 Mod 59
 Op 60
 Str 59

PTOC2 33, 37, 63
 ChgSet 64
 Health 64
 Mod 63
 Op 64
 Str 64

PTOC3 34, 37, 70
 ChgSet 71
 Health 71
 Mod 70
 Op 71
 Str 71

PTOC4 34, 37, 74
 ChgSet 75
 Health 75
 Mod 74
 Op 75
 Str 75

PTOC5 35, 37, 88
 Health 88
 Mod 88
 Op 89
 Str 89

PTOC6 33, 37, 55
 ChgSet 56
 Health 55
 Mod 55
 Op 56
 Str 55

PTOC7 33, 37, 56
 ChgSet 57
 Health 56
 Mod 56
 Op 57
 Str 57

PTOC8 33, 37
 ChgSet 62
 Health 61
 Mod 61
 Op 62
 Str 61

PTOC9 33, 37, 62
 ChgSet 63
 Health 62
 Mod 62
 Op 63
 Str 63

PTOF1 35, 38, 103
 BlkV 104
 Health 103
 Mod 103, 105
 Op 104
 Str 104

PTOF2 105
 BlkV 106
 Health 105
 Mod 105
 Op 106
 Str 106

PTOF3 107
 BlkV 108
 Health 107
 Mod 107
 Op 108
 Str 108

- PTOF4 109
 - BlkV 110
 - Health 109
 - Mod 109
 - Op 110
 - Str 110
 - PTOV1 35, 37, 83
 - Health 83
 - Mod 83
 - Op 84
 - Str 83
 - PTOV2 35, 84
 - Health 84
 - Mod 84
 - Op 85
 - Str 85
 - PTRC1 32, 37, 131
 - FinTr 132
 - Health 131
 - Mod 131
 - Str 131
 - Tr 132
 - PTRC2 33, 37, 65
 - Health 65
 - Mod 65
 - Op 67
 - Str 65
 - Str.dirGeneral 65
 - Str.dirNeut 67
 - Str.dirPhsA 66
 - Str.dirPhsB 66
 - Str.dirPhsC 67
 - Str.neut 67, 79
 - Str.phsA 66
 - Str.phsB 66, 67, 78, 79
 - Str.phsC 66, 67, 78, 79
 - PTRC3 34, 37, 76
 - Health 76
 - Mod 76
 - Op 79
 - Str 76
 - Str.dirGeneral 77
 - Str.dirNeut 79
 - Str.dirPhsA 77
 - Str.dirPhsB 78
 - Str.dirPhsC 78
 - Str.neut 79
 - Str.phsA 77
 - Str.phsB 78
 - Str.phsC 78
 - PTTR1 35, 38, 111
 - AlmThm 112
 - Health 111
 - Mod 111
 - Str 111
 - Tr 112
 - PTUF1 35, 38, 95
 - BlkV 96
 - Health 95
 - Mod 95
 - Op 96
 - Str 96
 - PTUF2 97
 - BlkV 98
 - Health 97
 - Mod 97
 - Op 98
 - Str 98
 - PTUF3 99
 - BlkV 100
 - Health 99
 - Mod 99
 - Op 100
 - Str 100
 - PTUF4 101
 - BlkV 102
 - Health 101
 - Mod 101
 - Op 102
 - Str 102
 - PTUV1 35, 37, 80
 - Health 80
 - Mod 80
 - Op 81
 - Str 80
 - PTUV2 35, 81
 - Health 81
 - Mod 81
 - Op 82
 - Str 82
 - PVOC1
 - Mod 67
- R**
- RDRE1 33, 39, 53
 - FltNum 54
 - GriFltNum 54
 - Health 53
 - Mod 53
 - RcdMade 53, 54
 - RcdStr 54
 - RREC1 35, 38, 120
 - AutoRecSt 121
 - Health 120
 - Mod 120
 - Op 121
 - RSYN1 35, 40, 122, 124
 - Anglnd 125
 - DifAngClc 126
 - DifHzClc 126
 - DifVClc 126
 - Health 124
 - Hzlnd 125
 - Mod 124
 - Rel 124
 - SynPrg 125
 - Vlnd 125

X

XCBR1 32, 37, 127
 BlkCls 128
 BlkOpn 128
 CBOpCap 128
 CirSpv 129
 Health 127
 Loc 127
 Mod 127
 OpCnt 127
 Pos 128
 SumSwARs1 130
 SumSwARs2 130
 SumSwARs3 130