
Water Specialist WS2H and WS3 Control Valve Drawings and Service Manual



HYDROCARBONS SUCH AS KEROSENE, BENZENE, GASOLINE, ETC., MAY DAMAGE PRODUCTS THAT CONTAIN O-RINGS OR PLASTIC COMPONENTS. EXPOSURE TO SUCH HYDROCARBONS MAY CAUSE THE PRODUCTS TO LEAK. DO NOT USE THE PRODUCT(S) CONTAINED IN THIS DOCUMENT ON WATER SUPPLIES THAT CONTAIN HYDROCARBONS SUCH AS KEROSENE, BENZENE, GASOLINE, ETC.

Table of Contents

General Specifications and Pre-Installation Checklist	4
Software and Power Supply Compatibility	5
Installation Instructions	6
Installation Summary	9
WS2H Control Valve Cycle Positions	10
WS3 Control Valve Cycle Positions	13
Front Cover and Drive Assembly	16
WS2H Drive Cap Asy, Downflow Piston, Regenerant Piston, Spacer Stack Asy,	
Drive Back Plate and Main Body, and Meter	17
WS3 Drive Cap Asy, Downflow Piston, Regenerant Piston, Spacer Stack Asy,	
Drive Back Plate, Main Body	18
V3075 and V3075BSPT WS3 3" Meter Assembly	19
Brine Valve Body and Injector Components	20
Base Tank Adapters	21
V3158-04 2" Drain Elbow ¾" Male NPT without silencer	22
V3008-05 2" Drain Fitting 1" Straight Male NPT without silencer	
V3079 and V3080 NPT and BSPT 1" and 1.5" DLFC	24
V3051 and V3051 BSPT 2" DLFC	
V3764 and V3764BSPT 3" DLFC ASY	26
V3063 and V3063BSPT 2" Motorized Alternating Valve	27
V3076 and V3076BSPT 2" Motorized Alternating Valve Rev2	
V3098 and V3098BSPT 2" No Hard Water Bypass MxF	29
V3083 and V3083BSPT 3" Motorized Alternating Valve	
V3099 and V3099BSPT 3" No Hard Water Bypass MxF	31
V3060 and V3060BSPT 2H Bypass Valve Auto and Manual	32
V3053 WS2H 2.5" Groove Lock Clamp	33
Error Codes	34
Trouble Shooting Guide	35
Standard Injector Graphs	43

Table 1 General Specifications and Pre-Installation Checklist

Minimum/Maximum Operating Pressures	20 psi (138 kPa) -125 psi (862 kPa	n)	
Minimum/Maximum Operating Temperatures	40°F (4°C) – 110°F (43°C)		
Power Adapter: Supply Voltage Supply Frequency Output Voltage Output Current	U.S. 120V AC 60 Hz 20V or 24V AC 800 mA	see Table 2	International 230V AC 50 Hz 20V or 24V AC 1000 mA
	are on the PC board, the motor, or thain power supply is by unplugging the		
Service flow rate	WS2H Valve: 125 gpm (473 lpm, WS3 Valve: 250 gpm (946 lpm, 56	28.4 m ³ /h) @ 1	5 psig (103 kPa) drop
Backwash flow rate	WS2H Valve: 125 gpm (473 lpm, WS3 Valve: 220 gpm (833 lpm, 5		
CV Service	WS2H Valve: 32.3 WS3 Valve: 64.6		
CV Backwash	WS2H Valve: 25.0 WS3 Valve: 44.0		
Meter: Accuracy Flow Range	WS2H Valve: Internal Meter ± 5 % 1.5 – 125 gpm (5.7 – 473 lpm)		WS3 Valve: Optional External
Regenerant Refill Rate	WS2H and WS3 Valves: Variable (8.33 lpm)	- Shipped from	Factory with 2.2 gpm
Injectors	WS2H & WS3 Valves: See Injector	or Graphs V301	0-2A through 2H
Brine Line Adapters Included	1" Male NPT Elbow & 3/4" x 1" So	olvent Weld Elb	oow
Inlet, Outlet and Drain Line Openings	WS2H Valve: 2" Female NPT or I WS3 Valve: 3" Female NPT or BS		
Distributor Tube Opening: WS2H Valve WS3 Valve	Female NPT Inlet & Outlet 2.375" OD (2.0" NPS) 3.5" OD (3" NPS)		Female BSPT Inlet & Outlet 63 mm OD 90 mm OD
Tank Connection: WS2H Valve WS3 Valve	4"-8UN, 6" Flange, Side Mount (2") Flange or Side Mount (3") Fema		
Shipping Weight	WS2H Valve with Meter: 50 lbs (22.7 kg) WS3 Valve: 57 lbs (25.9 kg) Meter Sold Separately		
PC Board Memory	Nonvolatile EEPROM (electrically erasable programmable read only memory)		
Compatible with the following typical concentrations of regenerants/chemicals	Sodium chloride, potassium chloric chlorine and chloramines	de, potassium j	permanganate, sodium bisulfite,

Table 2
Software and Power Supply Compatibility

Software	Version		Power Supply
V3242-01BOARD Main Board ¹	V3243-01BOARD System Board	Output Voltage	Part # and Description
114.10	1.02		
114.11	1.03		
115.17			
115.25	1.07 or 1.08	24 VAC	V3461 ² WS2H/3 AC ADAPTER V3461EU WS2H/3 AC ADAPTER EU
200.01		24 VAC	V3461UK WS2H/3 AC ADAPTER EU V3461UK WS2H/3 AC ADAPTER UK
215.02			
215.03	1.11 or 1.13		
215.04			
215 10			V3461 ² WS2H/3 AC ADAPTER V3461EU WS2H/3 AC ADAPTER EU V3461UK WS2H/3 AC ADAPTER UK
215.10	1.11 or 1.13	20 VAC ³	V3461-01 WS2H/3 AC ADAPTER 20V V3461EU-01 WS2H/3 AC ADAPTER EU 20V V3461UK-01 WS2H/3 AC ADAPTER UK 20V


¹ It is recommended to maintain one version throughout a system.

² Replacement V3461 power supplies have screw terminals and are shipped less a cord. Use cord from existing power supply to connect to the screw terminals.


³ V3461EU-01 and V3461UK-01 will not be available for sale until August 2010.

Installation:

WS2H CONTROL VALVE TOP VIEW



WS3 CONTROL VALVE TOP VIEW



DISTRIBUTOR PIPE HEIGHT:

Recommended distributor pipe height for top mounted WS2H Control valves is $2\frac{1}{4}$ " – $2\frac{1}{2}$ " above the top of tank for fiberglass tanks. Please verify distributor pipe and pilot o-ring engagement and make proper allowances for tank expansion.

Recommended distributor pipe height for top mounted WS3 Control valves is $2\frac{1}{2}$ " above the top of tank for fiberglass tanks. Please verify distributor pipe and pilot o-ring engagement and make proper allowances for tank expansion.

GENERAL INSTALLATION & SERVICE WARNINGS

The control valve and fittings are not designed to support the weight of the system or the plumbing.

Do not use Vaseline, oils, other hydrocarbon lubricants or spray silicone anywhere. A silicone lubricant may be used on black o-rings but is not necessary.

HYDROCARBONS SUCH AS KEROSENE, BENZENE, GASOLINE, ETC., MAY DAMAGE PRODUCTS THAT CONTAIN O-RINGS OR PLASTIC COMPONENTS. EXPOSURE TO SUCH HYDROCARBONS MAY CAUSE THE PRODUCTS TO LEAK. DO NOT USE THE PRODUCT(S) CONTAINED IN THIS DOCUMENT ON WATER SUPPLIES THAT CONTAIN HYDROCARBONS SUCH AS KEROSENE, BENZENE, GASOLINE, ETC.

THIS WATER METER SHOULD NOT BE USED AS THE PRIMARY MONITORING DEVICE FOR CRITICAL OR HEALTH EFFECT APPLICATIONS

Do not use pipe dope or other sealants on threads. Teflon tape is recommended to be used on all threads.

Use of pipe dope may break down the plastics in the control valve.



When servicing the valve, water may leak from the valve. Water from the valve may create a slip hazard. Clean up water spills.



Disconnect from electrical power prior to servicing the valve.

Allow two feet of clearance to service WS2H and WS3 valves.

The valve will withstand transportation and storage temperatures of -13 °F (-25 °C) to 131 °F (55 °C) and for short periods up to 158 °F (70 °C). If valve has been exposed to freezing conditions let valve warm up to room temperature before running water through it. The valve has been packaged to prevent damage from the effects of normal humidity, vibration and shock.

SITE REQUIREMENTS:

- The plug-in Power adapter is for dry locations only
- The tanks should be on a firm, level surface
- Electrical: Use an uninterrupted outlet installed within 15 feet (4.57 meters) of the water conditioner.

All plumbing should be done in accordance with local codes.

- 1. Locate the water conditioner so the distance between the drain and the water conditioner is as short as possible.
- 2. Regenerant tanks that must be refilled should be located where they are easily accessible. It is recommended a safety brine valve be used.
- 3. Do not install any water conditioner with less than 10 feet of piping between its outlet and the inlet of a water heater.
- 4. Do not locate unit where it or its connections (including the drain and overflow lines) will ever be subjected to room temperatures under 40° F (4° C).
- 5. The use of resin cleaners in a non-vented enclosure is not recommended.

- **6. INLET/OUTLET PLUMBING:** Connect to a supply line downstream of outdoor spigots. Install inlet and outlet shutoff valves for the control valve; see top view drawings for control valve inlet and outlet locations. Installation of a three valve bypass is recommended. If using plastic fittings ground the water conditioner per local electric codes. If an external water meter is used, install the water meter on the outlet side of the control valve. It is recommended that the meter assembly be installed horizontally or in a downflow vertical position to reduce turbine bearing wear. The turbine assembly may be orientated in any direction. Remove the cover and drive bracket and thread the water meter cord through the hole in the back plate. Reinstall the drive bracket. Weave the cord through the strain relief on the backplate and connect the end to the three prong connector labeled FLOW on the printed circuit board. Re-install the cover.
- **7. Drain:** Verify that the drain can handle the backwash rate of the water conditioner. Correctly size the drain line and install an appropriately sized drain line flow control. For WS2H and WS3 valves a drain line flow control are NOT supplied with a valve. For WS2H valves the drain outlet is 2" Female NPT or BSPT threads or 2.5" groove lock connection. For WS3 valves the drain port is 3" Female NPT or BSPT, no groove lock connection. If using copper, solder joints near the drain must be done prior to connecting the drain line flow control fitting. Leave at least 6" (152.4 mm) between the drain line flow control fitting and solder joints to prevent heat from damaging the flow control. Avoid elevating the drain line above the control valve where possible. Discharge the drain line through an air gap to a receptacle in accordance with local plumbing codes.

IMPORTANT: Never insert a drain line directly into a drain, sewer line, or trap. Always allow an air gap between the drain line and the receptacle to prevent back siphonage.

8. Regeneration: If the control valve is to be used to regenerate the water conditioner with brine (saturated salt solution) or other regenerants. The WS2H and WS3 control valves regenerant port has a 1" 90° Male NPT threaded outlet connection that swivels 360°. To ensure acceptable operation of the injectors use 1" pipe to connect to the brine tank. Smaller drain line flow controls may result in the injector performance not matching the injector graphs. Use an adequately size drain line flow control to ensure proper brine draw. See Table 3 for injector order number and size for tank diameter. An overflow drain line from the regenerant tank that discharges into an acceptable drain is recommended, as a regenerant overflow could damage furnishings or the building structure. Connect a line to the overflow fitting on the regenerant tank. If an overflow fitting is not already installed on the regenerant tank, install one. Do not elevate the overflow drain line. Discharge the overflow drain line through an air gap to a receptacle in accordance with local plumbing codes.

Table 3
WS2H and WS3 Valve Injector Order Information

Injector Order Number	Typical Tank Diameter ⁴
V3010-2A	18"
V3010-2B	21"
V3010-2C	24"
V3010-2D	30"
V3010-2E	36"
V3010-2F	42"
V3010-2G	48"
V3010-2H	63"

All injector graphs are at the end of this manual for total, slow rinse and draw flow rates.

⁴Actual injector size used may vary depending on the design and application of the system. Injectors in table are sized for a typical downflow softener using standard mesh synthetic cation exchange media regenerating with sodium chloride.


- 9. Power Adapter: If a Power Adapter is already connected to the control valve, plug the Power Adapter into an uninterrupted outlet. If the Power Adapter cord has not yet been connected to the control valve, remove the control valve cover and the drive bracket and thread Power Adapter cord through the hole in the back plate. Reinstall the drive bracket. Weave the cord through the strain relief on the backplate and connect the end to the four pin connector on the printed circuit board labeled POWER. Reinstall the cover. Plug the Power Adapter into an uninterrupted outlet.
- 10. Program the control valve: It is very important to program the control valve for the type of system (e.g. water softener of filter) and the end use application. Check the program used prior to testing the system.


Installation Summary

Installation Date:	
Installation Location:	
Installer(s):	
Phone Number:	
Application Type: (Softener) Other:	
Water Source:	
Water Test Results:	
Hardness: Iron:pH:_	
Other:	
Misc:	
Service Flow Rates: min max	
Tank Size: Diameter Height:	
Resin or Media Volume:	
Resin or Media Type:	
Capacity:	
Salt or Fill Setting per Regeneration:	
Brine Tank Size:	
Control Valve Configuration:	
Valve Type:	
Valve Part Number:	
Valve Serial Number:	
Regenerant Refill Control:	
Injector Size:	
Drain Line Flow Control:	gpm/lpm


WS2H Control Valve Cycle Positions

SERVICE







DRAW




SLOW RINSE




RINSE




SOFT WATER REFILL




WS3 Control Valve Cycle Positions SERVICE




BACKWASH




DRAW




SLOW RINSE



RINSE




SOFT WATER REFILL



Front Cover and Drive Assembly

Drawing No.	Order No.	Description	Quantity
1	V3068	WS2H/3 POD FRNT-BK COVERS	1
1a	V3082	WS2H/3 POD ASY COMPLETE W/BOARD*	Optional
2	V3241-01 BOARD	WS2H/3 PC BOARD DISPLAY	1
3	V3248	WS2H/3 CABLE DISPLAY POD	1
4	V3242-01BOARD	WS2H/3 PC BOARD VALVE	1
5	V3224-01R	WS2H/3 COVER ASY PLATINUM	1
6	V3107-01	WS1 MOTOR ASY	1
7	V3226-01	WS2H/3 DRIVE BRACKET ASY	1
8	V3110	WS1 DRIVE GEAR 12X36	3
9	V3109	WS1 DRIVE GEAR COVER	1
	V3461	WS2H/3 AC ADAPTER (shipped less cord)	1
	V3461EU	WS2H/3 AC ADAPTER EU	See Table 2
Not Shown	V3461UK	WS2H/3 AC ADAPTER UK	Software and
Not Shown	V3461-01	WS2H/3 AC ADAPTER 20VAC	Power Supply Compatibility
	V3461EU-01	WS2H/3 AC ADAPTER EU 20VAC	for option
	V3461UK-01	WS2H/3 AC ADAPTER UK 20VAC	selection
10	V3243-01BOARD	WS2H/3 PC BOARD SYSTEM	Optional
Not Shown	V3475-12	WS2H/3 SYS CONNECT CORD 12 FT RED	Optional
Not Shown	V3475-24	WS2H/3 SYS CONNECT CORD 24 FT BL	Optional
Not Shown	V3475-36	WS2H/3 SYS CONNECT CORD 36 FT YEL	Optional

^{*}Contains items 1,2 & 3 Pod Assembly, PC Board and Cable



WS2H Drive Cap Assembly, Downflow Piston, Regenerant Piston, Spacer Stack Assembly, Drive Back Plate, Main Body and Meter


Drawing No.	Order No.	Description	Quantity
1	V3275	WS2H/3 SCREW BTNSKT HD SS3/8-16X2-1/4 (7/32" hex allen wrench required)	4
2	V3291	WS2H/3 WASHER SS 3/8	4
3	V3225	WS2H/3 BACK PLATE	1
4	V3066	WS2H DRIVE ASY	1
5	V3289	O-RING 344	1
6	V3204-01	WS2H PISTON	1
7	V3238-01***	WS2H/3 BRINE PISTON	1
8	V3065	WS2H STACK ASY	1
Not Shown	V3468	WS2H/3 PLUG 1/4 HEX NPT (included when ordering V3201-03)	2
Not Snown	V3465	WS2H/3 PLUG 1/4 HEX BSPT (included when ordering V3201BSPT-03)	2
	V3201-03	WS2H BODY W/V3468 PLUG	1
9	V3201BSPT-03	WS2H BSPT BODY W/V3465 PLUG	1
10	V3632*	WS1.5/2/3 METER RETAINING CLIP	1
11	V3003-02	WS1.5/2H METER COMMERCIAL ASY	1
12	V3118-03	WS1.5/2 TURBINE ASY	1
13	V3105	O-RING 215	1
14	V3501	WS1.5/2 TURBINE CLIP	1
15	V3279	O-RING 346	1
16	V3280	O-RING 332 FOR VALVE BODIES WITH NPT THREADS	1
16	V3452	O-RING 230 FOR VALVE BODIES WITH BSPT THREADS	1
17	V3054**	WS2H 4 IN BASE CLAMP ASY	1
18	V3276	WS2H/3 BOLT HEX SS 5/16-18X1-3/4	1
19	V3269	WS2H/3 NUT 5/16-18 SS HEX	1
Not Shown	D1300-01	TOP BAFFLE DFSR CLACK 2/63MM	1

^{*} In 2008 a modification was made to Meter Housings to use V3632 WS1.5/2/3 Meter Retaining Clip. Do not use V3632 on old style housings which have holes through the castings to accept the U-shaped V3223 WS2 Meter Clip.

THIS WATER METER SHOULD NOT BE USED AS THE PRIMARY MONITORING DEVICE FOR CRITICAL OR HEALTH EFFECT APPLICATIONS.

Service or replace the turbine by:

- 1. Turn the bypass for the system off and relieve the pressure on the system.
- 2. Press downward on the remote meter assembly to relieve tension on the retaining clip V3632 (or the U-shaped V3223 WS2 Meter Clip). Remove the clip and take the meter assembly out of the housing.
- 3. Remove the bend from the two exposed tips of the retaining clip V3501 and remove clip.
- $4. \ Service \ or \ replace \ the \ V3118-03 \ WS15/2 \ Turbine \ Assembly \ and \ place \ it \ back \ in \ the \ turbine \ shaft.$
- 5. Insert the V3501 WS15/2 Turbine Clip and re-bend the exposed ends of the clip. The V3118-03 turbine has a groove to line up with the V3501 WS15/2 Turbine Clip.
- 6. Insert meter assembly back into the meter housing.
- 7. Re-install the meter retaining clip V3632 as shown below (or the U-shaped V3223 WS2 Meter Clip).
- 8. Open the bypass for the system slowly to bring back into service and check to be sure you have no water leaks.



^{**}V3054 WS2 4 IN BASE CLAMP ASY includes a V3276 WS2 BOLT HEX SS 5/16-18X1-3/4 and V3269 WS2 NUT 5/16-18 SS HEX.


^{***}V3238-01 Brine Piston is used for Backwash Only valves.

WS3 Drive Cap Assembly, Downflow Piston, Regenerant Piston, Spacer Stack Assembly, Drive Back Plate and Main Body

Drawing No.	Order No.	Description	Quantity
1	V3274	WS2H/3 SCREW BTNSKT HD SS3/8-16X2	4
1		(7/32" hex allen wrench required)	4
2	V3291	WS2H/3 WASHER SS 3/8	4
3	V3225	WS2H/3 BACK PLATE	1
4	V3093	WS3 DRIVE ASY	1
5	V3289	O-RING 344	1
6	V3666-01	WS3 PISTON	1
7	V3238-01**	WS2H/3 BRINE PISTON	1
8	V3092	WS3 STACK ASY	1
Nat Charm	V3468	WS2H/3 PLUG 1/4 HEX NPT (included when ordering V3667-03)	2
Not Shown	V3465	WS2H/3 PLUG 1/4 HEX BSPT (included when ordering V3667BSPT-03)	2
9	V3667-03	WS3 BODY W/V3468 PLUG	1
9	V3667BSPT-03	WS3 BSPT BODY W/V3465 PLUG	1
10	V3763	O-RING 361	1
11	V3762	O-RING 341 FOR VALVE BODIES WITH NPT OR BSPT THREADS	1
12	V3091*	WS3 BASE CLAMP ASY	1
13	V3276	WS2H/3 BOLT HEX SS 5/16-18X1-3/4	1
14	V3269	WS2H/3 NUT 5/16-18 SS HEX	1
Not Shown	V3672	TOP BAFFLE DFSR CLACK 3/90MM	1


^{*}V3091 WS3 BASE CLAMP ASY includes a V3276 WS2H/3 BOLT HEX SS 5/16-18X1-3/4 and V3269 WS2H/3 NUT 5/16-18 SS HEX.

^{**}V3238-01 Brine Piston is used for Backwash Only valves.



Install V3672 upper diffuser (not shown) when using the 6" Flange Base (V3090) ———

V3095 WS3 Meter NPT MxF Assembly and V3095BSPT-15 WS3 Meter BSPT MxF Assembly V3095-15 WS3 Meter ASY NPT MxF 15FT and V3095BSPT-15 WS3 Meter ASY BSPT MxF 15FT



Drawing No.	Order No.	Description	V3095	V3095BSPT	V3095-15	V3095BSPT-15
	V4039	WS3 METER COMMERCIAL ASY 4 FT CORD	1	1		
1	V 4039	(includes V3118-03, V3105 & V3501)	ı	'		
'	V3221	WS REMOTE METER ASY 15 FT CORD			1	1
	V 322 I	(includes V3118-03, V3105 & V3501)			'	'
2	V3118-03	WS15/2 TURBINE ASY	1	1	1	1
3	V3105	O-RING 215	1	1	1	1
4	V3501	WS15/2 TURBINE CLIP	1	1	1	1
	V3844-01	WS3 METER NPT MxF HOUSING	1		1	
5	V3844BSPT-01	WS3 METER BSPT MxF HOUSING		1		1
6	V3632	WS1.5/2/3 METER RETAINING CLIP	1	1	1	1
Not shown	V3602	WS3 FLOW STRAIGHTENER (located inside meter housing)	1	1	1	1

Installation

Installation of the V3075 WS3 Meter NPT Assembly can be accomplished with 3" NPT pipe. For V3075BSPT WS3 Meter BSPT Assembly use 3" BSPT pipe. It is recommended that the meter assembly be installed horizontally or in a downflow vertical position to reduce turbine bearing wear.

WHEN INSTALLING THE METER, MAKE SURE THE ARROW ON THE METER BODY IS GOING THE SAME DIRECTION AS THE WATER FLOW. THE METER CAN BE INSTALLED IN HORIZONTAL OR VERTICAL APPLICATIONS.

THIS WATER METER SHOULD NOT BE USED AS THE PRIMARY MONITORING DEVICE FOR CRITICAL OR HEALTH EFFECT APPLICATIONS.

OPERATING PRESSURES: 20 PSI MINIMUM / 125 PSI MAXIMUM OPERATING TEMPERATURES: 40°F MINIMUM / 110°F MAXIMUM

The 22 gauge wire crimp terminals are Molex Series 41572 or 40445. The housing connector is Molex Series 2695 White Housing, P/N 22-01-3037.


The housing connector diagram shows the proper installation of the RED, WHITE and BLACK wires for CLACK CORPORATION CONTROL VALVES. When connecting to other manufacturers control valves please contact your original equipment manufacturer for proper wiring instructions.

Wiring:

- The meter must be supplied with a DC voltage between 4 and 24 volts
- The RED wire is positive
- The BLACK wire is negative
- The WHITE wire is the meter output


Calibration:

- For WS2H valves select 8 pulses if valve software records in gallons and 2.1 if valve software records in liters.
- The calibration factor for the WS3 Meter Assembly is 8 pulses per gallon when used on applications other than WS2H valves.
- The meter flow range is $3.5-350~\text{gpm} \pm 5\%$ (output signal 0.46~Hz to 46.6~Hz). NOTE: Not all flow monitors will register accurately at either the low or high flow range of this meter. Contact your flow monitor manufacturer for limitations.
- Pressure drop at 350 gpm is 7.3 PSI




WS2H and WS3 Brine Valve Body and Injector Components

D	Order No.	Description	Qua	ntity
Drawing No.	Order No.	Description	WS2H	WS3
1	V3237-01	WS2H/3 SOFTFILL TUBE ASY	1	1
2a	V3236-04*	WS2H INJECTOR TUBE ASY FOR A THRU H	1	
2b	V3670-01**	WS3 INJECTOR TUBE DOWNFLOW ASY		1
3	V3289	O-RING 344	1	1
4	V3067	WS2H/3 BRINE BODY ASY	1	1
5	V3477	WS2H/3 INJECTOR CAP	1	1
6	V3152	O-RING 135	1	1
7	V3275	WS2H/3 SCREW BSHD SS 3/8-16X2-1/4 (7/32" hex allen wrench required)	4	4
8	V3291	WS2H/3 WASHER SS 3/8	4	4
9	V3162-022***	WS1 DLFC 022 FOR 3/4	1	1
10	V3231	WS2H/3 REFILL FLOW CNTRL RETAINER	1	1
11	V3277	O-RING 211	1	1
12	V3105	O-RING 215	1	1
13	V3150	WS1 SPLIT RING	1	1
14	V3151	WS1 NUT 1 QC	1	1
15	V3149	WS1 FTG 1 PVC MALE NPT ELBOW	1	1
Not Shown	V3189	WS1 FTG 3/4&1 PVC SLVNT 90	Optional	Optiona
	V3010-2A	WS2/2H/3 INJECTOR ASY A		
	V3010-2B	WS2/2H/3 INJECTOR ASY B		
	V3010-2C	WS2/2H/3 INJECTOR ASY C		
16****	V3010-2D	WS2/2H/3 INJECTOR ASY D		
10	V3010-2E	WS2/2H/3 INJECTOR ASY E		
	V3010-2F	WS2/2H/3 INJECTOR ASY F		
	V3010-2G	WS2/2H/3 INJECTOR ASY G		
	V3010-2H	WS2/2H/3 INJECTOR ASY H		
Not Shown	V3499****	WS2H/3 FITTING CAP 1 IN THREADED	1	1
Not Shown	V3797*****	WS1 FTG 1 PVC MALE BSPT ELBOW	BSPT Only	BSPT O1




- *V3236-04 WS2H INJECTOR TUBE ASY A thru H contains a V3285 O-RING 213 and a V3286 O-RING 216.
- **V3670-01 WS3 INJECTOR TUBE DOWNFLOW ASY contains a V3285 O-RING 213, V3286 O-RING 216 and a V3163 O-RING 019.
- ***Any V3162-XXX flow control may be used. V3237-01 WS2H SOFTFILL TUBE ASY contains a V3155 O-RING 112, V3287 O-RING 110 and a V3288 O-RING 206.
- ****V3010-2A through V3010-2G injectors contain a V3283 O-RING 117 and a V3284 O-RING 114. V3010-2H injectors use a V3283 O-RING 117 and D1263 O-RING 116
- Backwash Only Valves include a V3499 but do not include the following parts: V3189, V3162-022, V3231 and V3277.
- ***** Install V3499 on V3149 if valve is to be set up as a backwash only valve.
- ****** BSPT valves also include a V3797 WS1 FTG 1 PVC MALE BSPT ELBOW

V3064 WS2H/2QC 4 INCH BASE ASY (For use on WS2H or WS2QC only)



Drawing No.	Order No.	Description	Quantity
1	V3202-01	WS2H BASE	1
2	V3419	O-RING 347	1

V3055 WS2H/2QC 6 INCH FLANGE BASE ASY or V3090 WS3 6 INCH FLANGE BASE ASY




Drawing Order No.		Description		Quantity	
No.	Order No.	Description	V3055	V3090	
1	V3444	WS2H SCREW HEXCAP 5/16-18X2 SS	12	12	
2	V3293	WS2H WASHER SS 5/16 FLAT	24	24	
3	V3445	WS2H WASHER SPLIT LOCK 5/16 SS	12	12	
4	V3447	WS2H NUT HEX 5/16-8 FULL SS	12	12	
5	COR60FL	O RING 6 FLANGE ADAPTER	1	1	
	V3261-01	WS2H FLANGE BASE	1		
6	V3671-01	WS3 FLANGE BASE	·	1	



Order No.	Description	Inlet/Outlet	For Valve
V3260-02	WS2H/2QC SIDE MOUNT NPT ASY	2" Female NPT or 2.5" Groove Lock	WS2H NPT
V3674-02	WS3 SIDE MOUNT NPT ASY	3" Female NPT	WS3 NPT
V3674BSPT-02	WS3 SIDE MOUNT BSPT ASY	3" Female BSPT	WS3 BSPT

V3260BSPT-02 WS2H/2QC SIDE MOUNT BASE BSPT ASY




Drawing No.	Order No.	Description	Quantity
1	V3280	O-RING 332	1
2	V3260BSPT-01	WS2H SIDE MOUNT BASE BSPT	1

When using a side mount base with 2H or 2QC BSPT valves replace distributor pilot o-ring V3452 O-RING 230 with V3280 O-RING 332. See exploded view of 2H or 2QC valve for specific location of distributor pilot o-ring.

Order No. V3158-04
Description: WS2 Drain Elbow ¾" Male NPT without Silencer

DRAWING NUMBER	ORDER NUMBER	DESCRIPTION	QTY
1	V3983	WS2 DLFC ADAPTER	1
2	H4615	CLIP RETAINING 474/WS1	1
	V3162-007	WS1 DLFC 0.7 gpm for 3/4	
	V3162-010	WS1 DLFC 1.0 gpm for 3/4	
	V3162-013	WS1 DLFC 1.3 gpm for 3/4	
	V3162-017	WS1 DLFC 1.7 gpm for 3/4	ONE
	V3162-022	WS1 DLFC 2.2 gpm for 3/4	DLFC
	V3162-027	WS1 DLFC 2.7 gpm for 3/4	MUST BE
3	V3162-032	WS1 DLFC 3.2 gpm for 3/4	USED IF
	V3162-042	WS1 DLFC 4.2 gpm for 3/4	3/4"
	V3162-053	WS1 DLFC 5.3 gpm for 3/4	FITTING
	V3162-065	WS1 DLFC 6.5 gpm for 3/4	IS USED.
	V3162-075	WS1 DLFC 7.5 gpm for 3/4	
	V3162-090	WS1 DLFC 9.0 gpm for 3/4	
	V3162-100	WS1 DLFC 10 gpm for 3/4	
4	V3159-01	WS1 DLFC RETAINER ASY	1
5	V3163	O-RING 019	1
6	V3158-03	WS1 DRN ELBOW 3/4 MALE NO HOLE	1


This assembly is shipped without drain line flow control (DLFC) – install DLFC before using. Use a minimum drain line size of $^{3}\!\!\!\!/^{2}$.



Order No. V3008-05
Description: WS2 Drain Fitting 1" Male NPT Straight without Silencer

DRAWING NUMBER	ORDER NUMBER	DESCRIPTION	QTY
1	V3166-01	WS1 FTG FLOW CONTROL BODY	1
2	V3167	WS1 DRAIN FTG ADAPTER 1	1
3	V3163	O-RING 019	1
4	V3150	WS1 SPLIT RING	1
5	V3151	WS1 NUT 1" QC	1
6	V3105	O-RING 215	1
	V3190-090	WS1 DLFC 9.0 GPM FOR 1	
	V3190-100	WS1 DLFC 10.0 GPM FOR 1	ONE
	V3190-110	WS1 DLFC 11.0 GPM FOR 1	DLFC
7*	V3190-130	WS1 DLFC 13.0 GPM FOR 1	MUST BE USED IF
/	V3190-150	WS1 DLFC 15.0 GPM FOR 1	1"
	V3190-170	WS1 DLFC 17.0 GPM FOR 1	FITTING
	V3190-200	WS1 DLFC 20.0 GPM FOR 1	IS USED.
	V3190-250	WS1 DLFC 25.0 GPM FOR 1	
8	H4615	CLIP RETAINING	1
9	V3414	WS1.5 DLFC ADAPTER	1
10	V3649	BUSHING PVC SCH 80 1.5 TO 1.25 NPT	1

^{*} Order DLFC separately.




V3079 WS DLFC ASY 125 MNPT/15 FNPT, V3079BSPT WS DLFC ASY 125 MNPT/15 FBSPT, V3080 WS DLFC ASY 15 MNPT/15 FNPT and V3080BSPT WS DLFC ASY 15 MNPT/15 FBSPT

Drawing	Order No	Description		Quantity				
No.	Order No.	Description	V3079	V3079BSPT	V3080	V3080BSPT		
1	V3081	WS15 RETAINER DLFC ASY	1	1	1	1		
0	V3645	WS15 DLFC FLANGE OUTLET FNPT	1		1			
2	V3645BSPT	WS15 DLFC FLANGE OUTLET FBSPT		1		1		
3	V3646	WS15 DLFC FLANGE INLET MNPT		Ì	1	1		
4	V3388	WS125 DLFC FLANGE INLET MNPT	1	1				
5	V3652	BOLT HEXHD S/S HCS 5/16-18x3/4	4	4	4	4		
6	V3441	O-RING 226	1	1	1	1		
	V3162-007	WS1 DLFC 0.7 gpm for 3/4						
ĺ	V3162-010	WS1 DLFC 1.0 gpm for 3/4						
ĺ	V3162-013	WS1 DLFC 1.3 gpm for 3/4						
ĺ	V3162-017	WS1 DLFC 1.7 gpm for 3/4						
ſ	V3162-022	WS1 DLFC 2.2 gpm for 3/4						
ĺ	V3162-027	WS1 DLFC 2.7 gpm for 3/4						
ſ	V3162-032	WS1 DLFC 3.2 gpm for 3/4						
ĺ	V3162-042	WS1 DLFC 4.2 gpm for 3/4						
ĺ	V3162-053	WS1 DLFC 5.3 gpm for 3/4						
ĺ	V3162-065	WS1 DLFC 6.5 gpm for 3/4	In	stall at least one V3	190-XXX in ce	enter hole.		
Not Shown	V3162-075	WS1 DLFC 7.5 gpm for 3/4	Kno	ock out plugs allow in	stallation of u	p to 6 more		
ĺ	V3162-090	WS1 DLFC 9.0 gpm for 3/4		of V31	62-XXX.			
ĺ	V3162-100	WS1 DLFC 10.0 gpm for 3/4						
[V3190-090	WS1 DLFC 09.0 gpm for 1						
ĺ	V3190-100	WS1 DLFC 10.0 gpm for 1						
ĺ	V3190-110	WS1 DLFC 11.0 gpm for 1						
	V3190-130	WS1 DLFC 13.0 gpm for 1						
ĺ	V3190-150	WS1 DLFC 15.0 gpm for 1						
	V3190-170	WS1 DLFC 17.0 gpm for 1						
	V3190-200	WS1 DLFC 20.0 gpm for 1						
[V3190-250	WS1 DLFC 25.0 gpm for 1						

Assemblies are shipped without drain line flow control (DLFC). Assembly instructions:

- 1. Determine the desired flow rate. Select one V3190-XXX for the center hole and a combination of V3162-XXX to arrive at the desired flow rate. At least one V3190-XXX must be used and up to six of the V3162-XXX may be used.
- 2. Using a drill or punch remove the desired knockout(s) in V3081.
- 3. Smooth holes.
- 4. Install appropriate size(s) of drain line flow control washers. Play close attention to proper DLFC orientation.
- 5. Fit V3441 o-ring onto V3081 Retainer DLFC Asy and assemble. Properly orientate the V3081 in direction of flow.
- 6. Inlet threads for 1.25" female are NPT. Inlet threads for 1.5" male are NPT. Outlet threads for 1.5" are either female NPT or BSPT. 1.5" female outlet is stamped with N or B to indicate NPT or BSPT.





V3051 WS2 DLFC ASY NPT and V3051BSPT WS2 DLFC ASY BSPT

Drawing No.	Order No.	Description	Quantity
1	V3052	WS2 DLFC Retainer ASY	1
2	V3245	WS2 DLFC FLANGE INLET NPT	1
2	V3245BSPT	WS2 DLFC FLANGE INLET BSPT	1
2	V3246	WS2 DLFC FLANGE OUTLET NPT	1
3	V3246BSPT	WS2 DLFC FLANGE OUTLET BSPT	1
4	V3273	BOLT HEX HD S/S HCS 3/8-16X3/4	4
5	V3278	O-ring 338	1
	V3162-007	WS1 DLFC 0.7 gpm for 3/4	
	V3162-010	WS1 DLFC 1.0 gpm for 3/4	
	V3162-013	WS1 DLFC 1.3 gpm for 3/4	
	V3162-017	WS1 DLFC 1.7 gpm for 3/4	
	V3162-022	WS1 DLFC 2.2 gpm for 3/4	
	V3162-027	WS1 DLFC 2.7 gpm for ³ / ₄	Install One or
	V3162-032	WS1 DLFC 3.2 f gpm or 3/4	More DLFC's.
	V3162-042	WS1 DLFC 4.2 gpm for 3/4	Up to 5 of
	V3162-053	WS1 DLFC 5.3 gpm for 3/4	the V3162-
	V3162-065	WS1 DLFC 6.5 gpm for 3/4	XXX may be
Not Shown	V3162-075	WS1 DLFC 7.5 gpm for 3/4	installed in the small holes.
	V3162-090	WS1 DLFC 9.0 gpm for 3/4	Sman noies.
	V3162-100	WS1 DLFC 10.0 gpm for 3/4	Up to 4 of
	V3190-090	WS1 DLFC 9.0 gpm for 1	the V3190- XXX may be
	V3190-100	WS1 DLFC 10.0 gpm for 1	installed in the
	V3190-110	WS1 DLFC 11.0 gpm for 1	large holes.
	V3190-130	WS1 DLFC 13.0 gpm for 1	
	V3190-150	WS1 DLFC 15.0 gpm for 1	
	V3190-170	WS1 DLFC 17.0 gpm for 1	
	V3190-200	WS1 DLFC 20.0 gpm for 1	
	V3190-250	WS1 DLFC 25.0 gpm for 1	

Assemblies are shipped without drain line flow control (DLFC). Assembly instructions:


- 1. Determine the desired flowrate. Select a combination of V3162-XXX's and V3190-XXX's to arrive at the desired flow rate. Up to five of the smaller V3162-XXX's may be used. Up to four of the larger V3190-XXX's may be used.
- 2. Using a drill or punch remove the desired knockout(s) in V3052.
- 3. Smooth hole(s).
- 4. Install appropriate size(s) of drain line flow control washers. Pay close attention to proper DLFC orientation.
- 5. Assemble. Properly orientate the V3052 in the direction of flow.
- 6. Inlet and outlet threads are 2". Couplings for iron pipe may also be used.





V3764 WS3 DLFC NPT ASY or V3764BSPT WS3 DLFC BSPT ASY

Drawing No.	Order No.	Description	Quantity
	V3190-090	WS1 DLFC 9.0 gpm for 1	Install One or More DLFC washers.
	V3190-100	WS1 DLFC 10.0 gpm for 1	DLFC washers must be purchased separately.
	V3190-110	WS1 DLFC 11.0 gpm for 1	When using one retainer and one o-ring up to
,	V3190-130	WS1 DLFC 13.0 gpm for 1	5 DLFC washers can be used for flow rates from
	V3190-150	WS1 DLFC 15.0 gpm for 1	9 gpm up to 125 gpm.
	V3190-170	WS1 DLFC 17.0 gpm for 1	When using two retainers and two o-rings, 5 DLFC
	V3190-200	WS1 DLFC 20.0 gpm for 1	washers are used in one of the retainers and up to 4 more DLFC washers can be used in the other retainer for flow
	V3190-250	WS1 DLFC 25.0 gpm for 1	rates from 9 gpm up to 225 gpm.
2.	V3765-01	WS3 DLFC HOUSING NPT	1
2	V3765BSPT-01	WS3 DLFC HOUSING BSPT	1
3	V3766	WS3 DLFC RETAINER	1 or 2
4	V3767	WS3 DLFC RETAINER COVER	1
5	V3768	WS3 DLFC RETAINER RING	1
6	V3769	O-RING 336	1 or 2




Assemblies are shipped without drain line flow control (DLFC) washers.

Assembly instructions:

- 1. Determine the desired flow rate. Select a combination of V3190-XXX's to arrive at the desired flow rate.
- 2. Using a drill or punch remove the desired knockout(s) in V3766. Each V3766 retainer contains two types of knock outs. The larger knockouts are removed to install a DLFC. If two V3766 retainers are needed remove the smaller diameter knockout that lines up with the DLFC installed in the other retainer. One or two V3766 retainers may be used. When using one V3766 retainer V3190-XXX must be installed in the center hole. When using two V3766 retainers a V3190-XXX must be installed in the center hole of one of the retainers and the center hole on the other retainer must remain open.
- 3. Smooth hole(s).
- 4. Install appropriate size(s) of drain line flow control washers. Pay close attention to proper DLFC orientation.
- 5. Assemble. Each V3766 retainer must have a V3769 o-ring installed. One each of the V3767 retainer cover and V3768 retainer ring must be used whether one or two V3766 retainers are used. The positioning of the V3768 retainer ring varies depending on the number of V3766 retainer(s) used. Properly orientate the V3766(s) in the direction of flow.
- 6. Properly orientate the complete assembly in the direction of flow. Inlet and outlet threads are 3".


V3063 MOTOR ALTERNATING VLV 2 NPT and V3063BSPT MOTOR ALTERNATING VLV 2 BSPT

Drawing No.	Order No.	Description	Quantity
1	V3056	WS1.5&2ALT/2BYPASS AUTO CVRASY	1
2	V3476	WS MOTOR ASY 8 FT	1
3	V3272	WS2 SCREW 8X1 SS HEX SELF TAP	3
4	V3262-01	WS1.5&2ALT/2BY REDUCGEARCVRASY	1
5	V3110-01	WS1 DRIVE REDUCING GEAR PLAIN	3
6	V3264	WS2 BYPASS REDUCTION GEAR AXLE	3
7	V3292	WS2 SCREW BSHD SS 1/4-20X1-1/2	4
8	V3059	WS1.5&2ALT/2BYPAS AUTODRIVEASY	1
9	V3298-01	WS2 ALT VALVE BODY NPT	1
9	V3298BSPT-01	WS2 ALT VALVE BODY BSPT	I
Not Shown	V3474	WS ALT CONNECT CORD 8 FT BLK	1



Order No. V3076 • Description: MOTOR ALT VLV 2 NPT REV2 or Order No. V3076BSPT • Description: MOTOR ALT VLV 2 BSPT REV2

Drawing No.	Order No.	Description	Qu	antity
Drawing No.	Order No.	Description	V3076	V3076BSPT
1	V3073	MAV/NOHWBY COVER ASY	1	1
2	V3476	WS MOTOR ASY 8 FT	1	1
3	V3592	SCREW #8-1 PHPN T-25 SS	3	3
4	V3262-01	WS1.5&2ALT/2BY REDUCGEARCVRASY	1	1
5	V3110-01	WS1 DRIVE REDUCING GEAR PLAIN	3	3
6	V3264	WS2 BYPASS REDUCTION GEAR AXLE	3	3
7	V3642	SCREW 1/4-20 X 1 1/4 BHSCS SS	4	4
8	V3078	MAV/NOHWBY 2 DRIVE ASY	1	1
9	V3634-01	MAV/NOHWBY 2 PISTON	1	1
10	V3077	MAV/NOHWBY 2 STACK ASY	1	1
11	V3633-01	WS2 MAV BODY NPT	1	N/A
11	V3633-01BSPT	WS2 MAV BODY BSPT	N/A	1
Not Shown	V3474	WS ALT CONNECT CORD 8FT BLK	1	1




Operating Pressures:
20 PSI Minimum / 125 PSI Maximum
Operating Temperatures:
40°F Minimum / 110°F Maximum

Piston Orientation 2
No Hard Water Bypass Valve
Configurations.


Piston Orientation 1
Motorized Alternating Valve
and No Hard Water Bypass
Valve Configurations.

Order No. V3098 • Description: NO HARDWATERBYPASS 2INMXF NPT or Order No. V3098BSPT • Description: NO HARDWATERBYPASS 2INMXF BSPT

Drowing No.	Order No.	No. Description	Qua	antity
Drawing No.	Order No.	Description	V3098	V3098BSPT
1	V3073	MAV/NOHWBY COVER ASY	1	1
2	V3476	WS MOTOR ASY 8 FT	1	1
3	V3592	SCREW #8-1 PHPN T-25 SS	3	3
4	V3262-01	WS1.5&2ALT/2BY REDUCGEARCVRASY	1	1
5	V3110-01	WS1 DRIVE REDUCING GEAR PLAIN	3	3
6	V3264	WS2 BYPASS REDUCTION GEAR AXLE	3	3
7	V3642	SCREW 1/4-20 X 1 1/4 BHSCS SS (5/32" HEX ALLEN WRENCH REQUIRED)	4	4
8	V3078	MAV/NOHWBY 2 DRIVE ASY	1	1
9	V3634-01	MAV/NOHWBY 2 PISTON	1	1
10	V3887	WS2 NHWBY STACK ASY	1	1
11	V3828-01	WS2 NHWBY BODY M X F NPT	1	N/A
'''	V3828BSPT-01	WS2 NHWBY BODY M X F BSPT	N/A	1
Not Shown	V3805	STRAIN RELIEF COVER KIT	1	1




Operating Pressures:
 20 PSI Minimum / 125 PSI Maximum
 Operating Temperatures:
 40°F Minimum / 110°F Maximum




Order No. V3083 • Description: MOTOR ALT VLV 3 NPT or Order No. V3083BSPT • Description: MOTOR ALT VLV 3 BSPT

Drawina Na	Ouder No	Description	Qua	antity
Drawing No.	Order No.	Description		V3083BSPT
1	V3696	WS3 MAV COVER	1	1
2	V3476	WS MOTOR ASY 8 FT	1	1
3	V3592	SCREW #8-1 PHPN T-25 SS	3	3
4	V3262-01	WS 1.5&2ALT/2BY REDUCGEARCVRASY	1	1
5	V3110-01	WS1 DRIVE REDUCING GEAR PLAIN	3	3
6	V3264	WS2 BYPASS REDUCTION GEAR AXLE	3	3
7	V3789	SCREW 3/8-16 X 1.75 BHCS SS (7/32" hex allen wrench required)	4	4
8	V3085	WS3 MAV DRIVE CAP ASY	1	1
9	V3695-01	WS3 MAV PISTON	1	1
10	V3084	WS3 MAV STACK ASY	1	1
11	V3693-01	WS3 MAV BODY NPT	1	N/A
11	V3693BSPT-01	WS3 MAV BODY BSPT	N/A	1
	V3475-12	WS2H/WS3 SYSTEM CONNECTION CORD 12 FOOT RED		
Sold Separately	V3475-24	WS2H/WS3 SYSTEM CONNECTION CORD 24 FOOT BLUE		e used for twin
	V3475-36	WS2H/WS3 SYSTEM CONNECTION CORD 36 YELLOW	tank operation.	




•Operating Pressures: 20 PSI Minimum / 125 PSI Maximum •Operating Temperatures: 40°F Minimum / 110°F Maximum




Order No. V3099 • Description: NO HARDWATERBYPASS 3INMXF NPT or Order No. V3099BSPT • Description: NO HARDWATERBYPASS 3INMXF BSPT

Drawing No.	Order No.	Pagarintian.	Qı	antity
Drawing No.	Order No.	Description		V3099BSPT
1	V3696	WS3 MAV COVER	1	1
2	V3476	WS MOTOR ASY 8 FT	1	1
3	V3592	SCREW #8-1 PHPN T-25 SS	3	3
4	V3262-01	WS 1.5&2ALT/2BY REDUCGEARCVRASY	1	1
5	V3110-01	WS1 DRIVE REDUCING GEAR PLAIN	3	3
6	V3264	WS2 BYPASS REDUCTION GEAR AXLE	3	3
7	V3789	SCREW 3/8-16 X 1.75 BHCS SS (7/32" hex allen wrench required)	4	4
8	V3085	WS3 MAV DRIVE CAP ASY	1	1
9	V3695-01	WS3 MAV PISTON	1	1
10	V3888	WS3 NHWBY STACK ASY	1	1
11	V3830-01	WS3 NHWBY M X F BODY NPT	1	N/A
11	V3830BSPT-01	WS3 NHWBY M X F BODY BSPT	N/A	1



Operating Pressures:
20 PSI Minimum / 125 PSI Maximum
Operating Temperatures:
40°F Minimum / 110°F Maximum




V3060 WS2H BYPASS AUTO NPT, V3060BSPT WS2H BYPASS AUTO BSPT, V3061BSPT WS2H BYPASS MANUAL BSPT and V3061 WS2H BYPASS MANUAL NPT

Drawing No.	Order No.	D	Quantity	
		Description	V3060	V3061
1	V3056	WS1.5&2ALT/2BYPASS AUTO CVRASY	1	N/A
2	V3476	WS MOTOR ASY 8 FT		N/A
3	V3272	WS2H SCREW 8X1 SS HEX SELF TAP	3	N/A
4	V3262-01	WS1.5&2ALT/2BY REDUCGEARCVRASY	1	N/A
5	V3110-01	WS1 DRIVE GEAR PLAIN	3	N/A
6	V3264	WS2H BYPASS REDUCTION GEAR AXLE	3	N/A
7	V3292	WS2H SCREW BSHD SS 1/4-20X1-1/2	8	8
8	V3059	WS1.5&2ALT/2BYPAS AUTODRIVEASY	1	N/A
9	V3268	WS2H BYPASS COVER DOME MANUAL	1	2
10	V3058	WS2H BYPASS MANUAL DRIVE ASY	1	2
11	V3057	WS2H BYPASS BODY ASY NPT	1	1
	V3057BSPT	WS2H BYPASS BODY ASY BSPT		
Not Shown	V3053	WS2H 2-1/2 GROOVELOCK CLAMP ASY	2	2

Treated water is used for refill whether or not an auto or manual bypass is installed to either the inlet or outlet of a control valve. The Auto Drive Assembly may be connected to the inlet or outlet of the control valve to achieve no hard water bypass. If the Auto Drive Assembly is connected to the control valve:


- inlet then all regeneration cycles occur with treated water.
- outlet then all regeneration cycles except for refill occur with untreated water.

B indictates BSPT N indicates NPT



V3053 WS2 2-1/2 GROOVELOCK CLAMPASY

Drawing No.	Order No.	Description	Quantity
1	V3053	WS2 2-1/2 GROOVELOCK CLAMP ASY	1
2	V3290	WS2 GROOVE LOCK SEAL 2.5	1
3	V3269	WS2H NUT 5/16-18 SS HEX	1
4	V3293	WS2H WASHER SS 5/16 FLAT	1
5	V3276	WS2H BOLT HEX SS 5/16-18X1-3/4	1
Not Shown	S3086	SILICONE LUBRICANT	1



WS2H/ WS3 Error Codes

Possible Errors			
Code	Description		
1001	No Encoder Pulses		
1002	Unexpected Stall, Main Drive		
1003	Run Time To Long, Main Drive		
14001	Message Queue Full		
15003	Run Time To Long, Bypass Drive		
15010	Run Time To Short, Bypass Drive Could Not Drive Offline		
15011	Run Time To Short, Bypass Drive Could Not Drive Online		
16001	Communication Lost With Unit 2		
16002	Communication Lost With Unit 3		
16003	Communication Lost With Unit 4		
16004	Regen List Full		
17000	Run Time To Long, Separate Source Drive		
17002	Run Time To Short, Separate Source Drive		
18000	Reset Performed		
18001	Power Loss		
18002	Power Restored		

WS2H/ WS3 Trouble Shooting Guide

Problem	Possible Cause	Solution
	a. No power at electric outlet b. Control valve Power Adapter not plugged into outlet or power cord end not connected to PC board connection	a. Repair outlet or use working outlet b. Plug Power Adapter into outlet or connect power cord end to PC Board connection
1. No Display on POD	c. Improper power supply d. Poor connection between POD connector and PC Board.	c. Verify proper voltage is being delivered to PC Board d. Check connector on POD, possible broken wire or terminal pin not inserted properly in connector. Clean pins on PC Board by plugging & unplugging the
	e. Defective Power Adapter f. Defective PC Board	POD connector a few times to remove excess protective coating. e. Replace Power Adapter f. Replace PC Board
2. POD does not display correct time of day	 a. Power Adapter plugged into electric outlet controlled by light switch b. Tripped breaker switch and/or tripped GFI c. Power outage d. Defective PC Board 	a. Use uninterrupted outlet b. Reset breaker switch and/ or GFI switch c. Reset time of day d. Replace PC Board
3. Display does not indicate that water is flowing. Refer to user instructions for how the display indicates water is flowing	 a. Bypass/ isolation valve in bypass position b. Meter is not connected to meter connection on PC Board c. Restricted/ stalled meter turbine d. Meter wire not installed securely into three pin connector e. Defective meter f. Defective PC Board 	 a. Turn bypass/ isolation handles to place in service position b. Connect meter to three pin connection labeled FLOW on PC Board c. Remove meter and check for rotation or foreign material d. Verify meter cable wires are installed securely into three pin connector labeled FLOW e. Replace meter f. Replace PC Board
4. Control valve regenerates at wrong time of day	a. Power outage b. Time of day not set correctly c. Time of regeneration set incorrectly d. Control valve set at "on 0" (immediate regeneration)	a. Reset time of day. b. Reset to correct time of day c. Reset regeneration time d. Check programming setting and reset to dEL (for a delayed regen time)
5. Time of day flashes on and off	a. Power outage	a. Reset time of day.
6. Control valve does not regenerate automatically when the REGEN button is depressed and held.	a. Defective PC Board b. For the case of systems, another unit in regen would not allow another unit to go into regeneration.	a. Replace PC Board b. Wait for unit in regeneration to finish

Problem	Possible Cause	Solution
7. Control valve does not regenerate automatically but does when the REGEN button is depressed and held.	 a. Bypass/ isolation valves in bypass position b. Meter is not connected to meter connection on PC Board c. Restricted/ stalled meter turbine d. Incorrect programming e. Meter wire not installed securely into three pin connector f. Defective meter g. Defective PC Board 	 a. Turn bypass/ isolation valves handles to place in service position b. Connect meter to three pin connection labeled FLOW on PC Board c. Remove meter and check for rotation or foreign material d. Check for programming error e. Verify meter cable wires are installed securely into three pin connector labeled FLOW f. Replace meter g. Replace PC Board
8. Hard or untreated water is being delivered	Check water quality directly at unit outlet 1) Water quality is good a) Bypass/ isolation valves are open or faulty 2) Water quality is poor a) Damaged seal/stack assembly b) Faulty riser tube or seal c) Control valve body type and piston type mix matched 3) Media is exhausted, water quality is poor a) Higher than anticipated water usage b) Meter not registering c) No regenerant or low level of regenerant in regenerant tank d) Control fails to draw in regenerant e) Water quality fluctuation f) Fouled media bed	 External Bypass Leak a) Fully close bypass/ isolation valves or replace Internal Bypass Leak a) Replace seal/stack assembly b) Verify seal placement & engagement with riser c) Verify proper control valve body type and piston type match 3) No internal leaks a) Check program settings or diagnostics for abnormal water usage b) See Troubleshooting Guide #3 c) Check refill setting in programming. Check refill flow control for restrictions or debris and clean or replace, check refill flow control rate for proper fill time. d) Refer to Troubleshooting Guide #12 e) Test water and adjust program values accordingly f) Replace media bed
9. Control valve uses too much regenerant	a. Improper refill setting or refill fill flow control is not sized properly b. Improper program settings c. Control valve regenerates frequently	 a. Check refill setting and check refill flow control for proper refill rate. b. Check program setting to make sure they are specific to the water quality and application needs c. Check for leaking fixtures that may be exhausting capacity or system is undersized

Problem	Possible Cause	Solution
	a. Low water pressure	a. Check incoming water pressure – water pressure must remain at minimum of 25 psi
	b. Plugged, fouled, or incorrect injector size	b. Inspect and clean or replace injector, or replace injector with correct size for the application
10. Residual regenerant being	c. Restricted drain line	c. Check drain line for restrictions or debris and clean
delivered to service	d. Damaged seal/ stack assembly or piston allowing leakage during draw	d. Check seal/ stack assembly and piston for damage and replace
	e. Draw time too short f. Excessive refill g. Vacuum leak in draw line / elbow	e. Program proper draw time needed f. Program proper refill time needed g. Locate vacuum leak and fix
11. Excessive water in regenerant tank	 Tank is being overfilled a) Improper program settings b) Missing refill flow controller Previous regenerant is not being drawn out 	 Excess from fill cycle Verify program settings Visual inspection / measure volume output into container See Troubleshooting Guide #12
12. Control valve fails to draw in regenerant	 a. Injector is plugged b. Faulty regenerant piston c. Regenerant line connection leak d. Drain line restriction or debris cause excess back pressure e. Drain line too long or too high f. Low water pressure g. Damaged seal/ stack assembly 	 a. Remove injector and clean or replace b. Replace regenerant piston c. Inspect regenerant line for air leak d. Inspect drain line and clean to correct restriction e. Shorten length and/or height f. Check incoming water pressure – water pressure must remain at minimum of 25 psi g. Inspect seal stack assembly for damage and replace
13. Water running to drain	 a. Power outage during regeneration or unit is currently in regeneration b. Damaged seal/ stack assembly c. Piston assembly failure d. Drive cap assembly not tightened properly 	 a. Upon power being restored control will finish the remaining regeneration time. Reset time of day. b. Replace seal/ stack assembly c. Replace piston assembly d. Re-tighten the drive cap assembly
14. Motor drives intermittently during regeneration.	a. Low power	a. See Table 2 Software and Power Supply Compatibility


Problem	Possible Cause	Solution
15. Err – 1001 = Control unable to sense motor movement	a. Motor not inserted fully to engage pinion, motor wires broken or disconnected	a. Disconnect power, make sure motor is fully engaged, check for broken wires, make sure two pin connector on motor is connected to the two pin connection on the PC Board labeled REGEN. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position.
	b. PC Board not properly snapped into drive bracket	b. Properly snap PC Board into drive bracket and then Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position.
	c. Missing reduction gears	c. Replace missing gears
	d. Damaged or dirty reduction gear reflectors	d. Clean or replace reduction gear
	e. Faulty or dirty optics on back of PC board	e. Clean or replace PC Board
16. Err – 1002 = Control valve motor ran too short and was unable to find the next cycle position and stalled	a. Foreign material is lodged in control valve	a. Open up control valve and pull out piston assembly and seal/ stack assembly for inspection. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position.
	b. Mechanical binding	b. Check piston and seal/ stack assembly, check reduction gears, check drive bracket and main drive gear interface. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. Check
	c. Main drive gear too tight	that pinion is not pressed up tight against motor c. Loosen main drive gear. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. Verify free motion
	d. Improper voltage being delivered to PC Board	by rotating main drive gear by hand, driving piston in and out d. Verify that proper voltage is being supplied. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position.


Problem	Possible Cause	Solution
17. Err – 1003 = Control valve motor ran too long and was unable to find the next cycle position	 a. Motor failure during a regeneration b. Foreign matter built up on piston and stack assemblies creating friction and drag enough to time out motor c. Drive bracket not snapped in properly and out of position enough that reduction gears and drive gear do not interface d. Low voltage slowing drive 	 a. Check motor connections then Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. b. Replace piston and stack assemblies. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. c. Snap drive bracket in properly then press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. d. See Table 2 Software and Power Supply Compatibility
18. Err - 14001 = Message queue full	a. Master PC Board did not receive a response from slave units.	a. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position.
	a. Control valve programmed for ALT A or noHbP without having a motorized drive securely connected to the 2 pin terminal labeled "BYPASS" on the main PC Board	a. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. Then re- program valve to proper setting
19. Err -15003 = Motorized Bypass or MAV for NHBP valve motor ran too long and unable to find the proper park position Motorized Alternating Valve = MAV No Hard Water Bypass = NHBP	 b. Poor wire connection c. Excess drag causing timeout before stall d. Motorized Bypass or MAV for NHBP motor not fully engaged with reduction gears 	b. Remove power and check connection for Motorized Bypass or MAV for NHBP motor to PC Board two pin connection labeled BYPASS. Make sure wires in connector are inserted securely and no wires are broken. Clean pins on PC Board by plugging and unplugging the connector a few times to remove excess protective coating. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. c. Open up Motorized Bypass or MAV for NHBP to check for obstructions d. Properly insert motor into casing, do not force into casing. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position.


Problem	Possible Cause	Solution	
20. Err – 15010 = Motorized Bypass or MAV for NHBP valve motor ran too short (stalled) while trying to drive off-line	a. Foreign material is lodged in Motorized Bypass or MAV for NHBP valve	 a. Open up Motorized Bypass or MAV for NHBP and check for foreign material. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. b. Check poppet drive assembly or piston and seal/ stack assembly, check reduction gears, drive gear interface, and check Motorized Bypass or MAV for NHBP black drive pinion on motor. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. 	
Motorized Alternating Valve = MAV No Hard Water Bypass = NHBP	b. Mechanical binding		
21. Err – 15011 = Motorized Bypass or MAV for NHBP valve motor ran too short (stalled) while trying to drive on-line Motorized Alternating Valve = MAV No Hard Water Bypass = NHBP	a. Foreign material is lodged in Motorized Bypass or MAV for NHBP valveb. Mechanical binding	 a. Open up Motorized Bypass or MAV for NHBP and check for foreign material. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. b. Check poppet drive assembly or piston and seal/ stack assembly, check reduction gears, drive gear interface, and check Motorized Bypass or MAV for NHBP black drive pinion on motor. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. 	


Problem	Possible Cause	Solution
22. # of units error: Communications has been broken with the unit specified in the error message. These errors are logged as 16K series errors as follows: 16001: error with unit 2 16002: error with unit 3 16003: error with unit 4	a. System is programmed for the wrong number of units or a Slave unit is in "error # of units" mode due to loss of power. b. Poor connection on PC Boards c. More than one unit has determined that it is the master control	1) Correct all errors on satellite units before attempting to reset error on master a. Pressing any button while in the # of units error will enter the user into the setting screen. Adjust to the correct units for the system and press NEXT to exit the set up screen. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. Re-program valve to proper setting. b. Make sure wires in connector are inserted securely and no wires are broken. Clean pins on PC Board by plugging and unplugging the connector a few times to remove excess protective coating. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. c. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. Then reprogram each valve to operate as single individual unit. Re-program the control that is to be the master control and it will filter down the programming to the slave controls automatically.
23. Err – 17000 = MAV for Separate Source valve motor ran too long while trying to find proper park position	 a. Control valve programmed for "ON SEP In" with out having a MAV for separate source attached b. MAV for separate source motor wire not connected to System Board or poor connection c. MAV for separate source motor not fully engaged with reduction gears 	 a. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. Reprogram valve to proper setting b. Remove power and check connection on MAV for separate source motor wire to System Board two pin connection labeled AUX DRIVE. Make sure wires in connector are inserted securely and no wires are broken. Clean pins on System Board by plugging and unplugging the connector a few times to remove excess protective coating. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position. c. Properly insert motor into casing, do not force into casing. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston


Problem	Possible Cause	Solution
24. Err – 17002 = MAV for Separate Source valve motor ran too short while trying to find proper park position	a. Foreign material is lodged in MAV for separate source valve	a. Open up MAV for separate source and check for foreign material. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position.
	b. Mechanical binding	b. Check poppet drive assembly or piston and seal/ stack assembly, check reduction gears, drive gear interface, and check MAV for separate source black drive pinion on motor. Press NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position.
25. Err – 18000 = Reset was performed, this error code will display in the diagnostics under the error log	a. Press the NEXT and REGEN buttons for about 3 seconds to resynchronize software with piston position.	
26. Err – 18001 = Power loss, this error code will display in the diagnostics under error log	a. When power is lost a signal is sent to log the power loss	
27. Err – 18002 = Power restored, this error code will display in the diagnostics under error log	a. When power is restored a signal is sent to log the power being restored	


















































Revision History:

6/17/2014

PAGE 4:

Power Adapter: International 1000 mA

PAGE 7:

Slip Hazard Symbol and text

Disconnect electrical power symbol and text

Allow two feet of clearance to service WS2H and WS3 valves.

The valve will withstand transportation and storage temperatures of -13 °F (-25 °C) to 131 °F (55 °C) and for short periods up to 158 °F (70 °C). If valve has been exposed to freezing conditions let valve warm up to room temperature before running water through it. The valve has been packaged to prevent damage from the effects of normal humidity, vibration and shock.

7/9/2014

PAGE 21:

V3260BSPT-02 WS2H/2QC SIDE MOUNT BASE BSPT ASY

When using a side mount base with 2H or 2QC BSPT valves replace distributor pilot o-ring V3452 O-RING 230 with V3280 O-RING 332. See exploded view of 2H or 2QC valve for specific location of distributor pilot o-ring.

7/14/2015			
<u>PAGE 27:</u>			
5	V3110-01	WS1 DRIVE REDUCING GEAR PLAIN	3
PAGE 28:			
5	V3110-01	WS1 DRIVE REDUCING GEAR PLAIN	3
PAGE 29:			
5	V3110-01	WS1 DRIVE REDUCING GEAR PLAIN	3
PAGE 30:			
5	V3110-01	WS1 DRIVE REDUCING GEAR PLAIN	3
PAGE 31:			
5	V3110-01	WS1 DRIVE REDUCING GEAR PLAIN	3
PAGE 32:			
5	V3110-01	WS1 DRIVE REDUCING GEAR PLAIN	3