


GENERAL INSTALLATION FOR IDLC GENERATORS


UL2200		OVERALL	OVERALL	OVERALL	CORE	CORE	CORE	MOUNTING	MOUNTING	MOUNTING	WET
MODEL #	MODEL #	LENGTH	WIDTH	HEIGHT	HEIGHT 1	HEIGHT	WIDTH	HOLE 1	HOLE 2	WIDTH	WEIGHT
WODEL #		L	W	Н	CH1	2 CH2	CW	M1	М2	MW	(#) ±5%
IDLC180-3JU	IDLC180-3J			53	14	34	38	24.00	94.00		3708
IDLC200-3JU	IDLC200-3J	118	48	33	14	34	, 36	24.00	94.00	46.00	4368
IDLC225-3JU	IDLC225-3J			59	16	36	42	16.00	92.00		5119
IDLC250-3JU	IDLC250-3J										5308
IDLC275-3JU	IDLC275-3J										5510








PLAN VIEW



REAR VIEW

CH2

CH1



PLAN VIEW OF TANK ONLY

FRONT VIEW

LEFT SIDE VIEW

FOR INSTALLATION RECOMMENDATIONS REFER TO GEN SET MANUAL MN2407

ALL DIMENSIONS IN INCHES

ALL WEIGHTS IN POUNDS

DRAWING TO SCALE

TOLERANCES UNLESS OTHERWISE SPECIFIED DECIMALS .XX ±.25 FRACTIONS ±1/4

WEIGHTS SHOWN ARE TYPICAL AND INCLUDE ALTERNATORS SELECTED @125°C RISE

CUSTOMER IS RESPONSIBLE FOR DETERMINING THAT MOTOR PERFORMANCE IS SUITABLE IN THE APPLICATION.

REV. DESC: UPDATE TABLE		DAT DOD - DODGE - DELIANO			
REV. LTR: C	VERSION: 03	TDR: 000000451565	BALDOR • DØDGE • RELIANCE	9	
FILE: \PGA\00010\468 REVISED: 14: 27: 03 12/13/2007		BY: PGCONB0	IDLC 30-500-07E	] <	
MTL: -	TAB: OPEN_180_275	IDLC 30-300-07E			

SLS-30-500-07E