



Fire class: EI 60

1. Copper pipe 15-22mm, Armaflex-insulation.
2. Composite pipe 16-20mm, Armaflex-insulation.
3. Cable bundle max. 40mm.
4. Concrete wall min. 60mm.
5. Fire acrylic filling, Joints Fire Acryl Pro+, Depth=25mm, ETA-13/0992.
6. Firewool, Joints Fire Wool Pro+.
7. PS 100 PVC-pipe casing.

Min. seam width = 10mm.

Min. well penetration diameter = Pipe diameter + 20mm.