

**WESTINGHOUSE ELECTRIC CORP.
DISTRIBUTION AND CONTROL BUSINESS UNIT
5 PARKWAY CENTER
PITTSBURGH, PA. 15220
1-800-WES-KITS**

**SL 33-DK2-1
DEC. 30, 1996**

SUPPLEMENTAL INSTRUCTIONS FOR IL33-861-5

FOR BREAKER: *Westinghouse DK-15.*

1. Use IL33-861-5 to retrofit Westinghouse DK-15 breakers.
2. Substitute the following:

The DK-15 uses 200:5 current sensors only:

Sensor Style No. 8259A38H01 X1-X2 = 200:5