

2.2KW INVERTER GENERATOR MODEL NO: IG2200

PART NO: 8877055

OPERATION & MAINTENANCE INSTRUCTIONS



LS1209

INTRODUCTION

Thank you for purchasing this CLARKE 2.2kW Inverter Generator

Before attempting to use this product, please read this manual thoroughly and follow the instructions carefully. In doing so you will ensure the safety of yourself and that of others around you, and you can look forward to your purchase giving you long and satisfactory service.

GUARANTEE

This product is guaranteed against faulty manufacture for a period of 12 months from the date of purchase. Please keep your receipt which will be required as proof of purchase.

This guarantee is invalid if the product is found to have been abused or tampered with in any way, or not used for the purpose for which it was intended.

Faulty goods should be returned to their place of purchase, no product can be returned to us without prior permission.

This guarantee does not effect your statutory rights.

ENVIRONMENTAL PROTECTION

One of the most damaging sources of pollution is oil. Do not throw away used engine oil in with your domestic trash or down drains and sinks. Place it in a leak proof container and dispose of it according to local regulations.

TABLE OF CONTENTS

INTRODUCTION	.2
GUARANTEE	.2
ENVIRONMENTAL PROTECTION	.2
TABLE OF CONTENTS	.3
GENERAL SAFETY RULES	
Work area Positioning the generator	4
Fire prevention	4
Prevention of electric shock Additional safety rules for generators	5
SAFETY SYMBOLS	
GENERATOR OVERVIEW	
BEFORE USING THE GENERATOR	
Earth point	
Checking the air filter	9
Check the engine oil level Check the fuel level	10
USING YOUR GENERATOR	
Starting the engine	
Connecting electrical devices Economy switch	
Indicator lights	16
Shutting down the generator	
MAINTENANCE Engine oil (every 20 hours of use)	
Air filter (every 50 hours of use)	19
Spark plug (every 50 hours of use) Fuel tank filter	
TROUBLESHOOTING	
PARTS AND SERVICING	
SPECIFICATIONS	
DECLARATION OF CONFORMITY	
NOTES	
	. 20

GENERAL SAFETY RULES




WARNING: EXHAUST FUMES CAN BE EXTREMELY DANGEROUS IF INHALED

WORK AREA

- Always use in a well ventilated area.
- Always position the exhaust outlet away from people.
- Read these safety instructions before using the equipment.
- · Keep children away from the generator

POSITIONING THE GENERATOR


- Keep the generator at least 1 m (3 ft) from buildings or other equipment, or the engine may overheat.
- 2. Place the generator on a solid, flat surface.
- 3. Make sure the surrounding area is free from any material that could burn or be damaged by heat.



4. Never move or tilt the generator whilst it is switched on.

FIRE PREVENTION

- 1. *Always* switch the engine OFF when refuelling.
- 2. *Always* refuel in a well ventilated area.
- 3. *Never* refuel while smoking or in the vicinity of an open flame.
- Never overfill the tank, fill to the level specified (See "Check the fuel level" on page 11.).



5. *Never* smoke whilst refuelling and avoid smoking or using a naked flame near the generator.


6. **Never** start the engine if there is spilled fuel. Any spillage must be wiped clean and the generator allowed to dry before attempting to start the engine.


PREVENTION OF ELECTRIC SHOCK


- Never use the generator in wet conditions unless it is well protected/ covered. Under these conditions, adequate ventilation MUST be provided
- 2. *Never* operate the generator with wet hands
- 3. **Never** use water or any other liquids to clean the generator.
- 4. Make sure you ground (earth) the generator.

ADDITIONAL SAFETY RULES FOR GENERATORS

- Always make sure the applied load does not exceed the generator rating. Overloading the generator is dangerous and could cause serious damage.
- 2. **Always** disconnect the generator when carrying out any maintenance.
- Always allow the generator to reach operating speed before connecting a load.
- 4. **Never** allow the generator to run out of fuel when a load is connected.
- 5. **Never** transport the generator with fuel in the tank.
- Never connect the generator to a commercial or residential power supply; e.g. ring main.
- 7. *Never* allow the generator air vents to become blocked.







SAFETY SYMBOLS



Caution - The user should be aware of a general hazard



Dangerous Voltage



Flammable



Hot Surface - Do not touch




Poisonous fumes - Do not use the generator in an enclosed space.



Read Instruction manual before use.

GENERATOR OVERVIEW



NO	DESCRIPTION	NO	DESCRIPTION
1	Air Vent Knob	10	Earthing Point
2	Fuel Cap	11	Economy Control Switch
3	Fuel Valve Knob	12	AC Sockets
4	Starting Handle	13	DC Socket
5	Left Side Maintenance Cover	14	DC Circuit Breaker
6	Top Maintenance Cover	15	Overload Indicator
7	Muffler	16	Output Indicator
8	Choke	17	Oil Alarm Indicator
9	Engine ON/OFF Switch	18	Primer Bulb

Parts & Service: 020 8988 7400 / E-mail: Parts@clarkeinternational.com or Service@clarkeinternational.com

UNPACKING AND ASSEMBLY

Unpack your Generator and check the following items are present. Should there be any missing or damaged during transit contact your Clarke dealer immediately.

- 1 x Inverter Generator
- 1 x Spark Plug Box Spanner
- 1 x Screwdriver/Tommy Bar
- 1 x Container with Spout for Oil Filling
- 1 x Operating & Instruction Manual
- 1 x 12V Battery Connector Lead
- 1 x Oil Drain Tube

BEFORE USING THE GENERATOR

IMPORTANT: Generators should ALWAYS be earthed. Make sure you ground (earth) the generator.

Before using your generator check that:

- The generator is in good condition and free from any damage.
- The generator is clean and free from fuel or oil spillage.
- The generator is correctly located for use (See page 4).
- There is no leakage.
- **NOTE:** To avoid accidental spillage of fuel, always use a funnel to fill the fuel tank. If fuel is spilled it must be removed from the unit before attempting to start the engine.

EARTH POINT

Always connect the generator to an earth point. The earth terminal is shown on the right.




CHECKING THE AIR FILTER

1. Remove the left side maintenance panel.

2. Remove the three air filter cover screws shown on the right.

3. Slide out the air filter cover.

- 4. Remove the air filter element.
- 5. If the air filter is damaged contact Clarke spare parts department for a replacement.
 - If the filter is dirty, wash it in a solution of warm water and mild detergent and rinse thoroughly. Leave the filter to dry completely, once it is dry



immerse the filter in clean engine oil and sqeeze the filter to remove excess oil.



WARNING: DO NOT USE FLAMMABLE SOLVENTS OR PETROL TO CLEAN THE AIR FILTER.

6. Replace the filter into its original position and replace and secure the air filter cover then Replace the left side maintenance panel.

CHECK THE ENGINE OIL LEVEL




WARNING: YOUR GENERATOR MAY NOT BE SUPPLIED WITH OIL, ALWAYS ENSURE THAT THERE IS SUFFICIENT OIL BEFORE USE.

WARNING: TO CARRY OUT THIS CHECK, THE ENGINE MUST BE OFF.

NOTE: Place the generator on a level surface and check the oil level as follows.

1. Remove the maintenance panel shown on the right.

- 2. Turn the oil filler cap anticlockwise and remove from the oil reservoir, wipe the dipstick with a clean cloth.
- Insert the dipstick back into the oil filler tube and then remove it again.
- 4. If the oil is below the Min. level on the dipstick, Fill the oil reservoir with fresh oil.
 - Do not fill above the max level mark (0.45 litres)
 - We recommend the use of SAE30 oil in this generator.
 - Do not tilt the generator when adding engine oil. This could result in overfilling and damage to the engine.
- 5. Replace the oil filler cap.
- 6. Replace the left side maintenance panel.



CHECK THE FUEL LEVEL



WARNING: MAKE SURE THERE IS FUEL IN THE TANK WHEN USING THE GENERATOR. RUNNING OUT OF FUEL OR STOPPING THE ENGINE SUDDENLY WITH A LOAD CONNECTED COULD CAUSE SERIOUS DAMAGE.

- 1. To check the fuel level, open the fuel filler cap.
- 2. Slowly add fuel to the fuel tank (maximum 7L)
 - Do not overfill the fuel tank.
- 3. Replace the fuel filler cap securely.



WARNING: FUEL IS HIGHLY FLAMMABLE AND POISONOUS.

WARNING: SEE "GENERAL SAFETY RULES" ON PAGE 4 AND READ THEM CAREFULLY BEFORE REFUELING.

WARNING: DO NOT FILL ABOVE THE TOP OF THE FUEL FILTER OR IT MAY OVERFLOW WHEN THE FUEL HEATS UP AND EXPANDS.

WARNING: WIPE UP ANY SPILLED FUEL IMMEDIATELY.

WARNING: AFTER REFUELING, MAKE SURE THE FUEL FILLER CAP IS TIGHTENED SECURELY.

RECOMMENDED FUEL

Your generator has been designed to use regular unleaded petrol with a octane number of 86 or higher.

USING YOUR GENERATOR

STARTING THE ENGINE

- 1. Remove all connections from the AC sockets.
- 2. Hold the fuel tank cap so that it will not move, and turn the air vent knob to the ON position.

3. Turn fuel valve to the ON position (pointing downwards).

4. Set the engine switch to 'ON'.

- 5. Set the choke to the required position.
 - If the engine is cold, move the choke to the left.
 - If the generator is warm, move the choke to the right.



- 6. If this is the first time you are using the generator or if the generator had run out of fuel the last time you used it, pump the primer bulb 10 times to introduce fuel into the carburetter.
- Hold the generator handle firmly and pull the starting handle lightly until you start to feel resistance and then pull up sharply to start the engine.
 - NOTE: You may have to do this more than once.





WARNING: ONCE THE GENERATOR HAS STARTED, RELEASE THE STARTING HANDLE SLOWLY TO AVOID INJURY/DAMAGE AS IT WHIPS BACK.

NOTE: When you first start the generator, the overload indicator may light up for a few seconds, this is normal. If the overload indicator is still lit after 5 seconds, stop the engine and contact your Clarke dealer.

8. Once the engine has warmed up, move the choke to the right.



CONNECTING ELECTRICAL DEVICES

The generator can supply both 230V AC and 12V DC

AC POWER

- 1. Start the engine. See page 12.
- 2. Make sure the appliance is turned off before connecting it to the generator.
- 3. Connect the appliance to the generator.





CAUTION: MAKE SURE THAT THE APPLIANCE BEING CONNECTED IS IN GOOD WORKING ORDER, IF IT BEGINS TO ACT ABNORMALLY OR STOPS SUDDENLY, DISCONNECT IT FROM THE GENERATOR

CAUTION: MAKE SURE THE APPLIANCE DOES NOT EXCEED THE MAXIMUM RATED LOAD FOR THE GENERATOR.

CAUTION: ANY DEVICE WHICH CONTAINS AN INDUCTIVE LOAD E.G. DEVICES THAT CONTAIN A MOTOR MAY REQUIRE MORE CURRENT ON STARTUP.


DC POWER

For charging car batteries only



CAUTION: MAKE CONNECTIONS TO THE BATTERY AFTER STARTING THE GENERATOR.


- 1. Set the economy control switch to `OFF'.
- 2. Start the generator.





WARNING: TO PREVENT THE POSSIBILITY OF CREATING A SPARK NEAR THE BATTERY, CONNECT THE BATTERY CHARGING LEAD TO THE BATTERY FIRST AND THEN INSERT THE BATTERY CHARGING LEAD INTO THE GENERATOR.

- 3. Connect the battery charging leads to the battery.
 - Clamp the red wire to the positive (+) terminal and the black wire to the negative (-) terminal of the battery. Do not reverse these positions.
- 4. Connect the battery charging leads to the generator.






WARNING: AFTER YOU HAVE CHARGED THE BATTERY, ALWAYS DISCONNECT THE NEGATIVE LEAD FIRST.

DC OVER LOAD PROTECTOR


If the DC overload protector activates, wait for a few minutes and then press the reset button shown on the right.



ECONOMY SWITCH

When the economy control switch is turned on, the engine speed varies according to the load connected. This results in decreased fuel consumption and less noise.

When the economy control switch is turned off, the engine runs at the 5,000 r/min. regardless of whether there is a load connected or not.



CAUTION: THE ECONOMY CONTROL DOES NOT WORK EFFECTIVELY IF THE ELECTRICAL APPLIANCE REQUIRES `BURSTS' OF POWER.

CAUTION: TURN THE ECONOMY CONTROL FEATURE OFF WHEN CONNECTING HIGH LOAD APPLIANCES OR WHEN CONNECTING TO THE DC OUTPUT.

INDICATOR LIGHTS

PILOT LIGHT


The pilot light (Green) will remain on during normal operation.

OVERLOAD INDICATOR

The overload indicator (Red) will light up if there is an overload or a short circuit in the connected appliance.

If this happens, proceed as follows:

1. Turn off any connected electrical devices and stop the engine.



- 2. Reduce the total wattage of connected electric devices to within the rated output of the generator.
- 3. Check air inlet and around the control unit. If any blockages are found, remove them.
- 4. After checking, restart the engine.

LOW OIL INDICATOR

The oil indicator will light up when the oil level is low. To add oil, follow the instructions on page 10 $\,$

SHUTTING DOWN THE GENERATOR

To stop the generator in an emergency simply set the engine switch to 'OFF'.

NOTE: Turn off any electric devices.

NOTE: Set the economy control switch to the `0' (OFF) position.

- 1. Disconnect any electric devices.
- Turn the fuel valve knob to "OFF" (pointing left).

3. Turn the air vent knob to the off position.

4. Set the engine switch to the "0" (OFF) position.



MAINTENANCE


ENGINE OIL (EVERY 20 HOURS OF USE)



CAUTION: PROLONGED EXPOSURE TO USED ENGINE OIL IS DANGEROUS, ALWAYS WASH YOUR HANDS THOROUGHLY AFTER HANDLING USED ENGINE OIL.

1. Remove the maintenance panel shown on the right.

- 2. Turn the oil filler cap anticlockwise and remove from the oil tank.
- 3. Screw the oil drain tube into the oil tank as shown.
- 4. Tilt the generator to allow the oil to drain out of the oil reservoir into a suitable container.
 - **NOTE:** You may need assistance with this step as the generator is heavy.
- 5. Fill the oil reservoir with fresh oil.
 - Do not fill above the max level mark (0.45 litres)
 - We recommend the use of SAE30 oil in this generator.
- 6. Replace the oil filler cap and maintenance panel.




AIR FILTER (EVERY 50 HOURS OF USE)

1. Remove the maintenance panel shown on the right.

2. Remove the three air filter cover screws .

3. Pull out the air filter cover.

- 4. Remove the air filter element.
- 5. If the air filter is damaged contact Clarke spare parts department for a replacement.
 - If the filter is dirty, wash it in a solution of warm water and mild detergent and then rinse thoroughly.



• Leave the filter to dry completely, once it is dry immerse the filter in clean engine oil and sqeeze the filter to remove excess oil.



WARNING: DO NOT USE FLAMMABLE SOLVENTS OR PETROL TO CLEAN THE AIR FILTER.

6. Replace the filter into its original position and replace and secure the air filter cover.

SPARK PLUG (EVERY 50 HOURS OF USE)



CAUTION: ALLOW THE ENGINE TO COOL BEFORE REMOVING THE SPARK PLUG.

- 1. Remove the top maintenance panel.
- 2. Remove the spark plug cap from the spark plug.


3. Assemble the spark plug spanner as shown.



- 4. Use the spark plug spanner (supplied) to remove the spark plug.
- 5. Check for discoloration and use a wire brush to remove any carbon build up.

- 6. Check the spark plug gap (a) with a feeler guage, it should be between 0.6 and 0.7 mm.
 - Adjust if necessary.
- Check the overall condition of the spark plug and replace if damaged.

NOTE: Spark plugs are available from Clarke Spare Parts department 020 8988 7400.




8. Reinstall the spark plug and replace the spark plug cap.

FUEL TANK FILTER

Just inside the fuel tank is a fuel filter, check this filter periodically and remove any contaminants which may have accumulated.

- 1. Remove the fuel tank cap
- 2. Lift out the filter inside.



- 3. Clean the filter with solvent. If damaged, replace.
- 4. Relace the filter and fuel tank cap.

TROUBLESHOOTING

	CAUSE	SOLUTION
The generator fails	Engine switch is off	Set the engine switch to `on'
to start	Not enough oil in the generator	Add more oil, See page 10
	No fuel	Add more fuel, See page 11
	Spark plug not working correctly	Change the spark plug, See page 20
The generator fails to generate	The device you are trying to power is faulty	Make sure the device you want to power is working properly
electricity	The overload indicator is on	Remove the appliance immediately, do not connect any appliance that requires more than 2.2 KVA.
	(DC supply only) The DC Overload protector has activated.	Press the reset button. See page 16
The generator is difficult to start	The air filter is dirty	Clean the air filter. See page 19

If this does not solve your problem, please contact the Clarke service department. see below.

PARTS AND SERVICING

For Parts & Servicing, please contact your nearest dealer, or CLARKE International, on one of the following numbers.

PARTS & SERVICE TEL: 020 8988 7400 PARTS & SERVICE FAX: 020 8558 3622 or e-mail as follows: PARTS: Parts@clarkeinternational.com SERVICE: Service@clarkeinternational.com

Parts & Service: 020 8988 7400 / E-mail: Parts@clarkeinternational.com or Service@clarkeinternational.com

SPECIFICATIONS

		IG2200
Engine	Engine Model	152F
	Туре	Forced air cooled 4- stroke gasoline OHV
	Displacement (cm ³)	125
	Ignition type	T.D.I
	Fuel tank capacity (L)	7
	Maximum run time at full load (h)	6
	Engine oil capacity (L)	0.45
	Guaranteed sound power (LwA dB)	94 dB
Generator	Rated Frequency (Hz)	50
	Rated AC Voltage (V)	230
	Rated Power (KW)	2
	Max. Power (KW)	2.2
	Rated DC Voltage (V)	12
	Rated DC Current (A)	8.3
Dimensions	Length (mm)	542
	Width (mm)	288
	Height (mm)	486
	Unpacked Weight (kg)	26.6

DECLARATION OF CONFORMITY

Œ



Hemnall Street, Epping, Essex CM16 4LG

DECLARATION OF CONFORMITY

This is an important document and should be retained.

Product Description:2000W Inverter GeneratorModel number(s):IG2200Serial / batch Number:8877055Date of Issue:01/12/2009(Noise Conformity)UNotified Body:Societe Nationale De Certification ETD'Memologation S.A.R.L (SNCH)Homologation S.A.R.L (SNCH)Luxembourg230 SandweilerLuxembourgLarke InternationalDe Sondormity Assessment Procedure:No 2000/14/EC Annex VIMain facturer:20 SardweilerMoise Related Value:20 SardweilerBoard Sound Power Levei:9 dBGuaranteed Sound Power Levei:9 dBStaranteed Sound Power Levei: <t< th=""><th></th><th></th><th></th></t<>			
Serial / batch Number:8877055Date of Issue:01/12/2009(Noise Conformity)Societe Nationale De Certification ETD' Homologation S.A.R.L (SNCH) 11 Rout De Sandweiler 5230 Sandweiler LuxembourgTechnical Documentation Holder:Alan Pond Clarke International 2a Shrubland Road London E10,7RB UKConformity Assessment Procedure:to 2000/14/EC Annex VIManufacturer:to 2000/14/EC Annex VIManufacturer:98 dBGuaranteed Sound Power Level:94 dB	Product Description:	2000W Inverter Generator	
Date of Issue:01/12/2009(Noise Conformity)Societe Nationale De Certification ETD' Homologation S.A.R.L (SNCH) 11 Rout De Sandweiler 5230 Sandweiler LuxembourgTechnical Documentation Holder:Alan Pond Clarke International 2a Shrubland Road London E10,7RB UKConformity Assessment Procedure:to 2000/14/EC Annex VIManufacturer:Clarke International 2.0 kWMeasured Sound Power Level:99 dBGuaranteed Sound Power Level:94 dB	Model number(s):	IG2200	
(Noise Conformity)Notified Body:Societe Nationale De Certification ETD' Homologation S.A.R.L (SNCH) 11 Rout De Sandweiler 5230 Sandweiler LuxembourgTechnical Documentation Holder:Alan Pond Clarke International 2a Shrubland Road London E10,7RB UKConformity Assessment Procedure:to 2000/14/EC Annex VI Clarke International 2.0 kWManufacturer:to 2000/14/EC Annex VI Clarke International 2.0 kWMeasured Sound Power Level:89 dB 3 dBGuaranteed Sound Power Level:94 dB	Serial / batch Number:	8877055	
Notified Body:Societe Nationale De Certification ETD' Homologation S.A.R.L (SNCH) 11 Rout De Sandweiler 5230 Sandweiler LuxembourgTechnical Documentation Holder:Alan Pond Clarke International 2a Shrubland Road London E10,7RB UKConformity Assessment Procedure:to 2000/14/EC Annex VI Clarke International 2.0 kWMeasured Sound Power Level:89 dBGuaranteed Sound Power Level:94 dB	Date of Issue:	01/12/2009	
Homologation S.A.R.L (SNCH)11 Rout De Sandweiler5230 SandweilerLuxembourgTechnical Documentation Holder:Alan PondClarke International2a Shrubland RoadLondon E10,7RBUKManufacturer:to 2000/14/EC Annex VIManufacturer:Clarke InternationalNoise Related Value:20 kWMeasured Sound Power Level:89 dBGuaranteed Sound Power Level:94 dB	(Noise Conformity)		
11 Rout De Sandweiler5230 SandweilerLuxembourgTechnical Documentation Holder:Alan PondClarke International2a Shrubland RoadLondon E10,7RBUKConformity Assessment Procedure:to 2000/14/EC Annex VIManufacturer:Clarke InternationalNoise Related Value:2.0 kWMeasured Sound Power Level:89 dBGuaranteed Sound Power Level:94 dB	Notified Body:	Societe Nationale De Certification ETD'	
S230 Sandweiler LuxembourgTechnical Documentation Holder:Alan Pond Clarke International 2a Shrubland Road London E10,7RB UKConformity Assessment Procedure:to 2000/14/EC Annex VI Clarke International 2.0 kWNoise Related Value:2.0 kWMeasured Sound Power Level:99 dBGuaranteed Sound Power Level:94 dB		Homologation S.A.R.L (SNCH)	
LuxembourgTechnical Documentation Holder:Alan Pond Clarke International 2a Shrubland Road London E10,7RB UKConformity Assessment Procedure:to 2000/14/EC Annex VIManufacturer:Clarke InternationalNoise Related Value:2.0 kWMeasured Sound Power Level:89 dBGuaranteed Sound Power Level:94 dB		11 Rout De Sandweiler	
Technical Documentation Holder:Alan Pond Clarke International 2a Shrubland Road London E10,7RB UKConformity Assessment Procedure:to 2000/14/EC Annex VIManufacturer:Clarke InternationalNoise Related Value:2.0 kWMeasured Sound Power Level:89 dBGuaranteed Sound Power Level:94 dB		5230 Sandweiler	
Clarke International 2a Shrubland Road London E10,7RB UKConformity Assessment Procedure:to 2000/14/EC Annex VIManufacturer:Clarke InternationalNoise Related Value:2.0 kWMeasured Sound Power Level:89 dBGuaranteed Sound Power Level:94 dB		Luxembourg	
Clarke International 2a Shrubland Road London E10,7RB UKConformity Assessment Procedure:to 2000/14/EC Annex VIManufacturer:Clarke InternationalNoise Related Value:2.0 kWMeasured Sound Power Level:89 dBGuaranteed Sound Power Level:94 dB			
2a Shrubland Road London E10,7RB UKConformity Assessment Procedure:to 2000/14/EC Annex VIManufacturer:Clarke InternationalNoise Related Value:2.0 kWMeasured Sound Power Level:89 dBGuaranteed Sound Power Level:94 dB	Technical Documentation Holder:	Alan Pond	
London E10,7RB UK Conformity Assessment Procedure: to 2000/14/EC Annex VI Manufacturer: Clarke International Noise Related Value: 2.0 kW Measured Sound Power Level: 89 dB Guaranteed Sound Power Level: 94 dB		Clarke International	
UKConformity Assessment Procedure:to 2000/14/EC Annex VIManufacturer:Clarke InternationalNoise Related Value:2.0 kWMeasured Sound Power Level:89 dBGuaranteed Sound Power Level:94 dB		2a Shrubland Road	
Conformity Assessment Procedure:to 2000/14/EC Annex VIManufacturer:Clarke InternationalNoise Related Value:2.0 kWMeasured Sound Power Level:89 dBGuaranteed Sound Power Level:94 dB		London E10,7RB	
Manufacturer:Clarke InternationalNoise Related Value:2.0 kWMeasured Sound Power Level:89 dBGuaranteed Sound Power Level:94 dB		UK	
Manufacturer:Clarke InternationalNoise Related Value:2.0 kWMeasured Sound Power Level:89 dBGuaranteed Sound Power Level:94 dB			
Noise Related Value:2.0 kWMeasured Sound Power Level:89 dBGuaranteed Sound Power Level:94 dB	Conformity Assessment Procedure:	to 2000/14/EC Annex VI	
Measured Sound Power Level: 89 dB Guaranteed Sound Power Level: 94 dB	Manufacturer:	Clarke International	
Guaranteed Sound Power Level: 94 dB	Noise Related Value:	2.0 kW	
	Measured Sound Power Level:	89 dB	
IG2200 Generator (v/2) Page 1 of 2	Guaranteed Sound Power Level:	94 dB	
IG2200 Generator (rv2) Page 1 of 2			
IG2200 Generator (rv2) Page 1 of 2			
IG2200 Generator (rv2) Page 1 of 2			
IG2200 Generator (rv2) Page 1 of 2			
IG2200 Generator (rv2) Page 1 of 2			
IG2200 Generator (rv2) Page 1 of 2			
IG2200 Generator (rv2) Page 1 of 2			
IG2200 Generator (rv2) Page 1 of 2			
	IG2200 Generator (rv2)		Page 1 of 2

24 _____ 24 _____

Parts & Service: 020 8988 7400 / E-mail: Parts@clarkeinternational.com or Service@clarkeinternational.com



Parts & Service: 020 8988 7400 / E-mail: Parts@clarkeinternational.com or Service@clarkeinternational.com

NOTES

26

NOTES

- 27

Parts & Service: 020 8988 7400 / E-mail: Parts@clarkeinternational.com or Service@clarkeinternational.com



www.clarkeinternational.com