



http://www.delta.com.tw/industrialautomation/

2006-12-08
5011646001-CTE1

Timer / Counter / Tachometer Instruction Sheet

Thank you very much for purchasing DELTA CTA series. Please read this instruction sheet before using your CTA series to ensure proper operation and please keep this instruction sheet handy for quick reference.



DANGER! Caution! Electric Shock!

When the power is on, DO NOT touch the AC terminals in case an electric shock may occur.

Make sure the power is disconnected when you check the unit inside.




CTA series is an OPEN-TYPE device. They are intended for installation completely within an overall panel and are for use in counting or timing application. If it will cause serious injury to workers or damage on other equipments when used in a dangerous environment, please make sure it is installed in an automatic safety protection device.

1. Precaution

- Always use recommended solder-less terminals: Fork terminal with isolation (M3 screw, width 7.0mm), hole (diameter 3.2mm). Screw size: M3x6.5 (with 6.8x6.8 square washer). Recommended tightening torque: 0.4 N.m (4kgf.cm). Applicable wire: solid/twisted wire of 2mm², 12AWG to 24 AWG. Please be sure to tighten them properly.
- Prevent dust or metallic debris from falling into the device and cause malfunctions.
- DO NOT modify or uninstall the device.
- DO NOT use empty terminals.
- Make sure the wires are correctly connected to proper terminals.
- Keep away from high-voltage and high-frequency environment during installation in case of interference.
- Prevent using the device in premises which contain:
 - Dust or corrosive gas
 - High humidity
 - High radiation
 - Vibration and shock
- CTA series is an open-type device. Make sure to install it in an enclosure to prevent dust, humidity in case of an electric shock.
- Please make sure the power cables and signal device are installed correctly before switching on the power; otherwise serious damage may occur.
- DO NOT touch the terminals or repair the device when the power is on; otherwise an electric shock may occur.
- Please wait for one minute after the power is switched off to allow the capacitor to discharge and DO NOT touch the internal wiring within this period.
- Use dry cloth to clean the device. DO NOT use acid or alkaline liquid to clean the device.

2. Display, Indicators and Keys



LCD Display and Indicators

RST 1/2	Light on when reset signal is detected	BATCH	"Batch Counting Mode" in Counter and Tachometer function
K/P 1/2	Light on when key-protected mode is enabled	SET 12	SV1, SV2 display
OUT 1/2	Light on when output is executing	TAC	Light on when Tachometer function is executing
H M S	Hour, minute, second, unit of timer, displayed in Timer function	CNT	Light on when Counter function is executing
TOTAL	"Total Counting Mode" in Counter and Tachometer function	TMR	Light on when Timer function is executing


Key Operation

	Increase and decrease SV or change parameter settings.
	Left move 1 digit of the selected digit. The indicator of the selected digit will flash.
	Save the set parameters or switch among functions.
	Prevent settings from being changed. Key-protected mode still works after the power is switched off. Press to enter key-protected mode. In non-key-protected status, press to enter Lock 1. In Lock 1, press again to enter Lock 2. Press and at the same time to disable key-protected mode. (Lock 2) disables the functions of all keys. (Lock 2) allows users to change SV and functions of remain. only functions in non-key-protected status.
	Clear and reset PV.

Modes: Operation Mode and Configuration Mode

Operation	When the power is on, the timer/counter/tachometer is in the operation mode. Press to change SV, or to make change on a desired digit. The indicator of the selected digit will flash. After the change is made, press to save the setting. If SV or parameters are not changed, press once to switch between SET1 and SET2.
Configuration	Press in operation mode for more than 3 seconds to enter configuration mode. Press once to switch among parameters. To return to operation mode, press for more than 3 seconds.

3. Ordering Information



Product name	CTA: Delta Counter/Timer/Tachometer A series	Preset stage	0: 2 preset stage
Panel size	4: 48mm x 48mm 1/16DIN	Communication	0: none
Output 2	0: NPN; 1: Relay	Power supply	A: AC 100~240V

4. Specification

Power input	AC 100~240V, 50/60Hz
Input voltage range	85% to 110%, rated voltage
Power consumption	Less than 10VA
External power supply	12Vdc ±10%, 100mA
Display	Double-line, 6-digit negative transmissive LCD display
Input signal	Non-voltage input (NPN): ON impedance 1K ohm max. ON residual voltage: 2V max. Voltage input (PNP): High level: 4.5 to 30Vdc, Low level: 0 to 2Vdc
Output 1	Relay: SPST max.250Vac, 5A (resistance load)
Output 2	Transistor: NPN open collector. When 100mA/30Vdc, residual voltage=1.5Vdc max. Relay: SPDT max.250Vac, 5A (resistance load)
Dielectric strength	2000Vac 50/60 Hz for 1 minute
Vibration resistance	Without damage: 10~55Hz, amplitude=0.75mm, 3 axes for 2 hours
Shock resistance	Without damage: drop 4 times, 300m/s ² , 3 edges, 6 surfaces and 1 corner
Ambient temperature	0 °C to +50 °C
Storage temperature	-20 °C to +65 °C
Altitude	2000m or less
Ambient humidity	35% to 85% RH (non-condensing)
Pollution degree	Degree 2


5. Parameters in Configuration Mode

Timer							
FUnC	t_node	t_othd	t_Unit	t_out1	tSfr	inPtc	Back to "select a function"
Select a function	Setup Timer function, (counting up or down)	Select output mode of Timer	Setup the displayed unit of timer	Setup the pulse width of output 1	Reset min. pulse width	Select input type (PNP or NPN)	
Counter							
FUnC	inPtc	t_inpt	t_othd	dUtl	t_spd	t_out1	
Select a function	Select counting modes	Setup input mode of Counter	Setup output mode of Counter (not dual output)	Setup dual output counting mode (dual output)	Setup counting speed	Setup the pulse width of output 1	
Back to "select a function"	inPtc	tSfr	PuErS	PScale	Point	t_out2	
Back to "select a function"	Select input type (PNP or NPN)	Reset min. pulse width	Save data or not while switching off power	Setup pre-scale value	Setup the decimal point	Setup the pulse width of output 2	
Tachometer							
FUnC	t_othd	t_spd	Point	PScale			
Select a function	Setup output mode of Tachometer	Setup counting speed	Setup the decimal point	Setup pre-scale value			
Back to "select a function"	inPtc	tSfr	Se_Rg	St_EtC			
Back to "select a function"	Select input type (PNP or NPN)	Reset min. pulse width	Setup the average of input data	Setup the delay time while switching on power			
Timer + Counter Mixed							
FUnC	t_node	t_othd	t_Unit	t_othd	t_spd	t_out1	
Select a function	Setup Timer function, (counting up or down)	Setup output mode of timer	Setup the displayed unit of timer	Setup output mode of Counter	Setup counting speed	Setup the pulse width of output 1	
Back to "select a function"	inPtc	Reset	PUErS	PScale	Point	t_out2	
Back to "select a function"	Select input type (PNP or NPN)	Reset min. pulse width	Save data or not while switching off power	Setup pre-scale value	Setup the decimal point	Setup the pulse width of output 2	

6. Timer Function

There are counting up/down modes, several counting units and output modes to choose from in timer function.


t_node	Select counting up UP or counting down down			
t_out1	Setup the output time of timer, from 0 to 99.99 secs. 0= Hold output			
t_othd	Setup output modes			
Setup the counting unit of the timer.				
S 0.1	sec	0.01~9999.99	A unit = 10ms.	Max. counting = 9999.99 secs.
S 0.1	sec	0.1~9999.9	A unit = 0.1sec.	Max. counting = 9999.9 secs.
S 1	sec	1~99999	A unit = 1 sec.	Max. counting = 99999 secs.
MS 0.1	min.sec	0.01~9959.99	A unit = 0.01 sec.	Max. counting = 9999.99 secs.
MS 0.1	min.sec	0.1~9959.9	A unit = 0.1 sec.	Max. counting = 9999.99 secs.
MS 1	min	0.1~9999.9	A unit = 0.1 min.	Max. counting = 99999.9 mins.
MS 1	min	1~99999	A unit = 1 min.	Max. counting = 999999 mins.
HS 1	hr,min.sec	1~995959	A unit = 1 sec.	Max. counting = 359999 secs (100hr)
HS 1	hr,min	1~99959	A unit = 1 min.	Max. counting = 359999999 secs (10000hr)
H 1	hr	1~99999	A unit = 1 hr.	Max. counting = 999999 hrs



7. Counter Function

Counter functions include 1-stage counting, 2-stage counting, batch counting, total counting and dual counting.


Stage 1	1-stage	Only 1 SV is allowed. See "output modes of counter".
Stage 2	2-stage	2 SVs, 2 PVs are allowed. See "output modes of counter".
Batch	Batch	Apart from the counting of PV and SV, when PV=SV, the batch counting adds 1 and clear PV as 0 for recounting till the batch counting equals batch SV.
Total	Total	Total counting adds up all the counting values till they reach SV for output.
Dual	Dual	CP1 and CP2 can be independent counters, but the counting speed can only reach 5kHz. CP1 and CP2 can execute addition Add or subtraction Sub .



The output of SV can be 1-stage or 2-stage. When the output is set as 1-stage, Output 2 will be the same as the Output 1. The output modes include: F, N, C, R, K, P, Q, A, S, T, D

F	F	When PV reaches SV, output is enabled but counting continues. Recounting starts after reset signal is over.
N	N	When PV reaches SV, output is enabled but counting stops. Recounting starts after reset signal is over. Output 2 remains.
C	C	When PV reaches SV, recounting executes automatically. Output 2 is pulse output. Output 1 remains till Output 2 is over.
R	R	When PV reaches SV, counting stops till Output 2 (pulse) is over for recounting. Output 1 remains till Output 2 is over.
K	K	When PV reaches SV, output is enabled but counting continues. Recounting starts after reset signal is over.
P	P	When PV reaches SV, output is enabled and recounting is automatically executed. But display of counting remains till Output 2 (pulse) is over.
Q	Q	When PV reaches SV, output is enabled but the counting continues. Recounting starts after Output 2 (pulse) is over.
A	A	When PV reaches SV, output is enabled but the counting stops. Recounting starts and Output 2 (pulse) executes after reset signal is over.
S	S	When PV ≥ SV1, Output 1 is enabled. When PV ≥ SV2, Output 2 is enabled
T	T	When PV ≤ SV1, Output 1 is enabled. When PV ≥ SV2, Output 2 is enabled.
d	D	When SV=PV, output is enabled but counting continues. Addition and subtraction modes are valid.

The time of Output 1 and Output 2 (pulse) can be setup separately, ranging from 0.01 to 99.99 secs. Recounting refers to counting up or addition/subtraction counting starting from 0 and counting down starting from SV. The counting range: -99999~99999. The counting will restart from 0 if the counting exceeds the range.



In Timer + Counter function, SV1, PV1 and Output 1 are for Timer; SV2, PV2 and Output2 are for Counter. DIP switch is disabled. All timer and counter functions remain except


- RCY2, SCON, STON, STOFF in output mode of Timer function
- Command up/down, Individual up/down, quadrature counting in input mode, S, T, D in output mode of Counter function

Only 1-stage counting in Counter function is available.

10. Easy DIP Switch Setup

Users can use DIP switch to setup parameters. When DIP is switched to ON, the corresponding parameters can only be read, not changed.

SW	Counter	Timer	Tachometer
8	Reset pulse width ON: 1ms, OFF: 20ms	Reset pulse width ON: 1ms, OFF: 20ms	Reset pulse width ON: 1ms, OFF: 20ms
7	Input type ON: PNP OFF: NPN	Unit of Timer See Table 1	Input type ON: PNP OFF: NPN
6	N/A	Unit of Timer See Table 1	N/A
5	Counting speed ON: 10K CPS OFF: 30 CPS	Unit of Timer See Table 1	Counting speed ON: 10KHz OFF: 30Hz
4	Output mode of counter See Table 2	Output mode of Timer See Table 2	Output mode of Tachometer See Table 2
3	Output mode of counter See Table 2	Output mode of Timer See Table 2	Output mode of Tachometer See Table 2
2	Input mode of counter ON: counting down OFF: counting up	Time counting up/down ON: down OFF: up	N/A
1	ON: Enable DIP OFF: Disable DIP	ON: Enable DIP OFF: Disable DIP	ON: Enable DIP OFF: Disable DIP




SW5	SW6	SW7	Displayed unit
OFF	OFF	OFF	0.01 sec
ON	OFF	OFF	0.1 sec
OFF	ON	OFF	1 sec
ON	ON	OFF	min, 0.01 sec
OFF	OFF	ON	min, 0.1 sec
ON	OFF	ON	0.1 min
OFF	ON	ON	Min
ON	ON	ON	hr, min, sec


Table 1

11. Terminal Definition

Input connections



CTA4 series




Multi-function input pin

Counter	Timer	Tachometer	Timer + Counter
CP1	Gate	CP1	CP1
CP2	Gate	Reset1	Reset1
Reset1	Reset1	Reset1	Start
Reset2	Start		

12. Dimension & Panel Cutout

CTA4 series




13. How to Mount

Step-1. Insert the controller through the panel cutout.

Step-2. Insert the mounting bracket into the mounting groove at the top and bottom of the controller and push the mounting bracket forward until the bracket stops at panel wall.

Step-3. Insert and tighten screws on bracket to secure the controller in place.



Delta Electronics, Inc. 31-1 Shien Pan Road, Kuei Shan Industrial Park, Taoyuan Shien 33341, Taiwan, R.O.C.
TEL: +886-3-362-6301
FAX: +886-3-362-7267

Table 2

SW3	SW4	Counter	Timer	Tachometer
OFF	OFF	F	Signal ON Delay 1	Lo-Lo
ON	OFF	N	Signal ON Delay 2	Lo-Hi
OFF	ON	C	Signal OFF Delay	Hi-Lo
ON	ON	R	Signal ON	Hi-Hi